

DESCRIPTION	AS PER TENDER	DATA TO BE FILLED BY VENDOR
ACOUSTIC DUCT INSULATION		
Material	Glass Fibre Board	Glass Fibre Board
Density	24 or 32 kg / m3	16/24/32/48
Thickness	25 mm	25/50
Adhesive	Tar Product, Cold Sticking	
Covering	Black Glass Fibre	Plain/FSK/Alu Foil
	Internally coated for bacteria and mould resistance	
	Perforated Aluminum Foil, 26 G	
Support Frame	G I, C / 'Z' Section / Duct Material	Noted
Hardware	G I Nut / bolts with Star Washers on Framework	Noted
CHW PIPE WATER PIPE INSULATION		
Material	Nitrile Foam / EPDM, Class "O" / Thermo Break	Nitrile Foam / EPDM, Class "O"
Property	Fire Retardant	Yes
Joint Seal	As per Recommended Adhesive	Noted
Joint Cover	50 mm Al Tape	Noted
Thickness	32 mm	Noted
Finish	NIL for Indoor Application 160 GSM GC cloth finished with weather protective lag coating for Outdoor Application	Noted

