

				Compliance
16	DUCT Thermal Insulation Works with Approved make Antimicrobial quality Elastomeric nitrile rubber 40-60 kg/m ³ with thermal conductivity < 0.035 W/m ² K at an average temperature of 0°C; Fire Propagation compliance as per BS476 Part 6 to meet the Class 'O' Fire category (without Al/outer metallic foil); Water vapour permeability shall not exceed 0.017 Perm inch (2.48 x 10 ⁻¹⁴ Kg/m.s.Pa), Non VOC Water based Adhesive and the entire process of Application shall be as recommended by Mfr.			Comply
16.1	Exposed Ducting			
16.1.1	50 mm thick anti microbial elastomeric nitrile rubber 40-60 kg/m³ as above insulation for Ambient Exposed Supply / Return air / TFA Ducting Area covered with Factory Laminated 200 GSM GC barrier for UV and Mechanical Protection PLUS Antifungal Lag coating applied with approved make adhesive / additionally sealed with 75mm x 3 mm self adhesive tape on top at longitudinal and transverse joints simultaneously	75	Sq M	Comply
16.1.2	32 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m³ as above insulation for Exposed Supply air Ducting Area covered with Factory Laminated 200 GSM GC barrier for UV and Mechanical Protection PLUS Antifungal Lag coating applied with approved make adhesive / additionally sealed with 75mm x 3 mm self adhesive tape on top at longitudinal and transverse joints simultaneously	25	Sq M	Comply
16.1.3	25 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m ³ as above insulation for Exposed Supply air Ducting covered with Factory Laminated 200 GSM GC barrier for UV and Mechanical Protection applied with Antifungal Lag Coating approved make adhesive / additionally sealed with 75mm x 3 mm self adhesive tape on top at longitudinal and transverse joints simultaneously	200	Sq M	Comply
16.1.4	15 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m ³ as above insulation for Exposed Return air Ducting Area covered with Factory Laminated 200 GSM GC barrier for UV and Mechanical Protection and Antifungal Lag coating applied with approved make adhesive / additionally sealed with 75mm x 3 mm self adhesive tape on top at longitudinal and transverse joints simultaneously	10	Sq M	Comply
16.2	Internal area ducting			
16.2.1	32 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m ³ as above insulation for all Internal Area Supply air Ducting with Al Vapor barrier foil sealed with 75mm x 3 mm self adhesive Aluminium tape on top at longitudinal and transverse joints simultaneously	6000	Sq M	Comply

16.2.2	25 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m3 as above insulation for all Internal Area Supply air Ducting with Al Vapor barrier foil sealed with 75mm x 3 mm self adhesive Aluminium tape on top at longitudinal and transverse joints simultaneously	10	Sq M	Comply
16.2.3	15 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m3 as above insulation for all Internal Area Supply air Ducting with Al Vapor barrier foil sealed with 75mm x 3 mm self adhesive Aluminium tape on top at longitudinal and transverse joints simultaneously	10	Sq M	Comply
16.2.4	6 mm thick antimicrobial elastomeric nitrile rubber 40-60 kg/m3 as above insulation for Exhaust air Ducting (Toilet/Sluice etc) additionally sealed with 75mm x 3 mm self adhesive tape on top at longitudinal and transverse joints simultaneously	500	Sq M	Comply
17.1.1	Supply and fixing of acoustic lining inside sheet metal ducts using 140-180 kg/m3 Approved Make with Microban, having thickness specified below, conforming to Class 1 - BS 476 applied with Approved make adhesive (having less then max. permissibleVoC content as per GRIHA/Green Rating System) as specified with 15 mm thick and Microban Upto 4 RMT of SA and Return Ducting; Duct acoustic lining should be done while the ducts are still on floor, not after installing ducts in position	2500	Sq M	Comply
17.1.2	10 mm thick antimicrobial acoustic lining with Approved Make with Microban Upto 4 RMT of Supply Ducting of FCU and Exhaust ducting for Toilet / Sluice / DU Areas applied with adhesive having less then permissible VoC Content as per GRIHA/Green Rating System; Duct acoustic lining should be done while the ducts are still on floor, not after installing ducts in position	10	Sq M	Comply
18	Slab Under deck insulation as per latest CFO circular # Approved make 50 mm thick (2 layers of 25 mm each) Elastomeric nitrile rubber 40-60 kg/m3 with thermal conditivity < 0.035 W/m°K at an average temperature of 0°C; Fire Propagation compliance as per BS476 Part 6 to meet the Class 'O' Fire category (without Al/outer metallic foil); Water vapour permeability shall not exceed 0.017 Perm inch (2.48 x 10-14 Kg/m.s.Pa), Non VOC Water based Adhesive and the entire process of Application shall be as recommended by Mfr. including 300x300 heavy gauge GI wire netting with screws NOTE: Necessary re-work/repair/plugging of holes & cutouts in insulation will have to be carried out as required, after completion of ducting, false ceiling, lighting, etc." in HVAC scope; Areas applicable - 11th floor Deck / Deck Below OT Floor / Deck Below BMT Floor	4000	Sq M	Comply

19	AHU Room Insulation Supply and fixing of acoustic lining inside AHU Room for with 20 mm thk 140-180 kg/m3 Approved make acoustic insulation with Microban conforming to Class 1 - BS 476 applied with Mfr recommended adhesive as specified complete with required MS galvanized framed structure	2500	Sq M	Comply
----	---	------	------	---------------

