

COMPLIANCE SHEET

Projects :	BENGALURU AIRPORT MEP PROJECT	DATE : 05 December 2025
Material Description :	Sleeve For Refrigerant Copper Piping	
Documents No :		
Tender make :	A-flex/K- flex/Armacell/superlon	

Sr. No.	BOQ Description	Tender Specification	Proposed Specification
Sleeve For Refrigerant Copper Piping			
1	Make	A-flex/K- flex/Armacell/superlon	A-Flex
2	Insulation material shall be closed cell elastomeric EPDM (Ethylene Propylene Diene Monomer)	-	Closed cell elastomeric EPDM (Ethylene Propylene Diene Monomer)
3	Thermal conductivity of elastomeric EPDM rubber shall not exceed 0.033 W/mK at mean temperature of 0 Deg C according to ASTM C-518	-	0.033 W/mK at mean temperature of 0 Deg C according to ASTM C-518
4	Density of material shall be 60+20% kg/m3, EPDM insulaion shall be rated V0 as per UL 94.	-	40-60kg/m3, EPDM insulaion rated V 0 as per UL 94.
5	The insulation shall have fire performance such that it passes class 'A' as per ATM E84.	-	Class A as per ASTM E-84
6	Insulation material shall be non-corrosive as per DIN 1988.	-	Non Corrosive as per DIN 1988
7	Insulation shall have smoke density and toxicity tested according to IMO FTPC part 2 and 5 and in compliance with IMO 2010 FTP code ch.8.	-	Smoke and Toxicity test passed as per IMO Res. MSC 61(67) Anx 1.P2
8	Insulation material shall have inbuilt anti-microbial protection as UL-181 for Anti-fungal and ASTM-2180-1 for anti-bacterial.	-	It has inbuilt anti-microbial protection as UL-181 for Anti-fungal and ASTM-2180-1 for anti-bacterial.
9	The material should comply to RoHS Directive 2002/95/EC amended up to 2011/65/EU.	-	RoHS Not Detected as per EN Restriction of the use of hazardous substances directive (ROHS) 2002/95/EC
10	-	Pipe insulation material should be EPS/XPS/PUF/ closed cell flexible elastomeric foam/fibre glass as per requirement, specified with suitable density and thickness.	Noted

