

				Compliance
3	Supply, installation & testing of nitrile rubber insulation with GC cloth for chilled water piping insulation as per specifications & drawing on chilled water pipes of the following sizes: - For indoor chilled water pipes and Outdoor pipe shall be with UV protected and weather proof.			Compy
	Supply, installation and testing of 25 mm thick nitrile rubber insulation with protective coating glass cloth on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications.			Comply
3.01	25 mm Dia	Rmt.	750	
3.02	32 mm Dia	Rmt.	RO	
3.03	40 mm Dia	Rmt.	RO	
3.04	50 mm Dia	Rmt.	RO	
3.05	65 mm Dia	Rmt.	1500	
3.06	80 mm Dia	Rmt.	200	
4.0	Supply, installation and testing of 32mm thick nitrile rubber insulation with protective coating (glass cloth) on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications.			Comply
4.01	100 mm Dia	Rmt.	200	
4.02	125 mm Dia	Rmt.	RO	
4.03	150 mm Dia	Rmt.	100	
5.0	Supply, installation and testing of 45 mm thick nitrile rubber insulation in two layers with glass cloth . Each layer shall 32 mm + 13 mm respectively with protective coating on chilled water pipes and fittings like valves, flanges and unions, etc. as per the approved shop drawings & specifications :			Noted
5.01	200 mm Dia	Rmt.	RO	
5.02	250 mm Dia	Rmt.	300	
5.03	300 MM	Rmt.	RO	
5.04	400 MM	Rmt.	RO	
17	Supply & fixing of Thermal insulation for supply air duct using 13 mm thick class " O " Closed cell nitrile rubber based elastomeric insulation with the density of 40 - 55 kg/m³. The insulation manufactured as per BS 476 Part 7test & which should also meet UL94 supplementary materials for air distribution system which should not absorbs less 0.2% water by volume and should not emit objectionable odors and should have thermal conductivity of 0.033W/m.k @ 0deg C and water vapor permeance of 0.10. Joints should be sealed with 50 mm wide 3 mm thick self adhesive tape (Black Cotton Tape not acceptable). Adhesive shall be used additionally with VOC level not exceeding 50 grms / Litre.	Sqm.	5000	Comply
18	Supply & fixing of Thermal insulation for Exposed Duct using 25 mm thick class " O " Closed cell nitrile rubber with UV protected and weather proof based elastomeric insulation with the density of 40 - 55 kg/m³. The insulation manufactured as per BS 476 Part 7test & which should also meet UL94 supplementary materials for air distribution system which should not absorbs less 0.2% water by volume and should not emit objectionable odors and should have thermal conductivity of 0.033W/m.k @ 0deg C. and water vapor permeance of 0.10. Joints should be sealed with 50 mm wide 3 mm thick self adhesive tape (Black Cotton Tape not acceptable). Adhesive shall be used additionally with VOC level not exceeding 50 grms / Litre. Insulation shall be with necessary UV protection and weather protection for longer life.	Sqm.	800	Comply
19	Supply & fixing of Acoustic insulation for Supply air duct using 13 mm thick class 1 rating Open cell nitrile rubber elastomeric insulation with density of 140 - 180 kg / m³. The insulation manufactured which should also meet UL 94 test supplementary materials for air distribution system which should not absorbs less 0.2% water by volume should not support microbial growth and should not emit objectionable odors and should have thermal conductivity of 0.04 W/m K @ 20 deg C and water vapor permeance of 0.10. Adhesive shall be used additionally with VOC level not exceeding 50 grms / Litre.	Sqm.	RO	Comply
20	Supply and installation of Wall Acoustic insulation of AHU Room using 35 mm thick class 1 rating Open cell nitrile rubber elastomeric insulation with density of 140 - 180 kg with required accessories to complete the works.	Sqm.	7750	Comply
21	Supply and installation of Wall Acoustic insulation of plant room Room using 50 mm thick class 1 rating Open cell nitrile rubber elastomeric insulation with density of 140 - 180 kg with required accessories to complete the works.	Sqm.	RO	
14	Supply & fixing of Thermal insulation with UV protected & weather proof for Exposed Duct using 25 mm thick class " O " Closed cell nitrile rubber based elastomeric insulation with the density of 40 - 55 kg/m³. The insulation manufactured as per BS 476 Part 7test & which should also meet UL94 supplementary materials for air distribution system which should not absorbs less 0.2% water by volume (ASTM D 1056), should not support microbial growth (ASTM D2180, G21, G22) and should not emit objectionable odors (ASTM C 665) and should have thermal conductivity of 0.033W/m.k @ 0deg C as per DIN EN 12667. and water vapor permeance of 0.10. Joints should be sealed with 50 mm wide 3 mm thick self adhesive tape (Black Cotton Tape not acceptable). Adhesive shall be used additionally with VOC level not exceeding 50 grms / Litre. Insulation shall be with necessary UV protection and weather protection for longer life.	Sqm.	RO	Comply
15	Supply & fixing of Acoustic insulation for Supply air duct using 10 mm thick class 1 rating Open cell nitrile rubber elastomeric insulation with density of 140 - 180 kg / m³. The insulation manufactured as per BS 476 Part 7 & which should also meet UL 94 test supplementary materials for air distribution system which should not absorbs less 0.2% water by volume (ASTM c 209), should not support microbial growth (ASTM 2180, G21, G22) and should not emit objectionable odors (ASTM C 665) and should have thermal conductivity of 0.04 W/m K @ 20 deg C as per DIN EN 12667 and water vapor permeance of 0.10. Adhesive shall be used additionally with VOC level not exceeding 50 grms / Litre.	Sqm.	RO	Comply with Deviation K Value 0.047 W/mk at 20 C
2	Supply, installation & testing of nitrile rubber insulation with GC cloth for chilled water piping insulation as per specifications & drawing on chilled water pipes of the following sizes: - For outdoor chilled water insulation pipe Nitrile rubber insulation with UV and weather proof coating.			Comply
	Supply, installation and testing of 25 mm thick nitrile rubber insulation with protective coating glass cloth on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications.			
2.01	25 mm Dia	Rmt.	RO	
2.02	32 mm Dia	Rmt.	RO	
2.03	40 mm Dia	Rmt.	50	
2.04	50 mm Dia	Rmt.	RO	
2.05	65 mm Dia	Rmt.	RO	
2.06	80 mm Dia	Rmt.	50	
3	Supply, installation and testing of 32mm thick nitrile rubber insulation with protective coating (glass cloth) on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications.			Noted
3.01	100 mm Dia	Rmt.	RO	
3.02	125 mm Dia	Rmt.	RO	
3.03	150 mm Dia	Rmt.	RO	