

E	Thermal Insulation	UOM	Qty	Rate	Value	Material Description	Remark
1	Supplying, installing and testing of 25 mm thick insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on chilled water piping and fittings like valves, flanges union, etc. as per the approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.						Complies
1.1	25 mm dia pipes	RM	34	221	7514	ALP Aerocell NBR tube with GC 25x35	
2	Supply and installation of External Thermal insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on ducts as per the specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.						Complies
2.1	19 mm thick insulation for supply air ducts in return air path.	sq.m	1200	393	471600	ALP Aerocell NBR sheet with GC 19 mm	
2.2	13 mm thick insulation for fresh air ducts inside shaft and office toilet exhaust ducts.	sq.m	1300	320	416000	ALP Aerocell NBR sheet with GC 13 mm	
2.3	9 mm thick insulation for fresh air ducts inside shaft and office toilet exhaust ducts.	sq.m	14163	277	3923151	ALP Aerocell NBR sheet with GC 9 mm	
2.4	25 mm thick insulation for ducts exposed to atmosphere with UV Protection Paint over 7 mil glass cloth (HRW supply and return ducts on terrace)	sq.m	138	478	65964	ALP Aerocell NBR sheet with GC 25 mm	Complies
3	Supply, installation testing and commissioning of acoustic insulation. Material shall be nitrile rubber with 140-180 Kg/m ³ density and all accessories as per specification. The material should conform to Class 1 rating for surface spread of Flame in accordance to BS 476 Part 7 & UL 94 (HBF, HF 1 & HF 2) in accordance to UL 94, 1996.						Complies
3.1	15 mm thick	sq.m	850	630	535500	ALP Accosound 15 mm acoustic Insulation	
4	Supply, installation and testing of Nitrile Rubber Insulation with 7mil thick factory laminated fibreglass cloth protective coating on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.						Complies
	16 mm thick insulation	sq.m	425	357	151725	ALP Aerocell NBR sheet with GC 16 mm	
	19 mm thick insulation	sq.m	1650	393	648450	ALP Aerocell NBR sheet with GC 19 mm	
	25 mm thick insulation	sq.m	125	478	59750	ALP Aerocell NBR sheet with GC 25 mm	
5	Supply, installation and testing of Nitrile Rubber Insulation on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.						Complies
	16 mm thick insulation	sq.m	425	195	82875	ALP Aerocell plain NBR sheet 16 mm	
	19 mm thick insulation	sq.m	1650	230	379500	ALP Aerocell plain NBR sheet 19 mm	
	25 mm thick insulation	sq.m	125	317	39625	ALP Aerocell plain NBR sheet 25 mm	
6	Supply, installation, testing & commissioning of Nitrile Rubber insulation with UV protection and factory laminated aluminium foil over chilled water pipes exposed to sun. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.						Complies
	25 mm thick insulation	sq.m	110	414	45540	ALP Aerocell NBR sheet with Alu foil 25 mm	
7	Supplying, installing and testing of Nitrile Rubber insulation with 7mil thick factory laminated fibreglass cloth protective coating on condensate drain piping and fittings like valves, flanges union, etc. as per the approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.						Complies
	6 mm thick insulation	sq.m	140	277	38780	ALP Aerocell NBR sheet with GC 6 mm	
					6865974		

