

Confidential Document. This document contains confidential information proprietary to RIL Neither whole nor part of this document may be reproduced, disclosed	Insulation				
	S.NO.	DESCRIPTION	UNIT	Specifications	Reply
	A.	DUCT INSULATION FOR DUCTING			
	1	Make		Vendor to Sepcify	INWOOL
	2	Country of Origin		Vendor to Sepcify	India
	3	Material of insulation		Resin Bonded fiber glass with Factory reinforced AL foil	Fiber glass with FSK
	4	Thermal Conductivity 'K' valve,	W/mK @ 10°C	0.036	0.036
	5	Density Kg / m3	Kg/m3	24	24
	6	Vapor permeability		Vendor to Sepcify	0.89% (Water Absorption)
	7	Operational Range	°C	.(-) 40°C to 105°C	-40 to 230 C
	8	Thickness for supply air ducting	mm	Vendor to Sepcify	25 & 50mm
	9	External finish		Vendor to Sepcify	FSK
	10	Thickness for return air ducting	mm	Vendor to Sepcify	25mm
	11	External finish		Vendor to Sepcify	FSK
	12	Adhesive tape	Aluminum	AL	Alu Foil Tape
	13	Type & Make of adhesive		Vendor to Sepcify	INSEAL
	14	Fire performance	Fire retardant	Class 0 as per BS 476 part 6 & 7	Class O
	15	Technical Catalogue	Vendor to provide with offer	Required	Noted
	B.	DUCT ACCOUSTIC INSULATION			
	1	Make		Vendor to Sepcify	INWOOL
	2	Country of Origin		Vendor to Sepcify	India
	3	Material		fiber glass Rigid Board	Fiber glass with FSK
	4	Thermal Conductivity 'K' valve,		Vendor to Sepcify	0.036
	5	Density Kg / m3	Kg/m3	48	48
	6	Operational Range	°C	..-20°C to 85°C	-40 to 230 C
	7	Thickness	mm	15	Noted
	8	Finishing material	NA	Vendor to Sepcify	FSK
	9	Fire performance	Non Combustible	Required	Class O
	10	Technical Catalogue	Vendor to provide with offer	Required	Noted
	STANDARD DATA SHEET		Job Number		
	Duct Work And Fire Damper		Data Sheet No.		
	RELIANCE JAMNAGAR 3 PROGRAM		Rev.		
			Sheet		

