

ANNEXURE-IV				
INSULATION				
S.NO.	DESCRIPTION	UNIT	As Per Specifications	Remark
A	DUCTING			
1	Material of insulation		Closed-cell Elastomeric Nitrile	Comply
2	Make			
3	Thickness	mm	As per Specification	Comply
4	Density	kg/cm ³	40-55	Comply
5	Thermal conductivity	BTU.in/ft. ² hr. °F	0.00616	Comply
6	Fire performance		Class O as per BS 476 Part 6 & Part 7	Comply
7	Vapour permeability		12000	Comply
8	Temperature range	°C	Max. 85	Comply
9	External finish		Alu Foil	Comply
10	Type & Make of adhesive		Low Voc	Comply
11	FM Global certificated	Yes	Yes	Yes
B	CHILLED WATER PIPING			
1	Material of insulation			Closed-cell Elastomeric Nitrile
2	Make			
3	Thickness	mm		As per requirement
4	Density	kg/cm ³		40-60
5	Thermal conductivity	BTU.in/ft. ² hr. °F		0.035 w/mk at 10 C mean Temp.
6	Fire performance			Class O as per BS 476 Part 6 & Part 7
7	Vapour permeability			7000 without finishing
8	Temperature range	°C		-40 to 85 C
9	External finish			As per requirement
10	Type & Make of adhesive			Low VOC adhesive
11	FM Global approved	Yes/No		Yes

