

Sr.No	Description	Unit	Quantity	Remark
1	Acoustic Insulation of AHU Room wall / Return Air Box : SITC of acoustic material for the AHU Room using Ready-made acoustic panels with snap fit plugs. It shall have thickness of 30 ± 2 mm, It shall have length and width of 300 ± 2 mm, It shall have an NRC value of 0.70-0.75 as per ISO 354/ASTM 423C, It shall also have an STC (Sound Transmission Class) value of 18 ± 2 dB. Holes shall be made in accordance with the dimensions of the panel for application. Panels shall be directly fixed on the wall with the help of snap fit plugs inside the holes and the application shall be completed as per the guidelines given in the application manual.	Sqft	13617	Comply
7.3.4	Underdeck Insulation : SITC of thermal Insulation under RCC slab with PIR boards having density of 45 kg/m ³ and recommended thickness of 20 mm with both side FSK facing. Material shall have thermal conductivity of 0.023 W/m.k @ 10 deg C mean temperature confirming to ASTM C518 & thermal resistance of 4.937 °F ft ² hr/BTU. It shall have burning rate of 6 mm confirming to IS: 11239. Material shall possess Compressive strength of 115 Kpa confirming to IS: 11239. Material shall have water vapour permeability of 0.017 ng./s.m.pa in accordance to ASTM E96. It shall be fixed under RCC slab with the help of G.I wire & screw washer system and completes as per guidelines given in application manual			Comply
	20 mm thick	Sq.Mt.	3975	

