

E	Thermal Insulation			Remark
1	Supplying, installing and testing of 25 mm thick insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on chilled water piping and fittings like valves, flanges union, etc. as per the approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.			Complies
1.1	25 mm dia pipes	RM	34	
2	Supply and installation of External Thermal insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on ducts as per the specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.			Complies
2.1	19 mm thick insulation for supply air ducts in return air path.	sq.m	6742	
2.2	13 mm thick insulation for fresh air ducts inside shaft and office toilet exhaust ducts.	sq.m	2380	
2.3	25 mm thick insulation for ducts exposed to atmosphere with UV Protection Paint over 7 mil glass cloth (HRW supply and return ducts on terrace)	sq.m	128	
3	Supply, installation testing and commissioning of acoustic insulation. Material shall be nitrile rubber with 140-180 Kg/m ³ density and all accessories as per specification. The material should conform to Class 1 rating for surface spread of Flame in accordance to BS 476 Part 7 & UL 94 (HBF, HF 1 & HF 2) in accordance to UL 94, 1996.			
3.1	15 mm thick	sq.m	850	
4	Supply, installation and testing of Nitrile Rubber Insulation with 7mil thick factory laminated fibreglass cloth protective coating on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.			Complies
	16 mm thick insulation	sq.m	425	
	19 mm thick insulation	sq.m	1650	
	25 mm thick insulation	sq.m	125	
5	Supply, installation and testing of Nitrile Rubber Insulation on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.			Complies
	16 mm thick insulation	sq.m	425	
	19 mm thick insulation	sq.m	1650	
	25 mm thick insulation	sq.m	125	
6	Supply, installation, testing & commissioning of Nitrile Rubber insulation with UV protection and factory laminated aluminium foil over chilled water pipes exposed to sun. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.			Complies
	25 mm thick insulation	sq.m	110	
7	Supplying, installing and testing of Nitrile Rubber insulation with 7mil thick factory laminated fibreglass cloth protective coating on condensate drain piping and fittings like valves, flanges union, etc. as per the approved shop drawings and specifications. The insulation material shall be fire rated for Class 0 as per Reference Standards and codes for fire propagation test and for Class 1 as per BS 476 Part 7, 1987 for surface spread of flame test.			Complies
		sq.m	140	

