

Beam Schedule									
All levels based on a Ground Floor FFL of 90.490 (Finishes 90.520)									
Shown on PRP Drawing No.	Beam No.	Beam Size (All steel to be Grade S355 JR uno)	Beam Length [mm] (inc. end plate thickness) (All beam lengths to be checked on site)	Beam Level (Underside inc. btm plate thickness)	Top Plate Thickness [mm]	Btm Plate Thickness [mm]	Paint Condition	Intumescent Paint	Notes
64410-301	B101	150x100x6.3 RHS	4400mm	92.890	-	6	C2	Yes	Bottom plate approx 340mm wide, 4400mm long. Min 2No 8mm thick stiffening plates with 20mm chamfer and 6mm CFW to beam and plate @ each end of plate & @ max 900 crs
64410-301	B102	150x100x6.3 RHS	5965mm	92.890	-	6	C2	Yes	Bottom plate approx 340mm wide, 5965mm long. Min 2No 8mm thick stiffening plates with 20mm chamfer and 6mm CFW to beam and plate @ each end of plate & @ max 900 crs
64410-301	B103A	356x127x39 UKB	3990mm	93.062	-	-	C2	Yes	-
64410-301	B103B	140x140x10 SHS	3725mm	92.890	-	8	C2	Yes	Bottom plate approx 380mm wide, 3725mm long. Min 2No 8mm thick stiffening plates with 20mm chamfer and 6mm CFW to beam and plate @ each end of plate & @ max 900 crs
64410-301	B104	203x203x46 UKC	3975mm	92.795	-	-	C2	Yes	-
64410-301	B105	250x250x8 SHS	4700mm	93.315	-	-	C2	Yes	150x150x10 UKA Shelf Angle, 4700mm long with 6mm FW 100mm hit & miss
64410-301	B106	254x254x73 UKC	5855mm	93.305	6	-	C2	Yes	Top plate approx 330mm wide, 5855mm long with 6mm FW 100mm hit & 300mm miss
64410-301	B107	203x203x60 UKC	2985mm	93.206	-	-	C2	Yes	-
64410-301	B108A	406x178x54 UKB	4120mm	93.162	-	-	C2	Yes	2No 150x90x10 UKA Shelf Angles, 4120mm long with 6mm FW 100mm hit & miss
64410-301	B108B	160x80x5 RHS	3695mm	92.795	-	-	C2	Yes	-
64410-301	B109	2No 180x90x26 UKPFCs	3825mm	92.795	-	-	C2	Yes	with 160x160x5 SHS spacers and 2No M12 Grade 8.8 bolts @ max 450 crs
64410-301	B110	152x152x23 UKC	1400mm	93.263	-	-	C2	Yes	-
64410-301	B111	152x152x23 UKC	2895mm	93.263	-	-	C2	Yes	-
64410-301	B112	203x203x60 UKC	2200mm	92.795	-	-	C2	Yes	-
64410-301	L4	140x140x5 SHS	1935mm	92.890	-	-	C2	Yes	Inner leaf lintel to Playroom
All levels based on a First Floor FFL of 93.750 (Finishes 93.780)									
64410-302	B2201	203x203x46 UKC	1840mm	96.055	-	-	C2	Yes	-
64410-302	L4	140x140x5 SHS	2275mm	96.115	-	-	C2	Yes	Inner leaf lintel to Landing
All levels based on a Second Floor FFL of 96.975 (Finishes 97.005) & Top of flat roof joists of 99.810									
64410-303	B201	203x102x23 UKB	3040mm	99.557	-	-	C2	Yes	12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B202	203x102x23 UKB	4110mm	99.557	-	-	C2	Yes	12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B203	203x102x23 UKB	2990mm	99.354	-	-	C2	Yes	12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B204	203x102x23 UKB	4060mm	99.354	-	-	C2	Yes	12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B205	203x102x23 UKB	3040mm	99.557	-	-	C2	Yes	12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B206	203x102x23 UKB	4110mm	99.557	-	-	C2	Yes	12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B207	203x133x25 UKB	7135mm	Top: 99.557 Btm: 96.790	-	-	C2	Yes	Cranked Beam with 10mm thk division plate 12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B208	203x133x25 UKB	7135mm	Top: 99.557 Btm: 96.790	-	-	C2	Yes	Cranked Beam with 10mm thk division plate
64410-303	B209	203x133x25 UKB	7135mm	Top: 99.557 Btm: 96.790	-	-	C2	Yes	Cranked Beam with 10mm thk division plate 12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B210	203x133x25 UKB	7195mm	Top: 99.557 Btm: 96.790	-	-	C2	Yes	Cranked Beam with 10mm thk division plate 12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web
64410-303	B211	203x133x25 UKB	7195mm	Top: 99.557 Btm: 96.790	-	-	C2	Yes	Cranked Beam with 10mm thk division plate
64410-303	B212	203x133x25 UKB	7195mm	Top: 99.557 Btm: 96.790	-	-	C2	Yes	Cranked Beam with 10mm thk division plate 12mm Ø holes in web @ 450mm crs & 12mm Ø holes in top flange @ 450mm crs staggered either side of web

T2

T2

T2

Column Schedule											
Top of Foundation - 89.695 - TBC on site											
Shown on PRP Drawing No.	Column No.	Column Size (All steel to be Grade S355 JR uno)	Column Length [mm] (inc. cap plate and baseplate) (Lengths to be checked on site)	Top Level (Top of cap plate)	Btm Level (Underside of baseplate) (i.e top of grout)	Cap Plate Thickness	Baseplate Thickness	Paint Condition	Intumescent Paint	Grout (25mm thk)	Notes
64410-301	C001	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	Yes	ToF to B101
64410-301	C002	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	Yes	ToF to B101
64410-301	C003	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	Yes	ToF to B101
64410-301	C004	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	Yes	ToF to B102
64410-301	C005	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	No	ToF to B102
64410-301	C006	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	No	ToF to B102
64410-301	C007	100x100x6.3 SHS	3170mm	92.890	89.720	10mm	10mm	C2	Yes	No	ToF to B102
64410-301	C008	140x140x6.3 SHS	3342mm	93.062	89.720	200x150x12 UKA	10mm	C2	Yes	No	ToF to B103A
64410-301	C009	140x140x6.3 SHS	3342mm	93.062	89.720	200x150x12 UKA	10mm	C2	Yes	Yes	ToF to B103A
64410-301	C010	100x100x6.3 SHS	3595mm	93.315	89.720	10mm	10mm	C2	Yes	Yes	ToF to B105
64410-301	C011	203x203x46 UKC	3585mm	93.305	89.720	20mm	15mm	C2	Yes	Yes	ToF to B106
64410-301	C012	203x203x46 UKC	3585mm	93.305	89.720	20mm	15mm	C2	Yes	Yes	ToF to B106
64410-301	C013	203x203x46 UKC	3442mm	93.162	89.720	15mm	15mm	C2	Yes	Yes	ToF to B108A
64410-301	C014	203x203x46 UKC	3442mm	93.162	89.720	15mm	15mm	C2	Yes	Yes	ToF to B108A
64410-303	C201A	90x90x6.3 SHS	2767mm	99.557	96.790	10mm	10mm	C2	Yes	No	Top of planks to B207
64410-303	C201B	90x90x6.3 SHS	2672mm	99.557	96.790	10mm	10mm	C2	Yes	No	Top of planks to B208
64410-303	C201C	90x90x6.3 SHS	2672mm	99.557	96.790	10mm	10mm	C2	Yes	No	Top of planks to B209

NOTE: Schedule must be read in conjunction with Steelwork & Architectural Drawings.
Levels & Dimensions to be checked on site prior to fabrication. Any discrepancies to be reported to PRP.

- Notes:**
- PRP have assumed the role of a Designer in the context of the Construction (Design and Management) Regulations and The Building Safety Act. All parties must be aware of their duties under this legislation.
 - Construction work shall not be started until designs have been approved by Building Control.
 - Do not scale from this drawing.
 - All dimensions are in millimetres unless noted otherwise. All levels in metres unless noted otherwise.
 - Drawing shall be read in conjunction with all relevant architect's drawings. The architect shall retain overall responsibility for dimensional control. Any inconsistencies shall be reported to PRP.
 - All levels and dimensions shall be checked on site before any work commences. Setting out remains the responsibility of others.
 - Buildings shall be constructed in accordance with Approved Document A of The Building Regulations. Drainage shall be constructed in accordance with Approved Document H of The Building Regulations.
 - Temporary works shall be designed by others to BS 5975
 - Fire protective measures shall be designed by the Architect or contractor in accordance with Approved Document B of the Building Regulations.
 - Waterproofing shall be designed by others in accordance with Approved Document C of the Building Regulations.
 - For more information see PRP drawings:
64410 - 100series - Drainage and External Works
64410 - 200series - Foundations
64410 - 300series - Superstructure
 - This drawing must be read together with PRP drawings:
64410 - 300 - Typical Notes and Details

T2	21/11/2025	B107, B109 & B112 amended Issued for Tender	JD / HP
T1	14/11/2025	Issued for Draft Tender	JD / HP
Rev	Date	Description	By / Chk
PRP consulting engineers & surveyors Spring Hill Office Park Harborough Road Pitsoford NN6 9AA Telephone: 01604 889 870 northampton@prp.uk.com www.prp.uk.com Leicester Northampton London engineering excellence creating advantage			
Client: St Helens Pharmacy Ltd			
Architect: Ascot Design			
Project: 33 Prestbury Road Wilmslow SK9 2LJ			
Title: Superstructure Main House Beam & Column Schedule			
Status: TENDER			
Engineer:	JKT	Date:	September 2025
Drawn:	JD	Scales @ A1:	
Checked:	HP		1:50
Project No:	64410	Drg No:	307
		Rev:	T2