

Smart Electrical Grid Control Architecture

1. SCADA Integration

Substation automation communicates over IEEE 1815 (DNP3) and IEC 61850 protocol standards.

Phasor Measurement Units (PMUs) stream synchrophasor data at 60 samples per second to state estimators.

Substation Resiliency Specifications

2. Fault Isolation

Automated Fault Location, Isolation, and Service Restoration (FLISR) restores power to un-faulted segments within 75 seconds.

Backup diesel generator reserve runtime is specified for 72 continuous hours.