Building Inspection Division
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE OR THE CITY OF LAKELAND LAND DEVELOPMENT CODE
Date: 06/30/20
Permit Number: BLD16-00198

Panel: 1LF1-SEC1

Location: ELEV NO. 5 -
Supply From: T112.5
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1													2
3	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	4
5								1.08	1.08				6
7	MISC	20 A	3	1.08	1.08					3	20 A	RECEPT	8
9						1.08	1.08						10
11								1.08	1.08				12
13	MISC	20 A	3	1.08	1.08					3	20 A	MISC	14
15						1.08	1.08						16
17								1.08	1.08				18
19	MISC	20 A	3	1.08	1.08					3	20 A	MISC	20
21						1.08	1.08						22
23								1.08	1.08				24
25	MISC	20 A	3	1.08	1.08					3	20 A	MISC	26
27						1.08	1.08						28
29								1.08	1.08				30
31	MISC	20 A	3	1.08	1.08					3	20 A	MISC	32
33						1.08	1.08						34
35								1.08	1.08				36
37	MISC	20 A	3	1.08	1.08					3	20 A	MISC	38
39						1.08	1.08						40
41	POWER	20 A	1					0.72	0.00	1	20 A	SPARE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43				1.08	1.08								44
45	MISC	20 A	3			1.08	1.08			3	20 A	MISC	46
47								1.08	1.08				48
49				1.08	1.08								50
51	MISC	20 A	3			1.08	1.08			3	20 A	MISC	52
53								1.08	1.08				54
55				1.08	1.08								56
57	MISC	20 A	3			1.08	1.08			3	20 A	MISC	58
59								1.08	1.08				60
61				1.08	1.08								62
63	MISC	20 A	3			1.08	1.08			3	20 A	MISC	64
65								1.08	1.08				66
67				1.08	1.08								68
69	MISC	20 A	3			1.08	1.08			3	20 A	MISC	70
71								1.08	1.08				72
73				1.08	1.08								74
75	MISC	20 A	3			1.08	1.08			3	20 A	MISC	76
77								1.08	1.08				78
79				1.08	0.00					1	20 A	SPARE	80
81	MISC	20 A	3			1.08	0.00			1	20 A	SPARE	82
83								1.08	0.00	1	20 A	SPARE	84

SECTION 3

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
85				1.08	1.08								86
87	MISC	20 A	3			1.08	1.08			3	20 A	MISC	88
89								1.08	1.08				90
91				1.08	1.08								92
93	MISC	20 A	3			1.08	1.08			3	20 A	MISC	94
95								1.08	1.08				96
97				1.08	1.08								98
99	MISC	20 A	3			1.08	1.08			3	20 A	MISC	100
101								1.08	1.08				102
103	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	104
105	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	106
107	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	108
109	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	110
111	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	112
113	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	114
115	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	116
117	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	118
119	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	120
121	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	122
123	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	124
125	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	126
				33.5 kVA		33.5 kVA		34.2 kVA					
				279.0 A		279.0 A		285.0 A					

TOTAL CONNECTED LOAD: 101160 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Other	0 VA	0.00%	0 VA		
Power	720 VA	100.00%	720 VA	**Total Conn. Load:**	101160 VA
MISC	100440 VA	100.00%	100440 VA	**Total Est. Demand:**	101160 VA
				Total Conn.:	281 A
				Total Est. Demand:	281 A

Panel: 1LF3-SEC1

Location: ELEV NO. 5 -
Supply From:
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 225 A
MCB Rating: 225 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	COFFEE BREWER	50 A	2	3.00	0.00					1	20 A	SPARE	2
3						3.00	0.00			1	20 A	SPARE	4
5	RECEPTACLE	20 A	1					0.72	0.18	1	20 A	ELEVATOR PIT RECEPTACLE	6
7	POWER	20 A	1	0.72	0.18					1	20 A	POWER	8
9	POWER	20 A	1			0.36	0.18			1	20 A	POWER	10
11	POWER	20 A	1					0.18	0.72	1	20 A	RECEPTACLE	12
13	RECEPTACLE	20 A	1	0.36	0.50					1	20 A	ELEVATOR CAB LIGHTS	14
15	ELEVATOR MACHINE ROOM RECEPTACLE	20 A	1			0.18	0.54			1	20 A	RECEPTACLE	16
17	RECEPTACLE	20 A	1					0.36	0.00	1	20 A	SPARE	18
19	SPARE	20 A	1	0.00	0.54					1	20 A	RECEPTACLE	20
21	RECEPTACLE	20 A	1			0.36	0.72			1	20 A	RECEPTACLE	22
23	POWER	20 A	1					1.20	1.20	1	20 A	POWER	24
25	POWER	20 A	1	1.20	0.00					1	20 A	SPARE	26
27	SPARE	20 A	1			0.00	1.20			1	20 A	POWER	28
29	POWER	20 A	1					1.20	1.20	1	20 A	POWER	30
31	RECEPTACLE	20 A	1	0.90	0.72					1	20 A	RECEPTACLE	32
33	POWER	20 A	1			0.72	0.90			1	20 A	POWER	34
35	RECEPTACLE	20 A	1					0.72	0.00	1	20 A	SPARE	36
37	RECEPTACLE	20 A	1	0.36	0.36					1	20 A	RECEPTACLE	38
39	RECEPTACLE	20 A	1			0.54	0.36			1	20 A	RECEPTACLE	40
41	RECEPTACLE	20 A	1					0.36	0.36	1	20 A	RECEPTACLE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	RECEPTACLE	20 A	1	0.36	0.36					1	20 A	RECEPTACLE	44
45	RACK RECEPTACLE	30 A	2			0.10	0.10			2	30 A	RACK RECEPTACLE	46
47								0.10	0.10				48
49	RACK RECEPTACLE	30 A	2	0.10	0.50					1	20 A	POWER	50
51						0.10	0.90			1	20 A	RECEPTACLE	52
53	RECEPTACLE	20 A	1					0.18	0.36	1	20 A	RECEPTACLE	54
55		20 A	1	1.74									56
57							1.20			1	20 A	POWER	58
59	POWER	20 A	1					1.20	0.72	1	20 A	POWER	60
61	RECEPTACLE	20 A	1	0.18	0.18					1	20 A	RECEPTACLE	62
63	AV RACK	20 A	1			0.36							64
65									0.00	1	20 A	SPARE	66
67	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	68
69	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	70
71	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	72
73	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	74
75	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	76
77	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	78
79	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	80
81	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	82
83	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	84
				12.3 kVA		11.8 kVA		11.1 kVA					
				103.1 A		99.5 A		92.2 A					

TOTAL CONNECTED LOAD: 35140 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Power	15580 VA	100.00%	15580 VA		
Receptacle	19560 VA	75.56%	14780 VA	**Total Conn. Load:**	35140 VA
				Total Est. Demand:	30360 VA
				Total Conn.:	98 A
				Total Est. Demand:	84 A

Panel: 1LF2-SEC1

Location: J.C. 1-108
Supply From: T45
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 150 A
MCB Rating: 150 A

Notes: 150 AMP, 3 POLE CONTACTOR CONTROLLED PANELBOARD. CONTACTOR TO BE CONTROLLED VIA TIMECLOCK. CONTACTOR MAY BE INTEGRAL TO PANELBOARSD OR LOCATED IN A SEPARATE NEMA 1 ENCLOSURE.

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	2
3	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	4
5	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	6
7	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	8
9	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	10
11	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	12
13	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	14
15	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	16
17	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	18
19	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	20
21	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	22
23	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	24
25	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	26
27	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	28
29	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	30
31	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPTACLE	32
33	RECEPTACLE	20 A	1			0.90	1.08			1	20 A	RECEPTACLE	34
35	RECEPTACLE	20 A	1					1.08	1.08	1	20 A	RECEPTACLE	36
37	POWER	20 A	1	0.72	0.72					1	20 A	POWER	38
39	RECEPTACLE	20 A	1			1.08	1.08			1	20 A	POWER	40
41	RECEPTACLE	20 A	1					0.90	0.90	1	20 A	RECEPTACLE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	RECEPTACLE	20 A	1	0.54	1.08					1	20 A	RECEPTACLE	44
45	RECEPTACLE	20 A	1			0.54	0.54			1	20 A	RECEPTACLE	46
47	RECEPTACLE	20 A	1					0.54	0.54	1	20 A	POWER	48
49	RECEPTACLE	20 A	1	0.36	0.18					1	20 A	RECEPTACLE	50
51	RECEPTACLE	20 A	1			0.18	0.00			1	20 A	SPARE	52
53	POWER	20 A	1					1.44	0.00	1	20 A	SPARE	54
55	POWER	20 A	1	0.72	0.00					1	20 A	SPARE	56
57	POWER	20 A	1			0.36	0.00			1	20 A	SPARE	58
59	POWER	20 A	1					0.36	0.00	1	20 A	SPARE	60
61	POWER	20 A	1	0.36	0.00					1	20 A	SPARE	62
63	POWER	20 A	1			0.36	0.00			1	20 A	SPARE	64
65	AV RACK	20 A	1					0.54	0.00	1	20 A	SPARE	66
67	POWER	20 A	1	0.90	0.00					1	20 A	SPARE	68
69	RECEPTACLE	20 A	1			0.72	0.00			1	20 A	SPARE	70
71	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	72
73	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	74
75	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	76
77	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	78
79	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	80
81	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	82
83	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	84
				18.5 kVA		17.6 kVA		18.2 kVA					
				155.2 A		147.0 A		152.2 A					

TOTAL CONNECTED LOAD: 54360 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Power	7740 VA	100.00%	7740 VA		
RECEPT	33480 VA	64.93%	21740 VA	**Total Conn. Load:**	54360 VA
Receptacle	13140 VA	88.05%	11570 VA	**Total Est. Demand:**	41050 VA
RECPT	0 VA	0.00%	0 VA	**Total Conn.:**	151 A
				Total Est. Demand:	114 A

PANEL KEY	
1LF1	1LF3
	1LF2

AECOM
BATSON-COOK CONSTRUCTION

PROJECT

PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

CLIENT

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

CONSULTANT

AECOM

AECOM TECHNICAL SERVICES, INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA26000687

ENGINEERING
CA LIC. NO. 8115

http://www.aecom.com

REGISTRATION

HENRYK B. JUSZCZYK LICENSE NO. 58082 STATE OF FLORIDA PROFESSIONAL ENGINEER

HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082 ON THE DATE INDICATED HERE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

Henryk B Juszczyk
Digitally signed by Henryk B Juszczyk
Date: 2020.06.19 16:18:07-04'00'

ISSUE/REVISION

I/R	DATE	DESCRIPTION
4	MAY 01, 2020	SI-004
3	NOV 22, 2019	SI-001
2	OCT 25,2019	BUILDING DEPARTMENT COMMENTS
1	SEP 30, 2019	100% CONSTRUCTION DOCUMENTS
0	AUG 23, 2019	CONSTRUCTION DOCUMENTS

PROJECT NUMBER

60601397

SHEET TITLE

ELECTRICAL PANEL SCHEDULES

SHEET NUMBER

E5-1-11

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.

©2016 AECOM Corporation

Designer: Designer Checker: Checker Approved: Approver/ARCH E1 30"x42"
Project Management Initials:
Last Plotted: 5/12/2020 11:07:03 AM
Filename: BM 3800\60601397_Publix HQ\60601397_Publix HQ_ELECT_R2019.rvt
Printed on ___% Post-Consumer Recycled Content Paper