Building Inspection Division
Lakeland
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE
Date: 11/15/19
Permit Number: BLD19-06035

Panel: 2HF1

Location: ELEC 2-136
Supply From: MDP-HF
Mounting: Surface
Enclosure: 1
Volts: 480/277 Wye
Phases: 3
Wires: 4
A.I.C. Rating: 10,000
Mains Type: MLO
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	LIGHTING	20 A	1	3.66 kVA	4.05 kVA					1	20 A	LIGHTING	2
3	LIGHTING	20 A	1			3.20 kVA	0.39 kVA			1	20 A	LIGHTING	4
5	LIGHTING	20 A	1					1.89 kVA	0.00 kVA	1	20 A	SPARE	6
7	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	8
9	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	10
11	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	12
13	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	14
15	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	16
17	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	18
19	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	20
21	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	22
23	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	24
25	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	26
27	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	28
29	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	30
31	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	32
33	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	34
35	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	36
37	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	38
39	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	40
41	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	42
				7.7 kVA		3.6 kVA		1.9 kVA					
				28.8 A		13.9 A		6.8 A					

TOTAL CONNECTED LOAD: 13178 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Lighting	12876 VA	125.00%	16095 VA		
Other	315 VA	100.00%	315 VA	**Total Conn. Load:**	13178 VA
				Total Est. Demand:	16397 VA
				Total Conn.:	16 A
				Total Est. Demand:	20 A

Panel: 2HF2 SEC1

Location: ELEC 2-136
Supply From: MDP-HF
Mounting: Surface
Enclosure: 1
Volts: 480/277 Wye
Phases: 3
Wires: 4
A.I.C. Rating: 10,000
Mains Type: MLO
Mains Rating: 400 A
MCB Rating: 400 A

Notes: PROVIDE PANELBOARD WITH FEED THROUGH LUGS FOR FUTURE SECTION 2 INSTALLATION.

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1				7.73 kVA	7.73 kVA								2
3	AHU-2-7	30 A	3			7.73 kVA	7.73 kVA			3	30 A	AHU-2-8	4
5								7.73 kVA	7.73 kVA				6
7				15.01 kVA	15.01 kVA								8
9	EDH-2-7	70 A	3			15.01 kVA	15.01 kVA			3	70 A	EDH-2-8	10
11								15.01 kVA	15.01 kVA				12
13				9.93 kVA	12.29 kVA								14
15	FPU-2-7-1, FPU-2-7-2, FPU-2-7-3	60 A	3			9.93 kVA	12.29 kVA			3	60 A	FPU-2-8-1, FPU-2-8-2, FPU-2-8-3	16
17								9.93 kVA	12.29 kVA				18
19	POWER	20 A	1	0.30 kVA	0.30 kVA								20
21						10.00 kVA	0.30 kVA			3	20 A	FCU-3	22
23	EWH-2	60 A	3					10.00 kVA	0.30 kVA				24
25				10.00 kVA	0.00 kVA								26
27	SPACE	--	--			0.00 kVA	0.00 kVA			--	--	SPACE	28
29	SPACE	--	--					0.00 kVA	0.00 kVA	--	--	SPACE	30
31	SPACE	--	--	0.00 kVA	0.00 kVA					--	--	SPACE	32
33	SPACE	--	--			0.00 kVA	0.00 kVA			--	--	SPACE	34
35	SPACE	--	--					0.00 kVA	0.00 kVA	--	--	SPACE	36
37	VAV CONTROL TRANSFORMER (277 VOLTS)	20 A	1	0.50 kVA	0.00 kVA					--	--	SPACE	38
39	SPARE	20 A	1			0.00 kVA	0.00 kVA			--	--	SPACE	40
41	SPARE	20 A	1					0.00 kVA	0.00 kVA	--	--	SPACE	42
				78.8 kVA		78.0 kVA		78.0 kVA					
				284.5 A		281.6 A		281.6 A					

TOTAL CONNECTED LOAD: 234802 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
HVAC	187610 VA	100.00%	187610 VA		
Power	1000 VA	100.00%	1000 VA	**Total Conn. Load:**	234802 VA
				Total Est. Demand:	240601 VA
				Total Conn.:	282 A
				Total Est. Demand:	289 A

Panel: 2HG1

Location: ELEC 2-166
Supply From: MDP-HG
Mounting: Surface
Enclosure: 1
Volts: 480/277 Wye
Phases: 3
Wires: 4
A.I.C. Rating: 10,000
Mains Type: MLO
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	LIGHTING	20 A	1	3.81 kVA	4.02 kVA					1	20 A	LIGHTING	2
3	LIGHTING	20 A	1			3.35 kVA	3.16 kVA			1	20 A	LIGHTING	4
5	LIGHTING	20 A	1					0.21 kVA	0.63 kVA	1	20 A	LIGHTING	6
7	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	8
9	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	10
11	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	12
13	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	14
15	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	16
17	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	18
19	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	20
21	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	22
23	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	24
25	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	26
27	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	28
29	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	30
31	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	32
33	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	34
35	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	36
37	SPARE	20 A	1	0.00 kVA	0.00 kVA					1	20 A	SPARE	38
39	SPARE	20 A	1			0.00 kVA	0.00 kVA			1	20 A	SPARE	40
41	SPARE	20 A	1					0.00 kVA	0.00 kVA	1	20 A	SPARE	42
				7.8 kVA		6.5 kVA		0.8 kVA					
				31.4 A		26.7 A		3.0 A					

TOTAL CONNECTED LOAD: 15159 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Lighting	14815 VA	125.00%	18516 VA		
Other	360 VA	100.00%	360 VA	**Total Conn. Load:**	15159 VA
				Total Est. Demand:	18862 VA
				Total Conn.:	18 A
				Total Est. Demand:	23 A

Panel: 2HG2 SEC1

Location: ELEC 2-166
Supply From: MDP-HG
Mounting: Surface
Enclosure: 1
Volts: 480/277 Wye
Phases: 3
Wires: 4
A.I.C. Rating: 10,000
Mains Type: MLO
Mains Rating: 400 A
MCB Rating: 400 A

Notes: PROVIDE PANELBOARD WITH FEED THROUGH LUGS FOR FUTURE SECTION 2 INSTALLATION.

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1				7.73 kVA	7.73 kVA								2
3	AHU-2-9	30 A	3			7.73 kVA	7.73 kVA			3	30 A	AHU-2-10	4
5								7.73 kVA	7.73 kVA				6
7				15.01 kVA	15.01 kVA								8
9	EDH-2-9	70 A	3			15.01 kVA	15.01 kVA			3	70 A	EDH-2-10	10
11								15.01 kVA	15.01 kVA				12
13				7.80 kVA	13.58 kVA								14
15	FPU-2-10-1, FPU 10-2-10-2	60 A	3			7.80 kVA	13.58 kVA			3	20 A	FPU-2-9-2, FPU-2-8	16
17								7.80 kVA	13.58 kVA				18
19				4.49 kVA	0.00 kVA					--	--	SPACE	20
21	FCU-4	20 A	3			4.49 kVA	0.00 kVA			--	--	SPACE	22
23								4.49 kVA	0.00 kVA	--	--	SPACE	24
25	SPACE	--	--	0.00 kVA	0.00 kVA					--	--	SPACE	26
27	SPACE	--	--			0.00 kVA	0.00 kVA			--	--	SPACE	28
29	SPACE	--	--					0.00 kVA	0.00 kVA	--	--	SPACE	30
31	SPACE	--	--	0.00 kVA	0.00 kVA					--	--	SPACE	32
33	SPACE	--	--			0.00 kVA	0.00 kVA			--	--	SPACE	34
35	SPACE	--	--					0.00 kVA	0.00 kVA	--	--	SPACE	36
37	SPACE	--	--	0.00 kVA	0.00 kVA					--	--	SPACE	38
39	SPACE	--	--			0.00 kVA	0.00 kVA			--	--	SPACE	40
41	VAV CONTROL TRANSFORMER (277 VOLT)	20 A	1					0.50 kVA	0.00 kVA	--	--	SPACE	42
				71.3 kVA		71.3 kVA		71.7 kVA					
				257.6 A		257.6 A		259.0 A					

TOTAL CONNECTED LOAD: 214440 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
HVAC	167649 VA	100.00%	167649 VA		
Power	500 VA	100.00%	500 VA	**Total Conn. Load:**	214440 VA
				Total Est. Demand:	220239 VA
				Total Conn.:	258 A
				Total Est. Demand:	265 A

PANEL KEY	
2HF1	2HF2
2HG1	2HG2

AECOM
BATSON-COOK CONSTRUCTION

PROJECT

PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

CLIENT

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

CONSULTANT

AECOM

AECOM TECHNICAL SERVICES, INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA26000687

ENGINEERING
CA LIC. NO. 8115

http://www.aecom.com

REGISTRATION

HENRYK B. JUSZCZYK LICENSE NO. 58082 STATE OF FLORIDA PROFESSIONAL ENGINEER

HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082 ON THE DATE INDICATED HERE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

Henryk B Juszczyk
2019.09.30
18:17:33 -04'00'

ISSUE/REVISION

I/R	DATE	DESCRIPTION
1	SEP 30, 2019	100% CONSTRUCTION DOCUMENTS
0	AUG 23, 2019	CONSTRUCTION DOCUMENTS

PROJECT NUMBER

60601397

SHEET TITLE

ELECTRICAL PANEL SCHEDULES

SHEET NUMBER

E5-1-20

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.

Printed on ___% Post-Consumer Recycled Content Paper
©2016 AECOM Corporation