Panel: 2LG1-SEC1

Location: ELEC 2-166
Supply From: T112.5
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	2
3	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	4
5								1.08	1.08				6
7	MISC	20 A	3	1.08	1.08					3	20 A	MISC	8
9						1.08	1.08						10
11								1.08	1.08				12
13	MISC	20 A	3	1.08	1.08					3	20 A	MISC	14
15						1.08	1.08						16
17								1.08	1.08				18
19	MISC	20 A	3	1.08	1.08					3	20 A	MISC	20
21						1.08	1.08						22
23								1.08	1.08				24
25	MISC	20 A	3	1.08	1.08					3	20 A	MISC	26
27						1.08	1.08						28
29								1.08	1.08				30
31	MISC	20 A	3	1.08	1.08					3	20 A	MISC	32
33						1.08	1.08						34
35								1.08	1.08				36
37	MISC	20 A	3	1.08	1.08					3	20 A	MISC	38
39						1.08	1.08						40
41	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43				1.08	1.08								44
45	MISC	20 A	3			1.08	1.08			3	20 A	MISC	46
47								1.08	1.08				48
49				1.08	1.08								50
51	MISC	20 A	3			1.08	1.08			3	20 A	MISC	52
53								1.08	1.08				54
55				1.08	1.08								56
57	MISC	20 A	3			1.08	1.08			3	20 A	MISC	58
59								1.08	1.08				60
61				1.08	1.08								62
63	MISC	20 A	3			1.08	1.08			3	20 A	MISC	64
65								1.08	1.08				66
67				1.08	1.08								68
69	MISC	20 A	3			1.08	1.08			3	20 A	MISC	70
71								1.08	1.08				72
73				1.08	1.08								74
75	MISC	20 A	3			1.08	1.08			3	20 A	MISC	76
77								1.08	1.08				78
79				1.08	1.08								80
81	MISC	20 A	3			1.08	1.08			3	20 A	MISC	82
83								1.08	1.08				84

SECTION 3

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
85				1.08	1.08								86
87	MISC	20 A	3			1.08	1.08			3	20 A	MISC	88
89								1.08	1.08				90
91				1.08	1.08								92
93	MISC	20 A	3			1.08	1.08			3	20 A	MISC	94
95								1.08	1.08				96
97				1.08	1.08								98
99	MISC	20 A	3			1.08	1.08			3	20 A	MISC	100
101								1.08	1.08				102
103				1.08	1.08								104
105	MISC	20 A	3			1.08	1.08			3	20 A	MISC	106
107								1.08	1.08				108
109				1.08	1.08								110
111	MISC	20 A	3			1.08	1.08			3	20 A	MISC	112
113								1.08	1.08				114
115	SPARE	20 A	1	0.00	1.08								116
117	SPARE	20 A	1			0.00	1.08			3	20 A	MISC	118
119	SPARE	20 A	1					0.00	1.08				120
121	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	122
123	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	124
125	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	126
				40.0 kVA		40.0 kVA		40.0 kVA					
				333.0 A		333.0 A		333.0 A					

TOTAL CONNECTED LOAD: 119880 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
MISC	119880 VA	100.00%	119880 VA		
				Total Conn. Load:	119880 VA
				Total Est. Demand:	119880 VA
				Total Conn.:	333 A
				Total Est. Demand:	333 A

Panel: 2LG3-SEC1

Location: ELEC 2-166
Supply From: T75
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 225 A
MCB Rating: 225 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	2
3	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	4
5	RECEPTACLE	20 A	1					0.36	0.36	1	20 A	POWER	6
7	RECEPTACLE	20 A	1	0.54									8
9	RECEPTACLE	20 A	1			0.72							10
11	RECEPTACLE	20 A	1					0.18	0.54	1	20 A	POWER	12
13	POWER	20 A	1	0.18	1.08					1	20 A	RECEPTACLE	14
15	SPARE	20 A	1			0.00							16
17	RECEPTACLE	20 A	1					0.18					18
19	RECEPTACLE	20 A	1	0.18									20
21	RECEPTACLE	20 A	1			0.18	0.36			1	20 A	RECEPTACLE	22
23	RECEPTACLE	20 A	1					0.36	0.00	1	20 A	SPARE	24
25	SPARE	20 A	1	0.00	0.36					1	20 A	RECEPTACLE	26
27	RECEPTACLE	20 A	1			0.36	0.36			1	20 A	RECEPTACLE	28
29	RECEPTACLE	20 A	1					0.36	0.10	2	30 A	RACK RECEPTACLE	30
31	RACK RECEPTACLE	30 A	2		0.10	0.10							32
33						0.10	0.10			2	30 A	RACK RECEPTACLE	34
35	POWER	20 A	1					0.50	0.10				36
37	RECEPTACLE	20 A	1	0.36	0.72					1	20 A	RECEPTACLE	38
39	RACK RECEPTACLE	30 A	2			0.10	0.10			2	30 A	RACK RECEPTACLE	40
41								0.10	0.10				42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	RECEPTACLE	20 A	1	0.72	0.54					1	20 A	RECEPTACLE	44
45	RECEPTACLE	20 A	1			0.54	0.54			1	20 A	RECEPTACLE	46
47	RECEPTACLE	20 A	1					0.90	0.00	1	20 A	SPARE	48
49	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	50
51	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	52
53	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	54
55	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	56
57	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	58
59	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	60
61	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	62
63	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	64
65	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	66
67	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	68
69	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	70
71	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	72
73	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	74
75	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	76
77	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	78
79	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	80
81	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	82
83	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	84
				4.9 kVA		3.5 kVA		4.1 kVA					
				41.5 A		28.8 A		35.4 A					

TOTAL CONNECTED LOAD: 12480 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Power	1400 VA	100.00%	1400 VA		
Receptacle	11080 VA	95.13%	10540 VA	**Total Conn. Load:**	12480 VA
				Total Est. Demand:	11940 VA
				Total Conn.:	35 A
				Total Est. Demand:	33 A

Panel: 2LG2-SEC1

Location: ELEC 2-166
Supply From: T45
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 150 A
MCB Rating: 150 A

Notes: 150 AMP, 3 POLE CONTACTOR CONTROLLED PANELBOARD. CONTACTOR TO BE CONTROLLED VIA TIMECLOCK. CONTACTOR MAY BE INTEGRAL TO PANELBOAR5D OR LOCATED IN A SEPARATE NEMA 1 ENCLOSURE.

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	2
3	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	4
5	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	6
7	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	8
9	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	10
11	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	12
13	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	14
15	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	16
17	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	18
19	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	20
21	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	22
23	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	24
25	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	26
27	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	28
29	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	30
31	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	32
33	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	34
35	RECEPTACLE	20 A	1					1.26	1.08	1	20 A	RECEPT	36
37	SPARE	20 A	1	0.00	1.44					1	20 A	POWER	38
39	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	40
41	RECEPTACLE	20 A	1					0.90	0.36	1	20 A	RECEPTACLE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	RECEPTACLE	20 A	1	1.44	1.08					1	20 A	RECEPTACLE	44
45	RECEPTACLE	20 A	1			0.90	0.36			1	20 A	RECEPTACLE	46
47	RECEPTACLE	20 A	1					0.54	0.90	1	20 A	RECEPTACLE	48
49	POWER	20 A	1	0.36	0.00					1	20 A	SPARE	50
51	POWER	20 A	1			0.54	0.00			1	20 A	SPARE	52
53	RECEPTACLE	20 A	1					1.26	0.00	1	20 A	SPARE	54
55	RECEPTACLE	20 A	1	0.18	0.00					1	20 A	SPARE	56
57	RECEPTACLE	20 A	1			0.18	0.00			1	20 A	SPARE	58
59	RECEPTACLE	20 A	1					0.18	0.00	1	20 A	SPARE	60
61	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	62
63	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	64
65	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	66
67	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	68
69	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	70
71	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	72
73	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	74
75	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	76
77	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	78
79	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	80
81	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	82
83	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	84
				17.5 kVA		17.1 kVA		17.3 kVA					
				145.7 A		142.5 A		144.2 A					

TOTAL CONNECTED LOAD: 51840 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Power	2520 VA	100.00%	2520 VA		
RECEPT	39960 VA	62.51%	24980 VA	**Total Conn. Load:**	51840 VA
Receptacle	9360 VA	100.00%	9360 VA	**Total Est. Demand:**	36860 VA
				Total Conn.:	144 A
				Total Est. Demand:	102 A

PANEL KEY	
2LG1	**2LG3**
	2LG2

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

©2016 AECOM Corporation

Project Management Initials:
Designer: Designer Checker: Checker Approved: Approver ARCH E1 30"x42"

Last Plotted: 10/25/2019 3:33:08 PM
Filename: BM 300-60601397-Publix HQ\60601397_Publix HQ_ELECT_R2019.rvt

Printed on ___% Post-Consumer Recycled Content Paper

Building Inspection Division
City of Lakeland
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE
Date: 11/15/19
Permit Number: BLD19-06035

AECOM
BATSON-COOK CONSTRUCTION

PROJECT

PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

CLIENT

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

CONSULTANT

AECOM

AECOM TECHNICAL SERVICES, INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA26000687

ENGINEERING
CA LIC. NO. 8115

http://www.aecom.com

REGISTRATION

HENRYK B. JUSZCZYK LICENSE NO. 58082 STATE OF FLORIDA PROFESSIONAL ENGINEER

HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082 ON THE DATE INDICATED HERE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

Henryk B Juszczyk
2019.10.25 15:56:42
-04'00'

ISSUE/REVISION

I/R	DATE	DESCRIPTION
2	OCT 25,2019	BUILDING DEPARTMENT COMMENTS
1	SEP 30, 2019	100% CONSTRUCTION DOCUMENTS
0	AUG 23, 2019	CONSTRUCTION DOCUMENTS

PROJECT NUMBER

60601397

SHEET TITLE

ELECTRICAL PANEL SCHEDULES

SHEET NUMBER

E5-1-22

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.