# Panel: 3LF1-SEC1

**Location:** ELEV NO 5 -
**Supply From:** T112.5
**Mounting:** Surface
**Enclosure:** 1

**Volts:** 208/120 Wye
**Phases:** 3
**Wires:** 4

**A.I.C. Rating:** 10KA
**Mains Type:** MCB
**Mains Rating:** 400 A
**MCB Rating:** 400 A

**Notes:**

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 2 |
| 3 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 4 |
| 5 | MISC | 20 A | 3 | 1.08 | 1.08 | | | 1.08 | 1.08 | 3 | 20 A | MISC | 6 |
| 7 | | | | | | | | | | | | | 8 |
| 9 | | | | | | 1.08 | 1.08 | | | | | | 10 |
| 11 | MISC | 20 A | 3 | 1.08 | 1.08 | | | 1.08 | 1.08 | 3 | 20 A | MISC | 12 |
| 13 | | | | | | | | | | | | | 14 |
| 15 | | | | | | 1.08 | 1.08 | | | | | | 16 |
| 17 | MISC | 20 A | 3 | 1.08 | 1.08 | | | 1.08 | 1.08 | 3 | 20 A | MISC | 18 |
| 19 | | | | | | | | | | | | | 20 |
| 21 | | | | | | 1.08 | 1.08 | | | | | | 22 |
| 23 | MISC | 20 A | 3 | 1.08 | 1.08 | | | 1.08 | 1.08 | 3 | 20 A | MISC | 24 |
| 25 | | | | | | | | | | | | | 26 |
| 27 | | | | | | 1.08 | 1.08 | | | | | | 28 |
| 29 | MISC | 20 A | 3 | 1.08 | 1.08 | | | 1.08 | 1.08 | 3 | 20 A | MISC | 30 |
| 31 | | | | | | | | | | | | | 32 |
| 33 | | | | | | 1.08 | 1.08 | | | | | | 34 |
| 35 | MISC | 20 A | 3 | 1.08 | 1.08 | | | 1.08 | 1.08 | 3 | 20 A | MISC | 36 |
| 37 | | | | | | | | | | | | | 38 |
| 39 | | | | | | 1.08 | 1.08 | | | | | | 40 |
| 41 | | | | | | | | | | | | | 42 |

## SECTION 2

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 43 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 44 |
| 45 | | | | | | 1.08 | 1.08 | | | | | | 46 |
| 47 | | | | | | | | 1.08 | 1.08 | | | | 48 |
| 49 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 50 |
| 51 | | | | | | 1.08 | 1.08 | | | | | | 52 |
| 53 | | | | | | | | 1.08 | 1.08 | | | | 54 |
| 55 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 56 |
| 57 | | | | | | 1.08 | 1.08 | | | | | | 58 |
| 59 | | | | | | | | 1.08 | 1.08 | | | | 60 |
| 61 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 62 |
| 63 | | | | | | 1.08 | 1.08 | | | | | | 64 |
| 65 | | | | | | | | 1.08 | 1.08 | | | | 66 |
| 67 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 68 |
| 69 | | | | | | 1.08 | 1.08 | | | | | | 70 |
| 71 | | | | | | | | 1.08 | 1.08 | | | | 72 |
| 73 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 74 |
| 75 | | | | | | 1.08 | 1.08 | | | | | | 76 |
| 77 | | | | | | | | 1.08 | 1.08 | | | | 78 |
| 79 | MISC | 20 A | 3 | 1.08 | 0.00 | | | | | 1 | 20 A | SPARE | 80 |
| 81 | | | | | | 1.08 | 0.00 | | | 1 | 20 A | SPARE | 82 |
| 83 | | | | | | | | 1.08 | 0.00 | 1 | 20 A | SPARE | 84 |

## SECTION 3

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 85 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 86 |
| 87 | | | | | | 1.08 | 1.08 | | | | | | 88 |
| 89 | | | | | | | | 1.08 | 1.08 | | | | 90 |
| 91 | MISC | 20 A | 3 | 1.08 | 1.08 | | | | | 3 | 20 A | MISC | 92 |
| 93 | | | | | | 1.08 | 1.08 | | | | | | 94 |
| 95 | | | | | | | | 1.08 | 1.08 | | | | 96 |
| 97 | MISC | 20 A | 3 | 1.08 | 0.00 | | | | | 1 | 20 A | SPARE | 98 |
| 99 | | | | | | 1.08 | 0.00 | | | 1 | 20 A | SPARE | 100 |
| 101 | | | | | | | | 1.08 | 0.00 | 1 | 20 A | SPARE | 102 |
| 103 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 104 |
| 105 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 106 |
| 107 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 108 |
| 109 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 110 |
| 111 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 112 |
| 113 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 114 |
| 115 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 116 |
| 117 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 118 |
| 119 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 120 |
| 121 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 122 |
| 123 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 124 |
| 125 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 126 |
| | | | | 32.4 kVA | | 32.4 kVA | | 32.4 kVA | | | | | |
| | | | | 270.0 A | | 270.0 A | | 270.0 A | | | | | |

**TOTAL CONNECTED LOAD:** 97200 VA

| Load Classification | Connected Load | Demand Factor | Estimated Demand | Panel Totals | |
|---|---|---|---|---|---|
| MISC | 97200 VA | 100.00% | 97200 VA | | |
| | | | | **Total Conn. Load:** | 97200 VA |
| | | | | **Total Est. Demand:** | 97200 VA |
| | | | | **Total Conn.:** | 270 A |
| | | | | **Total Est. Demand:** | 270 A |

# Panel: 3LF3-SEC1

**Location:** ELEV NO 5 -
**Supply From:** T75
**Mounting:** Surface
**Enclosure:** 1

**Volts:** 208/120 Wye
**Phases:** 3
**Wires:** 4

**A.I.C. Rating:** 10KA
**Mains Type:** MCB
**Mains Rating:** 225 A
**MCB Rating:** 225 A

**Notes:**

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | COFFEE BREWER | 50 A | 2 | 3.00 | 0.00 | | | | | 1 | 20 A | SPARE | 2 |
| 3 | | | | | | 3.00 | 0.00 | | | 1 | 20 A | SPARE | 4 |
| 5 | RECEPTACLE | 20 A | 1 | | | | | 0.90 | 0.18 | 1 | 20 A | POWER | 6 |
| 7 | POWER | 20 A | 1 | 0.72 | 0.18 | | | | | 1 | 20 A | POWER | 8 |
| 9 | POWER | 20 A | 1 | | | 0.36 | 0.18 | | | 1 | 20 A | POWER | 10 |
| 11 | POWER | 20 A | 1 | | | | | 0.18 | 0.72 | 1 | 20 A | RECEPTACLE | 12 |
| 13 | RECEPTACLE | 20 A | 1 | 0.36 | 0.54 | | | | | 1 | 20 A | RECEPTACLE | 14 |
| 15 | RECEPTACLE | 20 A | 1 | | | 0.54 | 0.54 | | | 1 | 20 A | RECEPTACLE | 16 |
| 17 | RECEPTACLE | 20 A | 1 | | | | | 0.36 | | | | | 18 |
| 19 | | | | | 0.36 | | | | | 1 | 20 A | RECEPTACLE | 20 |
| 21 | RECEPTACLE | 20 A | 1 | | | 0.36 | 0.72 | | | 1 | 20 A | RECEPTACLE | 22 |
| 23 | POWER | 20 A | 1 | | | | | 1.20 | 1.20 | 1 | 20 A | POWER | 24 |
| 25 | POWER | 20 A | 1 | 1.20 | 0.00 | | | | | 1 | 20 A | SPARE | 26 |
| 27 | SPARE | 20 A | 1 | | | 0.00 | 1.20 | | | 1 | 20 A | POWER | 28 |
| 29 | POWER | 20 A | 1 | | | | | 1.20 | 1.20 | 1 | 20 A | POWER | 30 |
| 31 | RECEPTACLE | 20 A | 1 | 0.72 | 0.90 | | | | | 1 | 20 A | RECEPTACLE | 32 |
| 33 | RECEPTACLE | 20 A | 1 | | | 0.90 | 0.36 | | | 1 | 20 A | RECEPTACLE | 34 |
| 35 | RECEPTACLE | 20 A | 1 | | | | | 0.36 | 0.54 | 1 | 20 A | RECEPTACLE | 36 |
| 37 | RECEPTACLE | 20 A | 1 | 0.36 | 0.36 | | | | | 1 | 20 A | RECEPTACLE | 38 |
| 39 | RECEPTACLE | 20 A | 1 | | | 0.36 | 0.36 | | | 1 | 20 A | RECEPTACLE | 40 |
| 41 | RECEPTACLE | 20 A | 1 | | | | | 0.36 | 0.50 | 1 | 20 A | POWER | 42 |

## SECTION 2

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 43 | RACK RECEPTACLE | 30 A | 2 | 0.10 | 0.10 | | | | | 2 | 30 A | RACK RECEPTACLE | 44 |
| 45 | | | | | | 0.10 | 0.10 | | | | | | 46 |
| 47 | RACK RECEPTACLE | 30 A | 2 | | | | | 0.10 | | | | | 48 |
| 49 | | | | 0.10 | 0.90 | | | | | 1 | 20 A | RECEPTACLE | 50 |
| 51 | RECEPTACLE | 20 A | 1 | | | 0.36 | 0.18 | | | 1 | 20 A | RECEPTACLE | 52 |
| 53 | POWER | 20 A | 1 | | | | | 0.18 | 1.20 | 1 | 20 A | POWER | 54 |
| 55 | POWER | 20 A | 1 | 1.20 | 0.72 | | | | | 1 | 20 A | POWER | 56 |
| 57 | RECEPTACLE | 20 A | 1 | | | 0.18 | 0.36 | | | 1 | 20 A | AV RACK | 58 |
| 59 | | | | | | | | | | | | | 60 |
| 61 | | | | | 0.00 | | | | | 1 | 20 A | SPARE | 62 |
| 63 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 64 |
| 65 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 66 |
| 67 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 68 |
| 69 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 70 |
| 71 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 72 |
| 73 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 74 |
| 75 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 76 |
| 77 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 78 |
| 79 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 80 |
| 81 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 82 |
| 83 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 84 |
| | | | | 11.8 kVA | | 10.2 kVA | | 10.4 kVA | | | | | |
| | | | | 98.8 A | | 84.7 A | | 86.8 A | | | | | |

**TOTAL CONNECTED LOAD:** 32360 VA

| Load Classification | Connected Load | Demand Factor | Estimated Demand | Panel Totals | |
|---|---|---|---|---|---|
| Power | 12800 VA | 100.00% | 12800 VA | | |
| Receptacle | 19560 VA | 75.56% | 14780 VA | **Total Conn. Load:** | 32360 VA |
| | | | | **Total Est. Demand:** | 27580 VA |
| | | | | **Total Conn.:** | 90 A |
| | | | | **Total Est. Demand:** | 77 A |

# Panel: 3LF2-SEC1

**Location:** J.C. 3-108
**Supply From:**
**Mounting:** Surface
**Enclosure:** 1

**Volts:** 208/120 Wye
**Phases:** 3
**Wires:** 4

**A.I.C. Rating:** 10KA
**Mains Type:** MCB
**Mains Rating:** 150 A
**MCB Rating:** 150 A

**Notes: 150 AMP, 3 POLE CONTACTOR CONTROLLED PANELBOARD. CONTACTOR TO BE CONTROLLED VIA TIMECLOCK. CONTACTOR MAY BE INTEGRAL TO PANELBOARSD OR LOCATED IN A SEPARATE NEMA 1 ENCLOSURE.**

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | RECEPT | 20 A | 1 | 1.08 | 1.08 | | | | | 1 | 20 A | RECEPT | 2 |
| 3 | RECEPT | 20 A | 1 | | | 1.08 | 1.08 | | | 1 | 20 A | RECEPT | 4 |
| 5 | RECEPT | 20 A | 1 | | | | | 1.08 | 1.08 | 1 | 20 A | RECEPT | 6 |
| 7 | RECEPT | 20 A | 1 | 1.08 | 1.08 | | | | | 1 | 20 A | RECEPT | 8 |
| 9 | RECEPT | 20 A | 1 | | | 1.08 | 1.08 | | | 1 | 20 A | RECEPT | 10 |
| 11 | RECEPT | 20 A | 1 | | | | | 1.08 | 1.08 | 1 | 20 A | RECEPT | 12 |
| 13 | RECEPT | 20 A | 1 | 1.08 | 1.08 | | | | | 1 | 20 A | RECEPT | 14 |
| 15 | RECEPT | 20 A | 1 | | | 1.08 | 1.08 | | | 1 | 20 A | RECEPT | 16 |
| 17 | RECEPT | 20 A | 1 | | | | | 1.08 | 1.08 | 1 | 20 A | RECEPT | 18 |
| 19 | RECEPT | 20 A | 1 | 1.08 | 1.08 | | | | | 1 | 20 A | RECEPT | 20 |
| 21 | RECEPT | 20 A | 1 | | | 1.08 | 1.08 | | | 1 | 20 A | RECEPT | 22 |
| 23 | RECEPT | 20 A | 1 | | | | | 1.08 | 1.08 | 1 | 20 A | RECEPT | 24 |
| 25 | RECEPT | 20 A | 1 | 1.08 | 1.08 | | | | | 1 | 20 A | RECEPT | 26 |
| 27 | RECEPT | 20 A | 1 | | | 1.08 | 1.08 | | | 1 | 20 A | RECEPT | 28 |
| 29 | RECEPT | 20 A | 1 | | | | | 1.08 | 1.08 | 1 | 20 A | RECEPT | 30 |
| 31 | RECEPTACLE | 20 A | 1 | 1.08 | 0.90 | | | | | 1 | 20 A | RECEPTACLE | 32 |
| 33 | RECEPTACLE | 20 A | 1 | | | 1.08 | 1.44 | | | 1 | 20 A | RECEPTACLE | 34 |
| 35 | RECEPTACLE | 20 A | 1 | | | | | 0.90 | 1.08 | 1 | 20 A | RECEPTACLE | 36 |
| 37 | POWER | 20 A | 1 | 0.72 | 0.72 | | | | | 1 | 20 A | POWER | 38 |
| 39 | POWER | 20 A | 1 | | | 1.08 | 1.08 | | | 1 | 20 A | RECEPTACLE | 40 |
| 41 | RECEPTACLE | 20 A | 1 | | | | | 1.08 | 1.08 | 1 | 20 A | RECEPTACLE | 42 |

## SECTION 2

| CKT | Circuit Description | Trip | Poles | A | | B | | C | | Poles | Trip | Circuit Description | CKT |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 43 | RECEPTACLE | 20 A | 1 | 0.54 | 1.08 | | | | | 1 | 20 A | RECEPTACLE | 44 |
| 45 | RECEPTACLE | 20 A | 1 | | | 0.54 | 0.54 | | | 1 | 20 A | RECEPTACLE | 46 |
| 47 | POWER | 20 A | 1 | | | | | 0.50 | 0.54 | 1 | 20 A | RECEPTACLE | 48 |
| 49 | POWER | 20 A | 1 | 0.54 | 0.54 | | | | | 1 | 20 A | RECEPTACLE | 50 |
| 51 | POWER | 20 A | 1 | | | 1.44 | 0.00 | | | 1 | 20 A | SPARE | 52 |
| 53 | POWER | 20 A | 1 | | | | | 0.36 | 0.00 | 1 | 20 A | SPARE | 54 |
| 55 | POWER | 20 A | 1 | 0.36 | 0.00 | | | | | 1 | 20 A | SPARE | 56 |
| 57 | AV RACK | 20 A | 1 | | | 0.90 | 0.00 | | | 1 | 20 A | SPARE | 58 |
| 59 | RECEPTACLE | 20 A | 1 | | | | | 0.36 | 0.00 | 1 | 20 A | SPARE | 60 |
| 61 | POWER | 20 A | 1 | 1.08 | 0.00 | | | | | 1 | 20 A | SPARE | 62 |
| 63 | RECEPTACLE | 20 A | 1 | | | 0.36 | 0.00 | | | 1 | 20 A | SPARE | 64 |
| 65 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 66 |
| 67 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 68 |
| 69 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 70 |
| 71 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 72 |
| 73 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 74 |
| 75 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 76 |
| 77 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 78 |
| 79 | SPARE | 20 A | 1 | 0.00 | 0.00 | | | | | 1 | 20 A | SPARE | 80 |
| 81 | SPARE | 20 A | 1 | | | 0.00 | 0.00 | | | 1 | 20 A | SPARE | 82 |
| 83 | SPARE | 20 A | 1 | | | | | 0.00 | 0.00 | 1 | 20 A | SPARE | 84 |
| | | | | 14.9 kVA | | 15.8 kVA | | 15.3 kVA | | | | | |
| | | | | 124.5 A | | 132.5 A | | 128.0 A | | | | | |

**TOTAL CONNECTED LOAD:** 46080 VA

| Load Classification | Connected Load | Demand Factor | Estimated Demand | Panel Totals | |
|---|---|---|---|---|---|
| Power | 4320 VA | 100.00% | 4320 VA | | |
| RECEPT | 32400 VA | 65.43% | 21200 VA | **Total Conn. Load:** | 46080 VA |
| Receptacle | 9360 VA | 100.00% | 9360 VA | **Total Est. Demand:** | 34880 VA |
| | | | | **Total Conn.:** | 128 A |
| | | | | **Total Est. Demand:** | 97 A |

| PANEL KEY | |
|---|---|
| 3LF1 | 3LF3 |
| | 3LF2 |
| | |
| | |

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its clients, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

©2016 AECOM Corporation

Printed on ___% Post-Consumer Recycled Content Paper

Project Management Initials: Designer: Designer Checker: Checker Approved: Approver/ARCH E1 30"x42"
Last Plotted: 5/12/2020 11:07:16 AM
Filename: BM.360.0600/1397-Publix HQ/60601397_Publix HQ_ELECT_R2019.rvt

**Building Inspection Division**
Lakeland
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE OR THE CITY OF LAKELAND LAND DEVELOPMENT CODE
Date: 06/30/20
Permit Number: BLD16-00198

AECOM
BATSON-COOK CONSTRUCTION

**PROJECT**

**PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION**

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

**CLIENT**

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

**CONSULTANT**

**AECOM**

AECOM TECHNICAL SERVICES, INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA26000687

ENGINEERING
CA LIC. NO. 8115

http://www.aecom.com

**REGISTRATION**

HENRYK B. JUSZCZYK LICENSE NO. 58082 STATE OF FLORIDA PROFESSIONAL ENGINEER

HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082 ON THE DATE INDICATED HERE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

Henryk B Juszczyk
Digitally signed by Henryk B Juszczyk
Date: 2020.06.19 16:18:59-04'00'

**ISSUE/REVISION**

| I/R | DATE | DESCRIPTION |
|---|---|---|
| 3 | MAY 01, 2020 | SI-004 |
| 2 | OCT 25,2019 | BUILDING DEPARTMENT COMMENTS |
| 1 | SEP 30, 2019 | 100% CONSTRUCTION DOCUMENTS |
| 0 | AUG 23, 2019 | CONSTRUCTION DOCUMENTS |

**PROJECT NUMBER**

60601397

**SHEET TITLE**

**ELECTRICAL PANEL SCHEDULES**

**SHEET NUMBER**

**E5-1-31**

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.