Building Inspection Division
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE OR THE CITY OF LAKELAND LAND DEVELOPMENT CODE
Date: 06/30/20
Permit Number: BLD16-00198

Panel: 3LG1-SEC1

Location: SUPPLY 3-132
Supply From: T75
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	2
3	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	4
5	MISC	20 A	3	1.08	1.08			1.08	1.08	3	20 A	MISC	6
7						1.08	1.08						8
9								1.08	1.08				10
11	MISC	20 A	3	1.08	1.08			1.08	1.08	3	20 A	MISC	12
13						1.08	1.08						14
15								1.08	1.08				16
17	MISC	20 A	3	1.08	1.08			1.08	1.08	3	20 A	MISC	18
19						1.08	1.08						20
21								1.08	1.08				22
23	MISC	20 A	3	1.08	1.08			1.08	1.08	3	20 A	MISC	24
25						1.08	1.08						26
27								1.08	1.08				28
29	MISC	20 A	3	1.08	1.08			1.08	1.08	3	20 A	MISC	30
31						1.08	1.08						32
33								1.08	1.08				34
35	MISC	20 A	3	1.08	1.08			1.08	1.08	3	20 A	MISC	36
37						1.08	1.08						38
39								1.08	1.08				40
41	SPACE	--	--					0.00	0.00	--	--	SPACE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	MISC	20 A	3	1.08	1.08					3	20 A	MISC	44
45						1.08	1.08						46
47								1.08	1.08				48
49	MISC	20 A	3	1.08	1.08					3	20 A	MISC	50
51						1.08	1.08						52
53								1.08	1.08				54
55	MISC	20 A	3	1.08	1.08					3	20 A	MISC	56
57						1.08	1.08						58
59								1.08	1.08				60
61	MISC	20 A	3	1.08	1.08					3	20 A	MISC	62
63						1.08	1.08						64
65								1.08	1.08				66
67	MISC	20 A	3	1.08	1.08					3	20 A	MISC	68
69						1.08	1.08						70
71								1.08	1.08				72
73	MISC	20 A	3	1.08	1.08					3	20 A	MISC	74
75						1.08	1.08						76
77								1.08	1.08				78
79	MISC	20 A	3	1.08	1.08					3	20 A	MISC	80
81						1.08	1.08						82
83								1.08	1.08				84

SECTION 3

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
85	MISC	20 A	3	1.08	1.08					3	20 A	MISC	86
87						1.08	1.08						88
89								1.08	1.08				90
91	MISC	20 A	3	1.08	1.08					3	20 A	MISC	92
93						1.08	1.08						94
95								1.08	1.08				96
97	MISC	20 A	3	1.08	1.08					3	20 A	MISC	98
99						1.08	1.08						100
101								1.08	1.08				102
103	MISC	20 A	3	1.08	1.08					3	20 A	MISC	104
105						1.08	1.08						106
107								1.08	1.08				108
109	MISC	20 A	3	1.08	1.08					3	20 A	MISC	110
111						1.08	1.08						112
113								1.08	1.08				114
115	MISC	20 A	3	1.08	1.08					3	20 A	MISC	116
117						1.08	1.08						118
119								1.08	1.08				120
121	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	122
123	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	124
125	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	126
				41.0 kVA		41.0 kVA		41.0 kVA					
				342.0 A		342.0 A		342.0 A					

TOTAL CONNECTED LOAD: 123120 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
MISC	123120 VA	100.00%	123120 VA		
				Total Conn. Load:	123120 VA
				Total Est. Demand:	123120 VA
				Total Conn.:	342 A
				Total Est. Demand:	342 A

Panel: 3LG3-SEC1

Location: ELEC 3-137
Supply From: T75
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 225 A
MCB Rating: 225 A

Notes:

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	2
3	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	4
5	RECEPTACLE	20 A	1					0.36	0.36	1	20 A	POWER	6
7	RECEPTACLE	20 A	1	0.54	0.36					1	20 A	IDF ROOM WALL MOUNTED QUAD RECEPTACLE - LIFE SAFETY	8
9	RECEPTACLE	20 A	1			0.72	0.36			1	20 A	IDF ROOM WALL MOUNTED QUAD RECEPTACLE - LIFE SAFETY	10
11	POWER	20 A	1					0.18	0.54	1	20 A	POWER	12
13	POWER	20 A	1	0.18	1.08					1	20 A	RECEPTACLE	14
15	RECEPTACLE	20 A	1			0.36	0.36			1	20 A	RECEPTACLE	16
17	RECEPTACLE	20 A	1					0.36	0.36	1	20 A	RECEPTACLE	18
19	RECEPTACLE	20 A	1	0.18	0.00					1	20 A	SPARE	20
21	RECEPTACLE	20 A	1			0.36	0.36			1	20 A	RECEPTACLE	22
23	RACK RECEPTACLE	30 A	2					0.10	0.10	2	30 A	RACK RECEPTACLE	24
25				0.10	0.10								26
27	RACK RECEPTACLE	30 A	2			0.10	0.36			1	20 A	RECEPTACLE	28
29								0.10	0.18	1	20 A	RECEPTACLE	30
31	IDF ROOM CABLE TRAY MOUNTED QUAD RECEPTACLE - LIFE SAFETY	20 A	1	0.36	0.18					1	20 A	RECEPTACLE	32
33	IDF ROOM CABLE TRAY MOUNTED QUAD RECEPTACLE - LIFE SAFETY	20 A	1			0.36							34
35	POWER	20 A	1					0.50	0.90	1	20 A	RECEPTACLE	36
37	RECEPTACLE	20 A	1	0.36	0.10					2	30 A	RACK RECEPTACLE	38
39	RACK RECEPTACLE	30 A	2			0.10	0.10						40
41								0.10	0.00	1	20 A	SPARE	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	RECEPTACLE	20 A	1	0.72	0.54					1	20 A	RECEPTACLE	44
45	RECEPTACLE	20 A	1			0.54	0.54			1	20 A	RECEPTACLE	46
47	RECEPTACLE	20 A	1					0.90	0.00	1	20 A	SPARE	48
49	RECEPTACLE	20 A	1	0.54	0.00					1	20 A	SPARE	50
51	RECEPTACLE	20 A	1			0.54	0.00			1	20 A	SPARE	52
53	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	54
55	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	56
57	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	58
59	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	60
61	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	62
63	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	64
65	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	66
67	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	68
69	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	70
71	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	72
73	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	74
75	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	76
77	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	78
79	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	80
81	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	82
83	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	84
				5.3 kVA		5.2 kVA		5.0 kVA					
				44.7 A		43.2 A		42.0 A					

TOTAL CONNECTED LOAD: 15540 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Power	1580 VA	100.00%	1580 VA		
Receptacle	13960 VA	85.82%	11980 VA	**Total Conn. Load:**	15540 VA
				Total Est. Demand:	13560 VA
				Total Conn.:	43 A
				Total Est. Demand:	38 A

Panel: 3LG2-SEC1

Location: SUPPLY 3-132
Supply From: T45
Mounting: Surface
Enclosure: 1

Volts: 208/120 Wye
Phases: 3
Wires: 4

A.I.C. Rating: 10KA
Mains Type: MCB
Mains Rating: 150 A
MCB Rating: 150 A

Notes: 150 AMP, 3 POLE CONTACTOR CONTROLLED PANELBOARD. CONTACTOR TO BE CONTROLLED VIA TIMECLOCK. CONTACTOR MAY BE INTEGRAL TO PANELBOARD OR LOCATED IN A SEPARATE NEMA 1 ENCLOSURE.

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
1	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	2
3	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	4
5	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	6
7	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	8
9	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	10
11	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	12
13	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	14
15	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	16
17	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	18
19	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	20
21	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	22
23	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	24
25	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	26
27	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	28
29	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	30
31	RECEPT	20 A	1	1.08	1.08					1	20 A	RECEPT	32
33	RECEPT	20 A	1			1.08	1.08			1	20 A	RECEPT	34
35	RECEPT	20 A	1					1.08	1.26	1	20 A	RECEPTACLE	36
37	RECEPTACLE	20 A	1	0.72	0.36					1	20 A	RECEPTACLE	38
39	RECEPTACLE	20 A	1			0.90	1.08			1	20 A	RECEPT	40
41	RECEPT	20 A	1					1.08	1.08	1	20 A	RECEPT	42

SECTION 2

CKT	Circuit Description	Trip	Poles	A		B		C		Poles	Trip	Circuit Description	CKT
43	RECEPTACLE	20 A	1	1.08	0.90					1	20 A	RECEPTACLE	44
45	RECEPTACLE	20 A	1			0.36	0.54			1	20 A	RECEPTACLE	46
47	RECEPTACLE	20 A	1					0.90	0.00	1	20 A	SPARE	48
49	POWER	20 A	1	0.36	0.00					1	20 A	SPARE	50
51	POWER	20 A	1			0.36	0.00			1	20 A	SPARE	52
53	RECEPTACLE	20 A	1					0.18	0.00	1	20 A	SPARE	54
55	RECEPTACLE	20 A	1	0.18	0.00					1	20 A	SPARE	56
57	RECEPTACLE	20 A	1			0.18	0.00			1	20 A	SPARE	58
59	RECEPTACLE	20 A	1					0.90	0.00	1	20 A	SPARE	60
61	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	62
63	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	64
65	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	66
67	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	68
69	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	70
71	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	72
73	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	74
75	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	76
77	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	78
79	SPARE	20 A	1	0.00	0.00					1	20 A	SPARE	80
81	SPARE	20 A	1			0.00	0.00			1	20 A	SPARE	82
83	SPARE	20 A	1					0.00	0.00	1	20 A	SPARE	84
				16.6 kVA		16.4 kVA		17.3 kVA					
				138.2 A		136.5 A		144.2 A					

TOTAL CONNECTED LOAD: 50220 VA

Load Classification	Connected Load	Demand Factor	Estimated Demand	Panel Totals	
Power	1440 VA	100.00%	1440 VA		
RECEPT	41040 VA	62.18%	25520 VA	**Total Conn. Load:**	50220 VA
Receptacle	7740 VA	100.00%	7740 VA	**Total Est. Demand:**	34700 VA
				Total Conn.:	139 A
				Total Est. Demand:	96 A

PANEL KEY	
3LG1	**3LG3**
	3LG2

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.

AECOM
BATSON-COOK CONSTRUCTION

PROJECT

PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

CLIENT

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

CONSULTANT

AECOM

AECOM TECHNICAL SERVICES, INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA26000687

ENGINEERING
CA LIC. NO. 8115

http://www.aecom.com

REGISTRATION

HENRYK B. JUSZCZYK PROFESSIONAL ENGINEER LICENSE NO. 58082 STATE OF FLORIDA

HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082 ON THE DATE INDICATED HERE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

Henryk B Juszczyk
Digitally signed by Henryk B Juszczyk
Date: 2020.06.19 16:19:21-04'00'

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.

ISSUE/REVISION

I/R	DATE	DESCRIPTION
4	MAY 01, 2020	SI-004
3	NOV 22, 2019	SI-001
2	OCT 25,2019	BUILDING DEPARTMENT COMMENTS
1	SEP 30, 2019	100% CONSTRUCTION DOCUMENTS
0	AUG 23, 2019	CONSTRUCTION DOCUMENTS

PROJECT NUMBER

60601397

SHEET TITLE

ELECTRICAL PANEL SCHEDULES

SHEET NUMBER

E5-1-32

©2016 AECOM Corporation

Project Management Initials: Designer: Designer Checked: Checker Approved: Approver/ARCH E1 30"x42"

Last Plotted: 6/12/2020 11:07:22 AM
Filename: BM 3600\60601397_Publix HQ\60601397_Publix HQ_ELECT_R2019.rvt

Printed on ___% Post-Consumer Recycled Content Paper