Building Inspection Division
Lakeland
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE
Date: 11/15/19
Permit Number: BLD19-06035

MECHANICAL EQUIPMENT ELECTRICAL SCHEDULE

TAG	PANEL-CIRCUIT	VOLTAGE	PHASE	CONDUCTORS	CONDUIT	FUSE	LOAD (Watts)	DISC. SWITCH/POLES/ENCL	LEVEL	COMMENTS
AHU-1-9	1HF2 SEC1-2,4,6	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-8-3	1HF2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-8-2	1HF2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
AHU-1-8	1HF2 SEC1-1,3,5	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-9-2	1HF2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-9-3	1HF2 SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-9-1	1HF2 SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-8-1	1HF2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
AHU-1-10	1HG2 SEC1-1,3,5	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
AHU-1-11	1HG2 SEC1-2,4,6	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
CHWPP-3	MCC2-3	480 V	3	3-10 AWG	3/4"C	40A	20000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
CH-3	MCC2-1	480 V	3	6-250 kcmil	(2) 2 1/2"C	700A	322428 W	MCC2 LOCK-OUT / TAG-OUT	LEVEL 1	
CHWSP-3	MCC2-2	480 V	3	3-6 AWG	3/4"C	70A	20000 W	MCC2 LOCK-OUT / TAG-OUT	LEVEL 1	
CT-3	MCC2-4	480 V	3	3-6 AWG	3/4"C	80A	3492 W	MCC2 LOCK-OUT / TAG-OUT	LEVEL 1	
CWP-3	MCC2-5	480 V	3	3-3 AWG	1 1/4"C	125A	54015 W	MCC2 LOCK-OUT / TAG-OUT	LEVEL 1	
EDH-1-7	1HF2 SEC1-7,9,11	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 1	
EDH-1-8	1HF2 SEC1-8,10,12	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 1	
EDH-1-9	1HG2 SEC1-7,9,11	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 1	
EDH-1-10	1HG2 SEC1-8,10,12	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-10-1	1HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	5000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-10-3	1HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	5000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-10-2	1HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	5000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-11-2	1HG2 SEC1-13,15,17	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
FPU-1-11-1	1HG2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
AHU-2-7	2HF2 SEC1-1,3,5	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
AHU-2-8	2HF2 SEC1-2,4,6	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
AHU-2-9	2HG2 SEC1-1,3,5	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
AHU-2-10	2HG2 SEC1-2,4,6	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
EDH-2-9	2HG2 SEC1-7,9,11	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 2	
EDH-2-10	2HG2 SEC1-8,10,12	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 2	
EDH-2-8	2HF2 SEC1-8,10,12	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 2	
EDH-2-7	2HF2 SEC1-7,9,11	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-7-2	2HF2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-7-3	2HF2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-7-1	2HF2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-8-2	2HF2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-9-2	2HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-9-4	2HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	

MECHANICAL EQUIPMENT ELECTRICAL SCHEDULE

TAG	PANEL-CIRCUIT	VOLTAGE	PHASE	CONDUCTORS	CONDUIT	FUSE	LOAD (Watts)	DISC. SWITCH/POLES/ENCL	LEVEL	COMMENTS
FPU-2-10-1	2HG2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-8-3	2HF2 SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-8-1	2HF2 SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-9-3	2HG2 SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-10-2	2HG2 SEC1-13,15,17	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FPU-2-9-1	2HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	5000 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
AHU-3-7	3HF2-SEC1-1,3,5	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
AHU-3-8	3HF2-SEC1-2,4,6	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
AHU-3-9	3HG2 SEC1-1,3,5	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
AHU-3-10	3HG2 SEC1-2,4,6	480 V	3	3-8 AWG	3/4"C	30A	23185 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
EDH-3-9	3HG2 SEC1-7,9,11	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 3	
EDH-3-10	3HG2 SEC1-8,10,12	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 3	
EDH-3-8	3HF2-SEC1-8,10,12	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 3	
EDH-3-7	3HF2-SEC1-7,9,11	480 V	3	3-4 AWG	1 1/4"C	70A	45000 W	100/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-7-1	3HF2-SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-7-2	3HF2-SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-7-3	3HF2-SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-8-2	3HF2-SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-8-1	3HF2-SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-9-2	3HG2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-9-4	3HG2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-10-1	3HG2 SEC1-14,16,18	480 V	3	3-12 AWG	3/4"C	20A	7500 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-10-2	3HG2 SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-8-3	3HF2-SEC1-14,16,18	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-9-3	3HG2 SEC1-13,15,17	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
FPU-3-9-1	3HG2 SEC1-13,15,17	480 V	3	3-12 AWG	3/4"C	20A	5000 W	60/3/NAME PLATE/NEMA 1	LEVEL 3	
ERV-4	3HF2-SEC1-19,21,23	480 V	3	3-8 AWG	3/4"C	35A	23850 W	60/3/NAME PLATE/NEMA 3R	LEVEL 4	
ERV-5	3HG2 SEC1-19,21,23	480 V	3	3-8 AWG	3/4"C	35A	23850 W	60/3/NAME PLATE/NEMA 3R	LEVEL 4	
EF-1	1HG2 SEC1-19,21,23	480 V	3	3-12 AWG	3/4"C	20A	2830 W	60/3/NAME PLATE/NEMA 1	LEVEL 1	
EWH-1	1HF2 SEC1-19,21,23	480 V	3	3-6 AWG	3/4"C	40A	30000 W	600V, 3 POLE, 40A TOGGLE SWITCH	LEVEL 1	
FCU-1	1HF2 SEC1-20,22,24	480 V	3	3-12 AWG	3/4"C	20A	914 W	30/3/NAME PLATE/NEMA 1	LEVEL 1	
FCU-2	1HG2 SEC1-25,27,29	480 V	3	3-12 AWG	3/4"C	20A	914 W	30/3/NAME PLATE/NEMA 1	LEVEL 1	
FCU-3	2HF2 SEC1-20,22,24	480 V	3	3-12 AWG	3/4"C	20A	914 W	30/3/NAME PLATE/NEMA 1	LEVEL 2	
EWH-2	2HF2 SEC1-21,23,25	480 V	3	3-6 AWG	3/4"C	40A	30000 W	600V, 3 POLE, 40A TOGGLE SWITCH	LEVEL 2	
FCU-3	2HG2 SEC1-19,21,23	480 V	3	3-10 AWG	3/4"C	20A	10000 W	60/3/NAME PLATE/NEMA 1	LEVEL 2	
FCU-5	3HF2-SEC1-20,22, 24	480 V	3	3-12 AWG	3/4"C	20A	914 W	30/3/NAME PLATE/NEMA 1	LEVEL 3	
EWH-3	3HF2-SEC1-25,27, 29	480 V	3	3-6 AWG	3/4"C	40A	30000 W	600V, 3 POLE, 40A TOGGLE SWITCH	LEVEL 3	
FCU-6	3HG2 SEC1-20,22,24	480 V	3	3-12 AWG	3/4"C	20A	914 W	30/3/NAME PLATE/NEMA 1	LEVEL 3	
CHWSP-1		480 V	3	3-6 AWG	3/4"C	70A	20000 W	MCC2 LOCK-OUT / TAG-OUT	LEVEL 1	
CHWSP-4	MCC2-6	480 V	3	3-6 AWG	3/4"C	70A	20000 W	MCC2 LOCK-OUT / TAG-OUT	LEVEL 1	

1

MECHANICAL EQUIPMENT SCHEDULE GENERAL NOTES

1. MECHANICAL EQUIPMENT ELECTRICAL REQUIREMENTS ARE BASED ON DRAWINGS AND OTHER DATA PROVIDED BY THE EQUIPMENT OR SYSTEM VENDOR. AS SUCH, THE ELECTRICAL CONTRACTOR SHALL VERIFY AND ADJUST All ELECTRICAL CONNECTIONS, BRANCH CIRCUIT OVERCURRENT PROTECTION, CONDUCTORS AND RACEWAYS, ETC. - IF OR AS REQUIRED.
2. FURNISH CONDUCTORS AND RACEWAYS FOR SYSTEM DEVICES AND INSTRUMENTATION ACCORDING TO VENDOR'S DRAWINGS. REFER ALSO TO THE MECHANICAL SPECIFICATIONS. FAN MAY ALSO BE INTERLOCKED WITH OTHER MECHANICAL AND/OR ELECTRICAL CONTROLS.
3. VERIFY NAMEPLATE RATINGS, LOCATIONS, AND POINT OF POWER CONNECTIONS PRIOR TO ROUGH-IN.
4. DO NOT LOCATE DISCONNECT SWITCHES OVER UNIT ACCESS PANELS.
6. VERIFY EQUIPMENT NAMEPLATE MAXIMUM OVERCURRENT PROTECTION RATING AND SELECT FUSE SIZES PER MANUFACTURER'S SPECIFICATIONS.
7. FAN POWERED UNITS (FPU) ARE CONNECTED ON SAM CIRCUIT IN MOST CASES. THE CONDUIT AND WIRE SIZES INDICATED IN SCHEDULE ARE FOR THE LOAD SIDE OF DISCONNECTS TO EQUIPMENT. LINE SIDE CONDUIT AND WIRE FROM PANELBOARD TO DISCONNECT SHALL BE 1" CONDUIT WITH (3) 6 AWG & (1) 10 AWG EQUIPMENT GROUND.

AECOM
BATSON-COOK CONSTRUCTION

PROJECT

PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

CLIENT

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

CONSULTANT

AECOM

AECOM TECHNICAL SERVICES, INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA26000687

ENGINEERING
CA LIC. NO. 8115

http://www.aecom.com

REGISTRATION

HENRYK B. JUSZCZYK LICENSE NO. 58082 STATE OF FLORIDA PROFESSIONAL ENGINEER

HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY HENRYK B. JUSZCZYK, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 58082 ON THE DATE INDICATED HERE. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

Henryk B Juszczyk
2019.09.30
18:15:14 -04'00'

ISSUE/REVISION

I/R	DATE	DESCRIPTION
1	SEP 30, 2019	100% CONSTRUCTION DOCUMENTS
0	AUG 23, 2019	CONSTRUCTION DOCUMENTS

PROJECT NUMBER

60601397

SHEET TITLE

MECHANICAL EQUIPMENT SCHEDULE

SHEET NUMBER

E5-3-01

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.

Printed on ___% Post-Consumer Recycled Content Paper
©2016 AECOM Corporation