Building Inspection Division
Lakeland
THESE PLANS HAVE BEEN REVIEWED FOR COMPLIANCE WITH THE CURRENT EDITION OF THE FLORIDA BUILDING CODE OR THE CITY OF LAKELAND LAND DEVELOPMENT CODE
Date: 06/30/20
Permit Number: BLD16-00198

VARIABLE AIR VOLUME UNI...

Mark	INLET SIZE	AIRFLOWS MAX CFM	AIRFLOWS MIN CFM
VAV 1-8-1	10	750	210
VAV 1-8-2	8	625	125
VAV 1-8-3	4	200	45
VAV 1-8-4	6	600	65
VAV 1-8-5	4	375	45
VAV 1-8-6	4	375	45
VAV 1-8-7	4	90	45
VAV 1-8-8	4	270	45
VAV 1-8-9	4	180	45
VAV 1-8-10	4	270	45
VAV 1-8-11	4	375	45
VAV 1-8-12	8	750	125
VAV 1-8-13	4	115	45
VAV 1-8-14	4	145	45
VAV 1-8-15	4	115	45
VAV 1-8-16	4	145	45
VAV 1-8-17	6	500	65
VAV 1-8-18	4	115	45
VAV 1-8-19	4	50	45
VAV 1-8-20	4	120	45
VAV 1-8-21	4	300	45
VAV 1-8-22	4	265	45
VAV 1-9-1	4	340	45
VAV 1-9-2	4	80	45
VAV 1-9-3	4	220	45
VAV 1-9-4	4	150	45
VAV 1-9-5	4	215	45
VAV 1-9-6	4	215	45
VAV 1-9-7	4	225	45
VAV 1-9-8	4	150	45
VAV 1-9-9	4	150	45
VAV 1-9-10	4	120	45
VAV 1-9-11	4	260	45
VAV 1-9-12	4	120	45
VAV 1-9-13	4	50	45
VAV 1-9-14	4	120	45
VAV 1-9-15	4	120	45
VAV 1-9-16	4	50	45
VAV 1-9-17	4	120	45
VAV 1-9-18	8	840	125
VAV 1-9-19	8	840	125
VAV 1-9-20	8	840	125
VAV 1-9-21	6	420	65
VAV 1-9-22	4	50	45
VAV 1-9-22A	6	420	65
VAV 1-9-23	4	50	45
VAV 1-9-24	4	50	45
VAV 1-9-25	4	120	45
VAV 1-9-26	6	420	65
VAV 1-9-27	4	120	45
VAV 1-9-27A	6	420	65
VAV 1-9-28	4	55	45
VAV 1-9-29	4	120	45
VAV 1-9-30	8	840	125
VAV 1-9-31	4	120	45
VAV 1-9-31A	6	420	65
VAV 1-9-32	4	55	45
VAV 1-9-33	4	120	45
VAV 1-10-1	6	495	65
VAV 1-10-2	6	495	65
VAV 1-10-3	8	990	125
VAV 1-10-4	4	120	45
VAV 1-10-5	4	120	45
VAV 1-10-6	4	120	45
VAV 1-10-7	4	200	45
VAV 1-10-8	8	990	125
VAV 1-10-9	4	120	45
VAV 1-10-9A	6	495	65
VAV 1-10-10	4	55	45
VAV 1-10-11	4	55	45
VAV 1-10-12	4	55	45
VAV 1-10-13	4	290	45
VAV 1-10-14	4	290	45
VAV 1-10-15	4	260	45
VAV 1-10-16	4	80	45
VAV 1-10-17	4	55	45
VAV 1-10-18	4	120	45
VAV 1-10-19	4	120	45
VAV 1-10-20	4	120	45
VAV 1-10-21	8	990	125
VAV 1-10-22	4	200	45
VAV 1-10-23	6	495	65
VAV 1-10-24	8	990	125
VAV 1-11-1	8	900	125
VAV 1-11-2	4	120	45
VAV 1-11-2A	6	495	65
VAV 1-11-3	4	55	45
VAV 1-11-4	4	120	45
VAV 1-11-6	4	100	45
VAV 1-11-7	4	120	45
VAV 1-11-8	4	120	45
VAV 1-11-9	4	160	45
VAV 1-11-10	8	900	125
VAV 1-11-11	4	120	45
VAV 1-11-12	4	55	45
VAV 1-11-13	4	120	45
VAV 1-11-14	8	900	125
VAV 1-11-15	8	565	125
VAV 1-11-16	8	600	125
VAV 1-11-17	10	1645	210
VAV 1-11-18	10	1190	210
VAV 1-11-19	4	350	45
VAV 2-7-1	8	840	125
VAV 2-7-2	4	120	45
VAV 2-7-2A	4	120	45
VAV 2-7-3	4	55	45
VAV 2-7-3A	4	120	45
VAV 2-7-4	4	120	45

NOTES:
1. EACH VAV SHALL BE CONTROLLED BY A WIRED THERMOSTAT OR TEMPERATURE SENSOR. TEMPERATURE SENSORS WIRE MUST BE INSTALLED WITH ENOUGH SLACK TO ACCOMODATE RELOCATING MOVABLE WALLS.

VARIABLE AIR VOLUME UNI...

Mark	INLET SIZE	AIRFLOWS MAX CFM	AIRFLOWS MIN CFM
VAV 2-7-4A	4	120	45
VAV 2-7-5	6	420	65
VAV 2-7-6	8	560	125
VAV 2-7-7	6	420	65
VAV 2-7-8	6	420	65
VAV 2-7-9	6	420	65
VAV 2-7-10	4	200	45
VAV 2-7-11	4	105	45
VAV 2-7-12	4	300	45
VAV 2-7-13	4	130	45
VAV 2-7-14	4	270	45
VAV 2-7-15	6	420	65
VAV 2-7-16	10	840	210
VAV 2-7-17	4	120	45
VAV 2-7-18	4	120	45
VAV 2-7-19	4	145	45
VAV 2-7-20	4	145	45
VAV 2-7-21	4	310	45
VAV 2-7-22	8	560	125
VAV 2-7-23	4	120	45
VAV 2-7-24	4	55	45
VAV 2-7-25	4	120	45
VAV 2-7-26	4	275	45
VAV 2-8-1	4	330	45
VAV 2-8-2	4	80	45
VAV 2-8-3	4	220	45
VAV 2-8-4	4	140	45
VAV 2-8-5	4	145	45
VAV 2-8-6	4	220	45
VAV 2-8-7	4	225	45
VAV 2-8-8	4	150	45
VAV 2-8-9	4	150	45
VAV 2-8-10	4	120	45
VAV 2-8-11	4	200	45
VAV 2-8-11A	6	465	65
VAV 2-8-12	4	120	45
VAV 2-8-13	4	50	45
VAV 2-8-14	4	120	45
VAV 2-8-15	4	120	45
VAV 2-8-15A	6	465	65
VAV 2-8-16	4	50	45
VAV 2-8-17	4	120	45
VAV 2-8-18	8	930	125
VAV 2-8-19	8	930	125
VAV 2-8-20	8	930	125
VAV 2-8-21	6	465	65
VAV 2-8-22	4	50	45
VAV 2-8-22A	6	465	65
VAV 2-8-23	4	50	45
VAV 2-8-24	4	50	45
VAV 2-8-25	4	120	45
VAV 2-8-26	6	465	65
VAV 2-8-27	4	120	45
VAV 2-8-28	4	55	45
VAV 2-8-29	4	120	45
VAV 2-8-30	6	465	65
VAV 2-8-31	4	120	45
VAV 2-8-32	4	50	45
VAV 2-8-33	4	50	45
VAV 2-8-34	4	120	45
VAV 2-9-1	6	460	65
VAV 2-9-2	6	460	65
VAV 2-9-3	6	460	65
VAV 2-9-4	8	920	125
VAV 2-9-5	4	120	45
VAV 2-9-5A	6	460	65
VAV 2-9-6	4	120	45
VAV 2-9-7	4	120	45
VAV 2-9-8	4	200	45
VAV 2-9-9	8	920	125
VAV 2-9-10	4	120	45
VAV 2-9-10A	6	460	65
VAV 2-9-11	4	55	45
VAV 2-9-12	4	55	45
VAV 2-9-13	4	55	45
VAV 2-9-14	4	280	45
VAV 2-9-15	4	280	45
VAV 2-9-16	4	260	45
VAV 2-9-17	4	80	45
VAV 2-9-18	4	120	45
VAV 2-9-18A	6	405	65
VAV 2-9-19	4	55	45
VAV 2-9-20	4	120	45
VAV 2-9-21	8	920	125
VAV 2-9-22	4	200	45
VAV 2-9-23	6	460	65
VAV 2-9-24	8	920	125
VAV 2-10-1	8	810	125
VAV 2-10-3	4	100	45
VAV 2-10-4	4	120	45
VAV 2-10-5	4	120	45
VAV 2-10-6	8	810	125
VAV 2-10-7	4	375	45
VAV 2-10-8	4	160	45
VAV 2-10-9	6	405	65
VAV 2-10-10	4	120	45
VAV 2-10-11	4	55	45
VAV 2-10-12	4	120	45
VAV 2-10-13	6	405	65
VAV 2-10-14	8	565	125
VAV 2-10-15	4	120	45
VAV 2-10-16	4	55	45
VAV 2-10-17	4	120	45

VARIABLE AIR VOLUME UNI...

Mark	INLET SIZE	AIRFLOWS MAX CFM	AIRFLOWS MIN CFM
VAV 2-10-18	6	405	65
VAV 2-10-19	8	620	125
VAV 2-10-20	4	360	45
VAV 2-10-21	8	620	125
VAV 3-7-1	8	900	125
VAV 3-7-2	4	125	45
VAV 3-7-3	4	55	45
VAV 3-7-4	4	125	45
VAV 3-7-5	6	450	65
VAV 3-7-6	8	600	125
VAV 3-7-7	6	450	65
VAV 3-7-8	6	450	65
VAV 3-7-9	6	450	65
VAV 3-7-9A	4	50	45
VAV 3-7-9B	4	50	45
VAV 3-7-9C	4	50	45
VAV 3-7-10	4	200	45
VAV 3-7-11	4	105	45
VAV 3-7-12	4	310	45
VAV 3-7-13	4	130	45
VAV 3-7-14	4	290	45
VAV 3-7-15	6	450	65
VAV 3-7-16	6	450	65
VAV 3-7-17	6	450	65
VAV 3-7-18	4	125	45
VAV 3-7-19	4	140	45
VAV 3-7-20	4	125	45
VAV 3-7-21	4	140	45
VAV 3-7-22	4	300	45
VAV 3-7-23	6	450	65
VAV 3-7-24	4	125	45
VAV 3-7-24A	6	450	65
VAV 3-7-25	4	50	45
VAV 3-7-26	4	125	45
VAV 3-7-27	4	265	45
VAV 3-8-1	4	350	45
VAV 3-8-2	4	85	45
VAV 3-8-3	4	230	45
VAV 3-8-4	4	155	45
VAV 3-8-5	4	160	45
VAV 3-8-6	4	230	45
VAV 3-8-7	4	230	45
VAV 3-8-8	4	90	45
VAV 3-8-9	4	155	45
VAV 3-8-10	4	200	45
VAV 3-8-11	4	150	45
VAV 3-8-12	4	125	45
VAV 3-8-13	4	50	45
VAV 3-8-14	4	125	45
VAV 3-8-15	4	125	45
VAV 3-8-15A	6	495	65
VAV 3-8-16	4	50	45
VAV 3-8-17	4	125	45
VAV 3-8-18	8	990	125
VAV 3-8-19	8	990	125
VAV 3-8-20	8	990	125
VAV 3-8-21	6	495	65
VAV 3-8-22	4	125	45
VAV 3-8-23	4	125	45
VAV 3-8-24	4	50	45
VAV 3-8-25	4	125	45
VAV 3-8-26	6	495	65
VAV 3-8-27	4	125	45
VAV 3-8-27A	6	495	65
VAV 3-8-28	4	55	45
VAV 3-8-29	4	125	45
VAV 3-8-30	6	495	65
VAV 3-8-31	4	50	45
VAV 3-8-31A	6	495	65
VAV 3-8-32	4	50	45
VAV 3-8-33	4	50	45
VAV 3-8-34	4	125	45
VAV 3-9-1	6	495	65
VAV 3-9-2	6	495	65
VAV 3-9-3	6	495	65
VAV 3-9-4	8	990	125
VAV 3-9-5	4	125	45
VAV 3-9-6	4	125	45
VAV 3-9-7	4	125	45
VAV 3-9-8	4	200	45
VAV 3-9-9	8	990	45
VAV 3-9-10	4	125	45
VAV 3-9-10A	6	495	65
VAV 3-9-11	4	55	45
VAV 3-9-12	4	125	45
VAV 3-9-13	4	290	45
VAV 3-9-14	4	290	45
VAV 3-9-15	4	290	45
VAV 3-9-16	4	120	45
VAV 3-9-17	4	125	45
VAV 3-9-18	4	55	45
VAV 3-9-19	4	125	45
VAV 3-9-20	8	990	125
VAV 3-9-21	4	200	45
VAV 3-9-22	6	495	65
VAV 3-9-23	8	990	125
VAV 3-10-1	8	870	125
VAV 3-10-3	4	110	45
VAV 3-10-4	4	125	45
VAV 3-10-5	4	125	45
VAV 3-10-6	8	870	125
VAV 3-10-7	6	435	65
VAV 3-10-8	4	165	45
VAV 3-10-9	6	435	65
VAV 3-10-10	4	125	45
VAV 3-10-11	4	55	45
VAV 3-10-12	4	125	45
VAV 3-10-13	6	435	65
VAV 3-10-14	8	565	125
VAV 3-10-15	4	125	45
VAV 3-10-15A	6	435	65
VAV 3-10-16	4	55	45
VAV 3-10-17	4	125	45
VAV 3-10-18	6	435	65
VAV 3-10-19	8	580	125
VAV 3-10-20A	6	480	65
VAV 3-10-21	8	580	125

FAN POWERED UNIT SCHEDULE

Mark	INLET SIZE	COOLING AIRFLOWS MAX CFM	COOLING AIRFLOWS MIN CFM	FAN CFM	HEATING HEATING CAPACITY (KW)	HEATING FAN POWER (HP)	HEATING ELECTRICAL CHARACTERISTICS (V/PH/HZ)
FPU 1-8-1	14	3375	430	430	7.5	1/2	480/3/60
FPU 1-8-2	14	3355	430	430	7.5	1/2	480/3/60
FPU 1-8-3	14	2920	430	430	7.5	1/2	480/3/60
FPU 1-9-1	16	3760	575	575	10	3/4	480/3/60
FPU 1-9-2	14	3450	430	430	7.5	1/2	480/3/60
FPU 1-9-3	16	3985	575	575	10	3/4	480/3/60
FPU 1-10-1	14	3345	430	430	7.5	1/2	480/3/60
FPU 1-10-2	14	2950	430	430	7.5	1/2	480/3/60
FPU 1-10-3	12	2360	300	300	5	1/2	480/3/60
FPU 1-11-1	12	2065	300	300	5	1/2	480/3/60
FPU 1-11-2	12	2235	300	300	5	1/2	480/3/60
FPU 1-11-3	12	2420	300	300	5	1/2	480/3/60
FPU 2-7-1	14	3635	430	430	7.5	1/2	480/3/60
FPU 2-7-2	14	3675	430	430	7.5	1/2	480/3/60
FPU 2-7-3	14	3000	430	430	7.5	1/2	480/3/60
FPU 2-8-1	16	3845	575	575	10	3/4	480/3/60
FPU 2-8-2	14	3400	430	430	7.5	1/2	480/3/60
FPU 2-8-3	16	4000	575	575	10	3/4	480/3/60
FPU 2-9-1	14	3440	430	430	7.5	1/2	480/3/60
FPU 2-9-2	14	2950	430	430	7.5	1/2	480/3/60
FPU 2-9-3	12	2360	300	300	5	1/2	480/3/60
FPU 2-10-1	12	2065	300	300	5	1/2	480/3/60
FPU 2-10-2	14	2910	430	430	7.5	1/2	480/3/60
FPU 2-10-3	16	4410	575	575	10	3/4	480/3/60
FPU 2-10-4	14	3145	430	430	7.5	1/2	480/3/60
FPU 3-7-1	14	3425	430	430	7.5	1/2	480/3/60
FPU 3-7-2	14	3600	430	430	7.5	1/2	480/3/60
FPU 3-7-3	14	2930	430	430	7.5	1/2	480/3/60
FPU 3-8-1	14	3615	430	430	7.5	1/2	480/3/60
FPU 3-8-2	14	3330	430	430	7.5	1/2	480/3/60
FPU 3-8-3	16	3915	575	575	10	3/4	480/3/60
FPU 3-9-1	14	3240	430	430	7.5	1/2	480/3/60
FPU 3-9-2	14	2775	430	430	7.5	1/2	480/3/60
FPU 3-9-3	12	2220	300	300	5	1/2	480/3/60
FPU 3-10-1	12	1940	300	300	5	1/2	480/3/60
FPU 3-10-2	14	2880	430	430	7.5	1/2	480/3/60
FPU 3-10-3	16	4315	575	575	10	3/4	480/3/60
FPU 3-10-4	14	3065	430	430	7.5	1/2	480/3/60

NOTES:
1. EACH VAV SHALL BE CONTROLLED BY A WIRED THERMOSTAT.

ELECTRIC DUCT HEATER SCHEDULE

MARK	LOCATION	AHU/FAN NO.	AIRFLOW MIN. CFM	HEATING CAP KW	VOLT./PH.
EDH-1-7	MECH RM 1-134	AHU 1-8	1845	20	480/3/60
EDH-1-8	MECH RM 1-134	AHU 1-9	2025	20	480/3/60
EDH-1-9	MECH RM 1-165	AHU 1-10	1470	20	480/3/60
EDH-1-10	MECH RM 1-165	AHU 1-11	1685	20	480/3/60
EDH-2-7	MECH RM 2-134	AHU 2-7	1790	20	480/3/60
EDH-2-8	MECH RM 2-134	AHU 2-8	1985	20	480/3/60
EDH-2-9	MECH RM 2-165	AHU 2-9	1585	20	480/3/60
EDH-2-10	MECH RM 2-165	AHU 2-10	1760	20	480/3/60
EDH-3-7	MECH RM 3-134	AHU 3-7	1820	20	480/3/60
EDH-3-8	MECH RM 3-134	AHU 3-8	1985	20	480/3/60
EDH-3-9	MECH RM 3-165	AHU 3-9	1585	20	480/3/60
EDH-3-10	MECH RM 3-165	AHU 3-10	1735	20	480/3/60

NOTES:
1. PROVIDE SILICON CONTROLLED RECTIFIER (SCR) CONTROLLER.
2. PROVIDE DISCONNECT SWITCH.

AIR DEVICE SCHEDULE

TAG	FUNCTION	BASIS OF DESIGN MANUFACTURER	BASIS OF DESIGN MODEL	TYPE	FACE SIZE	GENERAL DATA MATERIAL	GENERAL DATA INTEGRAL VOLUME DAMPER	GENERAL DATA MAX NC	SCHEDULE NOTES
S-1	SUPPLY	PRICE	ASPD	SQUARE PLAQUE DIFFUSER	24" X 24"	ALUMINUM	Yes	25	
S-2	SUPPLY	PRICE	620DALS	SIDEWALL LOUVERED GRILLE	N/A	ALUMINUM	Yes	25	ALL 20" X 8" NECK SIZE
R-1	RETURN	PRICE	APDDR	SQUARE PERFORATED PLENUM RETURN	24" X 24"	ALUMINUM	No	25	ALL 22" X 22" NECK SIZE
R-2	RETURN	PRICE	620DALS	SIDEWALL LOUVERED GRILLE	N/A	ALUMINUM	No	25	ALL 20" X 8" NECK SIZE
E-1	EXHAUST	PRICE	80	EGGCRATE GRILLE	N/A	ALUMINUM	Yes	25	
T-1	TRANSFER	PRICE	80	EGGCRATE GRILLE	24" X 24"	ALUMINUM	No	25	ALL 22" X 22" NECK SIZE

VARIABLE AIR VOLUME UNIT SCHEDULE UPDATED

MARK	INLET SIZE	AIRFLOWS MAX CFM	AIRFLOWS MIN CFM
VAV 1-9-22A	6	420	65
VAV 1-9-27A	6	420	65
VAV 1-9-31A	6	420	65
VAV 1-10-9A	6	495	65
VAV 1-11-2A	6	495	65
VAV 2-7-2A	4	120	45
VAV 2-7-3A	4	120	45
VAV 2-7-4A	4	120	45
VAV 2-8-11A	6	465	65
VAV 2-8-15A	6	465	65
VAV 2-8-22A	6	465	65
VAV 2-9-5A	6	460	65
VAV 2-9-18A	6	405	65
VAV 2-9-10A	6	460	65
VAV 3-7-9A	4	125	45
VAV 3-7-9B	4	125	45
VAV 3-7-9C	4	125	45
VAV 3-7-24A	6	450	65
VAV 3-8-15A	6	495	65
VAV 3-8-27A	6	495	65
VAV 3-8-31A	6	495	65
VAV 3-9-10A	6	495	65
VAV 3-10-15A	6	435	65
VAV 3-10-20A	6	480	65

AECOM
BATSON-COOK CONSTRUCTION

PROJECT

PUBLIX HEADQUARTERS BUILDING ADDITION AND PARKING LOT EXPANSION

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

CLIENT

Publix

3300 PUBLIX CORPORATE PARKWAY
LAKELAND, FL 33811

www.publix.com

CONSULTANT

AECOM

AECOM TECHNICAL SERVICES INC.
800 Douglas Entrance
North Tower, 2nd Floor
Coral Gables, FL 33134
305.444.4691 tel 305.447.3580 fax
www.aecom.com

ARCHITECTURE
LICENSE NO. AA260000687

ENGINEERING
CA LIC. NO. 8115

www.aecom.com

REGISTRATION

JOHN TYE RECTOR
LICENSE
No. 53292
STATE OF FLORIDA
PROFESSIONAL ENGINEER

JOHN T. RECTOR, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 53292
06/19/20

John T Rector 2020.06.19 12:40:39 -04'00'

THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY JOHN T. RECTOR, PROFESSIONAL ENGINEER, STATE OF FLORIDA, LICENSE NO. 53292 ON THE DATE ADJACENT TO THE SEAL. PRINTED COPIES OF THIS DOCUMENT MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

NOTICE: THE OFFICIAL RECORD OF THIS SHEET IS THE ELECTRONIC FILE SIGNED AND SEALED UNDER RULE 61G15-23.004, F.A.C.

ISSUE/REVISION

I/R	DATE	DESCRIPTION
2	MAY 01, 2020	SI-004
1	NOV. 22, 2019	SI-001
	SEP 30, 2019	100% CONSTRUCTION DOCUMENTS
	AUG 23, 2019	CONSTRUCTION DOCUMENTS
	MAY 31, 2019	35% DESIGN COMPLETION

PROJECT NUMBER

60601397

SHEET TITLE

HVAC SCHEDULES

SHEET NUMBER

M0-0-20

Printed on ___% Post-Consumer Recycled Content Paper
©2016 AECOM Corporation