

GIVEN:

Number of Floors: 2

Reference: Excel
Section *Eq/Fig/Table/Notes*
Information

1. MEMBERS FOR ANALYSIS:

Member Ref.	Frame	Floor	Member	Section	Length	No translation			Lateral Translation			Lateral Deflection
						Axial Load	Mom. (x)	Mom.(y)	Axial Load	Mom. (x)	Mom.(y)	
(#)	(type)	Units		(Shape)	(ft)	$P_{nt} \text{ (kip)}$	$M_{ntx} \text{ (kip.ft)}$	$M_{nty} \text{ (kip.ft)}$	$P_{lt} \text{ (kip)}$	$M_{ltx} \text{ (kip.ft)}$	$M_{lty} \text{ (kip.ft)}$	$\Delta H \text{ (in)}$
1	Braced	First	Column	W8X40	15	296	14	0	0	0	0	0
2	Braced	Roof	Column	W8X40	15							
3	Braced	First	Column	W8X40	15	296	14	0	0	0	0	0
4	Braced	Roof	Column	W8X40	15							
5	Braced	First	Column	W8X40	15							
6	Braced	Roof	Column	W8X40	15							
9	Braced	First	Beam	W21X55	36							
10	Braced	First	Interior Beam	W21X55	36							
11	Braced	First	Beam	W21X55	36							
12	Braced	Roof	Beam	W14X34	36							
13	Braced	Roof	Interior Beam	W14X34	36							
14	Braced	Roof	Beam	W14X34	36							
15	Braced	Roof	Braces	WT9X48.5	39							
16	Braced	Roof	Braces	WT9X48.5	39							
17	Braced	First	Braces	WT9X48.5	39							
18	Braced	First	Braces	WT9X48.5	39							
1	Moment	First	Column	W8X40	15							
2	Moment	Roof	Column	W8X40	15							
7	Moment	First	Column	W8X40	15							
8	Moment	Roof	Column	W8X40	15							

21	Moment	First	Column	W8X40	15							
22	Moment	Roof	Column	W8X40	15							
23	Moment	First	Column	W8X40	15	57.2	32	0	29.4	159	0	0.003
24	Moment	Roof	Column	W8X40	15							
25	Moment	Roof	Beam	W12X16	24							
26	Moment	Roof	Interior Beam	W18X35	24	7.3	14.5	0	2.35	43.1	0	0.003
27	Moment	Roof	Beam	W12X16	24							
28	Moment	First	Beam	W14X22	24							
29	Moment	First	Interior Beam	W21X44	24	11.6	74.3	0	6	113	0	0.003
30	Moment	First	Beam	W14X22	24							

Reference:
Section

AISC 14th
Eq/Fig/Table/Notes

2. LOADS

Member Ref.	Frame	Floor	P_{story}	P_{mf}	Lateral Shear	α	Gravity Load	Notional Load
(#)	(type)	Units	(kip)	(kip)	(kip)	(LRFD)	(kip)	(kip)
1-B	Braced	First	3643.2	607.6	31	1	214	0.43
1-M	Moment	First	3643.2	607.6	31	1	214	0.43
2-B	Braced	Roof	622.1	607.6	31	1	470	0.94
2-M	Moment	Roof	622.1	607.6	31	1	470	0.94

3. DETERMINATION OF LATERAL-TORSIONAL BUCKLING FACTOR C_b

F

Eq.

F1-1

Member Ref.	Frame	Floor	Member	Section	Length	M_{max}	$M_{.25}$	$M_{.5}$	$M_{.75}$	C_b	K
(#)	(type)	Units		(Shape)	(ft)	(kip.ft)	(kip.ft)	(kip.ft)	(kip.ft)		
1	Braced	First	Column	W8X40	15	500.00	270.13	440.24	285.65	1.34	
3	Braced	First	Column	W8X40	15	500.00	270.13	440.24	285.65	1.34	
9	Braced	First	Beam	W21X55	36	500.00	270.13	440.24	285.65	1.34	
7	Moment	First	Column	W8X40	15	500.00	270.13	440.24	285.65	1.34	
8	Moment	Roof	Column	W8X40	15	500.00	270.13	440.24	285.65	1.34	
23	Moment	First	Column	W8X40	15	500.00	270.13	440.24	285.65	1.34	
24	Moment	Roof	Column	W8X40	15	500.00	270.13	440.24	285.65	1.34	
26	Moment	Roof	Interior Beam	W18X35	24	500.00	270.13	440.24	285.65	1.34	
27	Moment	Roof	Beam	W12X16	24	500.00	270.13	440.24	285.65	1.34	
29	Moment	First	Interior Beam	W21X44	24	500.00	270.13	440.24	285.65	1.34	
30	Moment	First	Beam	W14X22	24	500.00	270.13	440.24	285.65	1.34	

4. PRE-DETERMINATION OF EFFECTIVE LENGTH FACTOR K

Appendix 7

Eq.

C-A-7-1

Member Ref.	Frame	Floor	Member	Section	Length	Moment of Inertia	Modulus of Elasticity	Support end A	Support end B	Stiffness	Factor K
(#)	(type)	Units		(Shape)	(ft)	(in ⁴)	(ksi)	(type)	(type)	(kip.ft)	
1	Braced	First	Column	W8X40	15	146	29000	Pin	2/9	1960.2	0.8
2	Braced	Roof	Column	W8X40	15	146	29000	1*9	12	1960.2	
3	Braced	First	Column	W8X40	15	146	29000	Pin	4/9-10	1960.2	0.745
4	Braced	Roof	Column	W8X40	15	146	29000	3/9-10	12/13	1960.2	
9	Braced	First	Beam	W21X55	36	1140	29000	1*2/9	3-4*9-10	9566.0	0.66
10	Braced	First	Interior Beam	W21X55	36	1140	29000	Pin	Pin	9566.0	
12	Braced	Roof	Beam	W14X34	36	340	29000	Pin	Pin	2853.0	
13	Braced	Roof	Interior Beam	W14X34	36	340	29000	Pin	Pin	2853.0	
7	Moment	First	Column	W8X40	15	146	29000	Pin	8/30	1960.2	2.5
8	Moment	Roof	Column	W8X40	15	146	29000	7/30	27	1960.2	2.18
21	Moment	First	Column	W8X40	15	146	29000	Pin	21-22/28-29	1960.2	
22	Moment	Roof	Column	W8X40	15	146	29000	22-21/28-29	Pin	1960.2	
23	Moment	First	Column	W8X40	15	146	29000	Pin	24/29-30	1960.2	1.88
24	Moment	Roof	Column	W8X40	15	146	29000	23/29-30	26-27	1960.2	1.2
25	Moment	Roof	Beam	W12X16	24	103	29001	23/29-31	26-28	432.2	
26	Moment	Roof	Interior Beam	W18X35	24	510	29000	2*25	22/25-26	2139.8	1.25
27	Moment	Roof	Beam	W12X16	24	103	29000	24*26-27	8*27	432.1	1.6
28	Moment	First	Beam	W14X22	24	199	29001	1-2*28	21-22/28-29	835.0	
29	Moment	First	Interior Beam	W21X44	24	843	29000	Moment	Moment	3536.9	1.28
30	Moment	First	Beam	W14X22	24	199	29000	23-24/29-30	7*8/30	834.9	1.65

5. DETERMINATION OF EFFECTIVE LENGTH FACTOR K

Appendix 7

Eq.

C-A-7-2

Member Ref.	End	Support	Column 1	Column 2	Beam 1	Beam 2	Beam 3	Beam 4	Rotational Stiffness (G)	K
(#)	(type)	Units	(Shape)	(ft)	(in ⁴)	(ksi)	(kip.ft)	(kip.ft)	(kip.ft)	

1	A	Pin					10.00	0.80
	B	2/9	2	1	9		0.41	
3		Pin					10.00	0.745
		4/9-10	4	3	9	10	0.20	
9		1*2/9	1	2	9		0.41	0.66
		3-4*9-10	3	4	9		0.41	
7		Pin					10.00	2.5
		8/30	8	7	30		4.70	
8		7/30	7	8	30		4.70	2.18
		27	8		27		4.54	
23		Pin					10.00	1.88
		24/29-30	23	24	29	30	0.90	
24		23/29-30	23	24	29	30	0.90	1.2
		26-27	24		26	27	0.76	
26		2*25	24		26	27	0.45	1.25
		22/25-26	22		25	26	0.76	
27		24*26-27	24		26	27	0.76	1.6
		8*27	8		27		4.54	
29		Moment	22	21	28	29	0.90	1.28
		Moment	23	24	29	30	0.90	
30		23-24/29-30	24	23	30	29	0.90	1.65
		7*8/30	7	8	30		4.70	

6. RESULTS

F

Member Ref.	Frame	Floor	Member	Pre-Section	Length	New-Section	Unit Weight	Spacing or a	Beams/Bay	Qty of Members	Amount of Steel
(#)	(type)	Units		(Shape)	(ft)	(Shape)	(plf)	(ft)	(Units)	(Units)	(kips)
1	Braced	First	Column	W8X40	15	W12X50	50	12.0	0.0	1.20	1.50
2	Braced	Roof	Column	W8X40	15	W12X50	50	1.7	0.0	1.20	1.50
3	Braced	First	Column	W8X40	15	W12X50	50	5.0	0.0	1.20	1.50
4	Braced	Roof	Column	W8X40	15	W12X40	40	0.0	0.0	1.20	1.20
5	Braced	First	Column	W8X40	15	W12X50	50	0.0	0.0	1.20	1.50
6	Braced	Roof	Column	W8X40	15	W12X50	50	0.0	0.0	1.20	1.50
9	Braced	First	Beam	W21X55	36	W10X68	68	0.0	0.0	2.16	2.16
10	Braced	First	Interior Beam	W21X55	36	W14X30	30	0.0	0.0	2.16	2.16
11	Braced	First	Beam	W21X55	36	W14X30	30	0.0	0.0	2.16	2.16
12	Braced	Roof	Beam	W14X34	36	W10X19	19	0.0	0.0	1.37	1.37
13	Braced	Roof	Interior Beam	W14X34	36	W10X19	19	0.0	0.0	1.37	1.37
14	Braced	Roof	Beam	W14X34	36	W10X19	19	0.0	0.0	1.37	1.37
15	Braced	Roof	Braces	WT9X48.5	39	W10X33	33	0.0	0.0	3.78	2.57
16	Braced	Roof	Braces	WT9X48.5	39	W10X33	33	0.0	0.0	3.78	2.57
17	Braced	First	Braces	WT9X48.5	39	W10X33	33	0.0	0.0	3.78	2.57
18	Braced	First	Braces	WT9X48.5	39	W10X33	33	0.0	0.0	3.78	2.57
1	Moment	First	Column	W8X40	15	W10X33	33	12.0	0.0	1.20	1.50
2	Moment	Roof	Column	W8X40	15	W10X33	33	1.7	0.0	1.20	1.50
7	Moment	First	Column	W8X40	15	W12X50	50	0.0	0.0	1.20	1.50
8	Moment	Roof	Column	W8X40	15	W12X50	50	0.0	0.0	1.20	1.50
21	Moment	First	Column	W8X40	15	W10X68	68	0.0	0.0	1.17	2.04
22	Moment	Roof	Column	W8X40	15	W10X68	68	0.0	0.0	1.17	2.04
23	Moment	First	Column	W8X40	15	W10X68	68	0.0	0.0	1.17	2.04
24	Moment	Roof	Column	W8X40	15	W10X68	68	5.0	0.0	1.17	2.04
25	Moment	Roof	Beam	W12X16	24	W10X68	68	8.0	0.0	1.44	1.44
26	Moment	Roof	Interior Beam	W18X35	24	W10X39	39	0.0	0.0	1.92	1.87
27	Moment	Roof	Beam	W12X16	24	W14X30	30	0.0	0.0	1.44	1.44
28	Moment	First	Beam	W14X22	24	W10X39	39	0.0	0.0	1.92	1.92
29	Moment	First	Interior Beam	W21X44	24	W12X53	53	0.0	0.0	1.92	2.54
30	Moment	First	Beam	W14X22	24	W8X40	40	0.0	0.0	1.92	1.92

7. CONNECTIONS

J

Member Ref.	Frame	Floor	Member	Pre-Section	Length	New-Section	Unit Weight	Spacing or a	Beams/Bay	Qty of Members	Amount of Steel
(#)	(type)	Units		(Shape)	(ft)	(Shape)	(plf)	(ft)	(Units)	(Units)	(kips)
0	0	0	0	0	0	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
0	0	0	0	0	0	#N/A	#N/A	#N/A	#N/A	#N/A	#N/A
0	0	0	0	0	0	W12X50	50	#N/A	#N/A	#N/A	#N/A

I

COLUMN-CAPACITY

Member Ref:	23
Frame:	Moment
Floor:	First
Member:	Column
Ref. 2:	1-M

ASSUMPTIONS:

No transverse loads are applied to the member (Per section 7)

1. MATERIAL PROPERTIES:

Modulus of Elasticity:	E =	29000	ksi
	G =	11200	ksi
Yield Strength:	$F_y =$	50	ksi

2. MEMBER GEOMETRIC INFORMATION:

Beam Length	L =	15	ft	15 Project Information
-------------	-----	----	----	------------------------

Column Slenderness Parameters:

Unbraced Length, x:	$L_{bx} =$	15	ft	Global or Local System?
Unbraced Length, y:	$L_{by} =$	15	ft	
Unbraced Length, z:	$L_{bz} =$	15	ft	
Eff. Length Factor, x:	$K_x =$	1		
Eff. Length Factor, y:	$K_y =$	1		
Eff. Length Factor, z:	$K_z =$	1		

Reference: Excel

	Section	Eq/Fig/Table/Notes
3. SECTION PROPERTIES	Information	

Section:	W	W8X40			
Member is in:		Compression			
Moment of Inertia, x:	$I_{xw} =$	146	in ⁴	Depth:	$d =$ 8.25 in
Moment of Inertia, y:	$I_{yw} =$	49.1	in ⁴	Width:	$b_f =$ 8.07 in
Polar Moment of Inertia:	$J_w =$	1.12	in ⁴	Flange Thickness:	$t_f =$ 0.56 in
Radius of Gyration, x:	$r_{xw} =$	3.53	in	Web Thickness:	$t_w =$ 0.36 in
Radius of Gyration, y:	$r_{yw} =$	2.04	in	Area:	$A =$ 11.7 in ²
Section Modulus:	$S_x =$	35.5	in ³	r_{ts}	$r_{ts} =$ 2.81 in
Plastic Section Modulus, x:	$Z =$	39.8	in ³	Distance flange/centro	$h_0 =$ 11.60 in
T	$T =$	0	in	Warping Constant	$C_w =$ 726 in

3. PRELIMINARY ANALYSIS Eq. E 6-2a/b

Slenderness Ratios:	$(KL/r)_x =$	51.0			
	$(KL/r)_y =$	88.2	AISC	Table	3-2
	$(KL)_z =$	180.0	AISC	Table	3-2
Largest Possible Ratio:		88.2			
Compressive Control:		113.43	E		
Critical Stress, F_{cr} equation:		USE E3-2			

4. LOCAL SLENDERNESS CHECK: Table B4.1a

	Web	Flange
Member	h/tw	$bf/2t$
	17.6	7.21
Critical	λ_r	λ_r
Case	[case 5]	[case 1]
	35.9	35.9
Check	Nonslender	Nonslender

	Reference:	AISC 14th
	Section	Eq/Fig/Table/Notes
5. BUCKLING ANALYSIS:	E	

Euler Buckling Stress:	$F_{e3} =$	36.8	ksi	Eq. E3-4
Torsional Buckling Stress:	$F_{e4} =$	97.2	ksi	Eq. E4-4
Controlling Euler Stress:	$F_{e3} =$	36.8	ksi	
Critical Buckling Stress:	$F_{cr} =$	28.3	ksi	Eq. E3-2

6. COLUMN CAPACITY: Eq. E3-1

Compressive Strength: $P_n = 331.1$ ksi
Factor: $\Phi = 0.9$
Column Capacity: $\Phi \cdot P_n = 298.0$ ksi

Eq. E3-1

BEAM-COLUMN ANALYSIS

1. MATERIAL PROPERTIES:

Modulus of Elasticity:	E =	29000	ksi
	G =	11200	ksi
Yield Strength:	F _y =	50	ksi

2. MEMBER GEOMETRIC INFORMATION:

Beam Length	L =	15	ft	Project Information
-------------	-----	----	----	---------------------

Column Slenderness Parameters:

Unbraced Length, x:	L _{bx} =	15	ft	Global or Local System?
Unbraced Length, y:	L _{by} =	15	ft	
Unbraced Length, z:	L _{bz} =	15	ft	
Eff. Length Factor Check:		K>1		Check for values below
Eff. Length Factor, x:	K _x =	1		
Eff. Length Factor, y:	K _y =	1		
Eff. Length Factor, z:	K _z =	1		

Plastic Zones Lengths and Info:

Full plastic yield Length:	L _p =	7.2	ft
LTB Length:	L _r =	29.9	ft
	φ _b BF =	2.46	kips
	φ _b M _{px} =	149	kip.ft

Reference:	Excel
Section	Eq/Fig/Table/Notes
Information	

3. SECTION PROPERTIES

Section:	W	W8X40
Member is in:		Compression

Moment of Inertia, x:	I _{xw} =	146	in ⁴	Depth:	d =	8.25	in
Moment of Inertia, y	I _{yw} =	49.1	in ⁴	Width:	b _f =	8.07	in
Polar Moment of Inertia:	J _w =	1.12	in ⁴	Flange Thickness:	t _f =	0.56	in
Radius of Gyration, x:	r _{xw} =	3.53	in	Web Thickness:	t _w =	0.36	in
Radius of Gyration, y	r _{yw} =	2.04	in	Area:	A =	11.7	in ²
Section Modulus:	S _x =	35.5	in ³	r _{ts}	r _{ts} =	2.81	in
Plastic Section Modulus, x:	Z =	39.8	in ³	Distance flange/centro	h ₀ =	11.60	in
Plastic Section Modulus, y:	Z _y =	18.5	in	Warping Constant	C _w =	726	in ³
T	T =	0	in	Section Modulus:	S _y =	12.2	in ³

3. SLENDERNESS CHARACTERISTICS:

Table B4.1a

	Web	Flange
Flexure	Compact	Compact
Compression	Mntx =	32

4. CONSIDERATION OF IMPERFECTIONS - NOTIONAL LOADS:

C2.2(b)

Notional Load: $Z_1 = 0.428$ kip Eq. C2-1
 Second/First order drift ratio: 2 in

Is it applied at all levels in all combinations?

YES

Ref. to C.2.3(3)

Reference:

GTS

Section

Eq/Fig/Table/Notes

5. FIRST ORDER ANALYSIS FORCES:

GTS

Ultimate Axial Load, NT $P_{nt} = 57.2$ kips
 Ultimate Moment, NT, x $M_{ntx} = 32$ kip.ft
 Ultimate Moment, NT, y $M_{nty} = 0$ kip.ft
 Ultimate Axial Load, LT $P_{lt} = 29.4$ kips
 Ultimate Moment, LT, y $M_{ltx} = 159$ kip.ft
 Ultimate Moment, LT, y $M_{ltx} = 0$ kip.ft

Total V. load in story $P_{story} = 3643.2$ kip $P_{mf} = 607.6$ kipStory Shear in Direction of $H = 31$ kip $\alpha = 1$

LRFD

Lateral Deflection $\Delta H = 0.215$ inFact. Story Drift Limit $\Delta H/L = 0.0012$ **6. MEMBER CAPACITY:**

Eq. E3-1

Axial Capacity $\phi.P_n = 298.0$ ksi

Flexure Capacity

Along axis x: Zone = 2

 $C_b = 1.34$ Flexure Capacity, x $M_{cx} = 149.0$ kip.ftAlong axis y: $F_y.Z_y = 925$ Eq. F6-1 $1.6F_y.S_y = 976$ Eq. F6-1Flexure Capacity, y $M_{cy} = 832.5$ kip.ft

Reference:

AISC 14th

Section

Eq/Fig/Table/Notes

7. APPROXIMATE SECOND ORDER ANALYSIS:

C

Along axis x:

DAM:

Use reduced stiffness per C2.3

	$\tau_b =$	1.00	Apply to all	C	2.3(2)
Type of Curvature:		Single			
Smaller 1st-O End Mom:	$M_1 =$	-1			
Larger 1st-O End Mom:	$M_2 =$	1			
Modif. Coefficient, x:	$C_{mx} =$	1	App. 8	Eq.	A-8-4
Elastic Buckling Strength, x	$P_{ex} =$	1612 kip	App. 8	Eq.	A-8-5
Amplification Factor	$B_{1x} =$	1.0	App. 8	Eq.	A-8-3
Factor Check:		OK	Check		

Along axis y:

	$\tau_b =$	1	Apply to all	C	2.3(2)
Type of Curvature:		Single			
Smaller 1st-O End Mom:	$M_1 =$	-1			
Larger 1st-O End Mom:	$M_2 =$	1			
Modif. Coefficient, y	$C_{my} =$	1	App. 8	Eq.	A-8-4
Elastic Buckling Strength	$P_{ey} =$	542 kip	App. 8	Eq.	A-8-5
Amplification Factor	$B_{1y} =$	1.0	App. 8	Eq.	A-8-3
Factor Check:		OK	Check		

Calculate P-Δ Amplification Factor:

Along axis x:

	$R_m =$	0.97		A-8-8
	$P_{e-story} =$	25304.2 kip		A-8-7
	$B_{2x} =$	1.17		A-8-6
2nd-Order Axial Strength	$P_r =$	91.5 kip		A-8-2
2nd-Order Mom. Strength	$M_{rx} =$	0.0 kip.ft		A-8-1

Along axis y:

	$R_{my} =$	0.97		A-8-8
	$P_{e-storyY} =$	25304.2 kip		A-8-7
	$B_{2y} =$	1.00		A-8-6
2nd-Order Axial Strength	$P_{ry} =$	86.6 kip		A-8-2
2nd-Order Mom. Strength	$M_{ry} =$	-32.0 kip.ft		A-8-1

8. COMBINED FORCES INTERACTION EQUATION:

GTS

Check P_r/P_c	$P_r/P_c =$	0.307			
$P_r/P_c \geq 0.2$		1.294	OK	Eq.	H.1-1a
$P_r/P_c < 0.2$		0.000	OK	Eq.	H.1-1b
Design Check			OK	Eq.	H.1-1a