

#### **Binary format**

<SOF-SID10...SID0-RTR-IDE-r0-DLC3...0-DATABYTE1...DATABYTEn-CRC15...CRC1-CRCDEL-ACK-ACKDEL-EOF7...EOF1-IFS3...IFS1>

bits	Description		
SOF	Start Of Frame (always 0)		
SID10 & SID9	Priority (00: highest 11: lowest priority)		
SID8SID1	Address		
SID0	Always 0		
RTR	Remote Transmit Request		
IDE	Identifier Extension (always 0)		
r0	reserved (always 0)		
DLC3DLC0	Data Length Code (08)		
Databyte1	Command		
Databyte2	Parameter		
Databyte3	Parameter		
Databyte4	Parameter		
Databyte5	Parameter		
Databyte6	Parameter		
Databyte7	Parameter		
Databyte8	Parameter		
CRC15CRC1	Cyclic Redundancy Checksum		
CRCDEL	CRC Delimiter (always 1)		
ACK	Acknowledge slot (transmit 1 readback 0 if received correctly)		
ACKDEL	Acknowledge Delimiter (always 1)		
EOF7EOF1	End Of Frame (always 1111111)		
IFS3IFS1	InterFrame Space (always 111)		

#### The temperature sensor module can transmit the following messages:

- Sensor output status
- Manual push buttons status
- Sensor status
- Sensor temperature (incl. minimum and maximum)
- Time statistics (heater/cooler operation time)
- First, second and third part of the sensor settings
- Sensor configuration data
- Module type
- Bus error counter status
- First, second and third part of the sensor name
- Memory data
- Memory data block (4 bytes)

### The temperature sensor module can transmit the following commands:

- Updates LEDs on a push button module
- Clears LEDs on a push button module
- Sets LEDs on a push button module
- Blinks LEDs slowly on a push button module
- Blinks LEDs very fast on a push button module
- Set target temperature of the differential sensor

#### The temperature sensor module can receive the following message:

• Push button status

#### The temperature sensor module can receive the following commands:

- Update output LED
- Clear output LED
- Set output LED
- Blink output LED slowly
- Blink output LED fast
- Blink output LED very fast
- Clear Push button Led
- Module type request
- Bus error counter status request
- Sensor temperature request
- Reset min/max temperature
- Sensor status request
- Sensor settings request
- Sensor configuration data request
- Sensor name request
- Time statistics request
- Enable/disable anti block heating valve and pump
- · Reset time statistics
- · Lock local control
- Unlock local control
- Sensor zone number
- Set heating mode
- Set cooling mode
- Set temperature
- Switch to comfort mode
- Switch to day mode
- Switch to night mode
- Switch to safe temperature mode
- Set default sleep time
- Read memory data
- Read memory data block (4 bytes)
- Memory dump request
- Write memory data
- Write memory data block (4 bytes)
- Program availability

#### Transmits the sensor output status:

SID10-SID9 = 00 (highest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 4 databytes to send

DATABYTE1 = COMMAND\_OUTPUT\_STATUS (H'00')

DATABYTE2 = Output channel just activated (1 = just activated)

Contents	Output channel	
0xx1xxx1	Heater just activated	
0xxxxx1x	Turbo heater/cooler just activated	
0xxxx1xx	Comfort or day mode just activated	
0xxx1xxx	Cooler just activated	
0x1xxxxx	Low temperature alarm activated	
01xxxxxx	High temperature alarm activated	

DATABYTE3 = Outputs just deactivated (1 = just deactivated)

Contents	Output channel	
0xx1xxx1	Heater just deactivated	
0xxxxx1x	Turbo heater/cooler just deactivated	
0xxxx1xx	Comfort or day mode just deactivated	
0xxx1xxx	Cooler just deactivated	
0x0xxxxx	Low temperature alarm deactivated	
00xxxxxx	High temperature alarm deactivated	

DATABYTE4 = always zero

#### Transmits the manual push button status:

SID10-SID9 = 00 (highest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 4 databytes to send

DATABYTE1 = COMMAND\_PUSHBUTTON\_STATUS (H'00')

DATABYTE2 = Push buttons just pressed (1 = just pressed)

. aon battono	Just process (1 Just process)
Contents	Manual push button channel
xxxxxxx1	Heater push button just pressed
xxxxxx1x	Turbo heater/cooler push button just pressed
xxxxx1xx	Day mode push button just pressed
xxxx1xxx	Cooler push button just pressed
xxx1xxxx	Mode & heater (pump) button just pressed
xx1xxxxx	Mode & turbo (low alarm) button just pressed
x1xxxxxx	Mode & day (high alarm) button just pressed

DATABYTE3 = Push buttons just released (1 = just released)

	jact to to a ( t ) jact to to a up		
Contents	Manual push button channel		
xxxxxxx1	Heater push button just released		
xxxxxx1x	Turbo heater/cooler push button just released		
xxxxx1xx	Day mode push button just released		
Xxxx1xxx	Cooler push button just released		
xxx1xxxx	Mode & heater (pump) button just released		
xx1xxxxx	Mode & turbo (low alarm) button just released		
x1xxxxxx	Mode & day (high alarm) button just released		

DATABYTE4 = Push buttons long pressed (1 = longer than 0.85s pressed)

Contents	Manual push button channel		
xxxxxxxx1			
XXXXXXXI	Heater push button long pressed		
xxxxxx1x	Turbo heater/cooler push button long pressed		
xxxxx1xx	Day mode push button long pressed		
Xxxx1xxx	Cooler push button long pressed		
xxx1xxxx	Mode & heater (pump) button long pressed		
xx1xxxxx	Mode & turbo (low alarm) button long pressed		
x1xxxxxx	Mode & day (high alarm) button long pressed		

# Transmit the sensor status (Build 0949): SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 8 databytes to send
DATABYTE1 = COMMAND\_TEMP\_SENSOR\_STATUS (H'EA')
DATABYTE2 = Operating mode

operating mode			
Contents	Operating mode		
xxxxxxx1	Mode push button locked		
0xxxxxxx	Mode push button unlocked		
Xxxxx11x	Disable mode		
xxxxx01x	Manual mode		
xxxxx10x	Sleep timer mode		
xxxxxx00x	Run mode		
xxxx1xxx	Auto send sensor temperature enabled		
xxxx0xxx	Auto send sensor temperature disabled		
x100xxxx	Comfort mode		
x010xxxx	Day mode		
x001xxxx	Night mode		
x000xxxx	Safe temp mode (anti frost)		
1000xxxx	Cooler mode		
0xxxxxxx	Heater mode		

DATABYTE3 = Program step mode

Contents	Program step mode	
xxxxx0xx	No sensor program	
xxxxx1xx	Sensor program available	
xxx0xxx	No zone program	
xxxx1xxx	Zone program available	
0xxxxxxx	No all rooms program	
1xxxxxxx	All rooms program available	
x100xxxx	Comfort program step received	
x010xxxx	Day program step received	
x001xxxx	Night program step received	
X000xxxx	Safe temperature program step received	
xxxxxx1x	Enable unjamming heater valve	
xxxxxxxxx	Disable unjamming heater valve	
xxxxxxx1	Enable unjamming pump	
0xxxxxxx	Disable unjamming pump	

DATABYTE4 = Output status (1 = activated)

Catpat otatat	7 (1 = dottvatod)		
Contents	Output channel		
0xx0xxx0	Heater/pump off		
0xx1xxx1	Heater/pump on		
0xxxxx0x	Boost heater/cooler off		
0xxxxx1x	Boost heater/cooler on		
0xxxx0xx	Comfort and day mode off		
0xxxx1xx	Comfort or day mode on		
0xxx0xxx	Cooler off		
0xxx1xxx	Cooler on		
0x0xxxxx	Low alarm off		
0x1xxxxx	Low alarm on		
00xxxxxx	High alarm off		
01xxxxxx	High alarm on		

DATABYTE5 = Current sensor temperature into two's complement format (resolution 0.5°)

Contents	Current sensor temperature
01111111	63.5°C
00000001	0.5°C
00000000	0°C
11111111	-0.5°C
10010010	-55°C

DATABYTE6 = Current temperature set (resolution 0.5°)

Contents	Current temperature set
01101100	54°C
00101000	20°C
00000010	1°C
00000001	0.5°C
00000000	0°C
11111111	-0.5°C
11000000	-32°C

DATABYTE7 = High byte of the sleep timer

DATABYTE8 = Low byte of the sleep timer into minutes

#### Remark:

[DATABYTE7][DATABYTE8] contains a 16-bit sleep timer into minutes (1 to 65.279min).

If the sleep timer contains H'0000', the sleep timer is deactivated.

If the sleep timer contains a value between H'0001' and H'FEFF' (1 to 65.279min), the sleep timer is running for that time.

If the sleep timer contains H'FFFF', the sensor is in manual mode.

#### Transmit the sensor temperature:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 7 databytes to send

DATABYTE1 = COMMAND\_SENSOR\_TEMPERATURE (H'E6')

DATABYTE2 = High byte current sensor temperature

DATABYTE3 = Low byte current sensor temperature into two's complement format (resolution 0.0625°)

DATABYTE4 = High byte minimum sensor temperature

DATABYTE5 = Low byte minimum sensor temperature into two's complement format (resolution 0.0625°)

DATABYTE6 = High byte maximum sensor temperature

DATABYTE7 = Low byte maximum sensor temperature into two's complement format (resolution 0.0625°)

High byte	Low byte	Current sensor temperature
01111111	11100000	63.5°C
00000001	00000000	0.5°C
00000000	10000000	0.25°C
00000000	01000000	0.125°C
00000000	00100000	0.0625°C
00000000	00000000	0°C
11111111	11100000	-0.0625°C
11111111	11000000	-0.125°C
11111111	10000000	-0.25°C
11111110	00000000	-0.5°C
10010010	00000000	-55°C

#### Remark:

The 5 least significant bits of the low byte are always zero.

The low order bytes are not sending with the data length of 4 bytes (resolution 0.5°C)

#### Transmit time statistics

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 8 databytes to send

DATABYTE1 = COMMAND\_TIME\_STATISTICS (H'C8')

DATABYTE2 = statistics mode index

Contents	Time statistics
10000001	Heating antifreeze mode time statistics
10000010	Heating night mode time statistics
10000100	Heating day mode time statistics
10001000	Heating comfort mode time statistics
10010000	Heating global time statistics
01000001	Cooling standby mode time statistics
01000010	Cooling night mode time statistics
01000100	Cooling day mode time statistics
01001000	Cooling comfort mode time statistics
01010000	Cooling global time statistics

DATABYTE3 = 'ON' time (hours bcd digits 4 & 3)

DATABYTE4 = 'ON' time (hours bcd digits 2 & 1)

DATABYTE5 = 'ON' time (minutes bcd digits 2 & 1)

DATABYTE6 = Mode time (hours bcd digits 4 & 3)

DATABYTE7 = Mode time (hours bcd digits 2 & 1)

DATABYTE8 = Mode time (minutes bcd digits 2 & 1)

#### Remark:

The time is bcd formatted.

Databytes 3, 4 & 5 gives the total 'ON' time of the heater or cooler in the corresponding mode.

Databytes 6, 7 & 8 gives the total time of selected mode.

#### Transmit the first part of the sensor settings (Build 0949):

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 8 databytes to send

DATABYTE1 = COMMAND\_TEMP\_SENSOR\_SETTINGS\_PART1 (H'E8')

DATABYTE2 = Current temperature set (resolution 0.5°)

DATABYTE3 = Comfort temperature set for heating mode (resolution 0.5°)

DATABYTE4 = Day temperature set for heating mode (resolution 0.5°)

DATABYTE5 = Night temperature set for heating mode (resolution 0.5°)

DATABYTE6 = Anti freeze temperature set for heating mode (resolution 0.5°)

DATABYTE7 = Temperature difference set (resolution 0.5°)

DATABYTE8 = Hysteresis temperature set

٠.	., 515. 55.5 15 55. 414. 5 551	
	Contents	Hysteresis
	xxx11111	15.5°C
	Xxx00001	0.5°C
	Xxx00000	0°C

#### Transmit the second part of the sensor settings:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 8 databytes to send

DATABYTE1 = COMMAND\_TEMP\_SENSOR\_SETTINGS\_PART2 (H'E9')

DATABYTE2 = Comfort temperature set for cooling mode (resolution 0.5°)

DATABYTE3 = Day temperature set for cooling mode (resolution 0.5°)

DATABYTE4 = Night temperature set for cooling mode (resolution 0.5°)

DATABYTE5 = Safe temperature set for cooling mode (resolution 0.5°)

DATABYTE6 = High byte of the default sleep timer

DATABYTE7 = Low byte of the default sleep timer into minutes (1 to 65.279min)

DATABYTE8 = Default auto send temperature time interval into seconds

(valid range: 10...255s)

(1...9 = autosend when temperature changed)

(0 = autosend disabled)

#### Transmit the third part of the sensor settings:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 7 databytes to send

DATABYTE1 = COMMAND\_TEMP\_SENSOR\_SETTINGS\_PART3 (H'C6')

DATABYTE2 = Low temperature alarm setting (resolution 0.5°)

DATABYTE3 = High temperature alarm setting (resolution 0.5°)

DATABYTE4 = Lower temperature range cool mode (resolution 0.5°)

DATABYTE5 = Upper temperature range heat mode (resolution 0.5°)

DATABYTE6 = Calibration factor (resolution 0.5°)

Contents	Calibration factor
00001111	Calibration factor +7.5°C
00000001	Calibration factor +0.5°C
00000000	Calibration factor +0°C
11111111	Calibration factor -0.5°C
11110000	Calibration factor -8°C

DATABYTE7 = Differential (slave) sensor address (H'FF': no slave sensor)

### Transmit the fourth part of the sensor settings (Build 0949):

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes to send

DATABYTE1 = COMMAND\_TEMP\_SENSOR\_SETTINGS\_PART4 (H'B9')
DATABYTE2 = Minimum switching time (Build 0949):

Contents	Operating mode
00000000	No switching time protection
00000001	1 minute switching time protection
00000010	2 minute switching time protection
11111110	254 minute switching time protection
11111111	Default 1 minute switching time protection

#### Transmit the sensor configuration data:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 8 databytes to send

DATABYTE1 = COMMAND SENSOR CONFIG DATA (H'BB')

DATABYTE2 = Sensor configuration byte

Contents	Configuration
0xxxxxxx	One shot disabled
1xxxxxxx	One shot enabled
x00xxxxx	9 bit adc resolution
x01xxxxx	10 bit adc resolution
x10xxxxx	11 bit adc resolution
x11xxxxx	12 bit adc resolution
xxx00xxx	1 fault queue
xxx01xxx	2 fault queue
xxx10xxx	4 fault queue
xxx11xxx	6 fault queue
xxxxx0xx	Active low output
xxxxx1xx	Active high output
xxxxxxxxx	Comparator mode
xxxxxx1x	Interrupt mode (pulse)
0xxxxxxx	Shutdown disabled
xxxxxxx1	Shutdown enabled

DATABYTE3 = Sensor limit set high byte (bit 7 = sign bit)

DATABYTE4 = Sensor limit set low byte (bits 3...0 always zero)

DATABYTE5 = Sensor hysteresis set high byte (bit 7 = sign bit)

DATABYTE6 = Sensor hysteresis set low byte (bits 3...0 always zero)

DATABYTE7 = Sensor output status (0 = low / 1 = high)

```
Transmits the module type (Build 1001 or lower):
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 5 databytes to send
   DATABYTE1 = COMMAND_MODULE_TYPE (H'FF')
   DATABYTE2 = NODETYPE_TEMPERATURE_SENSOR (H'0C')
   DATABYTE3 = Sensor zone number
   DATABYTE4 = Build year
   DATABYTE5 = Build week
Transmits the module type (Build 1233 or higher):
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 8 databytes to send
   DATABYTE1 = COMMAND MODULE TYPE (H'FF')
   DATABYTE2 = NODETYPE_TEMPERATURE_SENSOR (H'0C')
   DATABYTE3 = Sensor zone number
   DATABYTE4 = Serial number high
   DATABYTE5 = Serial number low
   DATABYTE6 = Memory map version
   DATABYTE7 = Build year
   DATABYTE8 = Build week
Transmits the first part of the sensor name:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 8 databytes to send
   DATABYTE1 = COMMAND SENSOR NAME PART1 (H'F0')
   DATABYTE2 = Sensor bit number ('00000001' = Sensor 1)
   DATABYTE3 = Character 1 of the sensor name
   DATABYTE4 = Character 2 of the sensor name
   DATABYTE5 = Character 3 of the sensor name
   DATABYTE6 = Character 4 of the sensor name
   DATABYTE7 = Character 5 of the sensor name
   DATABYTE8 = Character 6 of the sensor name
Transmits the second part of the sensor name:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 8 databytes to send
   DATABYTE1 = COMMAND_SENSOR_NAME_PART2 (H'F1')
   DATABYTE2 = Sensor bit number ('00000001' = Sensor 1)
   DATABYTE3 = Character 7 of the sensor name
   DATABYTE4 = Character 8 of the sensor name
   DATABYTE5 = Character 9 of the sensor name
   DATABYTE6 = Character 10 of the sensor name
   DATABYTE7 = Character 11 of the sensor name
   DATABYTE8 = Character 12 of the sensor name
Transmits the third part of the sensor name:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 6 databytes to send
   DATABYTE1 = COMMAND SENSOR NAME PART3 (H'F2')
   DATABYTE2 = Sensor bit number ('00000001' = Sensor 1)
   DATABYTE3 = Character 13 of the sensor name
   DATABYTE4 = Character 14 of the sensor name
   DATABYTE5 = Character 15 of the sensor name
```

DATABYTE6 = Character 16 of the sensor name

Remarks:

Unused characters contain H'FF'.

Transmits the memory data:
SID10-SID9 = 11 (lowest priority)
SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 4 databytes to send

DATABYTE1 = COMMAND\_MEMORY\_DATA (H'FE')

DATABYTE2 = High memory address (must be H'00') DATABYTE3 = LOW memory address (H'00'...H'7F')

DATABYTE4 = memory data

```
Transmits memory data block (4 bytes):
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Address of the module
   RTR = 0
   DLC3...DLC0 = 7 databytes to send
   DATABYTE1 = COMMAND_MEMORY_DATA_BLOCK (H'CC')
   DATABYTE2 = High start address of memory block (must be H'00')
   DATABYTE3 = LOW start address of memory block (H'00'...H'FF')
   DATABYTE4 = memory data1
   DATABYTE5 = memory data2
   DATABYTE6 = memory data3
   DATABYTE7 = memory data4
Transmit: Updates LEDs on a push button module:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Address of the push button module for updating the LEDs
   RTR = 0
   DLC3...DLC0 = 4 databytes to send
   DATABYTE1 = COMMAND UPDATE LED (H'F4')
   DATABYTE2 = LED continuous on status (1 = LED on)
   DATABYTE3 = LED slow blinking status (1 = LED slow blinking)
   DATABYTE4 = LED fast blinking status (1 = LED fast blinking)
              The continuous on bit overrides the blinking modes.
              If the slow and fast blinking bits for a LED are both on, the LED blinks very fast.
Transmit: Clears LEDs on a push button module:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Address of the push button module for clearing LEDs
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND CLEAR LED (H'F5')
   DATABYTE2 = LED bit numbers (1 = clear LED)
Transmit: Sets LEDs on a push button module:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Address of the push button module for setting LEDs on
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND SET LED (H'F6')
   DATABYTE2 = LED bit numbers (1 = set LED)
Transmit: Blinks LEDs slowly on a push button module:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Address of the push button module for slowly blinking LEDs
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND_SLOW_BLINKING_LED (H'F7')
   DATABYTE2 = LED bit numbers (1 = slow blink LED)
Transmit: Blinks LEDs very fast on a push button module:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Address of the push button module for very fast blinking LEDs
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND VERYFAST BLINKING LED (H'F9')
   DATABYTE2 = LED bit numbers (1 = very fast blink LED)
Transmit: Bus error counter status
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 4 databytes to send
   DATABYTE1 = COMMAND BUSERROR COUNTER STATUS (H'DA')
   DATABYTE2 = Transmit error counter
   DATABYTE3 = Receive error counter
   DATABYTE4 = Bus off counter
```

### Transmit: Set target temperature of the differential sensor

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Differential sensor address

RTR = 0

DLC3...DLC0 = 3 databytes to send
DATABYTE1 = COMMAND\_SET\_TEMP (H'E4')
DATABYTE2 = 20 (index for current temperature set)
DATABYTE3 = Temperature set (resolution 0.5°)

Tomporation out (recondition o.e.)	
Contents	Temperature set
01111111	63.5°C
00101000	20°C
00000010	1°C
00000001	0.5°C
00000000	0°C
11111111	-0.5°C
11000000	-32°C
	·

#### 'Push button status' received:

SID10-SID9 = 00 (highest priority)

SID8...SID1 = Address of the push button module

RTR = 0

DLC3...DLC0 = 4 databytes received

DATABYTE1 = COMMAND\_PUSH\_BUTTON\_STATUS (H'00')

DATABYTE2 = Push buttons just pressed (1 = just pressed)

DATABYTE3 = Push buttons just released (1 = just released)

DATABYTE4 = Push buttons long pressed (1 = longer than 0.85s pressed)

#### 'Clear Push button LED' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Address of the push button module

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND CLEAR LED (H'F5')

DATABYTE2 = LEDs to clear (a one clears the corresponding LED)

#### 'Update output LED status' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 4 databytes received

DATABYTE1 = COMMAND\_UPDATE\_LED\_STATUS (H'F4')

DATABYTE2 = LED continuous on status (1 = LED on)

DATABYTE3 = LED slow blinking status (1 = LED slow blinking)

DATABYTE4 = LED fast blinking status (1 = LED fast blinking)

Contents	Output LED
xxxxxxx1	Heater
xxxxxx1x	Turbo heater/cooler
xxxxx1xx	Comfort or day mode
xxxx1xxx	Cooler
xxx1xxxx	Pump
xx1xxxxx	Low temperature alarm
x1xxxxxx	High temperature alarm

#### Remarks:

The continuous on bit overrides the blinking modes.

If the slow and fast blinking bits for a LED are both on, the LED blinks very fast.

#### 'Clear output LED' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND\_CLEAR LED (H'F5')

DATABYTE2 = LEDs to clear (a one clears the corresponding LED)

Contents	Output LED
xxxxxxx1	Heater
xxxxxx1x	Turbo heater/cooler
xxxxx1xx	Comfort or day mode
xxxx1xxx	Cooler
xxx1xxxx	Pump
xx1xxxxx	Low temperature alarm
x1xxxxxx	High temperature alarm

#### 'Set output LED' command received:

SID10-SID9 = 11 (lowest priority) SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND\_SET\_LED (H'F6')

DATABYTE2 = LEDs to set (a one sets the corresponding LED)

Contents	Output LED
xxxxxxx1	Heater
xxxxxx1x	Turbo heater/cooler
xxxxx1xx	Comfort or day mode
xxxx1xxx	Cooler
xxx1xxxx	Pump
xx1xxxxx	Low temperature alarm
x1xxxxxx	High temperature alarm

#### 'Slow blinking output LED' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND\_SLOW\_BLINKING\_LED (H'F7')

DATABYTE2 = LEDs to blink slow (1 = slow blinking)

Contents	Output LED
xxxxxxx1	Heater
xxxxxx1x	Turbo heater/cooler
xxxxx1xx	Comfort or day mode
xxxx1xxx	Cooler
xxx1xxxx	Pump
xx1xxxxx	Low temperature alarm
x1xxxxxx	High temperature alarm

#### 'Fast blinking output LED' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND\_FAST\_BLINKING\_LED (H'F8')

DATABYTE2 = LEDs to blink fast (1 = fast blinking)

Contents	Output LED
xxxxxxx1	Heater
xxxxxx1x	Turbo heater/cooler
xxxxx1xx	Comfort or day mode
xxxx1xxx	Cooler
xxx1xxxx	Pump
xx1xxxxx	Low temperature alarm
x1xxxxxx	High temperature alarm

#### 'Very fast blinking output LED' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND VERYFAST BLINKING LED (H'F9')

DATABYTE2 = LEDs to clear (1 = very fast blinking)

	·
Contents	Output LED
xxxxxxx1	Heater
xxxxxx1x	Turbo heater/cooler
xxxxx1xx	Comfort or day mode
xxxx1xxx	Cooler
xxx1xxxx	Pump
xx1xxxxx	Low temperature alarm
x1xxxxxx	High temperature alarm

```
'Module type request' command received:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 1
   DLC3...DLC0 = 0 databytes received
'Bus error counter status request' command received:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 1 databytes to send
   DATABYTE1 = COMMAND BUS ERROR CONTER STATUS REQUEST (H'D9')
'Sensor temperature request' command received:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND SENSOR TEMP REQUEST (H'E5')
   DATABYTE2 = Autosend time interval into seconds
                  (valid range: 10...255s)
                  (1...9 = autosend when temperature changed)
                  (0 = autosend disabled)
'Sensor status request' command received:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND_MODULE_STATUS_REQUEST (H'FA')
   DATABYTE2 = don't care
'Sensor settings request' command received:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND_TEMP_SENSOR_SETTINGS_REQUEST (H'E7')
   DATABYTE2 = don't care
'Sensor configuration data request' command received:
   SID10-SID9 = 11 (lowest priority)
   SID8...SID1 = Module address
   RTR = 0
   DLC3...DLC0 = 2 databytes to send
   DATABYTE1 = COMMAND SENSOR CONFIG DATA REQUEST (H'BA')
```

```
DATABYTE2 = don't care
```

#### 'Sensor name request' command received:

```
SID10-SID9 = 11 (lowest priority)
SID8...SID1 = Module address
RTR = 0
DLC3...DLC0 = 2 databytes received
DATABYTE1 = COMMAND SENSOR NAME REQUEST (H'EF')
DATABYTE2 = don't care
```

#### 'Time statistics request' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes to send

DATABYTE1 = COMMAND\_TIME\_STATISTICS\_REQUEST (H'C7')

DATABYTE2 = statistics mode index

Contents	Time statistics request		
10000001	Heating antifreeze mode time statistics		
10000010	Heating night mode time statistics		
10000100	Heating day mode time statistics		
10001000	Heating comfort mode time statistics		
10010000	Heating global time statistics		
01000001	Cooling standby mode time statistics		
01000010	Cooling night mode time statistics		
01000100	Cooling day mode time statistics		
01001000	Cooling comfort mode time statistics		
01010000	Cooling global time statistics		

#### 'Lock local control' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND LOCK LOCAL CONTROL (H'E1')

DATABYTE2 = don't care

#### 'Unlock local control' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND\_UNLOCK\_LOCAL\_CONTROL (H'E2')

DATABYTE2 = don't care

#### 'Set heating mode' command received:

 $SID10-\bar{S}ID9 = 11$  (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND SET HEATING MODE (H'E0')

DATABYTE2 = don't care

#### 'Set cooling mode' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes received

DATABYTE1 = COMMAND\_SET\_COOLING\_MODE (H'DF')

DATABYTE2 = don't care

#### 'Read data from memory' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_READ\_DATA\_FROM\_MEMORY (H'FD')

DATABYTE2 = High memory address (must be H'00')

DATABYTE3 = LOW memory address (H'00'...H'7F')

#### 'Read data block from memory' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_READ\_MEMORY\_BLOCK (H'C9')

DATABYTE2 = High memory address (must be H'00')

DATABYTE3 = LOW memory address (H'00'...H'FC')

#### 'Memory dump request' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Address of the module

RTR = 0

DLC3...DLC0 = 1 databytes received

DATABYTE1 = COMMAND MEMORY DUMP REQUEST (H'CB')

#### 'Set sensor zone number' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 2 databytes to send

DATABYTE1 = COMMAND SET SENSOR ZONE NUMBER (H'C5')

DATABYTE2 = Zone number (0= no zone / 1...7 = valid zone)

Remark: The module answers with his type

#### 'Write data to memory' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 4 databytes received

DATABYTE1 = COMMAND WRITE DATA TO MEMORY (H'FC')

DATABYTE2 = High memory address (must be H'00')

DATABYTE3 = LOW memory address (H'00'...H'FF')

DATABYTE4 = memory data to write

#### Remark

Wait for 'memory data' feedback before sending a next command on the velbus.

#### 'Write memory block' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 7 databytes received

DATABYTE1 = COMMAND\_WRITE\_MEMORY\_BLOCK (H'CA')

DATABYTE2 = High memory address (must be H'00')

DATABYTE3 = LOW memory address (H'00'...H'FC')

DATABYTE4 = memory databyte1 to write

DATABYTE5 = memory databyte2 to write

DATABYTE6 = memory databyte3 to write

DATABYTE7 = memory databyte4 to write

#### Remark:

Wait for 'memory data block' feedback before sending a next command on the velbus.

#### 'Set default sleep time' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_SET\_DEFAULT\_SLEEP\_TIME (H'E3')

DATABYTE2 = High byte of the default sleep time

DATABYTE3 = Low byte of the default sleep time into minutes

(valid range H'0001' to H'FEFF' or 1min to 65.279min)

Remark: Wait at least 20ms for sending a next command on the velbus

### 'Set temperature' command received (Build 0949):

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_SET\_TEMP (H'E4')

DATABYTE2 = Pointer to temperature variable (0...20)

Contents	Temperature variable	
0	Current temperature set	
1	Comfort temperature set for heating	
2	Day temperature set for heating	
3	Night temperature set for heating	
4	Safe temperature set for heating	
5	Temperature difference for turbo output	
6	Hysteresis (0°15.5°C)	
7	Comfort temperature set for cooling	
8	Day temperature set for cooling	
9	Night temperature set for cooling	
10	Safe temperature set for cooling	
11	Calibration factor (-8°+7.5°C)	
12	Reset minimum/maximum temperature	
13	Reset time statistics	
14	enable/disable anti-block valve/pump	
15	Low temperature alarm set	
16	High temperature alarm set	
17	Lower temperature range cool mode	
18	Upper temperature range heat mode	
19	Differential sensor address (H'FF' = no diff. sensor)	
20	Target temperature set for the differential sensor	
21	Minimum switching time	

DATABYTE3 = Temperature set (resolution 0.5°)

Contents	Temperature set	
01111111	63.5°C	
00101000	20°C	
00000010	1°C	
00000001	0.5°C	
00000000	0°C	
11111111	-0.5°C	
10010010	-55°C	

DATABYTE3 = Reset minimum/maximum temperature

Contents	Reset temperature			
00000001	Reset minimum temperature			
00000010	Reset maximum temperature			

DATABYTE3 = Reset time statistics mode index

Contents	Reset time statistics			
10000001	Reset heating antifreeze mode time statistics			
10000010	Reset heating night mode time statistics			
10000100	Reset heating day mode time statistics			
10001000	Reset heating comfort mode time statistics			
10010000	Reset heating global time statistics			
01000001	Reset cooling standby mode time statistics			
01000010	Reset cooling night mode time statistics			
01000100	Reset cooling day mode time statistics			
01001000	Reset cooling comfort mode time statistics			
01010000	Reset cooling global time statistics			

DATABYTE3 = Enable/disable unjamming heater valve & pump

-	Znasio, alcasio anjamining neator vario a pamp				
	Contents	Enable/disable unjamming valve and pump			
	00000000	Disable unjamming heater valve & pump			
	0000001	Disable unjamming heater valve & enable unjamming pump			
	00000010	Enable unjamming heater valve & disable unjamming pump			
	00000011	Enable unjamming heater valve & pump			

#### DATABYTE3 = Minimum switching time (Build 0949):

Contents	Operating mode		
00000000	No switching time protection		
00000001	1 minute switching time protection		
00000010	2 minute switching time protection		
11111110	254 minute switching time protection		
11111111	Default 1 minute switching time protection		

#### Remark:

Valid hysteresis range = 0 ...15.5°C

Valid calibration factor range = -8 ...7.5°C

Wait at least 10ms for sending a next command on the velbus.

#### 'Switch to comfort mode' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_SWITCH\_TO\_COMFORT\_MODE (H'DB')

DATABYTE2 = High byte of the sleep time

DATABYTE3 = Low byte of the sleep time into minutes

#### Remark

If the sleep time contains H'FF00', the command is a program step.

A sleep time between H'0001' and H'FEFF' (1 to 65.279min) starts the sleep timer for that time and program steps will not be executed during that time.

A sleep time of H'FFFF' puts the sensor into manual mode. Program steps will not be executed any more and local control is disabled.

A value of zero for the sleep time cancels the manual mode or sleep timer.

#### 'Switch to day mode' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_SWITCH\_TO\_DAY\_MODE (H'DC')

DATABYTE2 = High byte of the sleep time

DATABYTE3 = Low byte of the sleep time into minutes

#### Remark:

If the sleep time contains H'FF00', the command is a program step.

A sleep time between H'0001' and H'FEFF' (1 to 65.279min) starts the sleep timer for that time and program steps will not be executed during that time.

A sleep time of H'FFFF' puts the sensor into manual mode. Program steps will not be executed any more and local control is disabled.

A value of zero for the sleep time cancels the manual mode or sleep timer.

#### 'Switch to night mode' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_SWITCH\_TO\_NIGHT\_MODE (H'DD')

DATABYTE2 = High byte of the sleep time

DATABYTE3 = Low byte of the sleep time into minutes

#### Remark:

If the sleep time contains H'FF00', the command is a program step.

A sleep time between H'0001' and H'FEFF' (1 to 65.279min) starts the sleep timer for that time and program steps will not be executed during that time.

A sleep time of H'FFFF' puts the sensor into manual mode. Program steps will not be executed anymore and local control is disabled.

A value of zero for the sleep time cancels the manual mode or sleep timer.

#### 'Switch to safe temperature mode' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = Module address

RTR = 0

DLC3...DLC0 = 3 databytes received

DATABYTE1 = COMMAND\_SWITCH\_TO\_SAFE\_MODE (H'DE')

DATABYTE7 = High byte of the sleep time

DATABYTE8 = Low byte of the sleep time into minutes

#### Remark:

If the sleep time contains H'FF00', the command is a program step.

A sleep time between H'0001' and H'FEFF' (1 to 65.279min) starts the sleep timer for that time and program steps will not be executed during that time.

A sleep time of H'FFFF' puts the sensor into manual mode. Program steps will not be executed anymore and local control is disabled.

A value of zero for the sleep time cancels the manual mode or sleep timer.

#### 'Program availability' command received:

SID10-SID9 = 11 (lowest priority)

SID8...SID1 = H'00'

RTR = 0

DLC3...DLC0 = 4 databytes to send

DATABYTE1 = COMMAND\_SENSOR\_PROGRAM\_AVAILABILITY (H'BC')

DATABYTE2 = Program availabitlity (0 = no program; 1 = program available)

DATABYTE3 = Program type

Contents	Day			
032	Sensor program			
33	All rooms program			
34	Zone 1 program			
35	Zone 2 program			
36	Zone 3 program			
37	Zone 4 program			
38	Zone 5 program			
39	Zone 6 program			
40	Zone 7 program			
40255	Not valid			

DATABYTE4 = Sensor address

#### Remark:

This command will be received every time a program step is added, modified or deleted by the temperature controller VMB1TC.

## Memory map Build 0927 or 0947:

Address	Contents	Addres	Contents
		s	
H'0000'	Push button module address	H'0001'	Comfort mode push button 1 bit numbers
H'0018'	Push button module address	H'0019'	Comfort mode push button 13 bit numbers
H'001A'	Push button module address	H'001B'	Day mode push button 1 bit numbers
H'0032'	Push button module address	H'0033'	Day mode push button 13 bit numbers
H'0034'	Push button module address	H'0035'	Night mode push button 1 bit numbers
H'004C'	Push button module address	H'004D'	Night mode push button 13 bit numbers
H'004E'	Push button module address	H'004F'	Safe mode push button 1 bit numbers
H'0066'	Push button module address	H'0067'	Safe mode push button 13 bit numbers
H'0068'	Push button module address	H'0069'	Heating mode push button 1 bit numbers
H'0080'	Push button module address	H'0081'	Heating mode push button 13 bit numbers
H'0082'	Push button module address	H'0083'	Cooling mode push button 1 bit numbers
H'009A'	Push button module address	H'009B'	Cooling mode push button 13 bit numbers
H'009C'	Push button module address	H'009D'	Lock local control push button 1 bit numbers
H'00B4'	Push button module address	H'00B5'	Lock local control push button 13 bit numbers
H'00B6'	Push button module address	H'00B7'	Unlock local control push button 1 bit numbers
H'00CE'	Push button module address	H'00CF'	Unlock local control push button 13 bit numbers
H'00D0'	Not used	H'00D1'	Not used
H'00D8'	Not used	H'00D9'	Differential sensor address
H'00DA'	Calibration factor	H'00DB'	Lower temperature range cool mode
H'00DC'	Upper temp range heat mode	H'00DD'	Sensor zone number
H'00DE'	Low temperature alarm	H'00DF'	High temperature alarm
H'00E0'	Current program mode	H'00E1'	Current mode
H'00E2'	Current temperature set	H'00E3'	Comfort temp set for heating
H'00E4'	Day temp set for heating	H'00E5'	Night temp set for heating
H'00E6'	Safe temp set for heating	H'00E7'	Temp. difference for boost output or diff. sensor
H'00E8'	Hysteresis	H'00E9'	Comfort temp set for cooling
H'00EA'	Day temp set for cooling	H'00EB'	Night temp set for cooling
H'00EC'	Safe temp set for cooling	H'00ED'	Default sleep time high byte
H'00EE'	Default sleep time low byte	H'00EF'	Auto send time interval
H'00F0'	Sensor name character 1	H'00F1'	Sensor name character 2
H'00FE'	Sensor name character 15	H'00FF'	Sensor name character 16

### Remark:

Unused locations in the push button location contain H'FF'. Unused characters for the sensor name contain H'FF'.

## Memory map Build 0949 or Build 1001:

Address	Contents	Addres s	Contents
H'0000'	Push button module address	H'0001'	Comfort mode push button 1 bit numbers
H'0012'	Push button module address	H'0013'	Comfort mode push button 10 bit numbers
H'0014'	Push button module address	H'0015'	Day mode push button 1 bit numbers
H'0026'	Push button module address	H'0027'	Day mode push button 10 bit numbers
H'0028'	Push button module address	H'0029'	Night mode push button 1 bit numbers
H'003A'	Push button module address	H'003B'	Night mode push button 10 bit numbers
H'003C'	Push button module address	H'003D'	Safe mode push button 1 bit numbers
H'004E'	Push button module address	H'004F'	Safe mode push button 10 bit numbers
H'0050'	Push button module address	H'0051'	Heating mode push button 1 bit numbers
H'0062'	Push button module address	H'0063'	Heating mode push button 10 bit numbers
H'0064'	Push button module address	H'0065'	Cooling mode push button 1 bit numbers
H'0076'	Push button module address	H'0077'	Cooling mode push button 10 bit numbers
H'0078'	Push button module address	H'0079'	Lock local control push button 1 bit numbers
H'008A'	Push button module address	H'008B'	Lock local control push button 10 bit numbers
H'008C'	Push button module address	H'008D'	Unlock local control push button 1 bit numbers
H'009E'	Push button module address	H'009F'	Unlock local control push button 10 bit numbers
H'00A0'	Push button module address	H'00A1'	Normal open disable switch 1 bit numbers
H'00B2'	Push button module address	H'00B3'	Normal open disable switch 10 bit numbers
H'00B4'	Push button module address	H'00B5'	Normal closed disable switch 1 bit numbers
H'00C6'	Push button module address	H'00C7'	Normal closed disable switch 10 bit numbers
H'00C8'	Not used	H'00C9'	Not used
H'00D6'	Not used	H'00D7'	Not used
H'00D8'	Min switching time	H'00D9'	Differential sensor address
H'00DA'	Calibration factor	H'00DB'	Lower temperature range cool mode
H'00DC'	Upper temp range heat mode	H'00DD'	Sensor zone number
H'00DE'	Low temperature alarm	H'00DF'	High temperature alarm
H'00E0'	Current program mode	H'00E1'	Current mode
H'00E2'	Current temperature set	H'00E3'	Comfort temp set for heating
H'00E4'	Day temp set for heating	H'00E5'	Night temp set for heating
H'00E6'	Safe temp set for heating	H'00E7'	Temp. difference for boost output or diff. sensor
H'00E8'	Hysteresis	H'00E9'	Comfort temp set for cooling
H'00EA'	Day temp set for cooling	H'00EB'	Night temp set for cooling
H'00EC'	Safe temp set for cooling	H'00ED'	Default sleep time high byte
H'00EE'	Default sleep time low byte	H'00EF'	Auto send time interval
H'00F0'	Sensor name character 1	H'00F1'	Sensor name character 2
H'00FE'	Sensor name character 15	H'00FF'	Sensor name character 16

## Memory map Build 1233 & 1234:

Address	Contents	Addres	Contents
H'0000'	Push button module address	<b>s</b> H'0001'	Comfort mode push button 1 bit numbers
	r usii bulloii iiloudie address	110001	Cominit mode pash battorn i bit numbers
H'0012'	Push button module address	H'0013'	Comfort mode push button 10 bit numbers
H'0014'	Push button module address	H'0015'	Day mode push button 1 bit numbers
	1 don batton module address	110010	Buy mode puon button 1 bit numbers
H'0026'	Push button module address	H'0027'	Day mode push button 10 bit numbers
H'0028'	Push button module address	H'0029'	Night mode push button 1 bit numbers
H'003A'	Push button module address	H'003B'	Night mode push button 10 bit numbers
H'003C'	Push button module address	H'003D'	Safe mode push button 1 bit numbers
H'004E'	Push button module address	H'004F'	Safe mode push button 10 bit numbers
H'0050'	Push button module address	H'0051'	Heating mode push button 1 bit numbers
H'0062'	Push button module address	H'0063'	Heating mode push button 10 bit numbers
H'0064'	Push button module address	H'0065'	Cooling mode push button 1 bit numbers
H'0076'	Push button module address	H'0077'	Cooling mode push button 10 bit numbers
H'0078'	Push button module address	H'0079'	Lock local control push button 1 bit numbers
H'008A'	Push button module address	H'008B'	Lock local control push button 10 bit numbers
H'008C'	Push button module address	H'008D'	Unlock local control push button 1 bit numbers
H'009E'	Push button module address	H'009F'	Unlock local control push button 10 bit numbers
H'00A0'	Push button module address	H'00A1'	Normal open disable switch 1 bit numbers
H'00B2'	Push button module address	H'00B3'	Normal open disable switch 10 bit numbers
H'00B4'	Push button module address	H'00B5'	Normal closed disable switch 1 bit numbers
		•••	
H'00C6'	Push button module address	H'00C7'	Normal closed disable switch 10 bit numbers
H'00C8'	Not used	H'00C9'	Not used
H'00CA'	Not used	H'00CB'	Not used
H'00CC'	Zone address	H'00CD'	Module address
H'00CE'	Serial number high	H'00CF'	Serial number low
H'00D0'	Not used	H'00D1'	Not used
H'00D6'	Not used	H'00D7'	Not used
H'00D8'	Min switching time	H'00D9'	Differential sensor address
H'00DA'	Calibration factor	H'00DB'	Lower temperature range cool mode
H'00DC'	Upper temp range heat mode	H'00DD'	Sensor zone number
H'00DE'	Low temperature alarm	H'00DF'	High temperature alarm
H'00E0'	Current program mode	H'00E1'	Current mode
H'00E2'	Current temperature set	H'00E3'	Comfort temp set for heating
H'00E4'	Day temp set for heating	H'00E5'	Night temp set for heating
H'00E6'	Safe temp set for heating	H'00E7'	Temp. difference for boost output or diff. sensor
H'00E8'	Hysteresis	H'00E9'	Comfort temp set for cooling
H'00EA'	Day temp set for cooling	H'00EB'	Night temp set for cooling
H'00EC'	Safe temp set for cooling	H'00ED'	Default sleep time high byte
H'00EE'	Default sleep time low byte	H'00EF'	Auto send time interval
H'00F0'	Sensor name character 1	H'00F1'	Sensor name character 2
 L'00EE'	Concer name character 15		Conser name character 46
H'00FE'	Sensor name character 15	H'00FF'	Sensor name character 16

#### Remark:

Addresses 0xCC ... 0xCF are write protected

Unused locations in the push button location contain H'FF'. Unused characters for the sensor name contain H'FF'.

Differential sensor address:

Contains the address of the slave sensor to make a differential thermostat. The target temperature of the slave sensor follows the measured temperature of the current sensor plus or minus the value definied by the temperature difference for boost output.

The default is no differential thermostat (address set to H'FF').

Minimum switching time (Build 0949):

Contents	Operating mode			
00000000	No switching time protection			
00000001	1 minute switching time protection			
00000010	2 minute switching time protection			
11111110	254 minute switching time protection			
11111111	Default 1 minute switching time protection			

Current program mode:

Contents	Operating mode
xxxxxx0xx	No sensor program
xxxxx1xx	Sensor program available
xxx0xxx	No zone program
xxxx1xxx	Zone program available
0xxxxxxx	No all rooms program
1xxxxxxx	All rooms program available
x100xxxx	Comfort program step received
x010xxxx	Day program step received
x001xxxx	Night program step received
XXXX000X	Safe temperature program step received
xxxxxx1x	Enable unjamming heater valve
xxxxxxxx	Disable unjamming heater valve
xxxxxxx1	Enable unjamming pump
0xxxxxxx	Disable unjamming pump

#### Current mode:

Contents	Operating mode
xxxxxxx1	Mode push button locked
0xxxxxxx	Mode push button unlocked
xxxxx01x	Manual mode
xxxxx10x	Sleep timer mode
xxxxxx00x	Run mode
xxxx1xxx	Auto send sensor temperature enabled
xxxx0xxx	Auto send sensor temperature disabled
x100xxxx	Comfort mode
x010xxxx	Day mode
x001xxxx	Night mode
x000xxxx	Safe temp mode (anti frost)
1000xxxx	Cooler mode
0xxxxxxx	Heater mode

Current, comfort, day, night, safe, low alarm, high alarm, lower cool, upper heat temperature set (resolution 0.5°) (*Build 1001*):

Contents	Temperature set
01111000	60°C
00101000	20°C
00000010	1°C
0000001	0.5°C
00000000	0°C
11111111	-0.5°C
11000000	-32°C

Hysteresis (resolution 0.5°) (Build 0949):

Contents	Hysteresis
00011111	15.5°C
00000001	0.5°C
00000000	0°C

Temperature difference (resolution 0.5°):

Contents	Temperature difference
00010100	+10°C
00000001	+0.5°C
00000000	0°C
11111111	-0.5°C
11101100	-10°C

Calibration factor (resolution 0.5°):

Contents	Calibration factor
00001111	Calibration factor +7.5°C
00000001	Calibration factor +0.5°C
00000000	Calibration factor +0°C
11111111	Calibration factor -0.5°C
11110000	Calibration factor -8°C

Default sleep time into minutes: valid range H'0001' to H'FEFF' or 1min to 65.279min Auto send temperature time interval into seconds: valid range: 10...255s
1...9 = send if temperature is changed

0 = auto send disabled