

# Mitigating Peak Load and Heat Stress under Heat Waves by Scheduling Cooling and Energy Storage Systems

by

Zhujing Zhang

B.S., University of Michigan, Ann Arbor (2015)

Submitted to the Department of Architecture  
in partial fulfillment of the requirements for the degree of

Master of Science in Building Technology

at the

MASSACHUSETTS INSTITUTE OF TECHNOLOGY

September 2022

©2022 Massachusetts Institute of Technology  
All rights reserved.

Author .....  
Department of Architecture  
August 5, 2022

Certified by .....  
Leslie K. Norford  
Professor of Building Technology  
Thesis Supervisor

Accepted by .....  
Leslie K. Norford  
Chair, Department Committee on Graduate Students



# Mitigating Peak Load and Heat Stress under Heat Waves by Scheduling Cooling and Energy Storage Systems

by

Zhujing Zhang

Submitted to the Department of Architecture  
on August 5, 2022, in partial fulfillment of the  
requirements for the degree of  
Master of Science in Building Technology

## Abstract

As the climate changes, heat waves are becoming more frequent and severe. Exposure to heat waves could lead to heat stress. Heat waves intensify cooling demand and reduce air conditioner efficiencies. It causes peaks in electricity demand that pose operational challenges to the power grid. This thesis provides simulation-based methods to mitigate peak load and heat stress under heat waves by adjusting the schedules of the cooling and energy storage systems in buildings. This thesis demonstrates three scheduling methods: (1) cooling system scheduling, (2) energy storage system scheduling, and (3) combined cooling and energy storage system scheduling. The cooling system scheduling methods involve (1) generating baseline and training data with EnergyPlus (*EP*) simulations, (2) fitting surrogate models that relate cooling system adjustments to the perturbations in purchased power and Standard Effective Temperature (*SET\**, a comprehensive measure of thermal comfort, which is found to be a useful measurement of heat stress), and (3) embedding the *EP* data and trained models in an optimizer to schedule cooling system adjustments. The methods provide closely predicted optimized solutions with less computation cost than solving the problem by brute-force *EP* simulations. The energy storage system scheduling method relocates the power discharging from the energy storage system based on *EP* simulated baseline grid purchased power and its average value. The scheduling of the cooling and energy storage systems combines the two methods above. Case studies of these methods on a single building and a six-building neighborhood in the climate of Miami and Kuwait are offered. In these case studies, the methods reduce peak load significantly while maintaining *SET\** within comfortable ranges. Among the three methods, the combined scheduling of cooling and energy storage systems is able to reduce peak power the most.

Thesis Supervisor: Leslie K. Norford  
Title: Professor of Building Technology

## Acknowledgments

The past two years has been a joyful journey. First, I would like to thank my advisor Prof. Leslie Norford for the innumerable support and guidance he gave and also the great stories and jokes he told during our weekly meetings. It is always a pleasant experience working with him.

I am also super grateful for Dr. Kevin Kircher and Yuan Cai for offering their time to me and giving me so much technical support, especially on the linear regression models. I learned so much from them.

Next, I would also like to thank my research team members and people I know in the Building Technology program and MIT. Thanks to the DAR association for sponsoring me and providing great local knowledge of Kuwait. Thanks to Jonathon Brearley and David Birge for the inspirational conversations. Thanks to Eduardo Gascon Alvarez for introducing me pythermalcomfort. Thanks to the instructors and the TAs of the classes I took during these two years, it has widened my horizon and equipped me with great skills to solve challenging problems.

Finally, on a personal note,

Mingming and Meimei, meow.

à Yijiang, merci.

**Thesis Supervisor**

**Leslie K. Norford, PhD**

Professor of Building Technology



# Contents

<b>1</b>	<b>Introduction</b>	<b>17</b>
<b>2</b>	<b>Methods</b>	<b>21</b>
2.1	Cooling Systems Scheduling . . . . .	21
2.1.1	Data Generation . . . . .	22
2.1.2	Linear Regression Model Training . . . . .	23
2.1.3	Optimization and Scheduling . . . . .	25
2.2	Energy Storage System Scheduling . . . . .	26
2.2.1	Modeling, Sizing and Data Generation . . . . .	27
2.2.2	Scheduling . . . . .	28
2.2.3	Cost Analysis . . . . .	30
2.3	Cooling and Energy Storage Systems Scheduling . . . . .	32
2.3.1	Part 1: Data Generation . . . . .	33
2.3.2	Part 1: Neural Network Model Training . . . . .	34
2.3.3	Part 1:Scheduling and Optimizing Cooling Systems . . . . .	34
2.3.4	Part 2: Scheduling Energy Storage System . . . . .	35
2.3.5	Minimizing the Peak Purchased Power during Heat Waves and Maximizing Self-sufficient Hours after Grid Shutdown . . . . .	35
2.4	Linear Regression Model vs Neural Network Model . . . . .	36
2.5	Implementing Cooling Systems Scheduling in Real Building . . . . .	37
2.5.1	Baseline Model Learning for Real Building Implementation . .	39

<b>3 Miami Case Studies &amp; Results</b>	<b>43</b>
3.1 Miami Single Building and Six-Building Neighborhood Case Studies	
Setup . . . . .	43
3.2 Cooling System Scheduling Results . . . . .	47
3.2.1 Single Building Results . . . . .	47
3.2.2 Results with Wall R Value and Window U Value Variation . .	49
3.2.3 Six-Building Neighborhood Results . . . . .	52
3.3 Energy System Scheduling Results . . . . .	54
3.3.1 Single Building Results . . . . .	55
3.3.2 Six-Building Neighborhood Results . . . . .	57
3.4 Cooling and Energy Storage System Scheduling Results . . . . .	57
3.4.1 Single Building: Minimizing the Peak Grid Purchased Power during Heat Waves . . . . .	57
3.4.2 Single Building: Maximizing Self-sufficient Hours after Grid Shutdown . . . . .	59
<b>4 Kuwait Case Studies &amp; Results</b>	<b>71</b>
4.1 Kuwait Residential Case Studies Setup . . . . .	71
4.2 Cooling Systems Scheduling Results . . . . .	73
4.3 Energy Storage Scheduling Results . . . . .	76
4.4 Cooling and Energy Storage Systems Scheduling Results . . . . .	77
4.4.1 Minimizing the Peak Purchased Power during Heat waves . .	77
4.4.2 Maximizing Self-sufficient Hours after Grid Shutdown . . . .	82
<b>5 Discussion and Conclusion</b>	<b>85</b>
<b>A Cooling Systems Scheduling</b>	<b>89</b>
A.1 Baseline and Perturbation Data Generation . . . . .	89
A.2 Linear Regression Model Training . . . . .	96
A.3 CVX Optimization and Cooling Systems Scheduling . . . . .	104

<b>B Energy Storage System Scheduling</b>	<b>129</b>
B.1 Data Generation . . . . .	129
B.2 Energy Storage System Scheduling . . . . .	135
<b>C Cooling and Energy Storage Systems Scheduling</b>	<b>143</b>
C.1 Training Data Generation . . . . .	143
C.2 Neural Network Model Training . . . . .	153
C.3 Optimization . . . . .	157
<b>D Example IDF Files</b>	<b>169</b>
D.1 MIAMIPNNL idf . . . . .	169
D.2 MIAMIPNNLB5PV90opt idf . . . . .	352
D.3 Kuwait Residential idf . . . . .	516



# List of Figures

2-1	Workflow: cooling systems scheduling . . . . .	22
2-2	Surrogate model training . . . . .	25
2-3	PV and Battery Power Outline . . . . .	26
2-4	Power composition . . . . .	27
2-5	Battery discharge scheduling workflow . . . . .	29
2-6	Workflow: machine learning and optimization . . . . .	33
2-7	Workflow: implementing cooling systems scheduling in real building .	38
3-1	Miami case study outside dry bulb temperature . . . . .	44
3-2	Miami case study baseline conditions . . . . .	45
3-3	Miami case study models . . . . .	45
3-4	Miami single-building case study cooling system scheduling multi-objective sampling . . . . .	47
3-5	Miami single-building case study hourly demand power and $SET^*$ after cooling system scheduling . . . . .	48
3-6	Miami single-building case study cooling system scheduling . . . . .	49
3-7	Miami single building case study multi-objective sampling (moo) and optimization score ( $score_{opt}$ ) with wall R-value from 1.9 to 3.4 $m^2K/W$	50
3-8	Miami single building case study multi-objective sampling (moo) and optimization score ( $score_{opt}$ ) with window U-value from 1.1 to 4.5 $W/m^2K$	51
3-9	Miami six-building neighborhood case study aggregated demand power and average $SET^*$ . . . . .	52

3-10 Miami six-building neighborhood case study individual demand power and <i>SET</i> * . . . . .	53
3-11 Miami six-building neighborhood case study cooling system scheduling . . . . .	54
3-12 Miami single building case study electricity unit cost in short term and long term for PV and battery in various capacities . . . . .	55
3-13 Miami single building case study net purchased power before and after installing PV and battery . . . . .	56
3-14 Miami single building case study net purchased power, purchased power and battery discharge power before and after applying the energy storage system scheduling method . . . . .	60
3-15 Miami single building case study net purchased power after discharge scheduling for PV and battery in various capacities . . . . .	61
3-16 Miami single building case study eak purchased power reduction before and after battery discharge scheduling for PV and battery in various capacities . . . . .	62
3-17 Miami six-building neighborhood case study net purchased power and purchased power before and after applying the energy storage system scheduling methods . . . . .	63
3-18 Miami six-building neighborhood case study individual discharge power before and after energy storage system scheduling method . . . . .	64
3-19 Peak Load Reduction, Miami single building case study cooling and energy storage systems scheduling, step1:cooling system scheduling . .	65
3-20 Peak Load Reduction, Miami single building case study net purchased power, purchased power and <i>SET</i> * after step1: cooling system scheduling . . . . .	66
3-21 Peak Load Reduction, Miami single building case study cooling and energy storage systems scheduling, step2: energy storage system scheduling . . . . .	67
3-22 Self Sufficient Hours with PV and battery . . . . .	68
3-23 Self-sufficient hours maximization, Miami single building case study cooling and energy storage systems scheduling, step1: cooling system scheduling . . . . .	68

3-24 Self-sufficient hours maximization, Miami single building case study net purchased power, purchased power and $SET^*$ after cooling system scheduling . . . . .	69
4-1 Kuwait residential case study building model . . . . .	71
4-2 Kuwait case study outside dry bulb temperature . . . . .	72
4-3 Kuwait residential case study baseline condition . . . . .	73
4-4 Kuwait residential case study demand power and $SET^*$ after cooling system scheduling . . . . .	74
4-5 Kuwait residential case study cooling system scheduling . . . . .	75
4-6 Kuwait residential building power composition . . . . .	76
4-7 net purchased power . . . . .	77
4-8 Kuwait residential case study net purchased power before and after installing PV and battery . . . . .	77
4-9 Kuwait residential case study net purchased power, purchased power and battery discharge power before and after applying the energy storage system scheduling method . . . . .	78
4-10 Peak Load Reduction, Kuwait residential case study cooling and energy storage systems scheduling, step1:cooling system scheduling . . . . .	79
4-11 Peak Load Reduction, Kuwait residential case study net purchased power, purchased power and $SET^*$ after step1: cooling system scheduling . . . . .	80
4-12 Peak Load Reduction, Kuwait residential case study cooling and energy storage systems scheduling, step2: energy storage system scheduling . . . . .	81
4-13 Self-sufficient hours maximization, Kuwait residential case study cooling and energy storage systems scheduling, step1: cooling system scheduling . . . . .	82
4-14 Self-sufficient hours maximization, Kuwait residential case study net purchased power, purchased power and $SET^*$ after cooling system scheduling . . . . .	84



# List of Tables

2.1	Cost in short to long terms . . . . .	30
2.2	Surrogate models MSE comparisons . . . . .	37
2.3	Surrogate models prediction time comparisons . . . . .	37
3.1	Miami single building case study peak power and $SET^*$ under various scheduling methods . . . . .	58
4.1	Kuwait residential case study peak power and $SET^*$ under various scheduling methods . . . . .	82



# Chapter 1

## Introduction

Heat waves are extended periods of high temperature that affect lifestyle and lead to health consequences [65]. Under the trend of climate change and global warming, heat waves will become longer, more frequent, and stronger [12]. It is found that exposure to heat waves could lead to heat stress [46]. In quantifying heat stress, degree of thermal discomfort is shown to be useful measurement of heat stress [55]. Intensified heat stress would increase health risks[13], such as cardiovascular mortality and respiratory illnesses[61] or even cause heat-related deaths [44].

Research has shown for the indoor environment, under heat waves, the presence of air conditioning would significantly reduce the mortality rate [60] [70]. However, as the outdoor temperature rises, the increased energy consumption due to efficiency degradation of the air conditioner and growing demand would increase peak load, which poses great challenges to the grid and could even possibly lead to grid shutdown and power outage [7] [78]. Under heat waves the peak electric demand [79] and the reliability of the grid [71] have become particular problems. To respond to the peak load, extending the existing capacity or building new power plants is a conventional approach, which is costly and practically not efficient considering the small percentage of time peak load occurs in the time span of general usage [57]. The power loss during transmission is in a nonlinear relationship between the current; during the peak load, an increase of the supplied current would result in less efficiency in power transmission [64].

Studies on building adaptation have developed strategies to mitigate the impacts of heat waves. In particular, Porritt et al. [63] ranks building-level interventions for reducing overheating under heat waves. Simson et al. [67] identifies intervention guidance for building parameters, including orientation, window-to-wall ratios, and overhang dimensions that prevent summer overheating. In addition, published papers [22] [18], show that thermal mass of a building enables reductions in the peak air conditioning load. Given weather variability, the case study in [45] shows that a highly efficient building envelope not only leads to greater peak demand reduction but also improves thermal comfort. Although building adaptations show benefits in mitigating the impacts of heat waves, the cost and time associated with the construction are a factor that can not be neglected.

As an alternative to building renovations, optimizing the operation of air conditioning systems can reduce peak load [20] [41]. Scheduling, a form of energy management, can reduce renovation costs and efforts, but generally requires some investment in sensing, communication, and controls. Corbin et al. [23] describe a model predictive control method that generates hourly cooling setpoints to minimize the daily energy cost of a commercial building. Price-based energy management can reduce peak load [75] [69]. However, these approaches often under-emphasizes the thermal comfort of building occupants, a critical metric under heat waves.

As a complement to air-conditioning, ceiling-mounted or other fans can improve energy efficiency [77] by providing more comfortable air movement to occupants [31] [35][10]. The study of [39] optimizes ceiling fan airspeed to enhance thermal comfort and reduce electricity cost. At a group level, a coordinated optimization on a system of fans is able to incorporate the thermal comfort of multiple occupants in one room [53].

However, there is limited research on jointly optimizing the control of air conditioners and fans to mitigate both peak load and heat stress. In [54], Luo et al. evaluate thermal comfort under various constant room temperatures with different fan operating modes and find that a higher setpoint with fan-assisted cooling can achieve similar thermal comfort to a lower setpoint. In [68], Taylor et al. run large

iterations of EnergyPlus simulations to find optimal air conditioner and fan schedules that reduce total energy usage and ensure thermal comfort. Although the studies of Luo et al.[54] and Taylor et al. [68] considered both the air conditioner and fan, Luo et al. [54] only presents analytical results under defined constant settings without means for adjustment, and the optimization strategy by Taylor et al. [68] is limited by extensive computing required by EnergyPlus simulations. Moreover, in neither of the studies is peak load considered, which is critical under heat waves.

This thesis proposes simulation-based methods to jointly optimize the air conditioner and fan schedules that mitigate peak load and heat stress under heat waves in Section 2.1. In addition, the sustainable energy generated by the photovoltaic (PV) systems and stored by smart home batteries (SHB) is found to be effective in reducing peak load [5][34]. Extreme hot days generally are associated with extensive solar energy, which are able to be converted to electric energy by PV systems[48]. The SHB is capable of charging and discharging electric energy in a programmable way [9] [6]. In Section 2.2, strategies of scheduling the discharge of the energy storage system are presented. A combined scheduling of the air conditioner, fan, and battery are demonstrated in Section 2.3.

In the demonstration of the proposed strategies, this thesis uses the Standard Effective Temperature ( $SET^*$ ), one of the comprehensive measures of thermal comfort that describes the feels like temperature [32] [11], as the measurement of thermal comfort. Data are obtained from simulation with a commonly used physics-based building energy simulation tool, EnergyPlus (*EP*) [2]. This study involves energy storage and cooling systems scheduling. The discharge power from the energy storage systems corresponds well with the discharge scheduling. The efficiency associated with converting battery discharge power to demand supporting power through the inverter fluctuates in a quite small range around 5%. As for the cooling systems, special attention needs to be paid to the efficiency due to its variation under the change of the outside temperature. Optimizing the cooling schedules by brute-force running the physics-based simulation would lead to large computational efforts and possibilities for the optimizer to become stuck at local minima in this high-dimensional problem.

This thesis fits two types of surrogate models, a linear regression model, proposed by Kircher et al. [43] and a neural network model, to replace the physics-based simulation during the optimization. In data generation, a python based package, eppy [3] is used to parametrically modify the schedules of the systems and generate perturbation data for the surrogate training. In optimization, for the linear regression model, a convex optimization package CVXpy [25] is used to solve the optimization problems; for the neural network model, a SciPy minimize optimizer with Sequential Least Squares Programming is used. This thesis demonstrate three scheduling methods: 1) cooling systems scheduling, 2) energy storage system scheduling, and 3) cooling and energy storage systems scheduling. Detailed explanation of the methods will be shown in Section 2.1, Section 2.2, and Section 2.3.

The proposed methods are demonstrated through case studies of a single building and a six-building neighborhood in Miami and Kuwait during a heat wave. Section 3.1 and Section 4.1 demonstrate the case studies set up in Miami and Kuwait. The cooling system scheduling results are shown in Section 3.2 and Section 4.2; the energy storage systems scheduling results are presented in Section 3.3 and Section 4.3; the results for applying cooling and energy storage system scheduling are demonstrated in Section 3.4 and Section 4.4. The case studies show that by jointly scheduling cooling and energy storage systems, the proposed methods are able to achieve most peak load reduction while maintaining thermal comfort within a comfortable range.

# Chapter 2

## Methods

This chapter proposes three methods: cooling systems scheduling, energy storage system scheduling, and cooling + energy storage system scheduling. They will be demonstrated in details in Section 2.1, Section 2.2 and Section 2.3.

### 2.1 Cooling Systems Scheduling

The methods include three phases: data generation (Section 2.1.1), surrogate model training (Section 2.1.2), and optimization (Section 2.1.3). Figure 2-7 demonstrates the workflow of the proposed methodology. The generated data is simulated by a physics-based building energy simulation tool, EnergyPlus (*EP*) [2]. A python-based package, eppy [3], is used to parametrically modify the schedules in the *EP* file and generate perturbed target values with simulation. The data consists of the perturbation of the schedules and the perturbation of the target values. Two types of surrogate models, linear regression models proposed by Kircher et al. [43] and a neural network model, are implemented as a surrogate for *EP* in this proposed framework for different test cases, and they are trained with generated data. To solve the optimization problem with two different surrogate models, two types of optimizers are adopted. The CVXPY package [25] is used to solve the optimization problem with a linear regression model. Example code of the cooling systems scheduling python workflow is provided in Appendix A.




Figure 2-1: Workflow: cooling systems scheduling

### 2.1.1 Data Generation

In the first step, a baseline *EP* model is set up. This thesis uses the single-family prototype model in the ASHRAE 1A climate zone (very hot-humid) published by the Building Energy Codes Program [1] as the baseline. The baseline setpoint keeps is set as 23.9 °C for Miami case studies and 28 °C for Kuwait case studies. In addition to the air conditioning system, raising air speed by ceiling fans is an energy-efficient strategy that consumes less energy than the air conditioning system and [77] could benefit thermal comfort [10] [35]. The values of average air speed and power consumption of the ceiling fan refer to the data published by Liu et al. [52]. A baseline air speed of 0.35 m/s is implemented in this test with an average power consumption of 0.48 W/m<sup>2</sup>. An hourly baseline power  $\hat{P}(t)$  and Standard Effective Temperature  $\hat{SET}(t)$  is generated as the baseline target. Certain days are defined as simulation days. Under the heat wave context in this thesis, the hottest day and four weeks around the hottest day are simulated. Eppy [3] is used to parametrically modify the schedules of cooling systems. The perturbation range for temperature setpoint is ±3 °C and for air speed is ±0.35 m/s. For the target perturbation, at time  $k$ , the perturbation of power is calculated as  $P(t) - \hat{P}(t)$ ; the perturbation of  $SET^*$  is calculated as  $SET(t) - \hat{SET}(t)$ . A defined set of randomly generated perturbations

of the setpoint and air speed is used to simulate the perturbation of power and  $SET^*$ .

### 2.1.2 Linear Regression Model Training

In the second step, perturbation data, which includes the perturbation of temperature setpoint and air speed for input and the perturbation of power and  $SET^*$  for output, is used to train a perturbation model. The first three weeks of the perturbation data are used for training the perturbation model; the last week is used for validating the prediction of the trained perturbation model. Given the perturbation of setpoint and air speed as an input, the surrogate model predicts the perturbation of power and  $SET^*$  as output. This thesis implements the linear regression proposed by Kircher et al. [43] as the surrogate. Equation (2.1) is a standard form of linear regression, in which  $y$  is the output target vector,  $X$  is the input feature matrix,  $a$  is the coefficient vector, and  $e$  is the error vector. The coefficient vector  $a$  is fit by least squares as shown in equation (2.2):

$$y = Xa + e. \quad (2.1)$$

$$a = (X^T X)^{-1} X^T y. \quad (2.2)$$

Consider the power perturbation models with only setpoint perturbation as an example. The perturbation of power is restricted to be linear in the setpoint perturbations:

$$\delta_P(t) = a_1 \delta_T(t) + \cdots + a_m \delta_T(t - m + 1) + e_t. \quad (2.3)$$

In equation (2.3),  $m$  is a tunable memory parameter,  $\delta_P(t)$  and  $\delta_T(t)$  are power and temperature perturbations,  $e_t$  is the error at time  $t$ , and the parameter vector  $a$  is fit by least squares. In the standard linear regression form,  $y = Xa + e$ , the power perturbation can be written as

$$\begin{bmatrix} \delta_P(1) \\ \vdots \\ \delta_P(m) \\ \vdots \\ \delta_P(t) \end{bmatrix} = \begin{bmatrix} \delta_T(1) & & & & \\ \vdots & \ddots & & & \\ \delta_T(m) & \dots & \delta_T(1) & & \\ \vdots & & & \ddots & \\ \delta_T(t) & \dots & \delta_T(t-m+1) & & \end{bmatrix} \begin{bmatrix} a_1 \\ \vdots \\ a_m \\ \vdots \\ a_{t-m} \end{bmatrix} + \begin{bmatrix} e_1 \\ \vdots \\ e_m \\ \vdots \\ e_k \end{bmatrix}. \quad (2.4)$$

The coefficient vector  $a$  can be identified by least-squares estimation:  $a = (X^T X)^{-1} X^T y$ .


In implementation of this thesis' proposed method, two perturbation models are trained in equations (2.5) and (2.6), where perturbations of power  $\delta_P(t)$  and perturbation of  $SET^*$   $\delta_{SET}(t)$  are restricted to be linear in the setpoint perturbation  $\delta_T(t)$  and air speed perturbations  $\delta_{Airspeed}(t)$ .

$$\begin{bmatrix} \delta_P(1) \\ \vdots \\ \delta_P(m) \\ \vdots \\ \delta_P(k) \end{bmatrix} = \begin{bmatrix} \delta_T(1) & & \delta_{Air}(1) & & \\ \vdots & \ddots & \vdots & \ddots & \\ \delta_T(m) & \dots & \delta_T(1) & \delta_{Air}(m) & \dots & \delta_{Air}(1) \\ \vdots & \ddots & \vdots & \vdots & \ddots & \vdots \\ \delta_T(k) & \dots & \delta_T(t-m+1) & \delta_{Air}(t) & \dots & \delta_{Air}(t-m+1) \end{bmatrix} \begin{bmatrix} a_1 \\ \vdots \\ a_m \\ a_{m+1} \\ \vdots \\ a_{2m} \end{bmatrix} + \begin{bmatrix} e_{1_P} \\ \vdots \\ e_{m_P} \\ \vdots \\ e_{t_P} \end{bmatrix} \quad (2.5)$$


$$\begin{bmatrix} \delta_{SET}(1) \\ \vdots \\ \delta_{SET}(m) \\ \vdots \\ \delta_{SET}(k) \end{bmatrix} = \begin{bmatrix} \delta_T(1) & & \delta_{Air}(1) & & \\ \vdots & \ddots & \vdots & \ddots & \\ \delta_T(m) & \dots & \delta_T(1) & \delta_{Air}(m) & \dots & \delta_{Air}(1) \\ \vdots & \ddots & \vdots & \vdots & \ddots & \vdots \\ \delta_T(t) & \dots & \delta_T(t-m+1) & \delta_{Air}(t) & \dots & \delta_{Air}(t-m+1) \end{bmatrix} \begin{bmatrix} b_1 \\ \vdots \\ b_m \\ b_{m+1} \\ \vdots \\ b_{2m} \end{bmatrix} + \begin{bmatrix} e_{1_{SET}} \\ \vdots \\ e_{m_{SET}} \\ \vdots \\ e_{t_{SET}} \end{bmatrix} \quad (2.6)$$

The power perturbation model's RMSE convergence over the manually tuned memory number  $m$  is shown in Figure 2-2a. Figure 2-2b shows a comparison of the power prediction from the trained perturbation model (in dotted blue line) with the

power consumption data from the test data (in solid blue line) over 96 hours.



(a) RMSE for training electrical power surrogate model



(b) prediction with electrical power surrogate model

Figure 2-2: Surrogate model training

### 2.1.3 Optimization and Scheduling

In the third step, the baseline  $\hat{P}(k)$  and  $\hat{SET}(k)$  and the trained power and  $SET^*$  perturbation models (2.5) and (2.6) are fed into the load-shifting optimization. The goal of the optimization is to determine setpoint and air speed perturbations that minimize the weighted sum of the peak power and  $SET^*$  over a day. The objective goal can be written as a weighted sum function,

$$P_{weight} \cdot \max(P_{base} + \delta_P) + S_{weight} \cdot \max(SET_{base} + \delta_{SET}), \quad (2.7)$$

where  $P_{weight}$  and  $S_{weight}$  are assigned weights of peak power reduction and  $SET^*$  reduction in the optimization goal. Since the proposed methods use a linear regression model as the surrogate, a convex solver, CVXPY [25], can be applied to solve the optimization problems. The surrogate and optimizer choices in the proposed methods result in very low computation cost in solving such multi-objective, high-dimension optimization problems. These choices also guarantee that the optimization problems can be solved to global optimality.

## 2.2 Energy Storage System Scheduling




Figure 2-3: PV and Battery Power Outline

This section proposes a method to reduce the peak power purchased from the grid under heat waves by implementing and scheduling an energy storage system. Photovoltaic panels (PV) and battery provide and store sustainable energy. Studies have found PV and energy storage system effective for releasing the grid pressure in regions where solar power is resourceful [5]. Figure 2-3 shows the outline of power flow with PV and energy storage system. The demand is satisfied by PV-produced power, battery discharge power and the grid purchased power. The supply of the three power sources is coordinated by the storage operation center with specified operation schemes. As for the PV-produced power, in addition to supporting the demand, the remainder of the PV-produced power flows into battery storage and the grid. Figure 2-4 presents the composition of different types of power during a day in a building with an installed PV and energy storage system. Example code of the energy storage

system scheduling python workflow is provided in Appendix B.




Figure 2-4: Power composition

### 2.2.1 Modeling, Sizing and Data Generation

This thesis implements the "simple PhotovoltaicPerformance" object as PV and the "LiIonNMCBattery" as a battery for the residential *EP* model. The sizing of the PV is specified with the percentage of the coverage of the roof area. The battery is sized with a number of parallel strings of battery [26]. The capacity of the PV (kWp/MWh) is the peak PV produced power in kWp, normalized by the annual demand in MWh. The capacity of the battery (kWh/MWh) is the amount of energy able to be stored in the battery in kWh normalized by the annual demand in MWh. The distribution of the PV and battery energy is coordinated with an EP object named "Electric Distribution Center: Distribution". The default operation scheme of the distribution

center is called "TrackFacilityElectricDemandStoreExcessOnSite", which prioritizes meeting the demand when distributing the PV and battery power. The output under this setting is used as the baseline for this study. Different from the previous sections, demand is considered equivalent to peak load; since PV and battery are implemented in this section, the peak load is the peak power purchased from the grid. The excess PV power fed back to the grid is output as a negative value in the net purchased power.

$$P_{Buy} = P_{Demand} - P_{Battery \ discharge} - P_{PV} \quad (2.8)$$

To schedule an energy storage system, an operation scheme named "TrackChargeDischargeSchedules" is implemented. It takes a charge, discharge schedule *designstoragecontrolchargepower* and *designstoragecontroldischargepower* as inputs. The charge and discharge schedules are fractions in the range of 0 to 1. The *designstoragecontrolchargepower* and *designstoragecontroldischargepower* are the maximum power under schedule value 1. The hourly charge and discharge power are presented in equation 2.9 and equation 2.10.

$$P_{Charge}(t) = Charge\ Schedule\ Value(t) \times Design\ Storage\ Control\ Charge\ Power \quad (2.9)$$

$$P_{Discharge}(t) = Discharge\ Schedule\ Value(t) \times Design\ Storage\ Control\ Discharge\ Power \quad (2.10)$$

### 2.2.2 Scheduling

In this section, a method of scheduling the energy storage system is demonstrated for reducing the peak purchased power. Figure 2-5 shows an outline of the workflow. First, the number of self-sufficient hours is identified. As defined in equation 2.11,




Figure 2-5: Battery discharge scheduling workflow

self-sufficient hours in this thesis are times where PV produced power is equal to or more than the demand power plus the power for charging the battery. During this time, the building does not need battery discharging or grid purchased power to satisfy the demand. Self-sufficient hours are concentrated in the middle of the day when solar energy is abundant. In the case studies, the start and end of the self-sufficient hours are marked as vertical dotted lines. Since during the self-sufficient hours PV produced power is sufficient to support the building demand, these hours are not considered in the energy system scheduling.

$$P(t)_{PV} \geq P(t)_{Battery\ Charge} + P(t)_{Demand} \quad (2.11)$$

To reduce the peak of the purchased power, the next step is to reschedule the discharging of the battery so that the curve of the purchased power could be flattened. An average of the baseline purchased power is calculated in equation 2.12, where  $t$  are hours that are not included in the PV self-sufficient hours.

$$P_{buy\ average} = \frac{\sum_{t=0}^{24} P_{buy}(t)}{24 - \text{self sufficient hours}} \quad (2.12)$$

A difference of each hour's purchased power compared to the average purchased power is taken with equation 2.13. The  $\Delta P(t)_{discharge}$  would be positive if the purchased power is larger than the average value, and would be negative if the purchased power is smaller than the average value.

$$\Delta P(t)_{discharge} = P(t)_{buy} - P_{buy\ average} \quad (2.13)$$

As shown in equation 2.14, to convert the  $\Delta P(t)_{\text{discharge}}$  to  $\Delta \text{Discharge Schedule}$ , the  $\Delta P(t)_{\text{discharge}}$  is then divided by the value of design storage control discharge power specified in the *EP* model. This schedule fraction difference is added to the baseline discharge schedule value to get a new schedule for reducing the peak purchased power. The new discharge schedule would be applied to the *EP* model to generate a new output of purchased power.

$$\begin{aligned} \text{New Discharge Schedule Value}(t) = & \text{Baseline Discharge Schedule Value}(t) + \\ & \frac{\Delta P(t)_{\text{discharge}}}{\text{Storage Control Discharge Power}} \end{aligned} \quad (2.14)$$

### 2.2.3 Cost Analysis

A cost analysis of the PV and battery is conducted in this section. It considers the investment of the systems, installation, and maintenance, and income from grid feed-in. The unit cost of electricity in the short term to the long term is estimated. The calculation of the costs refers to the equation in the thesis by Weniger et al. on sizing the residential PV battery system [73]. Certain assumptions are made in this cost calculation, based on these assumptions, the unit cost of the electricity of various PV and battery capacities in the short and long terms is calculated in the steps below.

The short-term to long-term investment costs for PV and battery systems and the feed-in tariff refer to the data published in [72].

	5years	10years	15years	20years
PV system costs (\$/kWp)	1800	1500	1200	1000
Battery system costs (\$/kWh)	3000	1500	1000	600
Feed in tariff (\$/ kWh)	0.15	0.11	0.06	0.02

Table 2.1: Cost in short to long terms

For the investment in PV and battery, the annuity factor is considered and it is calculated as in equation 2.15. The interest rate of 4% is referred from the value published in paper [72]. The number of years for short term and long term ranges from 5 to 20 years.

$$Annuity = \frac{Interest\ rate}{1 - (1 + Interest\ rate)^{-number\ of\ years}} \quad (2.15)$$

The PV cost is calculated as in equation 2.16, where  $P_{PV\ peak}$  is the peak power, in kWp, the PV is able to produce. The operation cost is assumed to be 1.5 % of the cost of PV.

$$Investment_{PV} = Cost_{PV} \times P_{PV\ peak} \times (Annuity + Operation\ cost) \quad (2.16)$$

The battery cost is calculated as equation 2.17, where the  $P_{Battery\ capacity}$  is the amount of energy that can be stored in the battery in kWh.

$$Investment_{Battery} = Cost_{Battery} \times P_{Battery\ capacity} \times (Annuity + Operation\ cost) \quad (2.17)$$

The income from feeding power to the grid is calculated in equation 2.18, where the  $Energy_{pv}$  refers to the annual energy produced by the PV panel in kWh. As shown in equation 2.19, the self-consumption rate is the sum of PV produced power for direct use and charging the battery divided by the total PV produced power.

$$Income_{feed\ in} = Feed\ in\ tariff \times Energy_{pv} \times (1 - Self\ consumption\ rate\%) \quad (2.18)$$

$$Self\ consumption\ rate\ \% = \frac{E_{Direct\ Use} + E_{Battery\ charge}}{E_{PV}} \quad (2.19)$$

The cost for purchased power from the grid is calculated in equation 2.20. The

unit price for energy is assumed to be 0.34 \$/KWh.

$$\begin{aligned} Cost_{purchased} = & Purchased\ power\ unit\ price \times \\ & E_{demand} \times (1 - \text{Degree of self sufficiency}) \end{aligned} \quad (2.20)$$

The degree of self-sufficiency is demonstrated in equation 2.21. When the demand is more than the PV-produced energy, the direct use energy equals PV produced energy; when PV-produced energy is less than the demand, the direct use energy equals the demand.

$$\text{Degree of self sufficiency} = \frac{E_{directuse} + E_{Battery\ discharge}}{E_{demand}} \quad (2.21)$$

In all, taking in account the investment for PV and battery, cost of grid purchased power and the income from grid feed-in, the final unit price of electricity in \$/KWh is calculated in equation 2.22

$$\begin{aligned} Final\ electricity\ unit\ price = & \\ \frac{Investment_{PV} + Investment_{Battery} + Cost_{Purchased} - Income_{Feed\ in}}{E_{Demand}} \end{aligned} \quad (2.22)$$

## 2.3 Cooling and Energy Storage Systems Scheduling

In this section, the schedules of the cooling systems and the battery are adjusted under heat waves. The methods are divided into two parts: cooling systems scheduling and energy storage system scheduling. The steps in the first part, cooling systems scheduling, include: part 1: (1) generating data including hourly setpoint, air speed, PV generated power, outside temperature, purchaseed power, and  $SET^*$ , in EP simulations, (2) fitting a deep neural network that relates cooling systems schedules, PV produced power and outside temperature to the hourly purchased power and  $SET^*$ , and (3) embedding the trained machine learning model in SciPy's minimize optimizer to schedule the cooling systems for the set optimization goal. Figure 2-6 presents an overview of the workflow for part 1. For part 2, energy storage scheduling, the meth-

ods demonstrated in section 2.2 are applied to flatten the peak of the purchased power under heat waves. The method is tested under two scenarios: minimizing the peak purchased power during heat waves and maximizing self-sufficient hours after grid shutdown. Example code of the cooling and energy storage systems scheduling python workflow is provided in Appendix C.




Figure 2-6: Workflow: machine learning and optimization

### 2.3.1 Part 1: Data Generation

The data are generated with EnergyPlus simulation. This study implements PV and battery systems in the same single-family prototype model mentioned in the previous sections. The baseline cooling systems schedule and perturbation range are kept the same as Section 2.1. Building on the improvement from energy discharge scheduling from the previous section, this section takes the battery discharge schedule from the previous section as the baseline. It is known from the previous section that during PV self-sufficient hours, there would be no need for discharge. Except for the PV

self-sufficient hours, the range for battery charge and discharge schedule variation is a fraction from 0 to 1.

The hottest day and four weeks around the hottest day are defined as simulation periods. The hourly setpoint, air speed, PV-generated power, and outside dry bulb temperature are generated as input data for the next step, neural network model training; the hourly purchased power and  $SET^*$  are produced as target data. Three-fourths of data are used as training data, in which 80% are used for training and 20% are used for validation. The remaining one-fourth of the data are used as test data.

### 2.3.2 Part 1: Neural Network Model Training

This study uses a fully connected deep neural network with TensorFlow's Sequential model[24]. A deep neural network structure with five layers, in which the top and bottom layers consist of ten neurons, the middle layers consists of 50 neurons, is set up for this project. *Relu* is used as the activation function for each layer; *Softmax* is used in the last layer. The dropout rate of 0.05 is applied in each layer. *BatchNormalization* is used to reduce the risk of overfitting.

In the training process, the learning rate of 0.1 is set. The callback function is set up to monitor the loss of the validation training results and restore the best result. An epoch of 200 is applied in the training of the neural network model.

### 2.3.3 Part 1:Scheduling and Optimizing Cooling Systems

The trained neural network model is fed into an optimizer into a SciPy minimize optimizer. The Sequential Least SQuares Programming (SLSQP)[47] is used as an optimization method to minimize the objective function with variable bounds.

Since after the first part cooling systems scheduling, the output would be passed to the second part, energy storage systems scheduling, which could flatten the profile of the purchased power to its average value. The objective for the cooling systems

scheduling can be written as,

$$score_{opt} = P_{weight} \cdot P_{buy\ sum} + SET_{weight} \cdot SET_{max} \quad (2.23)$$

$P_{weight}$  and  $SET_{weight}$  are weights assigned to the sum of the purchased power and maximum  $SET^*$ .

The variable to be optimized is the setpoint and air speed schedules. To smooth the perturbation of the optimized schedule, multi-control-point NURBS curves are applied to the setpoint and air speed schedules as initial values for the optimizer. After running the optimizer 100 times, the minimal optimization score calculated with function 2.23 is taken as the optimized result. The reduced sum of the purchased power would allow the second part, energy storage system scheduling, to achieve a lower peak purchased power.

### 2.3.4 Part 2: Scheduling Energy Storage System

After the cooling systems scheduling, this step takes the resulting purchased power profile as the baseline. The energy system scheduling methods demonstrated in Section 2.2 are repeated in this step to flatten the curve of the purchased power.

### 2.3.5 Minimizing the Peak Purchased Power during Heat Waves and Maximizing Self-sufficient Hours after Grid Shut-down

To mitigate grid stress during a heat wave, the goal is to minimize the peak purchased power. This study tries to achieve this goal by combining the adjustment of the cooling systems and the discharge of the battery.

In the scenario of a grid shut down after a major heat wave, the duration that the power from PV and battery can support the building demand is the self-sufficient hours. The goal of this study is to maximize the number of hours. The self-sufficient hours are composed of PV directly supported hours and energy storage supported

hours. The condition for identifying the PV self-sufficiency has been demonstrated in equation 2.11. The condition for energy system self-sufficiency can be described as:

$$E_{battery} \geq \sum_{t=0}^{24} P_{demand}(t) \quad (2.24)$$

## 2.4 Linear Regression Model vs Neural Network Model

In cooling systems scheduling, a linear regression model is utilized; in cooling and energy storage system scheduling, a neural network model is implemented. The selections of the two types of models are based on the characteristics of the training data. The cooling systems scheduling involves only the perturbation of the air conditioner and fan schedule, thus the linear regression model is used to train a perturbation model. In the cooling and energy storage system scheduling, in addition to the parameters of the cooling systems, the training data involves solar radiation and outdoor temperature, which are not perturbation adjustments to the building system, thus neural network model is implemented to include more types of the parameters. These two types of models have their own advantages and disadvantages. In general, neural network model obtains higher accuracy in prediction, however, the models are often complex. The linear regression model has more advantages in terms of ease of use but has lower accuracy [81].

Comparing the mean square error (MSE) and computing time of the two models implemented in this thesis, the results are shown in Table 2.2 and 2.3. If using only the cooling systems adjustments as input parameters to train the linear regression and neural network models, the highest MSE of the linear regression models is 0.96 and the MSE of the neural network model is 1.63. However, if the outside temperature is added to the input parameters to train the neural network model, the MSE improves significantly improved to 0.87. Computing time for making hourly predictions for one day from a 1000-day average, take the neural network model 3.2060 ms, and take the linear regression model only 0.0017ms. The neural network model with sufficient data could obtain higher accuracy than the linear regression model, but then it takes

a longer time for making predictions.

	<i>MSE</i>
Linear Regression Model	0.96
Neural Network Model (input: setpoint + fan speed)	1.63
Neural Network Model (input: setpoint + fan speed+ outside T)	0.87

Table 2.2: Surrogate models MSE comparisons

	Prediction Time [ms]
Linear Regression Model	0.0017
Neural Network Model	3.2060

Table 2.3: Surrogate models prediction time comparisons

The two types of models are compatible with different methods for solving optimization problems. The linear regression model works with linear optimization methods such as CVX, used in this thesis. The linear optimization solves the optimization problem with low computing power and ensures the optimality of the solutions [16]; however, the neural network model would need stochastic optimization such as the SLSQP method used in this thesis, which requires a longer time to converge and global optimally is not ensured [37]. The computational efficiency of the linear regression model prediction and optimization makes the method better suited for real building implementation with home-automation systems.

## 2.5 Implementing Cooling Systems Scheduling in Real Building

The workflow of cooling systems scheduling demonstrated in Section 2.1 which utilizes a linear regression model, is implementable in real buildings and has several practical advantages. No building or equipment modeling is required, which allows flexibility in the application; limited data is required, which protect users privacy; no expensive computing required to get the scheduling solutions, which ensures efficiency. Recent

rapid development and wide use of smart home devices make feedback and control of the cooling systems possible[49][76].

The workflow of the real building implementable follows the same structure with methodology demonstrated in Section 2.1. What is different is the source of perturbation model training data. It would be collected from real building environment with smart meters, controllers and sensors instead of simulation outputs. In addition, since the baseline condition can no longer be simulated by *EP*, a surrogate model would need to be trained to predict the baseline power and thermal comfort conditions. The steps of the real building implementation methods are demonstrated in Figure 2-7. The baseline model learning are explained in Section 2.5.1, the perturbation model training and optimization can refer to previous demonstrations in Section 2.1.2 and Section 2.1.3. The optimized schedules can be input to air conditioner smart thermostats and fan smart speed controls. Working with smart devices, the proposed method is able to record, predict and adjust the environmental conditions and power consumption, and promote users' thermal satisfaction.




Figure 2-7: Workflow: implementing cooling systems scheduling in real building

### 2.5.1 Baseline Model Learning for Real Building Implementation

The goal of this section is to learn surrogate models that predict baseline load and heat stress conditions in the defined time interval. The data of load can be collected from electricity meters. For heat stress, the degree of thermal discomfort is often used as a measurement of heat stress [55]. There are two schools of thermal comfort models, the heat balance model, and the adaptive model. Heat balance models consider the human body as a thermodynamic system, which requires the human body to maintain an internal heat balance around  $37 \pm 0.5$  °C [19]. Predictive Mean Vote (*PMV*) model [28] and Standard Effective Temperature (*SET\**) [32] [11] are representatives of heat balance models. For the adaptive models, the occupant is assumed to be able to adapt to the environment to improve personal thermal comfort. Research has shown that thermal comfort conditions can be quite personal and relate to many personal parameters such as culture[17], age[40], and gender[42]. Building on the knowledge from these thermal comfort models, the recent development of machine learning algorithms and smart sensors has enabled great progress in data-driven models for personalized thermal comfort [30] [15] [56] [62]. To mitigate heat stress, it is important to maintain thermal comfort in a comfortable range.

For the air conditioner and fan, the two devices that this thesis is scheduling, the baseline conditions of the air conditioner and fan are set up. Recent fast development and wide application of smart-home devices have opened up the potential for data collection and smart control of household devices. In paper [49], Lee et al. use the data of smart meters and smart thermostats of the air conditioners to predict and control the load in residential buildings; in the paper [76], Yammen et al. offer methods to control the speed of the fan through a mobile application. The baseline schedule of the air conditioner and fan and the building load collected from the smart meters would be used to train the baseline models. In addition, occupancy factors including the information of the type of the day, time of the day, and occupancy schedules are critical to power consumption [80]. The occupancy data could be collected through

sensor or user logs. For the choice of algorithm, there is a great amount of existing research work that predicts load. Review paper [81] compares the performance of various algorithms for load prediction. Artificial Neural Network (ANN)[33] [14] and Support Vector Machine (SVM) [38][51] are two types of models can be trained with historical data and obtain high accuracy in prediction, however, the models are often complex. The statistical regression model [36] has more advantages in terms of ease of use, but has less accuracy.

For thermal comfort prediction, the above-mentioned heat balance model, adaptive model, or data-driven personalized thermal comfort model could be used to describe the thermal perception of the occupant. Review paper [29] lists input factors for generating thermal comfort values. Normally environmental factors include air temperature, mean radiant temperature, relative humidity, and air speed, which could be measured through a set of sensors [82]. Human factors involve anthropometric data, physiological factors, and behavioral factors. The anthropometric data include age, gender, ethnicity, height, and weight, which are often not included in the thermal comfort predicting inputs since the input values would not vary much; the physiological factors often included heart rate, Electroencephalogram (EEG), and skin temperature, which can be collected directly or measured through physiological sensors and is the most used inputs for thermal comfort models; the behavioral factors involve lifestyle, clothing insulation, and activity levels, which can be hard to quantify thus often not used in the input data. For the machine learning algorithm, a wide range of models have been applied to predict thermal comfort, including Artificial Neural Network (ANN) [30]and [66], Fuzzy Logic[15], and Support Vector Machine (SVM) [56] [62][8][74] and [59]. Review paper [29] points out SVM model is the most used in the reviewed works and obtains one the best prediction accuracy.

The above-mentioned existing machine learning models for power and thermal comfort predictions have their advantages and disadvantages. It would be hard to determine the best model without comparing the performance of a few models for the specific problem with specific requirements for accuracy, computing time, and ease of use. Testing a few models with available types and amounts of data, the

algorithm of the baseline models could be chosen based on the specific requirements of the problem.




# Chapter 3

## Miami Case Studies & Results


### 3.1 Miami Single Building and Six-Building Neighborhood Case Studies Setup

This section demonstrates the proposed methodology with a single building case study and a six-building neighborhood case study. The single-family residential prototype model of the ASHRAE 1A climate zone [1] is used as the baseline file for the case studies. The Miami TMY3 epw file is used as a weather file for the simulation. Figure 3-1a shows the outside temperature over a year of the chosen climate profile. The summer hottest day, shown in Figure 3-1b, is set as the optimization days.

With the constant default setpoint at 23.9 °C and air speed at 0.35 m/s, the baseline hourly power consumption and  $SET^*$  are shown as the pink line in Figure 3-2a and Figure 3-2b. The power demand and  $SET^*$  in the optimization day are used as the baseline for the case study. The pink line in Figure 3-2a shows, as the outside temperature rises in the afternoon, the power demand in the afternoon increases and reaches a peak, due to the increased thermal load and the decreased cooling system efficiency when the temperature difference between outdoor and indoor increases. To reduce the peak power, one easy solution would be raising the constant setpoint. If the setpoint is raised 3 °C, the resulting hourly power consumption is shown as the blue line in Figure 3-2a. Although the easy approach shifts the line of power consumption



(a) outside dry bulb temperature(whole year)




(b) outside dry bulb temperature(hottest day)


Figure 3-1: Miami case study outside dry bulb temperature

down, it compromises  $SET^*$  as shown in the blue line in Figure 3-2b. The darker gray and lighter gray shading boxes in Figure 3-2b indicate the thermally comfortable zone ( $22.2\text{-}25.6^\circ\text{C}$ ) and the lightly warm/cold zone ( $17.5\text{-}22.2^\circ\text{C}$ ,  $25.6\text{-}30^\circ\text{C}$ ) of  $SET^*$  [11]. The goal for the optimization of the case studies below is to reduce the peak load and maintain a thermally comfortable condition.

As shown in Figure 3-3a, the single building case study uses the single-family residential prototype model of the 1A climate zone [1] as a baseline. The prototype is a two-story single-family house with a floor area of  $110\text{ m}^2$  for each floor, and a window-to-wall ratio of 0.15 on each side of the building. The two stories are set as one conditioned zone, and the attic is set as an unconditioned zone. The measurement of




(a) power consumption(hottest day)




(b)  $SET^*$ (hottest day)

Figure 3-2: Miami case study baseline conditions



(a) single building model



(b) six-building neighborhood model

Figure 3-3: Miami case study models

power consumption and thermal performance are monitored in the conditioned zone. The air conditioner in the prototype is a Unitary Heat Pump Air to Air system with a direct expansion coil for cooling. The baseline setpoint keeps the default value at 23.9

$^{\circ}\text{C}$ . The implementation of average airspeed and power consumption of the ceiling fan is derived from data published by Liu et al. [52]. A baseline airspeed of 0.35 m/s is implemented in this test with an average power consumption of 0.48 W/m<sup>2</sup>.

The hourly baseline power  $\hat{P}(k)$  and Standard Effective Temperature  $\hat{SET}(k)$  of the prototype model are generated as baseline targets. The hottest day and four weeks around the hottest day are set as the run period. To generate perturbation data, eppy [3] is used to parametrically modify the schedules of the setpoint and air speed. The perturbation range for setpoint is  $\pm 3$   $^{\circ}\text{C}$  and for air speed is  $\pm 0.35$  m/s. One hundred fifty sets of schedule perturbations are generated.

One perturbation model for power and one perturbation model for  $SET^*$  are trained with linear regression functions in equations (2.5) and (2.6). The baseline power and  $SET^*$  and the trained power and  $SET^*$  perturbation models are fed into the convex linear solver, CVXPY [25] with goal function in equation (2.7). The proposed methods require low computation cost in solving the high-dimensional multi-objective optimization problems. A multi-objective sampling is applied with 1000 different combinations of randomly generated  $P_{weight}$ , and  $S_{weight}$  assigned to the optimization function (2.7).

The six-building neighborhood, as shown in Figure 3-3b, is composed of six single-family buildings with various footprints modified derived from the prototype single-family model. The geometry modification of the model is done with a python package, geomeppy [4], which can change dimension parameters in the models. The footprint of the buildings on each floor varies from 55 m<sup>2</sup> to 165 m<sup>2</sup>. The window-to-wall ratio of the buildings keeps at 0.15 on each side of the buildings.

The process of baseline and perturbation data generation and perturbation model training is repeated six times. In the end, for each unit, one perturbation model for power and one perturbation model for  $SET^*$  are trained with their respective linear regression function (2.5) (2.6). The baseline power and  $SET^*$  and the trained power and  $SET^*$  perturbation models of the six units are fed into the convex linear solver, CVXpy [25]. The goal of the optimization for the six-unit neighborhood case study is to reduce the aggregate peak power and  $SET^*$  of the six units. Similarly, a multi-

objective sampling is applied with 1000 different combinations of randomly generated  $P_{weight}$ , and  $S_{weight}$  assigned to the optimization goal.

## 3.2 Cooling System Scheduling Results

### 3.2.1 Single Building Results






Figure 3-4: Miami single-building case study cooling system scheduling multi-objective sampling

As shown in Figure 3-4, the multi-objective sampling method gives a range of optimized solutions to the case study problem. The solutions form a Pareto Front [50], in which each dot in the figure represents one unique optimal solution that cannot improve in one dimension without compromising the other. This section demonstrates the optimal solution of 75%  $P_{weight}$  to peak power optimization and 25%  $S_{weight}$  to peak  $SET^*$  optimization for the single building case study. In Figure 3-5a and Figure 3-5b, the pink line represents the baseline performance, the dotted blue line stands for surrogate prediction outputted from the optimizer, and the solid blue line is the building performance from *EP* simulation with the optimizer generated schedules. As indicated in both figures, the optimized power and  $SET^*$  in the solid blue lines were reduced by 7.8% and 2.8% compared to the baseline. Over the whole day, the total energy consumption of the optimized solution increases by 4.9%. The schedules of cooling system setpoint and ceiling fan air speed that result in the reduction are

shown in Figure 3-6a and Figure 3-6b. The optimized setpoint solution pre-cools the building earlier in the morning, then raises the setpoint temperature in the afternoon when the outside temperature increases. To maintain the indoor environment at a thermally comfortable level, the ceiling fan schedule raises the air speed in the afternoon.




(a) demand power




(b)  $SET^*$

Figure 3-5: Miami single-building case study hourly demand power and  $SET^*$  after cooling system scheduling



(a) setpoint schedule




(b) air speed schedule


Figure 3-6: Miami single-building case study cooling system scheduling

### 3.2.2 Results with Wall R Value and Window U Value Variation

In addition to the schedule optimization, building-level interventions such as wall R-value and window U-value influence the power consumption. Building off the single unit case study, this section demonstrates the result of the single-building optimization with wall R-values varying from  $1.9 \text{ m}^2\text{K/W}$  to  $3.4 \text{ m}^2\text{K/W}$ , and window U-values varying from  $1.1 \text{ W/m}^2\text{K}$  to  $4.5 \text{ W/m}^2\text{K}$ . The proposed methodology is applied for each of the single buildings with wall R-values in  $1.9, 2.2, 2.5, 2.8, 3.1, 3.4 \text{ m}^2\text{K/W}$ . Similarly, the process is repeated for each of the buildings with window U-values of



(a) moo with wall R value variations




(b)  $\text{score}_{opt}$  with wall R-value variations


Figure 3-7: Miami single building case study multi-objective sampling (moo) and optimization score ( $\text{score}_{opt}$ ) with wall R-value from 1.9 to 3.4 m $^{2}$ K/W

1.1, 2.8, and 4.5 W/m $^{2}$ K. Figures 3-7a and 3-8a present a wide range of solutions from the multi-objective sampling with wall R-value and window U-value variations. In both plots, the X-axis represents the optimized peak power and Y-axis represents the optimized peak  $SET^*$ . Lighter dots denote larger R and smaller U values.

Figures 3-7a and 3-8a show that as the wall R-value increases and the window U value decreases, the Pareto Front gets closer to the origin. The baseline peak power and  $SET^*$  of the prototype model with default wall R-value of 1.9 m $^{2}$ K/W and window U value of 2.8 W/m $^{2}$ K are used for comparison analysis. To cross-compare



(a) moo with window U value variations



(b)  $score_{opt}$  with window U value variations

Figure 3-8: Miami single building case study multi-objective sampling (moo) and optimization score ( $score_{opt}$ ) with window U-value from 1.1 to 4.5 W/m<sup>2</sup>K


the results of the optimization, an optimization score is introduced here:

$$score_{opt} = P_{weight} \cdot P_{reduction}\% + SET_{weight} \cdot SET_{reduction}\% \quad (3.1)$$


In equation (3.1),  $P_{weight}$  and  $S_{weight}$  are the assigned weights to peak power and peak  $SET^*$  optimization. The value of  $P_{weight}$  and  $S_{weight}$  are 60% and 40% in this result section.  $P_{reduction}$  and  $SET_{reduction}$  are peak power and  $SET^*$  reduction compared to the baseline peak power and  $SET^*$  of the prototype model. Smaller optimization scores indicate better optimization results. The optimization scores with wall R-value and window U value variation are shown in Figure 3-7b and Figure 3-8b. Figure 3-7b

shows that as the wall R-value changes from 1.9 m<sup>2</sup>K/W to 2.8 m<sup>2</sup>K/W, there is a significant improvement in the optimization score; after 2.8 m<sup>2</sup>K/W, although the optimization score still improves as the R-value increases, the magnitude of improvement is smaller. For the window U value variation, Figure 3-8b shows the decline of the optimization score is sharper as the window U value changes from 4.5 to 2.8 W/m<sup>2</sup>K than from 2.8 to 1.1 W/m<sup>2</sup>K.

### 3.2.3 Six-Building Neighborhood Results




(a) aggregated demand power




(b) average  $SET^*$

Figure 3-9: Miami six-building neighborhood case study aggregated demand power and average  $SET^*$

For the six-building neighborhood, to view varieties of solutions with this work-




(a) demand power




(b)  $SET^*$

Figure 3-10: Miami six-building neighborhood case study individual demand power and  $SET^*$

flow, a different set of weights, 65%  $P_{weight}$  to peak power and 35%  $S_{weight}$  to peak  $SET^*$ , is assigned to this optimization problem. Figure 3-9a and Figure 3-9b show the aggregate peak power is reduced 10.1% compared to the baseline and the average  $SET^*$  increases by only 2.2%. Over the whole day, the total energy of the optimized solution increases by 5.7%. Figure 3-10a and Figure 3-10b present the individual power and  $SET^*$  of the six buildings. As shown in Figure 3-11a and Figure 3-11b, the methodology is able to provide coordinated setpoint and air speed schedules for the small community.



(a) setpoint schedules



(b) air speed schedules

Figure 3-11: Miami six-building neighborhood case study cooling system scheduling

### 3.3 Energy System Scheduling Results

Figure 3-12 shows the cost of electricity unit price in 5 to 20 years with various PV and battery capacities. In the short term, within five years the unit cost of electricity for low PV and battery capacity is around 0.5-0.7 \$/kWh, which increases to more than 1.5-1.8 \$/kWh in high PV and battery capacities. The cost differences due to the PV and battery capacities tends to decrease in the long term.




Figure 3-12: Miami single building case study electricity unit cost in short term and long term for PV and battery in various capacities

### 3.3.1 Single Building Results

The net purchased power presents both the power purchased from the grid, which is the positive value, and the power feeding to the grid, which is the negative value. The net purchased power of the unit with PV (0.7kWp/MWh) and battery (1.3 kWh/MWh) compared to the baseline demand of the same model without PV and battery is shown in Figure 3-13. The peak power needed from the grid reduces 65% from 3.6 kW to 1.2 kW. Figure 3-14a and Figure 3-14b show further peak reduction




Figure 3-13: Miami single building case study net purchased power before and after installing PV and battery

with energy storage system scheduling. The peak purchased power was reduced to 0.66 (kW), which is about 45 % compared to the default PV and battery operation scheme, and about 81 % compared to no PV and battery. Since this section does not involve cooling system adjustment, there is no change in the thermal comfort of the building. Following the battery discharge scheduling method demonstrated in Section 2.2, as shown in Figure 3-14c, the new battery discharge schedule relocates some of the power discharging from the battery from the late afternoon to the early morning, which helps reduce the peak power purchased from the grid.

The battery discharging methods are repeated for various models with PV capacities in the range of 0.4 to 1.2 kWp/MWh battery capacities in range of 0.4 to 1.9 kWh/ MWh. Figure 3-15 shows the net purchased power after the energy storage scheduling compared to the baseline for the various PV and battery capacities. If the capacity of the battery equals the amount of PV-produced power, excluding the power supplied by PV to directly meet the building's demand, further enlarging the battery would not further reduce the peak load. If the battery capacity with sufficient PV produced power is enough for supporting the entire building demand, further increasing the PV capacity would not help further reducing the peak load. In the case studies, purchased grid power for charging the battery is not considered.

Figure 3-16 shows the peak purchased power reduction that can be achieved with

the various PV and battery settings, before the energy storage scheduling (left), and after the energy storage scheduling (right). It shows the medium PV and battery capacities such as PV capacity at 0.7kWp/MWh and battery capacity at 1.3 kWh/MWh are able to achieve around 81% of peak purchased power reduction after rescheduling the battery. Taking the cost of the electricity in various PV and battery sizing as shown in Figure 3-12, the cost of electricity under medium PV and battery sizing is about half of the high PV battery capacity.

### 3.3.2 Six-Building Neighborhood Results

Figure 3-18 shows in the same PV and battery capacity as the section above, in a six-building neighborhood, the amount of accumulated peak purchased power is able to achieve through collectively scheduling the energy storage systems of the neighborhood. The energy storage scheduling method demonstrated in Section 2.2 is applied, and the average of the accumulated purchased power is set as the guidance for relocating the battery discharging power. After applying the new battery discharge schedule shown in Figure 3-18b, the peak purchased power is able to reduce about 50% compared to the default energy storage schedule.

## 3.4 Cooling and Energy Storage System Scheduling Results

### 3.4.1 Single Building: Minimizing the Peak Grid Purchased Power during Heat Waves

Applying the cooling and energy system scheduling method demonstrated in Section 2.3, Figure 3-21 shows the case study on a single building with PV capacity of 0.7 kWp/MWh and battery capacity of 1.3 kWh/MWh. Figure 3-20a and 3-20b shows the net purchased power and purchased power with the optimized cooling system schedules shown in Figure 3-19a and 3-19b. The sum of the purchased power was

reduced by about 46 % compared to the constant value cooling system schedule. Figure3-20c shows that scheduling the cooling system achieved a 4% reduction in  $SET^*$ compared to the baseline. Based on the reduced total purchased power, the energy storage scheduling shown in Figure 3-21a is able to flatten the peak of the purchased power close to the average value, which is a 42 % reduction compared to the purchased power after cooling system scheduling, and 89% reduction comparing to the no PV and battery baseline power consumption.

In summary, Table 3.1 gathers the peak purchased power and  $SET^*$  of the case studies under each scheduling method. The cooling system scheduling is able to reduce the peak load by 7.8 % and reduce the  $SET^*$  max value by 2.8%; the energy storage system scheduling reduces the 81% of the peak purchased power; combining the two methods, the cooling, and energy storage systems scheduling reduces the peak purchased power by 89% and the  $SET^*$  by 4%.


	$P_{max}(KW)$	$P_{difference}$	$SET_{max}(^\circ C)$	$SET_{difference}$
Baseline	3.45	0 %	24.5	0 %
HVAC Scheduling	3.17	-8 %	24.9	+2 %
HVAC+Fan Scheduling	3.19	-8 %	23.8	-3 %
Energy Storage System Scheduling	0.66	-81 %	24.5	0 %
Cooling and Energy Storage Systems Scheduling	0.38	-89 %	23.4	-4 %

Table 3.1: Miami single building case study peak power and  $SET^*$  under various scheduling methods


### 3.4.2 Single Building: Maximizing Self-sufficient Hours after Grid Shutdown

Self-sufficient hours are times during which the building's demand is supported by the PV-produced power or power from the energy storage system. Figure 3-22 shows the number of self-sufficient hours with various PV and battery capacity under default battery discharge by demand schedule. The number of hours varies from 10 to 24 depending on the capacity of the PV and battery.


To maximize the number of self-sufficient hours in the scenario of a grid shutdown after a heat wave, the weight for reducing the demand power is raised to a higher value during the cooling system schedule optimization. After applying 90% weight to the sum of purchased power and 10% to the peak SET, the cooling system reschedule is able to reduce total purchased power by 75% compared to before the cooling reschedule,  $SET^*$  is compromised by 4%, 25.5 °C, and self-sufficiency extends to 24 hours. In the condition where the weather would be similar the following days, with cooling system scheduling the PV and battery would make the building self-sufficient.



(a) net purchased power



(b) purchased power



(c) battery discharge power

Figure 3-14: Miami single building case study net purchased power, purchased power and battery discharge power before and after applying the energy storage system scheduling method







Figure 3-15: Miami single building case study net purchased power after discharge scheduling for PV and battery in various capacities




(a) Peak purchased power with default discharge schedule



(b) Peak purchased power with discharge scheduling methods




(c) Peak purchased power reduction percentage with default discharge schedule




(d) Peak purchased power reduction percentage with discharge scheduling methods

Figure 3-16: Miami single building case study peak purchased power reduction before and after battery discharge scheduling for PV and battery in various capacities




(a) net purchased power




(b) purchased power

Figure 3-17: Miami six-building neighborhood case study net purchased power and purchased power before and after applying the energy storage system scheduling methods




(a) battery discharge power default




(b) battery discharge power scheduling

Figure 3-18: Miami six-building neighborhood case study individual discharge power before and after energy storage system scheduling method




(a) setpoint schedule




(b) air speed schedule


Figure 3-19: Peak Load Reduction, Miami single building case study cooling and energy storage systems scheduling, step1:cooling system scheduling



(a) net purchased power




(b) purchased power




(c)  $SET^*$


Figure 3-20: Peak Load Reduction, Miami single building case study net purchased power, purchased power and  $SET^*$  after step1: cooling system scheduling



(a) battery discharge power



(b) net purchased power



(c) purchased power

Figure 3-21: Peak Load Reduction, Miami single building case study cooling and energy storage systems scheduling, step2: energy storage system scheduling






Figure 3-22: Self Sufficient Hours with PV and battery




(a) setpoint schedule




(b) air speed schedule


Figure 3-23: Self-sufficient hours maximization, Miami single building case study cooling and energy storage systems scheduling, step1: cooling system scheduling



(a) net purchased power



(b) purchased power



(c)  $SET^*$

Figure 3-24: Self-sufficient hours maximization, Miami single building case study net purchased power, purchased power and  $SET^*$  after cooling system scheduling



# Chapter 4

## Kuwait Case Studies & Results

### 4.1 Kuwait Residential Case Studies Setup






Figure 4-1: Kuwait residential case study building model

This section demonstrates the proposed methodology with a Kuwait residential building. As shown in Figure 4-1, this case study tests a multi-family residential model in Kuwait. The *EP* model is developed by the research team members, Jonathon Brearley and David Birge. The details of the model can be found in Appendix D.3. The prototype is a three-story multi-family house with a floor area of 150 m<sup>2</sup> on each floor, and a window-to-wall ratio of 0.15 on each side of the building. The whole building operates under one setpoint and airspeed value in this case study. The measurement of load takes the sum of the whole building, and thermal performance takes the average of all zones.




(a) outside dry bulb temperature(whole year)




(b) outside dry bulb temperature(hottest day)

Figure 4-2: Kuwait case study outside dry bulb temperature

The Kuwait TMY3 epw file is used as the weather file for the simulation. Figure 4-2a shows the outside temperature over a year of the chosen climate profile. The summer hottest day, shown in Figure 4-2b, is set as the optimization day. A variable refrigerant flow (VRF) system is adopted for cooling. The baseline setpoint keeps the default value at 28 °C. The implementation of average airspeed and power consumption of the ceiling fan is derived from data published by Liu et al. [52]. A baseline air speed of 0.35 m/s is implemented in this test with an average power consumption of 0.48 W per floor area in m<sup>2</sup>. The baseline hourly power consumption and *SET\** are shown as a pink line in Figure 4-3a and Figure 4-3b. The darker gray and lighter gray shading boxes in Figure 4-3b indicate the thermally comfortable zone (22.2-25.6°C)



(a) power consumption(hottest day)




(b)  $SET^*$ (hottest day)

Figure 4-3: Kuwait residential case study baseline condition


and the lightly warm/cold zone ( $17.5\text{-}22.2^\circ\text{C}$ ,  $25.6\text{-}30^\circ\text{C}$ ) of  $SET^*$  [11]. The goal for the optimization of the case studies below is to reduce the peak load and maintain a thermally comfortable condition.

## 4.2 Cooling Systems Scheduling Results

Applying the cooling system scheduling methods demonstrated in Section 2.1, the optimized schedules of the cooling system setpoint and ceiling fan air speed are shown in Figure 4-5a and Figure 4-5b. The new setpoint schedule pre-cools the building earlier in the morning, then raises the setpoint temperature in the afternoon when




(a) demand power




(b)  $SET^*$

Figure 4-4: Kuwait residential case study demand power and  $SET^*$  after cooling system scheduling

the outside temperature reaches the highest. To maintain a thermally comfortable indoor environment, the ceiling fan schedule increases the air flow velocity in the afternoon. Figure 4-4a and Figure 4-4b show the power and SET before and after the scheduling. The peak load reduces from 12.2 kW to 9.3 kW, which is about a 24% reduction compared to the baseline. In the meantime, the max SET reduces 1%.



(a) setpoint schedule



(b) air speed schedule

Figure 4-5: Kuwait residential case study cooling system scheduling

### 4.3 Energy Storage Scheduling Results

This section adopts the energy storage scheduling method demonstrated in Section 2.2. Figure 4-7 shows the comparison of power needed from the grid between the no PV and battery and with PV and battery under baseline conditions. After applying the new energy storage discharging schedule, Figure 4-9a and Figure 4-9b show the peak net purchased power and purchased power reduction. The energy storage scheduling method reduces the peak purchased power to 2.4 kW and reaches 80% of reduction compared to the baseline. Since this section does not involve cooling system adjustment, there is no change in the thermal comfort of the building. As shown in Figure 4-9c, the new schedule relocates some of the battery discharging power from the late afternoon to early morning, which helps even out the power purchased from the grid.




Figure 4-6: Kuwait residential building power composition




Figure 4-7: net purchased power


Figure 4-8: Kuwait residential case study net purchased power before and after installing PV and battery

## 4.4 Cooling and Energy Storage Systems Scheduling Results


In this section, both cooling and energy storage systems are scheduled. The cooling system is scheduled first, and the energy storage scheduling would be applied after the cooling system scheduling. Following methods for optimizing the cooling system schedules in section 2.3.1 section 2.3.2 and section 2.3.3, the optimizer is set to reduce the weighted sum of the sum of purchased power and peak  $SET^*$  reduction.

### 4.4.1 Minimizing the Peak Purchased Power during Heat waves


In order to minimize the peak purchased power while maintaining a thermally comfortable environment during a heat wave, with 80% weight is assigned to the sum of purchased power reduction and 20% weight assigned to the peak  $SET^*$  reduction, the optimizer created new cooling schedules as shown in Figure 4-10a and Figure 4-10b. As shown in Figure 4-11b and Figure 4-11b, the optimized cooling schedule reduced the total purchased power by 52% compared to purchased power with only energy storage system scheduled. The peak  $SET^*$  resulted from this cooling system scheduling compromised for about 6 %.



(a) net purchased power




(b) purchased power




(c) battery discharge power

Figure 4-9: Kuwait residential case study net purchased power, purchased power and battery discharge power before and after applying the energy storage system scheduling method




(a) setpoint schedule




(b) air speed schedule

Figure 4-10: Peak Load Reduction, Kuwait residential case study cooling and energy storage systems scheduling, step1:cooling system scheduling


Based on the cooling system optimized results, the energy storage system scheduling methods are presented in section 2.3.4. The new battery discharge schedule shown in Figure 4-12a takes the average of the total purchased power from cooling system optimization, and relocates the discharge power to flatten the peak of the purchased power. The final net purchased power and purchased power after cooling and energy system schedules are shown in Figure 4-12b and Figure 4-12c. The peak purchased power is reduced to 1.3 kW, a decrease of about 38% compared to the purchased power of the last step, cooling system scheduling. Compared to the baseline, the peak purchased power was reduced by about 89 %, and the peak  $SET^*$  increased by



(a) net purchased power




(b) purchased power




(c)  $SET^*$


Figure 4-11: Peak Load Reduction, Kuwait residential case study net purchased power, purchased power and  $SET^*$  after step1: cooling system scheduling



(a) battery discharge power



(b) net purchased power



(c) purchased power

Figure 4-12: Peak Load Reduction, Kuwait residential case study cooling and energy storage systems scheduling, step2: energy storage system scheduling


around 6%. In all, the peak load and  $SET^*$  after applying the three methods are presented in Figure 4-12a.

	$P_{max}(kW)$	$P_{reduction}$	$SET_{max}(^\circ C)$	$SET_{reduction}$
Baseline	12.2	0 %	26.2	0 %
Cooling systems scheduling	9.3	24 %	26.0	1 %
Energy storage system scheduling	2.4	80 %	26.2	0 %
Cooling and energy storage systems scheduling	1.3	89 %	27.9	+6 %


Table 4.1: Kuwait residential case study peak power and  $SET^*$  under various scheduling methods

#### 4.4.2 Maximizing Self-sufficient Hours after Grid Shutdown

In the scenario after a grid shutdown, to maximize the number of hours that the building is able to be self-sufficient from PV produced power and the power stored in the energy storage system, this case study applied 95% weight to the total purchased power reduction and 5% to the peak  $SET^*$ . As shown in Figure 4-14b, the cooling system reschedule is able to reduce the sum of the purchased power to 14.9kWh, which is a 59 % reduction compared to the total purchased power with only battery discharge scheduling. As shown in Figure 4-14c, the peak  $SET^*$  increased 7%. Under this scenario, the resulting total power demand from the grid becomes the power needed to be supplied by the energy storage system. As result, self-sufficiency extends to 19 hours, which is 9 hours more before the cooling system scheduling. In the case study, the weather of post-grid shut down days is assumed to be similar.




(a) setpoint schedule




(b) air speed schedule


Figure 4-13: Self-sufficient hours maximization, Kuwait residential case study cooling and energy storage systems scheduling, step1: cooling system scheduling



(a) net purchased power



(b) purchased power



(c)  $SET^*$

Figure 4-14: Self-sufficient hours maximization, Kuwait residential case study net purchased power, purchased power and  $SET^*$  after cooling system scheduling

# Chapter 5

## Discussion and Conclusion

This thesis proposes methods to adjust cooling and energy storage systems that mitigate demand peak and heat stress under heat waves. As shown in Table 3.1 and Table 4.1, the methods in this thesis are able to identify with low computing cost schedules that mitigate the peak power and heat stress. Ranking the scheduling results in descending order, the methods that lead to the most peak load reduction to the least are, cooling + energy systems scheduling, energy storage system scheduling, and cooling systems scheduling.

In neighborhood level, as shown in Section 3.3.2, coordinately optimizing the scheduling among the households shows more advantage in peak load reduction than separately scheduling individual households. For building level interventions such as wall R value and window U value demonstrated in Section 3.2.2, the results show that as the wall R-value increases and the window U value decreases, the scheduling methods in general is able to generate better solutions for peak load and heat stress mitigation. As a next step, the proposed methods have great potential to integrate with other heat resilient strategies such as improvements in insulation, solar shading, and thermal mass.

It is shown in Figure 3-16 that implementing PV and energy storage system with energy storage scheduling could significantly reduce the peak purchased power. The capacity of the PV and battery would influence the range of reduction. As shown in Figure 3-15, in sizing the PV and batteries, if the is capacity of the battery equals

the amount of PV produced power excluding the power supplies the demand by PV directly, further enlarging the battery would not benefit the peak load reduction; if the battery capacity with sufficient PV produced power is enough for supporting the entire building demand, further increasing the PV capacity would not further reduce the peak load. In the case studies, purchased grid power for charging the battery is not considered. A cost analysis on PV and battery capacities is conducted in Figure 3-12. Coupling the two analyses, the medium PV and battery in the studied capacities are able to achieve great peak load reduction and is much cheaper than the high PV and capacity settings.

The cooling system scheduling methods, implemented with linear regression model, are implementable in real buildings with no need for building energy models. The choice of the surrogate models and optimizer ensures computing speed and global optimality of the solutions. The implementation of the method is able to be achieved by inputting optimized schedules to air conditioner smart thermostats and fan smart speed controls such as the devices mentioned in papers [83] and [76]. Although the hardware of these devices have been rapidly developed, the control complexity is still limited [49]. As the manufacturer allows more complex control algorithms to be implemented with the smart devices, the smart-devices would be able to archive more customized goals such as reducing peak load and ensuring thermal comfort at meantime.

In order to reduce the computing cost in solving the high-dimensional multi-objective optimization problems for scheduling cooling systems, the proposed methods train linear regression models and neural network models as surrogate replacements for physics-based simulations. Due to the nature of the surrogate model, surrogate predictions of power and thermal comfort show slight differences from *EP* simulations, although the relative error is small.

The perturbation methods demonstrated in this thesis are based on a defined baseline model and perturbation range. If a new baseline condition or perturbation range needs to be applied, a new model would need to be trained. To offer large-scale solutions, a separate surrogate model that is able to predict the baseline and

perturbation values would be necessary.

The uncertainty observed in usage patterns in real buildings is not taken into account in the simulation based workflow. In building energy modeling, there is some research on modeling the uncertainty of use patterns in the built environment [21] [58]. In practice, model predictive control methods build off the prediction and control of the power usage based on knowledge of the previous period's energy usage [27]. The intent of the proposed simulation based workflow is to offer preliminary guidelines for power usage under heat waves, thus the uncertainty in usage patterns is not considered here.

The methods proposed in this thesis are useful for analyzing and optimizing peak building energy and thermal performance under historical or projected heat waves with adaptations in building operational schedules. The simulation-based methods offer flexible means to analyze existing buildings, building retrofits, or future construction. This thesis demonstrates the methods with air conditioner setpoint, fan speed, and battery discharging schedule optimization; the framework could extend the optimization features to other building operational schedules. In addition to the optimization target demonstrated here – peak load and heat stress mitigation – the methodology could be applied to an extended range of goals such as total energy usage, carbon emissions, and electricity costs.



# Appendix A

## Cooling Systems Scheduling

### A.1 Baseline and Perturbation Data Generation

Set data path

```
import pandas as pd
import os
import numpy as np
from matplotlib import pyplot as plt
# get current code (ipynb) file path
ipynb_path = os.path.dirname(os.path.realpath("__file__"))
# ! REMEMBER TO CHANGE THIS EVERYTIME WE SET UP A NEW RUN!!!
current_run_tag = 'Testrun'

#".." move up one folder
# general_path is the general path where all the file relate to the
# test stored
general_path = os.path.abspath(os.path.join(ipynb_path, ".."))
# data_path where the current run data stores
data_path = os.path.join(general_path, current_run_tag)
# check whether this path exist, if not, build this path
if not os.path.exists(data_path):
    os.mkdir(data_path)
    print('Create new folder: ', data_path)
```

```

else:
    print('Folder already existed: ', data_path)

```

## Set Eppy path

```

# build IDD file path for windows or mac systems
from sys import platform
if platform == "darwin":
    # Mac (IOS)
    energyplus_path = '/Applications/EnergyPlus-9-5-0'
elif "win" in platform:
    # Windows
    energyplus_path = 'C://EnergyPlusV9-5-0'
else:
    raise ValueError()
print(energyplus_path)

# set energyplus path, needs python reboot if changed
from eppy.modeleditor import IDF
IDF.setiddname(os.path.join(energyplus_path, 'Energy+.idd'))

```

## Baseline data generation

```

# define weather file path
epw_name = 'USA_FL_Miami.Intl.AP.722020_TMY3.epw'
weather_filepath = os.path.join(general_path, 'weather', ,
    'USA_FL_Miami.Intl.AP.722020_TMY3', epw_name)
assert os.path.exists(weather_filepath)

base_fname='MIAMIPNNL' # input baseline idf file name
base_dir='{}_baserun'.format(base_fname)
perturb_dir='{}_perturb'.format(base_fname)

# establish idf file
fname= os.path.join(general_path, 'PNNLexamplefile','{}.idf'.format(
    base_fname))
assert os.path.exists(fname)

```

```

idf = IDF(fname, weather_filepath)

# identify cooling schedule in the idf file
allschedule=idf.idfobjects['Schedule:Compact']
ClgSetPSch=allschedule[-5]
VairSch=allschedule[-2]
fanSch=allschedule[0]

# build baseline output data folder first
base_output_path= os.path.join(data_path, base_dir)
if not os.path.exists(base_output_path):
    os.mkdir(base_output_path)
else:
    print('Folder already existed: ', base_output_path)

# run baseline idf file
idf.run(readvars=True, expandobjects=True, output_directory=
         base_output_path)

# read idf output csv file
Data = np.genfromtxt(os.path.join(base_output_path, "eplusout.csv"),
                     delimiter=",", dtype=float, skip_header=217)
_,c=Data.shape
Tout=Data[:,1:2] # Tout at column 1
MRT=Data[:,2:3]
Tair=Data[:,4:5]
RH=Data[:,5:6]
Setpt=Data[:,6:7]

SET=Data[:,c-1:c] #c
P_kw=Data[:,c-2:c-1]/1000 #kw
P_kw_cool=Data[:,c-3:c-2]/1000 #kw

# export baseline data
pd.DataFrame(P_kw).to_csv(os.path.join(base_output_path, 'p_base.csv'
                                         ))

```

```
pd.DataFrame(SET).to_csv(os.path.join(base_output_path, "SET_base.csv"))
```

Listing A.1: Set Baseline Path and Generate Baseline Data

## Perturbation data generation

```
# build perturbation data folder
perturb_output_path = os.path.join(data_path, perturb_dir)
if not os.path.exists(perturb_output_path):
    os.mkdir(perturb_output_path)
else:
    print('Folder already existed: ', perturb_output_path)

def perturbation(i):

    n=24 # simulation duration
    wk=4
#     smhr=240 #simulation start hr

    import random
    epw_name = 'USA_FL_Miami.Intl.AP.722020_TMY3.epw'
    weather_filepath = os.path.join(general_path, 'weather', 'USA_FL_Miami.Intl.AP.722020_TMY3', epw_name)
    assert os.path.exists(weather_filepath)

    fname= os.path.join(general_path, 'PNNLexamplefile','{}.idf'.format(base_fname))
    assert os.path.exists(fname)
    idf = IDF(fname, weather_filepath)

    allschedule=idf.idfobjects['Schedule:Compact']
    ClgSetPSch=allschedule[-5]
    VairSch=allschedule[-2]
    fanSch=allschedule[0]
```

```

t_ref=23.888888888889 # celcius , baseline temperature
base_airspeed=0.35 # m/s, baseline air speed
T_range=3 # define setpoint perturbation range
W_range=0.35 # define airspeed perturbation range
W=[]

# index for field in idf schedule
i_str=3 # string field
i_num=4 # setpoint number field
i_hr=0 # field time start
time_ct=0 # count number of setpoint for a day
for time_ct in range(24):
    i_hr=i_hr+1
    fanSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
i_hr)
    VairSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
i_hr)
    ClgSetPSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
i_hr)
    i_str=i_str+2

    b = [-T_range,T_range]
    choice=random.choice(b)
    ClgSetPSch['Field_{}'.format(i_num)] = t_ref+choice

airspeed_choice=random.choice([-1,1])
airspeed=base_airspeed+airspeed_choice*W_range
VairSch['Field_{}'.format(i_num)] = airspeed
W.append(airspeed_choice) # getting scaled perturbation of
airspped in 0-1 for the perturbation model training purpose
fanSch['Field_{}'.format(i_num)] = airspeed* 10/7 # power
schedule =airspeed/0.7

i_num=i_num+2
time_ct=time_ct+1

```

```

    idf.run(readvars=True, expandobjects=True, output_directory=
perturb_output_path)

    Data_1 = np.genfromtxt(os.path.join(perturb_output_path, "eplusout.csv"), delimiter=",", dtype=float, skip_header=217)

    _,n=Data_1.shape

    Setpt_1=Data_1[:,6:7]
    Delta_T=Setpt_1-t_ref

    SET_1=Data_1[:,n-1:n]
    Delta_SET=SET_1-SET

    P_kw_1=Data_1[:,n-2:n-1]/1000
    Delta_P=P_kw_1-P_kw

    W=np.reshape(W, (len(W), 1))
    W_nstack = np.vstack([W for i in range(7*wk)]) # 29 days:
simulation period 7/7-8/4.

    # the perturbation data for training, we took scaled value of
+-1

    results=np.hstack((Delta_P,Delta_SET,Delta_T,W_nstack))

    return results

```

Call perturbation function for defined number of times

```

num=50# sample size

# set up data structure for parsing training data in the next step
R=np.hstack((P_kw,SET,Setpt,Setpt)) # does not matter what content
in it, we are just using the shape of the baseline data here,
will be overwritten with the generated data
row,_=R.shape
t=R[0:row-7*24,:] # data start from 0_row, t matrix, training data 3

```

```

    week

t_row, _ = t.shape
v = R[row - 7 * 24: row, :] # data end in row_row, v matrix, validation data
                           : last 1 week
v_row, _ = v.shape

# empty matrix to be filled
train = np.zeros(t.shape)
valid = np.zeros(v.shape)

for i in range(num):
    r = perturbation(i) # result of one run of function: clg_setpoints
    ## START PARSING THE DATA
    r_t = r[0:t_row, :]
    r_v = r[t_row:row, :]
    train = np.vstack((train, r_t))
    valid = np.vstack((valid, r_v))

# take out zeros
T_row, _ = train.shape
train_data = train[t_row:T_row, :]
V_row, _ = valid.shape
valid_data = valid[v_row:V_row, :]

# build output path for perturbation data
data_perturb_output_path = os.path.join(perturb_output_path, "data_nozero")
if not os.path.exists(data_perturb_output_path):
    os.mkdir(data_perturb_output_path)

# save perturbation data
import pandas as pd
pd.DataFrame(train_data).to_csv(os.path.join(
    data_perturb_output_path, 'train_data.csv'))
pd.DataFrame(valid_data).to_csv(os.path.join(
    data_perturb_output_path, 'valid_data.csv'))

```

## A.2 Linear Regression Model Training

Set perturbation path and import perturbation data

```
import os
import pandas as pd
import numpy as np
from matplotlib import pyplot as plt

base_fname='MIAMIPNNL'
base_dir='{}_baserun'.format(base_fname)
perturb_dir='{}_perturb'.format(base_fname)
T_range=3

# ! REMEMBER TO CHANGE THIS EVERYTIME WE SET UP A NEW RUN!!!
current_run_tag = 'Testrun'

# get current code file path
ipynb_path = os.path.dirname(os.path.realpath("__file__"))

# casestudy_path is the general path where all the file relate to
# the test stored
#".." move up one folder
general_path = os.path.abspath(os.path.join(ipynb_path, ".."))
general_path

# data_path where the current run data stores
data_path = os.path.join(general_path, "{}".format(current_run_tag))
# check whether this path exist, if not, build this path
if not os.path.exists(data_path):
    os.mkdir(data_path)
    print('Create new folder: ', data_path)
else:
    print('Folder already existed: ', data_path)
```

```

result_path = os.path.join(general_path, 'results','{}'.format(
    current_run_tag))

if not os.path.exists(result_path):
    os.mkdir(result_path)
    print('Create new folder: ', result_path)
else:
    print('Folder already existed: ', result_path)

# getting training and validation data shape
nt, _ = train_data.shape
nv, _ = val_data.shape

# getting number of iterations in perturbation data generation
samplesize=len(train_data)/24/(3*7)
samplesize=int(samplesize)
samplesize

SET_pert=train_data[:, 1]
# SET_pert
P_pert=train_data[:, 0]
# P_pert

# scaling data to 0-1
P_pert_scaled=(P_pert-P_pert.min())/(P_pert.max()-P_pert.min())
SET_pert_scaled=(SET_pert-SET_pert.min())/(SET_pert.max()-SET_pert.
    min())

```

Define memory size and train the SET perturbation model

```

m=20 # adjust memory size
# memory tuning # define memories to sweep

memories = list(range(0, m))
nm = len(memories)

```

```

# import and scale target data for training and validation
yt = (train_data[:, 1]-train_data[:, 1].min())/(train_data[:, 1].max()
    ()-train_data[:, 1].min())
yv = (val_data[:, 1]-val_data[:, 1].min())/(val_data[:, 1].max()-
    val_data[:, 1].min())

# initialize error metric storage
rmset = np.zeros((nm, 1))
rmsev = np.zeros((nm, 1))
maet = np.zeros((nm, 1))
maev = np.zeros((nm, 1))

for m in memories:
    # define data matrices size with zeros
    Xt_T = np.zeros((nt, m+1)) # traindata: temperature perturbation
    Xt_W = np.zeros((nt, m+1)) # traindata: airspeed perturbation
    Xv_T = np.zeros((nv, m+1))
    Xv_W = np.zeros((nv, m+1))

    # feed info from traindata set to matrix
    for j in range(0, m+1):
        Xt_T[j:nt+1, j] = train_data[:nt-j, 2]/T_range # temperature
        # scale setpoint perturbation to 0-1
        Xt_W[j:nt+1, j] = train_data[:nt-j, 3] # airspeed scaled to
        0-1 in the data generation

        Xv_T[j:nv+1, j] = val_data[:nv-j, 2]/T_range
        Xv_W[j:nv+1, j] = val_data[:nv-j, 3]

    #2 variable, with shift
    Xt=np.hstack([np.ones((Xt_T.shape[0],1)), Xt_T,Xt_W]) # we add a
    column of ones to shift the prediction results, so it matches

```

```

better

Xv=np.hstack([np.ones((Xv_T.shape[0],1)), Xv_T,Xv_W])

# no shift
# Xt=np.hstack([Xt_T,Xt_W])
# Xv=np.hstack([Xv_T,Xv_W])

# least-squares model parameters, KW/C^2
a = np.linalg.solve(np.dot(Xt.T, Xt), np.dot(Xt.T, yt))

# compute error standard deviations
rmset[m, 0] = np.sqrt(np.mean(np.square(yt - np.dot(Xt, a)))) # error
rmsev[m, 0] = np.sqrt(np.mean(np.square(yv - np.dot(Xv, a)))))

# compute MAEs
maet[m] = np.mean(np.abs(yt - np.dot(Xt, a)))
maev[m] = np.mean(np.abs(yv - np.dot(Xv, a)))

# plot: error vs. memory
f, ax = plt.subplots(1)
# plt.figure()
plt.plot(memories, rmset, '-o', memories, rmsev, '-o')
plt.xlabel('Memory m (hours)', fontsize=13)
plt.ylabel('RMSE (C)', fontsize=13)
plt.legend(['Training', 'Validation'])
plt.grid(True)
plt.title('SET Perturbation Model RMSE', fontsize=15)
ax.set_ylim(ymin=0)
# plt.xlim((0, 10))
plt.ylim((0, 0.2))
plt.savefig(os.path.join(result_path , 'SET_RMSE_scale_shift_m{}'
    '_sample{}_{}.png'.format(m+1,samplesize,base_fname)))
plt.show()

```

Visualize trained model prediction and save trained

## model coefficients

```
Y=yv[0:96] # Power perturbation from data
Yc=np.dot(Xv,a)[0:96] # X*beta # c for calculate

plt.figure(figsize=(11.25, 7.875))
plt.plot(Y, 'o', Yc, '-')
plt.xlabel('Time (hours)', fontsize=13)
plt.ylabel('SET (C)', fontsize=13)
plt.legend(['Original Data', 'Perturbation Model Prediction'])
plt.grid(True)
plt.rcParams["figure.figsize"] = (10,6)
plt.title('SET Prediction Validation', fontsize=15)
plt.xticks(np.arange(0, 96, step=12))
plt.savefig(os.path.join(result_path ,
    'SETpredictioncomparison_scale_shift_m{}_sample{}_{}.png'.format(m
+1,samplesize,base_fname)))
plt.show()

# compute error standard deviations
rmset = np.sqrt(np.mean(np.square(yt - np.dot(Xt, a))))
rmsev = np.sqrt(np.mean(np.square(yv - np.dot(Xv, a)))))

# compute MAEs
maet = np.mean(np.abs(yt - np.dot(Xt, a)))
maev = np.mean(np.abs(yv - np.dot(Xv, a)))

# report
print('-----')
print('Training RMSE:', round(rmset, 2))
print('Validation RMSE:', round(rmsev, 2))
print('Tuned Parameters')
print('Memories:', m+1)
#print('Temperature Threshold:', thetaMin+1)
print('Coefficients:', a)

t_rmse='Training RMSE', rmset
```

```

v_rmse='Validation RMSE', rmsev
rmse=[t_rmse,v_rmse]
pd.DataFrame(rmse).to_csv(os.path.join(result_path,
    SET_rmse_scale_shift_m{}_sample{}.csv'.format(m+1,samplesize,
    base_fname)))

# save coefficient
pd.DataFrame(a).to_csv(os.path.join(data_path,perturb_dir,
    SET_a_scale_shift_m{}_sample{}.csv'.format(m+1,samplesize)))

```

Define memory size and train the power perturbation model

```

m=20 # define memory size
# memory tuning # define memories to sweep

memories = list(range(0, m))
nm = len(memories)

# import and scale target data for training and validation
yt = (train_data[:, 0]-train_data[:, 0].min())/(train_data[:, 0].max()
    -train_data[:, 0].min())
yv = (val_data[:, 0]-val_data[:, 0].min())/(val_data[:, 0].max()-
    val_data[:, 0].min())

# initialize error metric storage
rmset = np.zeros((nm, 1))
rmsev = np.zeros((nm, 1))
maet = np.zeros((nm, 1))
maev = np.zeros((nm, 1))

for m in memories:
    # define data matrices size with zeros
    Xt_T = np.zeros((nt, m+1)) # traindata: temperature perturbation
    Xt_W = np.zeros((nt, m+1)) # traindata: airspeed perturbation

```

```

Xv_T = np.zeros((nv, m+1))
Xv_W = np.zeros((nv, m+1))

# feed info from traindata set to matrix
for j in range(0, m+1):
    Xt_T[j:nt+1, j] = train_data[:nt-j, 2]/T_range # temperature
    Xt_W[j:nt+1, j] = train_data[:nt-j, 3] # airspeed

    Xv_T[j:nv+1, j] = val_data[:nv-j, 2]/T_range
    Xv_W[j:nv+1, j] = val_data[:nv-j, 3]

# 2 variables
Xt=np.hstack([np.ones((Xt_T.shape[0],1)), Xt_T,Xt_W])
Xv=np.hstack([np.ones((Xv_T.shape[0],1)), Xv_T,Xv_W])

#shift with a constant 1
# Xt=np.hstack([Xt_T,Xt_W])
# Xv=np.hstack([Xv_T,Xv_W])

# least-squares model parameters, KW/C^2
a = np.linalg.solve(np.dot(Xt.T, Xt), np.dot(Xt.T, yt))

# compute error standard deviations
rmset[m, 0] = np.sqrt(np.mean(np.square(yt - np.dot(Xt, a)))) # error
rmsev[m, 0] = np.sqrt(np.mean(np.square(yv - np.dot(Xv, a)))))

# compute MAEs
maet[m] = np.mean(np.abs(yt - np.dot(Xt, a)))
maev[m] = np.mean(np.abs(yv - np.dot(Xv, a)))

plt.figure(figsize=(11.25, 7.875))
f, ax = plt.subplots(1)
plt.plot(memories, rmset, '-o', memories, rmsev, '-o')

```

```

plt.xlabel('Memory m (hours)', fontsize=13)
plt.ylabel('RMSE(kw)', fontsize=13)
plt.legend(['Training', 'Validation'])
plt.grid(True)
plt.title('Power perturbation Model RMSE', fontsize=15)
#ax.set_ylim(ymin=0)
#plt.xlim((0, 10))
#plt.ylim((0, 2.5))
plt.savefig(os.path.join(result_path, 'Power_RMSE_scale_shift_m{}'
    '_sample{}_{}.png'.format(m+1, samplesize, base_fname)))
# plt.show()

```

Visualize trained model prediction and save trained model coefficients

```

Y=yv[0:96] # Power purterbation from data
Yc=np.dot(Xv,a)[0:96] # X*beta # c for calculate
plt.figure(figsize=(11.25, 7.875))
plt.plot(Y, 'o', Yc, '-')
plt.xlabel('Time (hours)', fontsize=13)
plt.ylabel('Power(kw)', fontsize=13)
plt.legend(['Original Data', 'Perturbation Model Prediction'])
plt.grid(True)
plt.rcParams["figure.figsize"] = (10,6)
plt.title('Power Prediction Validation', fontsize=15)
plt.xticks(np.arange(0, 96, step=12))
plt.savefig(os.path.join(result_path,
    'Powerpredictioncomparison_scale_shift_m{}_sample{}_{}.png'.format
    (m+1, samplesize, base_fname)))
plt.show()

# compute error standard deviations
rmset = np.sqrt(np.mean(np.square(yt - np.dot(Xt, a))))
rmsev = np.sqrt(np.mean(np.square(yv - np.dot(Xv, a)))))

# compute MAEs

```

```

maet = np.mean(np.abs(yt - np.dot(Xt, a)))
maev = np.mean(np.abs(yv - np.dot(Xv, a)))

# report
print('-----')
print('Training RMSE:', round(rmset, 2))
print('Validation RMSE:', round(rmsev, 2))
print('Tuned Parameters')
print('Memories:', m+1)
#print('Temperature Threshold:', thetaMin+1)
print('Coefficients:', a)

t_rmse='Training RMSE', rmset
v_rmse='Validation RMSE', rmsev
rmse=[t_rmse,v_rmse]

pd.DataFrame(rmse).to_csv(os.path.join(result_path,
    'Power_rmse_scale_shift_m{}_sample{}.csv'.format(m+1,samplesize
    ,base_fname)))

# save coefficient
pd.DataFrame(a).to_csv(os.path.join(data_path,perturb_dir,
    'power_a_scale_shift_m{}_sample{}.csv'.format(m+1,samplesize)))

```

### A.3 CVX Optimization and Cooling Systems Scheduling

Set data Path, import baseline data and trained models

```

import pandas as pd
import numpy as np
from matplotlib import pyplot as plt
import os
import cvxpy as cp

```

```

import math

# ! REMEMBER TO CHANGE THIS EVERYTIME WE SET UP A NEW RUN!!!
current_run_tag = 'Testrun'
base_fname='MIAMIPNNL'

base_dir='{}_baserun'.format(base_fname)
perturb_dir='{}_perturb'.format(base_fname)
cvx_dir='{}_cvx'.format(base_fname)
TPcvx_dir='{}_cvx_T&P'.format(base_fname)

m=20
T_range=3
W_range=0.35
smhr=240 # simulation hour is the 240th hour of the simulation
           period, since 240th hour is the start of the hottest day(7/29),
           we used this day as the optimization day
T_ref=23.888888888889
n= 24
perturbation_method='scale_shift'
sim_period=24
# get current code file path
ipynb_path = os.path.dirname(os.path.realpath("__file__"))

#".." move up one folder
# general_path is the general path where all the file relate to the
# test stored
general_path = os.path.abspath(os.path.join(ipynb_path, ".."))
# data_path where the current run data stores
data_path = os.path.join(general_path,"{}".format(current_run_tag))
# check whether this path exist, if not, build this path
if not os.path.exists(data_path):
    os.mkdir(data_path)
    print('Create new folder: ', data_path)
else:
    print('Folder already existed: ', data_path)

```

```

result_path= os.path.join(general_path , 'results','{}'.format(
    current_run_tag))

# check whether this path exist, if not, build this path
if not os.path.exists(result_path):
    os.mkdir(result_path)
    print('Create new folder: ', result_path)
else:
    print('Folder already existed: ', result_path)

base_output_path = os.path.join(data_path,base_dir)
if os.path.exists(base_output_path):
    print('Folder already existed: ',base_output_path)

perturb_output_path = os.path.join(data_path,perturb_dir)
if os.path.exists(perturb_output_path):
    print('Folder already existed: ',perturb_output_path)
cvx_output_path = os.path.join(data_path, cvx_dir)
if not os.path.exists(cvx_output_path):
    os.mkdir(cvx_output_path)
    print('Create new folder: ',cvx_output_path)
else:
    print('Folder already existed: ',cvx_output_path)

method_cvx_output_path = os.path.join(cvx_output_path,
    perturbation_method)
if not os.path.exists(method_cvx_output_path):
    os.mkdir(method_cvx_output_path)
    print('Create new folder: ',method_cvx_output_path)
else:
    print('Folder already existed: ',method_cvx_output_path)

train_data=pd.read_csv(os.path.join(data_path,perturb_dir ,',
    data_nozero' , 'train_data.csv'),header=0)
train_data= np.asarray(train_data).squeeze()
train_data=train_data[:,1:5]

```

```

val_data=pd.read_csv(os.path.join(data_path,perturb_dir,'data_nozero
','valid_data.csv'),header=0)
val_data= np.asarray(val_data).squeeze()
val_data=val_data[:,1:5]

samplesize=len(train_data)/24/21
samplesize=int(samplesize)

P_pert=train_data[:, 0]
SET_pert=train_data[:, 1]

P_perturbmax=P_pert.max()
P_perturbmin=P_pert.min()
SET_perturbmax=SET_pert.max()
SET_perturbmin=SET_pert.min()

# import perturbation model coefficient
a1= np.genfromtxt(os.path.join(perturb_output_path,"power_a_{}_{m}{}
_sample{}.csv".format(perturbation_method,m,samplesize)),
delimiter=",", dtype=float, skip_header=1)
a1=a1[:,1]
a1 # for dP

a2= np.genfromtxt(os.path.join(perturb_output_path,"SET_a_{}_{m}{}
_sample{}.csv".format(perturbation_method,m,samplesize)),
delimiter=",", dtype=float, skip_header=1)
a2=a2[:,1]
a2 #for SET

# import baseline load, Power consumption from energyplus simulation
    data base run

# for unitary file, baseline only take cooling power for now
# for david file, baseline = total power
pbase_all = pd.read_csv(os.path.join(base_output_path,'p_base.csv'),
header=0)

```

```

pbase_all= np.asarray(pbase_all).squeeze()
pbase_all=pbase_all[:,1]

Pbasemax=pbase_all.max()
Pbasemin=pbase_all.min()

# import baseline SET, Power consumption from energyplus simulation
# data base run
# for unitary file, baseline only take cooling power for now
# for david file, baseline = total power
SETbase_all = pd.read_csv(os.path.join(base_output_path,'SET_base.csv'), header=0)
SETbase_all = np.asarray(SETbase_all).squeeze()
SETbase_all=SETbase_all[:,1]

SETbasemax=SETbase_all.max()
SETbasemin=SETbase_all.min()

```

## Define CVX optimization function

```

#optimization function
def optimization_function_new(a, n, m, Pbase,a2,SETbase,p,s,sP,sS,
    scon,smul,pcon,pmul):
    # Input:
    # a: (m+1, 1) np array, parameter vector beta,coefficient
    # imported from perturbation model
    # n: int, time duration (used to be called 'K'), we simulate
    # time '0' to time 'n-1'
    # m: int, number of coefficients (memory of trace back)
    # Pbase: (n , 1) np array, baseline P values, value imported
    # from data base run
    # Return:
    # the optimized solution for the designated horizon (n=24, 24
    # hours)
    # including both deltaP and deltaT

```

```

# we assume that delta_T(0) = ... = delta_T()
# make zero metrix as placeholder for matrix

dTmem = np.zeros(m-1) # temperature
dWmem = np.zeros(m-1) # airspeed

# declare variable, x is the deltaT (dT) we are trying to solve
for, x2 is the dW
# index remapping: x(k) = dT(k-m+1) <=> dT(k) = x(k+m-1)
#vector variable

x = cp.Variable(n+m-1) # dT
x2 = cp.Variable(n+m-1) # dW

dP = cp.Variable(n) #objective
dS= cp.Variable(n) # objective

objective = cp.Minimize(s*((cp.max(SETbase + dS)-SETbasemin)/(SETbasemax-SETbasemin))+p*(1*((cp.max(Pbase + dP)-Pbasemin)/(Pbasemax-Pbasemin)))+sS*cp.sum(cp.abs(dS[1:n]-dS[:n-1]))+sP*cp.sum(cp.abs(dP[1:n]-dP[:n-1])))

# 2 variable
constraints = [x[0:m-1] == dTmem,x2[0:m-1] == dWmem] #,x3[0:1]
== dRmem,x4[0:1] == dMmem]

# 1 variable
# constraints = [x[0:m-1] == dTmem]

# if n>24 dTmem take previous last m-1 hr

for k in range(n):
    # dP(k) = a(m)*dT(k-m+1) + ... + a(1)*dT(k)
    #           = a(m)*x(k+m-1)+ ... + a(1)*x(k)
    #           = a'*[x(k+m-1); ...; x(k)]
    #           = a'*flipped([x(k+m-1); ...; x(k)])

```

```

# if a has a0 included
#           = a'*flipped([x(k+m-1); ... x(k);1])

# print(np.dot(a, x[k:k + m]))
# Xt=np.hstack([np.ones((Xt.shape[0],1)), Xt])
#print(len(a))

# your perturbation model defined here, # coefficient * k

# if statement make sure the for when shift perturbation is
used, (there will be m+1 coefficients), the x matrix would have
all ones column
if len(a) == m:
    constraints += [dP[k] == cp.sum(cp.multiply(a, x[k: k +
m]))]
    constraints += [dS[k] == cp.sum(cp.multiply(a2, x[k: k +
m]))]

else:
    #scaled objective, 1 variable
    #dPscaled=(dP-dP.min())/(dP.max()-dP.min())-> dP=
    dPscaled*(dP.max()-dP.min())+dP.min()
    constraints += [dP[k] == P_perturbmin+(P_perturbmax-
    P_perturbmin)*(cp.sum(cp.multiply(a, cp.hstack([x[k: k + m],1])))]

    constraints += [dS[k] == SET_perturbmin+
    SET_perturbmax-SET_perturbmin)*(cp.sum(cp.multiply(a2, cp.hstack
    ([x[k: k + m],1]))))]

    # obj not scaled, 1variable
    # constraints += [dP[k] == cp.sum(cp.multiply(a, cp.
    hstack([x[k: k + m],1])))] # hstack 1 add to the end, to match
    the a_flip
    constraints += [dS[k] == cp.sum(cp.multiply(a2, cp.
    hstack([x[k: k + m],1])))]

```

```

        # scaled obj, 2 variable
        constraints += [dP[k] == P_perturbmin+(P_perturbmax-
P_perturbmin)*(cp.sum(cp.multiply(a, cp.hstack([x2[k: k + m],x[k:
k + m],1])))) # hstack 1 add to the end, to match the a_flip
        constraints += [dS[k] == SET_perturbmin+(SET_perturbmax-
SET_perturbmin)*(cp.sum(cp.multiply(a2, cp.hstack([x2[k: k + m],x
[k: k + m],1]))))]

        # obj not scaled, 2 variable
#         constraints += [dP[k] == cp.sum(cp.multiply(a, cp.
hstack([x2[k: k + m],x[k: k + m],1))))] # hstack 1 add to the end
, to match the a_flip
#         constraints += [dS[k] == cp.sum(cp.multiply(a2, cp.
hstack([x2[k: k + m],x[k: k + m],1))))]

        constraints += [cp.abs(x[m-1:n+m])<=1] # dT_setpoint perturb
constraints += [cp.abs(x2[m-1:n+m])<=1] # dW_Airspeed
perturb

prob = cp.Problem(objective, constraints)

#     prob.solve()
prob.solve(verbose=True) # turn verbose on for sampling method
#     print("status:", prob.status)
#     print("optimal value", prob.value)

plt.figure(figsize=(11.25, 7.875))
step = range(n)
plt.plot(step, Pbase, step, Pbase+dP.value)
plt.xlabel('Time [Hour]')
plt.ylabel('[kw]')
plt.grid(True)
plt.legend(['Baseline', 'Optimized'])
plt.title('Power Consumption_day{}'.format(i/n))
# adjust the top leaving bottom unchanged

```

```

plt.yticks(np.arange(0, 4.5, step=0.5)) # Set label locations.
plt.show()

plt.figure(figsize=(11.25, 7.875))
step = range(n)
plt.plot(step, SETbase, step, SETbase+dS.value)
plt.xlabel('Time [Hour]')
plt.ylabel('SET [C]')
plt.grid(True)
plt.legend(['Baseline', 'Optimized'])
plt.title('SET_day{}'.format(i/n))
# adjust the top leaving bottom unchanged
plt.yticks(np.arange(0, 32, step=4)) # Set label locations.
plt.show()

# temperature plot (optimized and unoptimized)
plt.figure(figsize=(11.25, 7.875))
plt.plot(step, T_range*x.value[m-1:m+n]+T_ref)
plt.ylabel('C')
plt.xlabel('Hour')
plt.title('Setpoint_Perturbation_day{}'.format(i/n))
plt.yticks(np.arange(18, 30, step=1))
plt.grid(True)
plt.show()

# temperature plot (optimized and unoptimized)
plt.figure(figsize=(11.25, 7.875))
plt.plot(step, x2.value[m-1:m+n]*W_range+0.35)
plt.ylabel('m/s')
plt.xlabel('Hour')
plt.title('air velocity_Perturbation_day{}'.format(i/n))
plt.yticks(np.arange(0, 0.8, step=0.1)) # set the ylim to
bottom, top
plt.grid(True)
plt.show()

```

```

#      return the optimized solution for the designated horizon (24
hours) take out the memory size value
#      print(len(x.value[m-1:]))
#      print(x.value[m-1:])
#      print(x.value)
#      print(len(x.value))

return dP.value,dS.value,x.value[m-1:],x2.value[m-1:]

```

## Sampling optimization for defined size

```

a1_flip = np.flip(a1)
a2_flip = np.flip(a2)
# flip coefficient a to match the order of x matrix
from smt.sampling_methods import LHS

xlimits = np.array([[0.000, 1.000]])
sampling = LHS(xlimits=xlimits)

num =1000 ##### define sampling size here
Q = sampling(num)

s_group=Q[:, 0] # radom number from 0-1

P_max=[]
S_max=[]

p_weight=[]
s_weight=[]

optimal_dP = []
optimal_dT = []
optimal_dS = []
optimal_dW = []

n=24

```

```

for k in range (num):
    s=s_group[k] # weight for SET: randomly generated number 0-1
    p=1-s # weight for P: 1-weight_SET
    sS=0.003 # Weight for smoothing the optimized result, adjust the
    value here, try a few, see what is making sense
    sP=0.003

    for i in range(0, sim_period, n):
        Pbase = pbase_all[i+smhr:smhr+i+n] # specifying the
        optimizing day, for here is 8/14, start from hr 312
        SETbase = SETbase_all[i+smhr:smhr+i+n]

        #start calling the optimization:function
        optimization_function_new, dT and dP are returns from the
        optimization function
        dP,dS,dT,dW= optimization_function_new(a1_flip, n, m, Pbase,
        a2_flip,SETbase,p,s,sP,sS,scon,smul,pcon,pmul)

        P_max.append(max(Pbase+dP))
        S_max.append(max(SETbase+dS))

        p_weight.append(p)
        s_weight.append(s)

    # accumulate return results to the list
    optimal_dT = optimal_dT + list(dT)
    optimal_dP = optimal_dP + list(dP)
    optimal_dS = optimal_dS + list(dS)
    optimal_dW = optimal_dW + list(dW)

# round up results
for j in range(len(optimal_dT)):
    if abs(optimal_dT[j]) <= 10**(-3):

```

```

    optimal_dT[j] = 0.0
else:
    optimal_dT[j] = round(optimal_dT[j], 2)

for j in range(len(optimal_dW)):
    if abs(optimal_dW[j]) <= 10**(-3):
        optimal_dW[j] = 0.0
    else:
        optimal_dW[j] = round(optimal_dW[j], 2)

pd.DataFrame(optimal_dT).to_csv(os.path.join(method_cvx_output_path
                                              , 'dT_m{}_M00{}_sample{}.csv'.format(m, num, samplesize)))
pd.DataFrame(optimal_dP).to_csv(os.path.join(method_cvx_output_path
                                              , 'dP_m{}_M00{}_sample{}.csv'.format(m, num, samplesize)))
pd.DataFrame(optimal_dS).to_csv(os.path.join(method_cvx_output_path
                                              , 'dS_m{}_M00{}_sample{}.csv'.format(m, num, samplesize)))
pd.DataFrame(optimal_dW).to_csv(os.path.join(method_cvx_output_path
                                              , 'dW_m{}_M00{}_sample{}.csv'.format(m, num, samplesize)))
pd.DataFrame(P_max).to_csv(os.path.join(method_cvx_output_path
                                              , 'P_max_m{}_M00{}_sample{}.csv'.format(m, num, samplesize)))
pd.DataFrame(S_max).to_csv(os.path.join(method_cvx_output_path
                                              , 'S_max_m{}_M00{}_sample{}.csv'.format(m, num, samplesize)))

```

Read optimization results, define weights for the peak power and SET reduction, visualizing the optimized results.

```

P_max= np.genfromtxt(os.path.join(method_cvx_output_path , 'P_max_m{}_'
                                              _M00{}_sample{}.csv'.format(m, num, samplesize)), delimiter=",",
                                              dtype=float, skip_header=1)
P_max=P_max[:,1]
S_max= np.genfromtxt(os.path.join(method_cvx_output_path , 'S_max_m{}_'
                                              _M00{}_sample{}.csv'.format(m, num, samplesize)), delimiter=",",
                                              dtype=float, skip_header=1)
S_max=S_max[:,1]

```

```

# define your weight here for the objective function
s_weight=0.20
p_weight=0.80
# the objective is the weighted sum of the scaled max P and SET
# reduction
objective_score=((P_max-min(P_max))/(max(P_max)-min(P_max)))*
    p_weight+((S_max-min(S_max))/(max(S_max)-min(S_max)))*s_weight
q1=objective_score.tolist().index(min(objective_score))
q1
result_path = os.path.join(result_path,base_fname)
if not os.path.exists(result_path):
    os.mkdir(result_path)
    print('Create new folder: ',result_path)
else:
    print('Folder already existed: ',result_path)

result_output_path = os.path.join(result_path,'s{}p{}index{}'.format
(s_weight,p_weight,q1))
if not os.path.exists(result_output_path):
    os.mkdir(result_output_path)
    print('Create new folder: ',result_output_path)
else:
    print('Folder already existed: ',result_output_path)
plt.figure(figsize=(11.25, 7.875))
plt.plot(P_max, S_max, "o")
plt.plot(P_max[q1],S_max[q1], "o",color='orange')

plt.xlabel("Peak Power [kw]",fontsize=13)
plt.ylabel("Peak SET [C]",fontsize=13)
plt.legend(['MOO sampling {}'.format(num),'best solution {}_SET {}'
    '_power, index {}'.format(s_weight,p_weight,q1)]#, 'best solution
    # about 20%_SET 80%_power, index {}'.format(q2), 'best solution
    # about 20%_SET 80%_power, index {}'.format(q3)]#, 'best solution
    # about 20%_SET 80%_power, index {}'.format(q4), 'best solution
    # about 20%_SET 80%_power, index {}'.format(q5)])
plt.title('MOO sampling and solution',fontsize=15)

```

```

plt.savefig(os.path.join(result_output_path,'MOO single index.png'))
plt.show()

```

Check Optimized Results with EP Simulation, Set  
data path and import baseline and optimized data

```

import os
import numpy as np
import pandas as pd
from matplotlib import pyplot as plt

index=1
sweight=0.25
pweight=0.75
base_fname='MIAMIPNNL'
current_run_tag = 'Testrun'

samplesize=1# number of ep run in data generation

base_dir='{}_{baserun}'.format(base_fname)
perturb_dir='{}_{perturb}'.format(base_fname)
cvx_dir='{}_{cvx}'.format(base_fname)
TPcvx_dir='{}_{cvx_T&P}'.format(base_fname)

m=20 # perturbation model training memory size
num=2 # moo sampling size

W_range=0.35
T_range=3

T_ref=23.888888888889
smhr=240 # simulation hour is the 240th hour of the simulation
          period, since 240th hour is the start of the hottest day(7/29),
          we used this day as the optimization day
sim_begin_day=29

```

```

sim_begin_month=7
sim_period = 24 # number of hours
n=24 #optimization period, hr

perturbation_method='scale_shift'

# get current code file path
ipynb_path = os.path.dirname(os.path.realpath("__file__"))

#".." move up one folder
# general_path is the general path where all the file relate to the
# test stored
general_path = os.path.abspath(os.path.join(ipynb_path, ".."))

# data_path where the current run data stores
data_path = os.path.join(general_path, "{}".format(current_run_tag))
# check whether this path exist, if not, build this path
if not os.path.exists(data_path):
    os.mkdir(data_path)
    print('Create new folder: ', data_path)
else:
    print('Folder already existed: ', data_path)

result_path = os.path.join(general_path, 'results',"{}".format(
    current_run_tag),base_fname,'s{}p{}index{}'.format(sweight,
    pweight,index))
if not os.path.exists(result_path):
    os.mkdir(result_path)
    print('Create new folder: ',result_path)
else:
    print('Folder already existed: ',result_path)

base_output_path = os.path.join(data_path,base_dir)
if os.path.exists(base_output_path):
    print('Folder already existed: ',base_output_path)
perturb_output_path = os.path.join(data_path,perturb_dir)
if os.path.exists(perturb_output_path):

```

```

    print('Folder already existed: ',perturb_output_path)

cvx_output_path = os.path.join(data_path, cvx_dir)
if not os.path.exists(cvx_output_path):
    os.mkdir(cvx_output_path)
    print('Create new folder: ',cvx_output_path)
else:
    print('Folder already existed: ',cvx_output_path)

method_cvx_output_path = os.path.join(cvx_output_path,
                                     perturbation_method)
if not os.path.exists(method_cvx_output_path):
    os.mkdir(method_cvx_output_path)
    print('Create new folder: ',method_cvx_output_path)
else:
    print('Folder already existed: ',method_cvx_output_path)

TPcvx_output_path = os.path.join(data_path,TPcvx_dir)
if not os.path.exists(TPcvx_output_path):
    os.mkdir(TPcvx_output_path)
    print('Create new folder: ',TPcvx_output_path)
else:
    print('Folder already existed: ',TPcvx_output_path)

dT= np.genfromtxt(os.path.join(cvx_output_path ,perturbation_method ,
                               "dT_{}{}_M00{}_sample{}.csv".format(m,num,samplesize)),delimiter=",",
                  dtype=float, skip_header=1)
setpoint=dT[:,1]*T_range+T_ref # scale back dT
setpoint=setpoint[24*index:24*(index+1)]
setpoint

dW= np.genfromtxt(os.path.join(cvx_output_path ,perturbation_method ,
                               "dW_{}{}_M00{}_sample{}.csv".format(m,num,samplesize)),delimiter=",",
                  dtype=float, skip_header=1)
airspeed=dW[:,1]*W_range+0.35 # scale back dW
airspeed=airspeed[24*index:24*(index+1)]
airspeed

```

```

fanonoff=airspeed/0.7
fanonoff

```

Listing A.2: Set Data Path and Import Data

## Apply optimized cooling system schedules to EP

```

# build IDD file path for windows or mac systems
from sys import platform
if platform == "darwin":
    # Mac (IOS)
    energyplus_path = '/Applications/EnergyPlus-9-5-0'
elif "win" in platform:
    # Windows
    energyplus_path = 'C://EnergyPlusV9-5-0'
else:
    raise ValueError()
print(energyplus_path)

# weather file path
epw_name = 'USA_FL_Miami.Intl.AP.722020_TMY3.epw'
weather_filepath = os.path.join(general_path, 'weather', ,
    'USA_FL_Miami.Intl.AP.722020_TMY3', epw_name)
assert os.path.exists(weather_filepath)

# set energyplus path, needs python reboot if changed
from eppy.modeleditor import IDF
IDF.setiddname(os.path.join(energyplus_path, 'Energy+.idd'))

# establish idf file
fname= os.path.join(general_path, 'PNNLexamplefile','{}.idf'.format(
    base_fname))
assert os.path.exists(fname)
idf = IDF(fname, weather_filepath)

allschedule=idf.idfobjects['Schedule:Compact']

```

```

ClgSetPSch=allschedule[-5]
VairSch=allschedule[-2]
fanSch=allschedule[0]

run_period=idf.idfobjects['RunPeriod'][0]
run_period

# the perturbationtraining data start from 7/7 end in 8/4
# the cvx optimization day starts on 7/7 end in sim_period/n
# begin day
run_period.Begin_Month=sim_begin_month
run_period.Begin_Day_of_Month=sim_begin_day
# end day
run_period.End_Month=sim_begin_month
run_period.End_Day_of_Month=sim_begin_day

run_period # hottest day as optimization day

# apply setpoint from cvx to energyplus cooling schedule
#if only analyze one day, set schedule through 12/31
#if have more than one days' schedule for input, input day by day,
    end in 12/31
# energyplus need schedule to end in 12/31 to work properly
for i in range(int(sim_period/24)):

    if i+1==int(sim_period/24):
        ClgSetPSch['Field_{}'.format(1+26*i)]= 'Through:12/31'
        ClgSetPSch['Field_{}'.format(1+1+26*i)]= 'For: AllDays'
        VairSch['Field_{}'.format(1+26*i)]= 'Through:12/31'
        VairSch['Field_{}'.format(1+1+26*i)]= 'For: AllDays'
        fanSch['Field_{}'.format(1+26*i)]= 'Through:12/31'
        fanSch['Field_{}'.format(1+1+26*i)]= 'For: AllDays'

    else:
        ClgSetPSch['Field_{}'.format(1+26*i)]= 'Through:7/{}'.format(
i+sim_begin_day) # starting from 7/7
        ClgSetPSch['Field_{}'.format(1+1+26*i)]= 'For: AllDays'
        VairSch['Field_{}'.format(1+26*i)]= 'Through:7/{}'.format(i+

```

```

    sim_begin_day)

    VairSch['Field_{}'.format(1+1+26*i)]= 'For: AllDays'
    fanSch['Field_{}'.format(1+26*i)]= 'Through:7/{}'.format(i+
sim_begin_day)

    fanSch['Field_{}'.format(1+1+26*i)]= 'For: AllDays'
    for h in range(24):
        ClgSetPSch['Field_{}'.format(1+1+26*i+h+1)]= 'Until: {}:00,{}'.
format(h+1, setpoint[0+i*24:24+i*24][h])
        VairSch['Field_{}'.format(1+1+26*i+h+1)]= 'Until: {}:00,{}'.
format(h+1, airspeed[0+i*24:24+i*24][h])
        fanSch['Field_{}'.format(1+1+26*i+h+1)]= 'Until: {}:00,{}'.
format(h+1, fanonoff[0+i*24:24+i*24][h])

# build baseline output data folder first
method_TPcvx_output_path= os.path.join(TPcvx_output_path,
perturbation_method)
if not os.path.exists(method_TPcvx_output_path):
    os.mkdir(method_TPcvx_output_path)
else:
    print('Folder already existed: ',method_TPcvx_output_path)

idf.run(readvars=True, expandobjects=True, output_directory=
method_TPcvx_output_path)

```

## Visualize and save results

```

Data = np.genfromtxt(os.path.join(method_TPcvx_output_path, "
eplusout.csv"), delimiter=",", dtype=float, skip_header=49)
_,c=Data.shape
Tout=Data[:,1:2] # Tout at column 1
MRT=Data[:,2:3]
Tair=Data[:,4:5]
RH=Data[:,5:6]
Setpt=Data[:,6:7]

SET=Data[:,c-1:c]

```

```

P_kw=Data[:,c-2:c-1]/1000
P_kw_cool=Data[:,c-3:c-2]/1000

# import baseline data from data generation folder
pbase = pd.read_csv(os.path.join(base_output_path,'p_base.csv'),
                     header=0)
pbase = np.asarray(pbase).squeeze()
pbase=pbase[:,1] # get rid of first column of index
# get the baseline P data for the last day
pbase=pbase[smhr:smhr+n]
pbase

SETbase = pd.read_csv(os.path.join(base_output_path,'SET_base.csv'),
                      header=0)
SETbase = np.asarray(SETbase).squeeze()
SETbase=SETbase[:,1]
SETbase=SETbase[smhr:smhr+n]
SETbase

dP= np.genfromtxt(os.path.join(method_cvx_output_path,"dP_m{}_MOO{}"
                               "_sample{}.csv".format(m,num,samplesize)), delimiter=",",
                  dtype=float, skip_header=1)
p_cvx=dP[:,1][24*index:24*(index+1)]+pbase # get rid of first
                                               column
p_cvx

dS= np.genfromtxt(os.path.join(method_cvx_output_path,"dS_m{}_MOO{}"
                               "_sample{}.csv".format(m,num,samplesize)), delimiter=",",
                  dtype=float, skip_header=1)
SET_cvx=dS[:,1][24*index:24*(index+1)]+SETbase # get rid of first
                                               column
SET_cvx

SET_flatten=np.reshape(SET,24)
SET_flatten

```

```

err=SET_cvx.tolist()-SET_flatten
err

rel_errs = abs(err)/SET_flatten
rel_errs

UL=30*np.ones(24)
LL=17*np.ones(24)
nL=22.2*np.ones(24)
nU=25.6*np.ones(24)

plt.figure(figsize=(11.25, 7.875))
step = range(n)
plt.errorbar(step,SET_cvx[0:n], yerr=err, capsized=2, uplims=True,
             color='lightsteelblue', linewidth=2.5) #, uplims=True, lolims=True
             , label='uplims=True, lolims=True')
for r_err, x,y in zip(rel_errs, step,SET_cvx[0:n]):
    plt.annotate('{:.2f}'.format(r_err), (x-0.05, y+0.05))

# other lines
plt.xlabel('Time [Hour]', fontsize=13)
plt.ylabel('C', fontsize=13)
shadingx = np.linspace(0, 24)
plt.gca().fill_between(shadingx, 22.2,25.6, facecolor = 'grey',
                       edgecolors = 'grey', alpha = 0.2)
shadingx2 = np.linspace(0, 24)
plt.gca().fill_between(shadingx, 17,30, facecolor = 'lightgrey',
                       edgecolors = 'lightgrey', alpha = 0.3)
# plt.plot(step,UL[0:n],color='salmon', linewidth=0.5)
# plt.plot(step,LL[0:n],color='tomato', linewidth=0.5)
# plt.plot(step,nL[0:n],color='gold', linewidth=0.5)
# plt.plot(step,nU[0:n],color='goldenrod', linewidth=0.5)
plt.plot(step,SETbase[0:n],color='palevioletred', linewidth=2.5)
plt.plot(step,SET[0:n],color='royalblue', linewidth=3)
plt.legend(['baseline SET', 'SET_EnergyPlus', 'Thermal neutrality zone
            ', 'Thermal comfort zone', 'SET_CVX',])
plt.title('SET', fontsize=15)

```

```

plt.yticks(np.arange(0, 32, step=2))
plt.grid(True, linewidth=0.2)
plt.savefig(os.path.join(result_path, 'SET_withRE_p{}s{}_index{}.png',
    .format(pweight, sweight, index)))

P_kw_total_flatten=np.reshape(P_kw,24)
P_kw_total_flatten

p_err=p_cvx.tolist()-P_kw_total_flatten
p_err

#RELATIVE ERROR
p_rel_errs=abs(p_err)/P_kw_total_flatten
p_rel_errs

# power with error
plt.figure(figsize=(11.25, 7.875))
step = range(n)

plt.errorbar(step,p_cvx[0:n], yerr=p_err, capsized=2, uplims=True,
    color='lightsteelblue', linewidth=2.5) #, uplims=True, lolims=True
    , label='uplims=True, lolims=True')
for r_err, x,y in zip(p_rel_errs, step,p_cvx[0:n]):
    plt.annotate('{:.2f}'.format(r_err), (x-0.05, y+0.05))

plt.plot(step,pbase[0:24],color='palevioletred', linewidth=2.5)
plt.plot(step,P_kw[0:24],color='royalblue', linewidth=3)
plt.xlabel('Time [Hour]', fontsize=13)
plt.ylabel('P[kw]', fontsize=13)
plt.legend(['baseline', 'Power_EnergyPlus', 'Power_CVX',])
plt.title('Power', fontsize=15)
plt.grid(True, linewidth=0.2)
plt.yticks(np.arange(0, 6, step=0.5)) # Set label locations.
plt.savefig(os.path.join(result_path, 'power_withRE_p{}s{}_index{}'.
    png'.format(pweight, sweight, index)))

```

```

plt.figure(figsize=(10, 7))
step = range(n)
plt.plot(step, airspeed[0:24], linewidth=2.5, color='teal')
plt.plot(step, baselineairspeed[0:24], linewidth=1.5, color='palevioletred')
plt.xlabel('Time [Hour]', fontsize=13)
plt.ylabel('m/s', fontsize=13)
plt.grid(True)
plt.title('Airspeed', fontsize=15)
plt.ylim(-0.1, 0.8)    # set the ylim to bottom, top
plt.xlim(0, 24)      # set the ylim to bottom, top
plt.grid(True, linewidth=0.2)
plt.savefig(os.path.join(result_path, 'airspeed_p{}s{}_index{}.png'.
format(pweight, sweight, index)))

plt.figure(figsize=(10, 7))
step = range(n)
plt.plot(step, setpoint[0:24], linewidth=2.5, color='teal')
plt.plot(step, baselinesetpoint[0:24], linewidth=1.5, color='palevioletred')
plt.xlabel('Time [Hour]', fontsize=15)
plt.ylabel('C', fontsize=15)
plt.grid(True)
plt.title('Setpoint', fontsize=15)
plt.ylim(17, 30)    # set the ylim to bottom, top
plt.xlim(0, 24)      # set the ylim to bottom, top
plt.grid(True, linewidth=0.2)
plt.savefig(os.path.join(result_path, 'setpoint_p{}s{}_index{}.png'.
format(pweight, sweight, index)))

pd.DataFrame(P_kw_cool).to_csv(os.path.join(result_path, 'Pcool_EP_p{}s{}_index{}.csv'.format(pweight, sweight, index)))
pd.DataFrame(P_kw-P_kw_cool).to_csv(os.path.join(result_path, 'Pother_EP_p{}s{}_index{}.csv'.format(pweight, sweight, index)))
pd.DataFrame(P_kw).to_csv(os.path.join(result_path, 'p_EP_p{}s{}_index{}.csv'.format(pweight, sweight, index)))

```

```
pd.DataFrame(SET).to_csv(os.path.join(result_path,'SET_EP_p{}s{}  
_index{}.csv'.format(pweight,sweight,index)))  
pd.DataFrame(p_cvx).to_csv(os.path.join(result_path,'p_cvx_p{}s{}  
_index{}.csv'.format(pweight,sweight,index)))  
pd.DataFrame(SET_cvx).to_csv(os.path.join(result_path,'SET_cvx_p{}s  
{}_index{}.csv'.format(pweight,sweight,index)))  
pd.DataFrame(pbase).to_csv(os.path.join(result_path,'pbase_p{}s{}  
_index{}.csv'.format(pweight,sweight,index)))  
pd.DataFrame(SETbase).to_csv(os.path.join(result_path,'SETbase_p{}s  
{}_index{}.csv'.format(pweight,sweight,index)))  
pd.DataFrame(setpoint).to_csv(os.path.join(result_path,'setpoint_p{}  
s{}_index{}.csv'.format(pweight,sweight,index)))  
pd.DataFrame(airspeed).to_csv(os.path.join(result_path,'airspeed_p{}  
s{}_index{}.csv'.format(pweight,sweight,index)))
```



# Appendix B

## Energy Storage System Scheduling

This section demonstrate python based workflow works based in google Colab. The setup of EnergyPlus in Colab is different from how it was done in Jupyter Notebook.

### B.1 Data Generation

Mount Colab path in Google Drive

```
import pandas as pd
import os
import numpy as np
from matplotlib import pyplot as plt
from google.colab import drive
drive.mount('/content/drive', force_remount=False)
```

Setup EnergyPlus and Eppy in Colab environment

```

# https://github.com/woo-seung/energyplus_colab/blob/master/
    energyplus_colab.ipynb

# install EP to "/usr/local/EnergyPlus-9-5-0"
!chmod +x /content/drive/My\ Drive/EnergyPlus-9.5.0-de239b2e5f-Linux-
-Ubuntu18.04-x86_64.sh

!sudo /content/drive/My\ Drive/EnergyPlus-9.5.0-de239b2e5f-Linux-
Ubuntu18.04-x86_64.sh

# to capture C-level stdout/stderr pipes in Python
# !pip install wurlitzer

# check EP
print('\n- Check EnergyPlus Version')
!energyplus -version

# setting
# %load_ext wurlitzer
# %unload_ext wurlitzer

import sys
import shutil
energyplus_path = '/usr/local/EnergyPlus-9-5-0'
sys.path.insert(0, energyplus_path)
# from pyenergyplus.api import EnergyPlusAPI
!pip install eppy
# set energyplus path, needs python reboot if changed
from eppy.modeleditor import IDF
IDF.setiddname(os.path.join(energyplus_path, 'Energy+.idd'))

```

Set data paths

```

# for file naming in various battery and pv capacity settings
B_string=5 # number of battery parallel string in battery in the idf
file

PV_percent=90 # PV surface coverage % in idf file

dic_path= '/content/drive/My Drive/PVbattery/'
run_path=os.path.join(dic_path, "B{}PV{}".format(B_string,PV_percent
))

if not os.path.exists(run_path):

```

```

os.mkdir(run_path)
print('Create new folder: ', run_path)
else:
    print('Folder already existed: ', run_path)

# build model specific baseline output path
BASE_OUTPUT_PATH= os.path.join(run_path, "B{}PV{}baserun".format(
    B_string,PV_percent))
if not os.path.exists(BASE_OUTPUT_PATH):
    os.mkdir(BASE_OUTPUT_PATH)
    print('Create new folder: ', BASE_OUTPUT_PATH)
else:
    print('Folder already existed: ', BASE_OUTPUT_PATH)

# initial base run
sub1_BASE_OUTPUT_PATH= os.path.join(BASE_OUTPUT_PATH, 'B{}PV{}'
    baserun1'.format(B_string,PV_percent))
if not os.path.exists(sub1_BASE_OUTPUT_PATH):
    os.mkdir(sub1_BASE_OUTPUT_PATH)
    print('Create new folder: ', sub1_BASE_OUTPUT_PATH)
else:
    print('Folder already existed: ', sub1_BASE_OUTPUT_PATH)

# base run after editing charging schedule
sub2_BASE_OUTPUT_PATH= os.path.join(BASE_OUTPUT_PATH, 'B{}PV{}'
    baserun2'.format(B_string,PV_percent))
if not os.path.exists(sub2_BASE_OUTPUT_PATH):
    os.mkdir(sub2_BASE_OUTPUT_PATH)
    print('Create new folder: ', sub2_BASE_OUTPUT_PATH)
else:
    print('Folder already existed: ', sub2_BASE_OUTPUT_PATH)

# build model specific perturb output path
PERTURB_OUTPUT_PATH= os.path.join(run_path, 'B{}PV{}perturb'.format(
    B_string,PV_percent))

```

```

if not os.path.exists(PERTURB_OUTPUT_PATH):
    os.mkdir(PERTURB_OUTPUT_PATH)
    print('Create new folder: ', PERTURB_OUTPUT_PATH)
else:
    print('Folder already existed: ', PERTURB_OUTPUT_PATH)

# path for saving perturbation data
DATA_PERTURB_OUTPUT_PATH= os.path.join(PERTURB_OUTPUT_PATH, "B{}PV{}perturbdata".format(B_string,PV_percent))
if not os.path.exists(DATA_PERTURB_OUTPUT_PATH):
    os.mkdir(DATA_PERTURB_OUTPUT_PATH)
    print('Create new folder: ', DATA_PERTURB_OUTPUT_PATH)
else:
    print('Folder already existed: ', DATA_PERTURB_OUTPUT_PATH)

perturb_output_path2= os.path.join(PERTURB_OUTPUT_PATH, 'dTdWdD')
if not os.path.exists(perturb_output_path2):
    os.mkdir(perturb_output_path2)
else:
    print(perturb_output_path2, "exist")

# path for saving ML training data
ML_PATH = os.path.join(PERTURB_OUTPUT_PATH, 'B{}PV{}ML_model'.format(B_string,PV_percent))
if not os.path.exists(ML_PATH):
    os.mkdir(ML_PATH)
    print('Create new folder: ', ML_PATH)
else:
    print('Folder already existed: ', ML_PATH)

# path for saving optimization results
OPT_PATH = os.path.join(run_path, 'B{}PV{}opt'.format(B_string,PV_percent))
if not os.path.exists(OPT_PATH):
    os.mkdir(OPT_PATH)
    print('Create new folder: ', OPT_PATH)

```

```

else:
    print('Folder already existed: ', OPT_PATH)

# path for saving optimized EP checking results
EP_OPT_PATH = os.path.join(OPT_PATH, 'EP_RUN')
if not os.path.exists(EP_OPT_PATH):
    os.mkdir(EP_OPT_PATH)
    print('Create new folder: ', EP_OPT_PATH)
else:
    print('Folder already existed: ', EP_OPT_PATH)

# path for importing IDF files
IDF_FOLDER = os.path.join(run_path, 'B{}PV{}idf'.format(B_string,
PV_percent))
if not os.path.exists(IDF_FOLDER):
    os.mkdir(IDF_FOLDER)
    print('Create new folder: ', IDF_FOLDER)
else:
    print('Folder already existed: ', IDF_FOLDER)

MANUAL_PATH = os.path.join(run_path, 'B{}PV{}manual'.format(B_string,
PV_percent))
if not os.path.exists(MANUAL_PATH):
    os.mkdir(MANUAL_PATH)
    print('Create new folder: ', MANUAL_PATH)
else:
    print('Folder already existed: ', MANUAL_PATH)

# path for saving plots
PLOT_PATH = os.path.join(run_path, 'B{}PV{}plots'.format(B_string,
PV_percent))
if not os.path.exists(PLOT_PATH):
    os.mkdir(PLOT_PATH)
    print('Create new folder: ', PLOT_PATH)
else:
    print('Folder already existed: ', PLOT_PATH)

```

## Run baseline EP file

```
EPW_PATH = r'/content/drive/My Drive/PVbattery/idf/USA_FL_Miami.Intl.AP.722020_TMY3.epw'
IDF_PATH = r'{}{}'.format(IDF_FOLDER, base_fname)
idf = IDF(IDF_PATH, EPW_PATH)
base_fname='MIAMIPNNL_B{}PV{}opt'.format(B_string,PV_percent)
idf = IDF(IDF_PATH, EPW_PATH)
idf.run(readvars=True, expandobjects=True, output_directory=
        sub1_BASE_OUTPUT_PATH)

df_base = pd.read_csv (os.path.join(sub1_BASE_OUTPUT_PATH, 'eplusout.csv'))
# df_base[216:]
# after getting rid of 217, starting from 7/19 1:00
# DATE: hottest 7/29 4pm [240:240+24]

L=len(np.array(df_base[216:]['Environment:Site Outdoor Air Drybulb
Temperature [C](Hourly)']))
Tout=np.reshape(np.array(df_base[216:]['Environment:Site Outdoor Air
Drybulb Temperature [C](Hourly)]),(L,1))
PV=np.reshape(np.array(df_base[216:]['PV ARRAY LOAD CENTER:Electric
Load Center Produced Electricity Rate [W](Hourly)'])/1000,(L,1))
BD=np.reshape(np.array(df_base[216:]['LIIONBATTERY:Electric Storage
Discharge Power [W](Hourly)'])/1000,(L,1))
BC=np.reshape(np.array(df_base[216:]['LIIONBATTERY:Electric Storage
Charge Power [W](Hourly)'])/1000,(L,1))
P_buy=np.reshape(np.array(df_base[216:]["Whole Building:Facility Net
Purchased Electricity Rate [W](Hourly)"])/1000,(L,1))
P_demand=np.reshape(np.array(df_base[216:]["Whole Building:Facility
Total Electricity Demand Rate [W](Hourly)"])/1000,(L,1))
```

## B.2 Energy Storage System Scheduling

Extract baseline battery charging and discharging schedules

```
i_num=4
# discharge_baseline_sch
# charge_baseline_sch
allschedule=idf.idfobjects['Schedule:Compact']
dischargeSch=allschedule[-6]
chargeSch=allschedule[-7]

discharge_baseline_sch=[]
charge_baseline_sch=[]
for time_ct in range(24):
    discharge_baseline_sch.append(float(dischargeSch['Field_{}'.
format(i_num)]))
    charge_baseline_sch.append(float(chargeSch['Field_{}'.format(
i_num)]))
    i_num=i_num+2
    time_ct=time_ct+1

discharge_capacity_limit=sum(discharge_baseline_sch)
# discharge_capacity_limit=round(discharge_capacity_limit, 1)
discharge_capacity_limit=discharge_capacity_limit*0.978
discharge_capacity_limit

# hrs that PV could supply all demand
x1=[]
for i in range(24):
    if PV[240:240+24][i]>P_demand[240:240+24][i]+BC[240:240+24][i]:
        x1.append(i)
print(x1)
plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Power (kW)', fontsize=15)
plt.rcParams['font.family'] = 'serif'
```

```

plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(P_buy[240:240+24],color='palevioletred', linewidth=2.5, label = 'Baseline Purchased Power')
plt.plot(PV[240:240+24],color='orange', linewidth=1, label = 'PV' )
plt.plot(BD[240:240+24],color='teal', linewidth=1, label = 'Discharge Power')
plt.plot(BC[240:240+24],color='yellowgreen', linewidth=1, label = 'Charge Power' )
plt.plot(P_demand[240:240+24],color='grey', linewidth=1, label = 'Demand Power')
# plt.plot(BC[240:240+24]+P_demand[240:240+24],color='green',
#          linewidth=1, label = 'Charge+Demand Power' )
# plt.axhline(y=ave_integrated_value, color='dimgray', linestyle =':',label='P buy positive average' )
plt.axvline(x=x1[0], color='dimgray', linestyle=':',label='PV self supply start' )
plt.axvline(x=x1[-1], color='dimgray', linestyle=':',label='PV self supply end' )

# plt.legend(bbox_to_anchor=(1,0), loc="lower left")
plt.xticks(np.arange(0, 24, step=5))
plt.yticks(np.arange(-14, 18, step=3))

plt.grid(True, linewidth=0.1)

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "NNP&shcedule_analysis_baseline1.PDF"), dpi=1500)

```

## Generate New Discharging Schedule

```

P_buy_pos=[]
active_num = 0
for i in range(24):
    if P_buy[240:240+24][i]>0.1:
        P_buy_pos.append(float(list(P_buy[240:240+24])[i]))
        active_num += 1

```

```

    else:
        P_buy_pos.append(0)
print(sum(P_buy_pos))
print(active_num)

ave_integrated_value=np.array(sum(P_buy_pos))/(24-len(x1))
ave_integrated_value

discharge_cap_EP=2780/1000 #this value takes from the the idf file,
# object: ElectricLoadCenter:Distribution, value: Design Storage
# Control Discharge Power. This value represent the discharge power
# with the schedule maximum fraction of value 1.

new_discharge_sch=[]
for j in range(24):
    if x1[0]<=j<=x1[-1]:
        new_discharge_sch.append(0)
    elif j < 24:
        new_discharge_sch.append(discharge_baseline_sch[j]+(P_buy_pos[j]-ave_integrated_value)/discharge_cap_EP)
new_discharge_sch

for i in range (24):
    if new_discharge_sch[i]<0:
        new_discharge_sch[i]=0
new_discharge_sch

# if sum(new_discharge_sch)>discharge_capacity_limit:
for i in range(24):
    new_discharge_sch[i]=(new_discharge_sch[i]/sum(new_discharge_sch))
    *discharge_capacity_limit
new_discharge_sch

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)

```

```

plt.ylabel('Discharge Fraction', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(discharge_baseline_sch, color='palevioletred', linewidth=2.5)
plt.plot(new_discharge_sch, color='royalblue', linewidth=2.5)
# plt.legend(['baseline discharge schedule','optimized discharge
# schedule'])#, loc='lower center')
plt.axvline(x=x1[0], color='dimgray', linestyle=':', label='PV self
    supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':', label='PV self
    supply end')
plt.xticks(np.arange(0, 24, step=5))
plt.yticks(np.arange(0, 1.2, step=0.2))
plt.grid(True, linewidth=0.1)
# plt.legend(bbox_to_anchor=(1,0), loc="lower left")

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH,"NN_manual_dischargesch{}.PDF".
    format(discharge_capacity_limit)), dpi=1500)

```

Apply new discharge schedule to Idf file

```

# idf_updated = IDF(IDF_PATH_updated, EPW_PATH)
allschedule=idf.idfobjects['Schedule:Compact']
dischargeSch=allschedule[-6]
i_str=3 # string field
i_num=4 # setpoint number field
i_hr=0 # field time start
time_ct=0 # count number of setpoint for a day
for time_ct in range(24):
    i_hr=i_hr+1
    dischargeSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    i_str=i_str+2
    dischargeSch['Field_{}'.format(i_num)]=list(new_discharge_sch)[
        time_ct]
    i_num=i_num+2

```

```

idf.run(readvars=True, expandobjects=True, output_directory=
MANUAL_PATH)

df_manual = pd.read_csv (os.path.join(MANUAL_PATH , 'eplusout.csv'))

Tout3=list(df_manual[216:]['Environment:Site Outdoor Air Drybulb
Temperature [C](Hourly)'])
PV3=list(df_manual[216:]['PV ARRAY LOAD CENTER:Electric Load Center
Produced Electricity Rate [W](Hourly)'])/1000
BD3=list(df_manual[216:]['LIIIONBATTERY:Electric Storage Discharge
Power [W](Hourly)'])/1000
P_buy3=list(df_manual[216:]["Whole Building:Facility Net Purchased
Electricity Rate [W](Hourly)"])/1000
P_demand3=list(df_manual[216:]["Whole Building:Facility Total
Electricity Demand Rate [W](Hourly)"])/1000
BC3=list(df_manual[216:]['LIIIONBATTERY:Electric Storage Charge Power
[W](Hourly)'])/1000

max(P_buy3[240:240+24])

# baseline peak without PV and battery
baseline_peak=3.446326647640300

a=int((max(P_buy[240:240+24])-max(P_buy3[240:240+24]))/max(P_buy
[240:240+24])*100)
print("Reduced Power compare to PVB default without new scheduling",
a, "%")

b=int((baseline_peak-max(P_buy3[240:240+24]))/baseline_peak*100)
print("Reduced Power compare to baseline",b, "%")

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Power (kW)', fontsize=15)
plt.rcParams['font.family'] = 'serif'

```

```

plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(P_buy[240:240+24],color='palevioletred', linewidth=2.5)
# plt.plot(list(predicted_opt_pbuy[minindex*24:minindex*24+24]), color='royalblue', linewidth=2.5, linestyle='dotted')
plt.plot(P_buy3[240:240+24],color='royalblue', linewidth=2.5)
# plt.legend(['Purchased Power_baseline ','Purchased Power manual reschedule']), loc='lower center')
# plt.title("Reduced Power{}%".format(a))
plt.yticks(np.arange(-14, 7, step=3))
plt.axhline(y=ave_integrated_value, color='dimgray', linestyle=':', label='P buy positive average')
plt.axvline(x=x1[0], color='dimgray', linestyle=':', label='PV self supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':', label='PV self supply end')
plt.grid(True, linewidth=0.1)
# plt.legend(bbox_to_anchor=(1,0), loc="lower left")

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "NN_EP_manual{}.PDF".format(discharge_capacity_limit)), dpi=1500)

P_buy_pos3=[]
for i in range(24):
    if P_buy3[240:240+24][i]>0.1:
        P_buy_pos3.append(list(P_buy3[240:240+24])[i])
    else:
        P_buy_pos3.append(0)
plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Power (kW)', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(P_buy_pos, color='palevioletred', linewidth=2.5, label='Purchased power baseline')
plt.plot(P_buy_pos3,color='royalblue', linewidth=2.5, label='Purchased

```

```

    power manual reschedule')

plt.axhline(y=ave_integrated_value, color='dimgray', linestyle=':', 
            label='P buy positive average')
# plt.axhline(y=ave_integrated_value2, color='dimgray', linestyle
# =':',label='P buy positive average')

plt.axvline(x=x1[0], color='dimgray', linestyle=':',label='PV self
            supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':',label='PV self
            supply end')
plt.xticks(np.arange(0, 24, step=5))

# plt.title("Reduced Power{}%".format(a))
# plt.legend(bbox_to_anchor=(1,0), loc="lower left")
plt.yticks(np.arange(0,4, step=0.6))
plt.grid(True, linewidth=0.1)

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH,"NN_EP_manual_posP{}.PDF".format(
    discharge_capacity_limit)),dpi=1500)

idf_updated.saveas('/content/drive/My Drive/PVbattery/B{}PV{}/B{}PV
    {}idf/MIAMIPNNL_B{}PV{}opt_BDreschedule.idf'.format(B_string,
PV_percent,B_string,PV_percent,B_string,PV_percent))

```



# Appendix C

## Cooling and Energy Storage Systems Scheduling

This section demonstrate python based workflow works based in google Colab. The setup of EnergyPlus in Colab is different from how it was done in Jupyter Notebook.

### C.1 Training Data Generation

Mount Colab path in Google Drive

```
import pandas as pd
import os
import numpy as np
from matplotlib import pyplot as plt
from google.colab import drive
drive.mount('/content/drive', force_remount=False)
```

Setup EnergyPlus and Eppy in Colab environment

```
# https://github.com/woo-seung/energyplus_colab/blob/master/
energyplus_colab.ipynb
```

```

# install EP to "/usr/local/EnergyPlus-9-5-0"
!chmod +x /content/drive/My\ Drive/EnergyPlus-9.5.0-de239b2e5f-Linux-
-Ubuntu18.04-x86_64.sh
!sudo /content/drive/My\ Drive/EnergyPlus-9.5.0-de239b2e5f-Linux-
Ubuntu18.04-x86_64.sh
# to capture C-level stdout/stderr pipes in Python
# !pip install wurlitzer
# check EP
print('\n- Check EnergyPlus Version')
!energyplus -version

# setting
# %load_ext wurlitzer
# %unload_ext wurlitzer
import sys
import shutil
energyplus_path = '/usr/local/EnergyPlus-9-5-0',
sys.path.insert(0, energyplus_path)
# from pyenergyplus.api import EnergyPlusAPI
!pip install eppy
# set energyplus path, needs python reboot if changed
from eppy.modeleditor import IDF
IDF.setiddname(os.path.join(energyplus_path, 'Energy+.idd'))

```

## Set Data paths

```

B_string= 15 # number of battery parallel string in battery in the
               idf file
PV_percent=50 # PV surface coverage % in idf file

dic_path= '/content/drive/My Drive/PVbattery/'
run_path=os.path.join(dic_path, "B{}PV{}".format(B_string,PV_percent
))
if not os.path.exists(run_path):
    os.mkdir(run_path)
    print('Create new folder: ', run_path)
else:

```

```

    print('Folder already existed: ', run_path)

# build model specific baseline output path
BASE_OUTPUT_PATH= os.path.join(run_path, "B{}PV{}baserun".format(
    B_string,PV_percent))
if not os.path.exists(BASE_OUTPUT_PATH):
    os.mkdir(BASE_OUTPUT_PATH)
    print('Create new folder: ', BASE_OUTPUT_PATH)
else:
    print('Folder already existed: ', BASE_OUTPUT_PATH)

# initial base run
sub1_BASE_OUTPUT_PATH= os.path.join(BASE_OUTPUT_PATH, 'B{}PV{}'
    'baserun1'.format(B_string,PV_percent))
if not os.path.exists(sub1_BASE_OUTPUT_PATH):
    os.mkdir(sub1_BASE_OUTPUT_PATH)
    print('Create new folder: ', sub1_BASE_OUTPUT_PATH)
else:
    print('Folder already existed: ', sub1_BASE_OUTPUT_PATH)

# base run after editing charging sche
sub2_BASE_OUTPUT_PATH= os.path.join(BASE_OUTPUT_PATH, 'B{}PV{}'
    'baserun2'.format(B_string,PV_percent))
if not os.path.exists(sub2_BASE_OUTPUT_PATH):
    os.mkdir(sub2_BASE_OUTPUT_PATH)
    print('Create new folder: ', sub2_BASE_OUTPUT_PATH)
else:
    print('Folder already existed: ', sub2_BASE_OUTPUT_PATH)

# build model specific perturb output path
PERTURB_OUTPUT_PATH= os.path.join(run_path, 'B{}PV{}perturb'.format(
    B_string,PV_percent))
if not os.path.exists(PERTURB_OUTPUT_PATH):
    os.mkdir(PERTURB_OUTPUT_PATH)
    print('Create new folder: ', PERTURB_OUTPUT_PATH)
else:
    print('Folder already existed: ', PERTURB_OUTPUT_PATH)

# path for saving perturbation data

```

```

DATA_PERTURB_OUTPUT_PATH= os.path.join(PERTURB_OUTPUT_PATH , "B{}PV{}"
    perturbdata".format(B_string,PV_percent))
if not os.path.exists(DATA_PERTURB_OUTPUT_PATH):
    os.mkdir(DATA_PERTURB_OUTPUT_PATH)
    print('Create new folder: ', DATA_PERTURB_OUTPUT_PATH)
else:
    print('Folder already existed: ', DATA_PERTURB_OUTPUT_PATH)

# path for saving ML training data
ML_PATH = os.path.join(PERTURB_OUTPUT_PATH , 'B{}PV{}ML_model'.format
    (B_string,PV_percent))
if not os.path.exists(ML_PATH):
    os.mkdir(ML_PATH)
    print('Create new folder: ', ML_PATH)
else:
    print('Folder already existed: ', ML_PATH)

# path for saving
perturb_output_path2= os.path.join(PERTURB_OUTPUT_PATH , 'dTdWdD')
if not os.path.exists(perturb_output_path2):
    os.mkdir(perturb_output_path2)
else:
    print(perturb_output_path2 , "exist")

# path for saving optimization results
OPT_PATH = os.path.join(run_path , 'B{}PV{}opt'.format(B_string ,
    PV_percent))
if not os.path.exists(OPT_PATH):
    os.mkdir(OPT_PATH)
    print('Create new folder: ', OPT_PATH)
else:
    print('Folder already existed: ', OPT_PATH)

# path for saving optimized EP checking results
EP_OPT_PATH = os.path.join(OPT_PATH , 'EP_RUN')
if not os.path.exists(EP_OPT_PATH):
    os.mkdir(EP_OPT_PATH)
    print('Create new folder: ', EP_OPT_PATH)

```

```

else:
    print('Folder already existed: ', EP_OPT_PATH)

# path for saving plots
PLOT_PATH = os.path.join(run_path, 'B{}PV{}plots'.format(B_string,
    PV_percent))
if not os.path.exists(PLOT_PATH):
    os.mkdir(PLOT_PATH)
    print('Create new folder: ', PLOT_PATH)
else:
    print('Folder already existed: ', PLOT_PATH)

MANUAL_PATH = os.path.join(run_path, 'B{}PV{}manual'.format(B_string,
    PV_percent))
if not os.path.exists(MANUAL_PATH):
    os.mkdir(MANUAL_PATH)
    print('Create new folder: ', MANUAL_PATH)
else:
    print('Folder already existed: ', MANUAL_PATH)

# for manual adjust setpoint for test
MANUAL_PATH_pcoool= os.path.join(MANUAL_PATH, 'manualpcoool')
if not os.path.exists(MANUAL_PATH_pcoool):
    os.mkdir(MANUAL_PATH_pcoool)
else:
    print(MANUAL_PATH_pcoool,"exist")

# path for saving plots
IDF_FOLDER = os.path.join(run_path, 'B{}PV{}idf'.format(B_string,
    PV_percent))
if not os.path.exists(IDF_FOLDER):
    os.mkdir(IDF_FOLDER)
    print('Create new folder: ', IDF_FOLDER)
else:
    print('Folder already existed: ', IDF_FOLDER)

base_fname='MIAMIPNNL_B{}PV{}opt'.format(B_string,PV_percent)

```

Run Baseline EP file

```

# path for idf files
IDF_FOLDER = os.path.join(run_path, 'B{}PV{}idf'.format(B_string,
    PV_percent))

if not os.path.exists(IDF_FOLDER):
    os.mkdir(IDF_FOLDER)
    print('Create new folder: ', IDF_FOLDER)
else:
    print('Folder already existed: ', IDF_FOLDER)

base_fname='MIAMIPNNL_B{}PV{}opt'.format(B_string,PV_percent)

# set energyplus path, needs python reboot if changed
from eppy.modeleditor import IDF

IDF.setiddname(os.path.join(energyplus_path, 'Energy+.idd'))

EPW_PATH = r'/content/drive/My Drive/PVbattery/idf/USA_FL_Miami.Intl
    .AP.722020_TMY3.epw'

IDF_PATH_BD='/content/drive/My Drive/PVbattery/B{}PV{}B{}PV{}idf/
    MIAMIPNNL_B{}PV{}opt_BDreschedule.idf'.format(B_string,
PV_percent,B_string,PV_percent,B_string,PV_percent)

idf = IDF(IDF_PATH_BD, EPW_PATH)

idf.run(readvars=True, expandobjects=True, output_directory=
    MANUAL_PATH)

df_manual = pd.read_csv (os.path.join(MANUAL_PATH,'eplusout.csv'))
# after getting rid of 217, starting from 7/19 1:00
# DATE: hottest 7/29 4pm [240:240+24]

l=len(list(df_manual[216:]['Environment:Site Outdoor Air Drybulb
    Temperature [C](Hourly)']))
Tout=np.reshape(list(df_manual[216:]['Environment:Site Outdoor Air
    Drybulb Temperature [C](Hourly)']),(1,1))
PV=np.reshape(list(df_manual[216:]['PV ARRAY LOAD CENTER:Electric
    Load Center Produced Electricity Rate [W](Hourly)'])/1000),(1,1))
BD=np.reshape(list(df_manual[216:]['LIIONBATTERY:Electric Storage
    Discharge Power [W](Hourly)'])/1000),(1,1))
P_buy=np.reshape(list(df_manual[216:]["Whole Building:Facility Net
    Purchased Electricity Rate [W](Hourly)"])/1000),(1,1))

```

```

P_demand=np.reshape(list(df_manual[216:]["Whole Building:Facility
    Total Electricity Demand Rate [W](Hourly)"]/1000),(1,1))
BC=np.reshape(list(df_manual[216:]['LIIONBATTERY:Electric Storage
    Charge Power [W](Hourly)'])/1000),(1,1))
SET=np.reshape(list(df_manual[216:]["PEOPLE_UNIT1:Zone Thermal
    Comfort Pierce Model Standard Effective Temperature [C](Hourly) "
    ]),(1,1))

```

Generate cooling and energy storage system schedules for defined number of times

```

!pip install geomdl
import numpy as np
import random
from geomdl import BSpline
from geomdl import knotvector

num = 100
i = 0
failed_i = 0
saved_discharge_sch = []
saved_setpoint_sch = []
saved_air_sch = []
saved_fan_sch = []
while i < num:
    q_discharge_sch = []
    q_setpoint_sch = []
    q_air_sch = []
    q_fan_sch = []
    for j in range(24):
        if j in x0:
            q_setpoint_sch.append(23.88 - 3)
        else:
            q_setpoint_sch.append(23.88 + (0 + (3 - (0)) * np.random.random()))

```

```

for g in range (24):
    air_v= 0 + (0.7-(0))*np.random.random()
    q_air_sch.append(air_v)
    q_fan_sch.append(air_v/0.7)

for k in range(24):
    if k in x1:
        q_discharge_sch.append(0)
    else:
        q_discharge_sch.append(dischARGE_baseline_sch[k]+(-0.4 +
        (0.4-(-0.4))*np.random.random()))

    saved_setpoint_sch.append(q_setpoint_sch)
    saved_air_sch.append(q_air_sch)
    saved_fan_sch.append(q_fan_sch)
    if sum(q_discharge_sch)<discharge_capacity_limit:
        saved_discharge_sch.append(q_discharge_sch)
        i += 1
    else:
        failed_i += 1
        continue
print(f'succeeded attempt {i}, failed attempt {failed_i}')
# saved_discharge_sch

```

Define training data generation function

```

def clg_setpoints(i):
    import random
    idf = IDF(IDF_PATH_BD, EPW_PATH)
    allschedule=idf.idfobjects['Schedule:Compact']
    ClgSetPSch=allschedule[-5]
    VairSch=allschedule[-2]
    fanSch=allschedule[0]
    dischargeSch=allschedule[-6]
    i_str=3 # string field
    i_num=4 # setpoint number field
    i_hr=0 # field time start

```

```

time_ct=0 # count number of setpoint for a day
wk=4

for time_ct in range(24):
    i_hr=i_hr+1
    fanSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    VairSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    ClgSetPSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    dischargeSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    i_str=i_str+2
    fanSch['Field_{}'.format(i_num)] = saved_fan_sch[i][time_ct]
    VairSch['Field_{}'.format(i_num)] = saved_air_sch[i][time_ct]
    ClgSetPSch['Field_{}'.format(i_num)] = saved_setpoint_sch[i][time_ct]
    dischargeSch['Field_{}'.format(i_num)]=saved_discharge_sch[i][time_ct]
    i_num=i_num+2

idf.run(readvars=True, expandobjects=True, output_directory=
perturb_output_path2)
df1 = pd.read_csv (os.path.join(perturb_output_path2, 'eplusout.
csv'))

l=len(list(df1[216:]['Environment:Site Outdoor Air Drybulb
Temperature [C](Hourly)']))
Tout1=np.reshape(list(df1[216:]['Environment:Site Outdoor Air
Drybulb Temperature [C](Hourly)']),(l,1))
PV1=np.reshape(list(df1[216:]['PV ARRAY LOAD CENTER:Electric
Load Center Produced Electricity Rate [W](Hourly)'])/1000,(l,1))
BD1=np.reshape(list(df1[216:]['LIIONBATTERY:Electric Storage
Discharge Power [W](Hourly)'])/1000,(l,1))

```

```

P_buy1=np.reshape(list(df1[216:]["Whole Building:Facility Net Purchased Electricity Rate [W](Hourly)"])/1000),(1,1))

SET1=np.reshape(list(df1[216:]["PEOPLE_UNIT1:Zone Thermal Comfort Pierce Model Standard Effective Temperature [C](Hourly) "]),(1,1))

Discharge=np.reshape(saved_discharge_sch[i], (len(saved_discharge_sch[i]), 1))
Discharge_nstack=np.vstack([Discharge for c in range(7*wk)])

Setpoint=np.reshape(saved_setpoint_sch[i], (len(saved_setpoint_sch[i]), 1))
Setpoint_nstack=np.vstack([Setpoint for c in range(7*wk)])

Air=np.reshape(saved_air_sch[i], (len(saved_air_sch[i]), 1))
Air_nstack=np.vstack([Air for c in range(7*wk)])

Fan=np.reshape(saved_fan_sch[i], (len(saved_fan_sch[i]), 1))
Fan_nstack=np.vstack([Fan for c in range(7*wk)])

results=np.hstack((P_buy1,SET1,Tout1,PV1,Discharge_nstack,
Setpoint_nstack,Air_nstack,Fan_nstack))

return results

```

Generate training data for defined number of times

```

num=100

R=np.hstack((SET,SET,SET,SET,SET,SET,SET)) #dim 7 (P_buy, SET,
    setpoint, discharge sche, outside T,P_pv,solar radiation)
row,_=R.shape
t=R[0:row-7*24,:] # data start from 0_row, t matrix, training data 3
    week
v=R[row-7*24:row,:]
# data end in row_row, v matrix, validation data
: last 1 week

```

```

# empty shape SIZE according to base run
t_row, _ = t.shape
v_row, _ = v.shape
train = np.zeros(t.shape)
valid = np.zeros(v.shape)

for i in range(num):
    r = clg_setpoints(i) # result of one run of function:
    clg_setpoints
    ## START PARSING THE DATA
    r_t = r[0:t_row, :]
    r_v = r[t_row:row, :]
    train = np.vstack((train, r_t))
    valid = np.vstack((valid, r_v))
    i = i + 1

# take out zeros
T_row, _ = train.shape
train_data = train[t_row:T_row, :]
V_row, _ = valid.shape
valid_data = valid[v_row:V_row, :]

DATA_PERTURB_OUTPUT_PATH = os.path.join(perturb_output_path2, "B{}PV{}"
                                         .format(B_string, PV_percent))
if not os.path.exists(DATA_PERTURB_OUTPUT_PATH):
    os.mkdir(DATA_PERTURB_OUTPUT_PATH)
# save data
import pandas as pd
pd.DataFrame(train_data).to_csv(os.path.join(
    DATA_PERTURB_OUTPUT_PATH, 'train_data.csv'))
pd.DataFrame(valid_data).to_csv(os.path.join(
    DATA_PERTURB_OUTPUT_PATH, 'valid_data.csv'))

```

## C.2 Neural Network Model Training

```

import pandas as pd
import numpy as np
from matplotlib import pyplot as plt
import os
import math
import tensorflow as tf
from sklearn.model_selection import train_test_split
from tensorflow.keras import layers, models
from sklearn import preprocessing

X_train_data=train_data[:,2:7]
X_train_data
X_test_data=val_data[:,2:7]
X_test_data
q=np.array(train_data[:,0:2])
Y_train_data=q.reshape(len(q),2)
Y_train_data

qt=np.array(val_data[:,0:2])
Y_test_data=qt.reshape(len(qt),2)
Y_test_data

# Should not have seprate scalers for train and test data
X_train_scaler = preprocessing.MinMaxScaler()
X_train_scaler.fit(X_train_data)

X_train_data_scaled = X_train_scaler.transform(X_train_data)
X_test_data_scaled = X_train_scaler.transform(X_test_data)

Y_train_scaler = preprocessing.MinMaxScaler()
Y_train_scaler.fit(Y_train_data)

Y_train_data_scaled = Y_train_scaler.transform(Y_train_data)
Y_test_data_scaled = Y_train_scaler.transform(Y_test_data)

```

```

random_state=42

X_training, X_validation, Y_training, Y_validation =
    train_test_split(X_train_data_scaled, Y_train_data_scaled,
test_size=.2, random_state=random_state)

# TRAINED ML MODEL 2: EPOCH 25

def create_regression_param_model(input_dim, output_dim):
    model=[layers.InputLayer(input_shape=input_dim)]

    model.append(layers.Dense(10, name="e0"))
    model.append(layers.BatchNormalization())
    model.append(layers.ReLU())
    model.append(layers.Dropout(0.05))

    model.append(layers.Dense(20, name="e22"))
    model.append(layers.BatchNormalization())
    model.append(layers.ReLU())
    model.append(layers.Dropout(0.05))

    model.append(layers.Dense(50, name="e23"))
    model.append(layers.BatchNormalization())
    model.append(layers.ReLU())
    model.append(layers.Dropout(0.05))

    model.append(layers.Dense(20, name="e3"))
    model.append(layers.BatchNormalization())
    model.append(layers.ReLU())
    model.append(layers.Dropout(0.05))

    model.append(layers.Dense(10, name="e4")) # activation='sigmoid')
    model.append(layers.BatchNormalization())
    model.append(layers.Softmax()) # try last layer with soft max,
    sigmoid
    model.append(layers.Dense(output_dim))

```

```

    return tf.keras.Sequential(model, name='
regression_prediction_model')

# compile NN regression model
input_dim = 5
output_dim = 2

learning_rate = 0.1
# normalizer = tf.keras.layers.Normalization()
# normalizer.adapt(np.array(param_train))

NNmodel = create_regression_param_model(input_dim, output_dim)
# tf.keras.losses.MeanSquaredError()
NNmodel.compile(loss='mean_squared_error',
                  optimizer=tf.keras.optimizers.Adam(learning_rate))

early_stopping=tf.keras.callbacks.EarlyStopping(
    monitor='val_loss',
    # min_delta=0.01,
    patience=100,
    # # verbose=0,
    # # mode='min',
    # # baseline=None,
    restore_best_weights=True)

epoch_num =200

# callback = tf.keras.callbacks.EarlyStopping(monitor='val_loss',
#                                              patience=200)
history = NNmodel.fit(x=X_training, y=Y_training, epochs=epoch_num,
                      batch_size=128,
                      validation_data=(X_validation,Y_validation),
                      callbacks=[early_stopping])
from matplotlib.pyplot import figure
font = {'weight' : 'normal','size': 14}
plt.rc('font', **font)

```

```

plt.rc('axes', labelsize=22)      # fontsize of the axes title
plt.rc('axes', titlesize=22)
figure(figsize=(6, 3))
plt.plot(history.history['loss'], color='#173000')
plt.plot(history.history['val_loss'], color='#b73000')
plt.ylabel('loss_MSE')
plt.xlabel('epoch')
plt.legend(['Train', 'Validation'], loc='upper right')
plt.tight_layout()
plt.savefig(os.path.join(ML_PATH,"MSE_dTdWdD{}_scaledxy.PDF".format(
    epoch_num)),dpi=1500)

NNmodel.save_weights( os.path.join(ML_PATH,'dTdWdD{}_scaledxy.pt' .
    format(epoch_num)))

```

### C.3 Optimization

```

!pip install geneticalgorithm
from geneticalgorithm import geneticalgorithm as ga

def obj_fn_y(X):
    fixed_P_pv=PV[240:240+24]
    fixede_Tout=Tout[240:240+24]
    # nn_input_batch = []
    nn_input_batch=np.zeros((0,5))
    for i in range(24):
        hourly_vars_BD = X[i]
        hourly_vars_T = X[24+i]
        hourly_vars_Air = X[48+i]
        nn_input = np.hstack([fixede_Tout[i],fixed_P_pv[i],
        hourly_vars_BD,hourly_vars_T,hourly_vars_Air]) # [
        Discharge_nstack,PV_1,Tout_1]
        nn_input_scaled = X_train_scaler.transform([nn_input])
        nn_input_batch=np.vstack((nn_input_batch,nn_input_scaled))
    # nn_input_batch.append(nn_input) ## for list

```

```

model_pred = NNmodel.predict(nn_input_batch)

return model_pred

def obj_fn_maxy(X):
    fixed_P_pv=PV[240:240+24]
    fixede_Tout=Tout[240:240+24]
    # nn_input_batch = []
    nn_input_batch=np.zeros((0,5))
    for i in range(24):
        # hourly_vars = X[i]
        hourly_vars_BD = X[i]
        hourly_vars_T = X[24+i]
        hourly_vars_Air = X[48+i]
        nn_input = np.hstack([fixede_Tout[i],fixed_P_pv[i],
        hourly_vars_BD,hourly_vars_T,hourly_vars_Air])#, shared_vars])
        nn_input_scaled = X_train_scaler.transform([nn_input])
        nn_input_batch=np.vstack((nn_input_batch,nn_input_scaled))
        # nn_input_batch.append(nn_input) ## for list
    # model_pred = NNmodel.predict(np.array(nn_input_batch))
    model_pred = NNmodel.predict(nn_input_batch)

    return sum(model_pred[:,0]*0.9)/20+np.max(model_pred[:,1]*0.1) #
    assign weight to the objective, since here the two objective
    values are not scaled, some scaling factor would need to be
    applied

h_BD=np.array([[0,1]]*24)
h_T=np.array([[20.89,26.89]]*24)
h_Air=np.array([[0,0.7]]*24)
varbound=np.vstack((h_BD,h_T,h_Air))
# varbound

def constraint_fn(x):
    x_BD=[]
    for i in range (24):
        x_BD.append(x[i])

```

```

    return discharge_capacity_limit - np.sum(x_BD)
    # constrain function need to write in a form result >=0
# equivalent to lambda x: np.sum(x) - discharge_capacity_limit

cons = ({'type': 'ineq', 'fun' : constraint_fn}) #'jac' : lambda x:
       np.array([0.0, 1.0])})

def nurb(p1,p2,p3,p4):
    import random
    from geomdl import BSpline
    from geomdl import knotvector

    # Create the curve instance
    crv = BSpline.Curve()

    # Set degree
    crv.degree = 2

    crv.ctrlpts = [[0, p1], [1/4, p2], [2/4, p3], [3/4, p4],[1, p1]]
    crv.knotvector = knotvector.generate(crv.degree, crv.ctrlpts_size)

    # Update delta
    num_pts = 24
    crv.delta = 1.0/num_pts
    points_b = np.array(crv.evalpts)
    # points_b[:,1]
    return points_b[:,1]

#function
def optimization_with_constraint(new_sch):
    import scipy.optimize
    x_initial=new_sch
    res = scipy.optimize.minimize(obj_fn_maxy, x_initial, bounds=
        varbound, constraints=cons, method='SLSQP', options={'disp': True
        , 'maxiter': 1000, 'ftol': 1e-06})

    if res.success:

```

```

opt_schedule=res.x
opt_BD=np.reshape(opt_schedule[0:24],(24,1))
opt_T=np.reshape(opt_schedule[24:48],(24,1))
opt_Air=np.reshape(opt_schedule[48:72],(24,1))
opt_schedule_forEP=np.hstack((opt_BD,opt_T,opt_Air))
predicted_opt_y=obj_fn_y(res.x)
results=np.hstack((predicted_opt_y,opt_schedule_forEP))
return results
# return opt_schedule_forEP,predicted_opt_y
else:
    return None
#func
# random sampling number
num=50
testname='noBD_newNNlayer_p0.9s0.1_newNN_initial_dTdWdD{}'.format(
    num)
import numpy as np
saving_results = np.zeros((0,5))
for i in range(num):
    import random
    new_discharge_sch=[]
    new_setpoint_sch=[]
    new_air_sch=[]
    p1= 0 + (4-(0)) * np.random.random() # lower + (upp - lower) *
    random(0~1)
    p2= 0 + (4-(0)) * np.random.random()
    p3= 0 + (3-(0)) * np.random.random()
    p4= 0 + (4-(0)) * np.random.random()
    a1= 0 + (0.35-(0)) * np.random.random() # lower + (upp - lower)
    * random(0~1)
    a2= 0 + (0.35-(0)) * np.random.random()
    a3= -0.35 + (0-(-0.35)) * np.random.random()
    a4= 0 + (0.35-(0)) * np.random.random()
    dTs = nurb(p1,p2,p3,p4)
    dWs= nurb(a1,a2,a3,a4)
    for j in range(24):

```

```

if j in x0:
    new_setpoint_sch.append(23.88-3)
else:
    new_setpoint_sch.append(23.88+dTs[j])

for g in range (24):
    new_air_sch.append(0.35+dWs[g])

for k in range(24):
    new_discharge_sch.append(0)

# for k in range(24):
#     if k in x1:
#         new_discharge_sch.append(0)
#     else:
#         if k < x1[0]:
#             new_discharge_sch.append(discharge_baseline_sch[k]+(0 +
# (0.2-(0))*np.random.random()))
#         else:
#             new_discharge_sch.append(discharge_baseline_sch[k]+(-0.2
# + (0-(-0.2))*np.random.random()))

new_sch=new_discharge_sch+new_setpoint_sch+new_air_sch ##??
result_opt=optimization_with_constraint(new_sch)

if result_opt is not None:
    saving_results = np.vstack([saving_results, result_opt])
    pd.DataFrame(np.array(saving_results)).to_csv(os.path.join(
OPT_PATH , '{}.csv'.format(testname)))

df = pd.read_csv (os.path.join(OPT_PATH , '{}.csv'.format(testname)))
print (df)
df.rename(columns = {'0':"predicted_opt_pbuy","1":"predicted_opt_SET
", '2':'opt_discharge_schedule_forEP','3':'opt_setpoint_schedule_forEP','4':'opt_airspeed_schedule_forEP'},inplace = True)

```

```

predicted_opt_pbuy=df["predicted_opt_pbuy"]
predicted_opt_SET=df["predicted_opt_SET"]

# devide every 24
predicted_opt_y_max=[]
for i in range (num):
    predicted_opt_y_max.append(predicted_opt_pbuy[i*24:i*24+24].max()
    *0.8+predicted_opt_SET[i*24:i*24+24].max()*0.2)
predicted_opt_y_max

minindex=predicted_opt_y_max.index(min(predicted_opt_y_max))
minindex

i=minindex
max(predicted_opt_pbuy[i*24:i*24+24])
max(predicted_opt_SET[i*24:i*24+24])

Y_opt_scaled=np.hstack((np.reshape(np.array(predicted_opt_pbuy[i*24:
    i*24+24]),(24,1)),np.reshape(np.array(predicted_opt_SET[i*24:i
    *24+24]),(24,1))))
# Y_opt_scaled
Y_opt_pred=Y_train_scaler.inverse_transform(Y_opt_scaled)
Y_opt_pred

opt_discharge_schedule_forEP=list(df["opt_discharge_schedule_forEP"]
    [minindex*24:minindex*24+24])
opt_setpoint_schedule_forEP=list(df["opt_setpoint_schedule_forEP"][
    minindex*24:minindex*24+24])
opt_air_schedule_forEP=list(df["opt_airspeed_schedule_forEP"][
    minindex*24:minindex*24+24])
opt_fan_schedule_forEP=list(np.array(opt_air_schedule_forEP)/0.7)

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Discharge Fraction', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(discharge_baseline_sch,color='palevioletred', linewidth=2.5)

```

```

plt.plot(list(opt_discharge_schedule_forEP),color='royalblue',
         linewidth=2.5)
plt.legend(['baseline discharge schedule','optimized discharge
schedule'])#,loc='lower center')
# plt.axhline(y=ave_integrated_value, color='dimgray', linestyle
=':',label='P buy positive average')
plt.axvline(x=x1[0], color='dimgray', linestyle=':',label='PV self
supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':',label='PV self
supply end')
plt.xticks(np.arange(0, 24, step=5))
# plt.yticks(np.arange(0, 1.6, step=0.5))
plt.grid(True,linewidth=0.1)

# plt.legend(bbox_to_anchor=(1,0), loc="lower left")

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH,"dTdWdD_dischargesch{}_{minindex}{}.
PDF".format(testname,minindex)),dpi=1500)

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Setpoint (C)', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(np.ones(24)*23.99,color='palevioletred', linewidth=2.5)
plt.plot(list(opt_setpoint_schedule_forEP),color='royalblue',
         linewidth=2.5)
plt.legend(['baseline discharge schedule','optimized discharge
schedule'])#,loc='lower center')
# plt.axhline(y=ave_integrated_value, color='dimgray', linestyle
=':',label='P buy positive average')
plt.axvline(x=x1[0], color='dimgray', linestyle=':',label='PV self
supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':',label='PV self

```

```

        supply end' )

plt.xticks(np.arange(0, 24, step=5))
# plt.yticks(np.arange(0, 1.6, step=0.5))
plt.grid(True, linewidth=0.1)
# plt.legend(bbox_to_anchor=(1,0), loc="lower left")

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "dTdWdD_setpoint{}_{minindex}.PDF".
    format(testname, minindex)), dpi=1500)

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Fan Airspeed (m/s) ', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(np.ones(24)*0.35, color='palevioletred', linewidth=2.5)
plt.plot(list(opt_air_schedule_forEP), color='royalblue', linewidth
    =2.5)
plt.legend(['baseline discharge schedule', 'optimized discharge
    schedule'])#, loc='lower center')
# plt.axhline(y=ave_integrated_value, color='dimgray', linestyle
    =':', label='P buy positive average')
plt.axvline(x=x1[0], color='dimgray', linestyle=':', label='PV self
    supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':', label='PV self
    supply end')

plt.xticks(np.arange(0, 24, step=5))
# plt.yticks(np.arange(0, 1.6, step=0.5))
plt.grid(True, linewidth=0.1)
# plt.legend(bbox_to_anchor=(1,0), loc="lower left")

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "dTdWdD_air{}_{minindex}.PDF".format
    (testname, minindex)), dpi=1500)

```

## Check Optimized Solutions with EP

```
idf = IDF(IDF_PATH_BD, EPW_PATH)
```

```

allschedule=idf.idfobjects['Schedule:Compact']
ClgSetPSch=allschedule[-5]
VairSch=allschedule[-2]
fanSch=allschedule[0]
dischargeSch=allschedule[-6]
i_str=3 # string field
i_num=4 # setpoint number field
i_hr=0 # field time start
time_ct=0 # count number of setpoint for a day

for time_ct in range(24):
    i_hr=i_hr+1
    fanSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(i_hr)
    VairSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(i_hr)
    ClgSetPSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    # dischargeSch['Field_{}'.format(i_str)] = 'Until: {}:00'.format(
        i_hr)
    i_str=i_str+2
    fanSch['Field_{}'.format(i_num)] = opt_fan_schedule_forEP[
        time_ct]
    VairSch['Field_{}'.format(i_num)] = opt_air_schedule_forEP[
        time_ct]
    ClgSetPSch['Field_{}'.format(i_num)] =
    opt_setpoint_schedule_forEP[time_ct]
    # dischargeSch['Field_{}'.format(i_num)]=
    opt_discharge_schedule_forEP[time_ct]
    i_num=i_num+2
idf.run(readvars=True, expandobjects=True, output_directory=
EP_OPT_PATH)

df_opt = pd.read_csv (os.path.join(EP_OPT_PATH,'eplusout.csv'))
Tout_opt=list(df_opt[216:]['Environment:Site Outdoor Air Drybulb
Temperature [C](Hourly)'])
PV_opt=list(df_opt[216:]['PV ARRAY LOAD CENTER:Electric Load Center
Produced Electricity Rate [W](Hourly)'])/1000

```

```

BD_opt=list(df_opt[216:]['LIIIONBATTERY:Electric Storage Discharge
Power [W](Hourly)']/1000)

P_buy_opt=list(df_opt[216:]["Whole Building:Facility Net Purchased
Electricity Rate [W](Hourly)"]/1000)

SET_opt=list(df_opt[216:]["PEOPLE_UNIT1:Zone Thermal Comfort Pierce
Model Standard Effective Temperature [C](Hourly)"])

a=int((max(P_buy[240:240+24])-max(P_buy_opt[240:240+24]))/max(P_buy
[240:240+24])*100)
print("Reduced Power",a,"%")

b=int((max(SET[240:240+24])-max(SET_opt[240:240+24]))/max(SET
[240:240+24])*100)
print("Reduced SET",b,"%")

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Power (kW)', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(P_buy[240:240+24], color='palevioletred', linewidth=2.5)
plt.plot(Y_opt_pred[:,0], color='royalblue', linewidth=2.5, linestyle=
'dotted')
plt.plot(P_buy_opt[240:240+24], color='royalblue', linewidth=2.5)
# plt.legend(['Purchased Power_baseline ','Purchased Power_NN
# prediction','Purchased Power_EP simulation']), loc='lower center
')
plt.title("Reduced Power{}%".format(a))
# plt.yticks(np.arange(-14, 8, step=3))
plt.grid(True, linewidth=0.1)

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "dTdWdD_EP_Popt{}_index{}_reduce
{}%.PDF".format(testname,minindex,a)), dpi=1500)

P_buy_pos_opt=[]
for i in range(24):

```

```

if P_buy_opt[240:240+24][i]>0.1:
    P_buy_pos_opt.append(list(P_buy_opt[240:240+24])[i])
else:
    P_buy_pos_opt.append(0)

P_buy_pos_NN=[]
for i in range(24):
    if Y_opt_pred[:,0][i]>0.1:
        P_buy_pos_NN.append(Y_opt_pred[:,0][i])
    else:
        P_buy_pos_NN.append(0)

plt.figure(figsize=(6, 3))
plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('Power (kW)', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(P_buy_pos, color='palevioletred', linewidth=2.5, label='Purchased Power_baseline')
plt.plot(P_buy_pos_opt, color='royalblue', linewidth=2.5, label='Purchased Power_EP simulation')
plt.plot(P_buy_pos_NN, color='royalblue', linewidth=2.5, label='Purchased Power_NN prediction', linestyle="dotted")
plt.axvline(x=x1[0], color='dimgray', linestyle=':', label='PV self supply start')
plt.axvline(x=x1[-1], color='dimgray', linestyle=':', label='PV self supply end')
plt.title("Reduced Power{}".format(a))
# plt.legend(bbox_to_anchor=(1,0), loc="lower left")
# plt.yticks(np.arange(-14, 8, step=3))
plt.grid(True, linewidth=0.1)

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "dTdWdD_EP_pos_Popt{}{}_index{}"
                       "_reduce{}.PDF".format(testname, minindex, a)), dpi=1500)

plt.figure(figsize=(6, 3))

```

```

plt.xlabel('Time (hour)', fontsize=15)
plt.ylabel('SET (C)', fontsize=15)
plt.rcParams['font.family'] = 'serif'
plt.rcParams['font.serif'] = ['Times New Roman']
plt.plot(SET[240:240+24], color='palevioletred', linewidth=2.5)
plt.plot(SET_opt[240:240+24], color='royalblue', linewidth=2.5)
plt.plot(Y_opt_pred[:,1], color='royalblue', linewidth=2.5, linestyle=
'dotted')
# plt.legend(['Purchased Power_baseline ','Purchased Power_NN
prediction','Purchased Power_EP simulation'])#,loc='lower center
')
plt.axvline(x=x1[0], color='dimgray', linestyle=':',label='PV self
supply start' )
plt.axvline(x=x1[-1], color='dimgray', linestyle=':',label='PV self
supply end' )

plt.grid(True, linewidth=0.1)

plt.tight_layout()
plt.savefig(os.path.join(PLOT_PATH, "dTdWdD_EP_SET_opt{}{}_index{}"
_reduce{}%.PDF".format(testname,minindex,b)), dpi=1500)

```

# Appendix D

## Example IDF Files

cooling system optimization idf

### D.1 MIAMIPNNL idf

This file is modified based on the Building energy codes program published prototype residential energy model for 1A climate. The original model could be found here: <https://www.energycodes.gov/building-models>.

```
!-Generator IDFEditor 1.51
!-Option SortedOrder

!-NOTE: All comments with '!--' are ignored by the IDFEditor and are
       generated automatically.
!-      Use '!' comments if they need to be retained when using the
       IDFEditor.

! - ===== ALL OBJECTS IN CLASS: VERSION =====
```

```

! GPARAM parameters as run:

! ID = US+SF+CZ1AWH+hp+slab+IECC_2021
! weatherfile = USA_FL_Miami.Intl.AP.722020_TMY3.epw
! climate_zone = Climate Zone 1
! moisture_regime = Moist
! humidity_designation = Warm-Humid
! tropical_designation = Not Tropical
! bldg_type = Single-Family
! fndn_type = Slab
! system_tag = Heat Pump
! code = IECC_2021
! permits = 21846.545507574
! vent_fan_efficiency = 1.4
! cfm25 = 4
! afn_control = MultizoneWithDistribution
! is_duct_base = no
! leakage_ratio = 0.0792
! dhw_type =
! TEMPLATE_PATH = template/v9.5

Version ,
9.5;                                ! - Version Identifier

! - ===== ALL OBJECTS IN CLASS: SIMULATIONCONTROL
=====

SimulationControl ,
Yes,                                     ! - Do Zone Sizing Calculation
Yes,                                     ! - Do System Sizing Calculation
No,                                      ! - Do Plant Sizing Calculation
Yes,                                     ! - Run Simulation for Sizing Periods
Yes,                                     ! - Run Simulation for Weather File Run
Periods
,
! - Do HVAC Sizing Simulation for Sizing
Periods

```

```

;

! - Maximum Number of HVAC Sizing

Simulation Passes


! - ===== ALL OBJECTS IN CLASS: BUILDING =====

Building ,
    US+SF+CZ1AWH+hp+slab+IECC_2021 , ! - Name
    0 , ! - North Axis {deg}
    Suburbs , ! - Terrain
    0.04 , ! - Loads Convergence Tolerance Value {W}
}
    0.4 , ! - Temperature Convergence Tolerance
Value {deltaC}
    FullExterior , ! - Solar Distribution
    25 , ! - Maximum Number of Warmup Days
    6 ; ! - Minimum Number of Warmup Days


! - ===== ALL OBJECTS IN CLASS: SURFACECONVECTIONALGORITHM:
INSIDE =====

SurfaceConvectionAlgorithm:Inside ,
    TARP ; ! - Algorithm


! - ===== ALL OBJECTS IN CLASS: TIMESTEP =====

Timestep ,
    6 ; ! - Number of Timesteps per Hour


! - ===== ALL OBJECTS IN CLASS: SITE:LOCATION =====

! Location and design-day objects created by:
! Site:Location and design-day objects created by:

```

```

! ./tools/bin/ddy2idf ./tools/epw//USA_FL_Miami.Intl.AP.722020_TMY3.
ddy
!

Site:Location ,
    Miami Intl Ap_FL_USA Design_Conditions , !- Name
    25.82 , !- Latitude {deg}
    -80.30 , !- Longitude {deg}
    -5.00 , !- Time Zone {hr}
    11.00 ; !- Elevation {m}

!- ===== ALL OBJECTS IN CLASS: SIZINGPERIOD:DESIGNDAY
=====

SizingPeriod:DesignDay ,
    Miami Intl Ap Ann Htg 99.6% Condns DB , !- Name
    1 , !- Month
    21 , !- Day of Month
    WinterDesignDay , !- Day Type
    8.7 , !- Maximum Dry-Bulb Temperature {C}
    0.0 , !- Daily Dry-Bulb Temperature Range {
    deltaC}
    DefaultMultipliers , !- Dry-Bulb Temperature Range Modifier
    Type
    ,
    !- Dry-Bulb Temperature Range Modifier
    Day Schedule Name
    Wetbulb , !- Humidity Condition Type
    8.7 , !- Wetbulb or DewPoint at Maximum Dry-
    Bulb {C}
    ,
    !- Humidity Condition Day Schedule Name
    ,
    !- Humidity Ratio at Maximum Dry-Bulb {
    kgWater/kgDryAir}
    ,
    !- Enthalpy at Maximum Dry-Bulb {J/kg}
    ,
    !- Daily Wet-Bulb Temperature Range {
    deltaC}
    101193. , !- Barometric Pressure {Pa}

```

```

3.8,                                     !- Wind Speed {m/s}
340,                                      !- Wind Direction {deg}
No,                                       !- Rain Indicator
No,                                       !- Snow Indicator
No,                                       !- Daylight Saving Time Indicator
ASHRAEClearSky,                           !- Solar Model Indicator
,                                         !- Beam Solar Day Schedule Name
,                                         !- Diffuse Solar Day Schedule Name
,                                         !- ASHRAE Clear Sky Optical Depth for
Beam Irradiance (taub) {dimensionless}
,
                                         !- ASHRAE Clear Sky Optical Depth for
Diffuse Irradiance (taud) {dimensionless}
0.00;                                     !- Sky Clearness

SizingPeriod:DesignDay ,
Miami Intl Ap Ann Clg .4% Condns DB=>MWB,   !- Name
7,                                         !- Month
21,                                         !- Day of Month
SummerDesignDay,                           !- Day Type
33.2,                                      !- Maximum Dry-Bulb Temperature {C}
6.7,                                       !- Daily Dry-Bulb Temperature Range {
deltaC}
DefaultMultipliers,                      !- Dry-Bulb Temperature Range Modifier
Type
,
                                         !- Dry-Bulb Temperature Range Modifier
Day Schedule Name
Wetbulb,                                    !- Humidity Condition Type
25.3,                                      !- Wetbulb or DewPoint at Maximum Dry-
Bulb {C}
,
                                         !- Humidity Condition Day Schedule Name
,
                                         !- Humidity Ratio at Maximum Dry-Bulb {
kgWater/kgDryAir}
,
                                         !- Enthalpy at Maximum Dry-Bulb {J/kg}
,
                                         !- Daily Wet-Bulb Temperature Range {
deltaC}
101193.,                                    !- Barometric Pressure {Pa}

```

```

4.5,                               !- Wind Speed {m/s}
140,                               !- Wind Direction {deg}
No,                                !- Rain Indicator
No,                                !- Snow Indicator
No,                                !- Daylight Saving Time Indicator
ASHRAETau,                          !- Solar Model Indicator
,                                   !- Beam Solar Day Schedule Name
,                                   !- Diffuse Solar Day Schedule Name
0.528,                             !- ASHRAE Clear Sky Optical Depth for
Beam Irradiance (taub) {dimensionless}
1.905;                            !- ASHRAE Clear Sky Optical Depth for
Diffuse Irradiance (taud) {dimensionless}

! - ===== ALL OBJECTS IN CLASS: RUNPERIOD =====

RunPeriod,
annual,                            !- Name
7,                                  !- Begin Month
12,                                !- Begin Day of Month
,                                    !- Begin Year
8,                                  !- End Month
15,                                !- End Day of Month
,                                    !- End Year
Sunday,                            !- Day of Week for Start Day
Yes,                               !- Use Weather File Holidays and
Special Days
Yes,                               !- Use Weather File Daylight Saving
Period
No,                                !- Apply Weekend Holiday Rule
Yes,                               !- Use Weather File Rain Indicators
Yes;                               !- Use Weather File Snow Indicators

! - ===== ALL OBJECTS IN CLASS: SITE:WATERMAINSTEMPERATURE
=====
```

```

! Weather_file = USA_FL_Miami.Intl.AP.722020_TMY3.epw;
! Using the stat2idf and the ddy2idf script...
! Water mains temperature correlation object created by:
! Water mains temperature object created by:
! ./tools/bin/stat2idf ./tools/epw//USA_FL_Miami.Intl.AP.722020_TMY3
  .stat
!

Site:WaterMainsTemperature ,
  Correlation,           !- Calculation Method
  ,                      !- Temperature Schedule Name
  24.4916666666667,     !- Annual Average Outdoor Air
  Temperature {C}
  8.7;                  !- Maximum Difference In Monthly
  Average Outdoor Air Temperatures {deltaC}

! - ===== ALL OBJECTS IN CLASS: SCHEDULETYPELIMITS
=====

ScheduleTypeLimits ,
  any number;           !- Name

ScheduleTypeLimits ,
  On/Off,                !- Name
  0,                     !- Lower Limit Value
  1,                     !- Upper Limit Value
  Discrete;              !- Numeric Type

ScheduleTypeLimits ,
  control_type,          !- Name
  0,                     !- Lower Limit Value
  4,                     !- Upper Limit Value
  Discrete;              !- Numeric Type

ScheduleTypeLimits ,

```

```

        fraction,                      ! - Name
        0,                            ! - Lower Limit Value
        1,                            ! - Upper Limit Value
        Continuous;                  ! - Numeric Type

ScheduleTypeLimits,
    Temperature,                  ! - Name
    -60,                          ! - Lower Limit Value
    200,                          ! - Upper Limit Value
    Continuous;                  ! - Numeric Type

ScheduleTypeLimits,
    Fractional,                  ! - Name
    0,                            ! - Lower Limit Value
    1,                            ! - Upper Limit Value
    Continuous,                  ! - Numeric Type
    dimensionless;              ! - Unit Type

! - ===== ALL OBJECTS IN CLASS: SCHEDULE:DAY:HOURLY
=====

!
!

Schedule:Day:Hourly,
    OccupancyDay,                ! - Name
    Fraction,                    ! - Schedule Type Limits Name
    1.00000,                     ! - Hour 1
    1.00000,                     ! - Hour 2
    1.00000,                     ! - Hour 3
    1.00000,                     ! - Hour 4
    1.00000,                     ! - Hour 5
    1.00000,                     ! - Hour 6
    1.00000,                     ! - Hour 7
    0.88310,                     ! - Hour 8
    0.40861,                     ! - Hour 9

```

```

0.24189,           !- Hour 10
0.24189,           !- Hour 11
0.24189,           !- Hour 12
0.24189,           !- Hour 13
0.24189,           !- Hour 14
0.24189,           !- Hour 15
0.24189,           !- Hour 16
0.29498,           !- Hour 17
0.55310,           !- Hour 18
0.89693,           !- Hour 19
0.89693,           !- Hour 20
0.89693,           !- Hour 21
1.00000,           !- Hour 22
1.00000,           !- Hour 23
1.00000;          !- Hour 24

```

```

Schedule:Day:Hourly,
LightingDay,          !- Name
Fraction,             !- Schedule Type Limits Name
0.0625,              !- Hour 1
0.0625,              !- Hour 2
0.0625,              !- Hour 3
0.0625,              !- Hour 4
0.1875,              !- Hour 5
0.390625,            !- Hour 6
0.4375,              !- Hour 7
0.390625,            !- Hour 8
0.171875,            !- Hour 9
0.1171875,           !- Hour 10
0.1171875,           !- Hour 11
0.1171875,           !- Hour 12
0.1171875,           !- Hour 13
0.1171875,           !- Hour 14
0.1171875,           !- Hour 15
0.203125,            !- Hour 16
0.4375,              !- Hour 17

```

0.609375 ,	! - Hour 18
0.8203125 ,	! - Hour 19
0.984375 ,	! - Hour 20
1 ,	! - Hour 21
0.6875 ,	! - Hour 22
0.3828125 ,	! - Hour 23
0.15625 ;	! - Hour 24

Schedule:Day:Hourly ,

LightingDay_EELighting_OccSensors ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.065170403 ,	! - Hour 1
0.065170403 ,	! - Hour 2
0.065170403 ,	! - Hour 3
0.065170403 ,	! - Hour 4
0.195511208 ,	! - Hour 5
0.407315016 ,	! - Hour 6
0.456192818 ,	! - Hour 7
0.407315016 ,	! - Hour 8
0.179218607 ,	! - Hour 9
0.122194505 ,	! - Hour 10
0.122194505 ,	! - Hour 11
0.122194505 ,	! - Hour 12
0.122194505 ,	! - Hour 13
0.122194505 ,	! - Hour 14
0.122194505 ,	! - Hour 15
0.211803808 ,	! - Hour 16
0.456192818 ,	! - Hour 17
0.635411425 ,	! - Hour 18
0.855361533 ,	! - Hour 19
0.947933128 ,	! - Hour 20
0.947933128 ,	! - Hour 21
0.716874428 ,	! - Hour 22
0.399168715 ,	! - Hour 23
0.162926006 ;	! - Hour 24

```

Schedule:Day:Hourly ,
LightingDay_EELighting_Garage_OccSensors , !- Name
Fraction , !- Schedule Type Limits Name
0.048125 , !- Hour 1
0.048125 , !- Hour 2
0.048125 , !- Hour 3
0.048125 , !- Hour 4
0.144375 , !- Hour 5
0.30078125 , !- Hour 6
0.336875 , !- Hour 7
0.30078125 , !- Hour 8
0.13234375 , !- Hour 9
0.090234375 , !- Hour 10
0.090234375 , !- Hour 11
0.090234375 , !- Hour 12
0.090234375 , !- Hour 13
0.090234375 , !- Hour 14
0.090234375 , !- Hour 15
0.15640625 , !- Hour 16
0.336875 , !- Hour 17
0.46921875 , !- Hour 18
0.631640625 , !- Hour 19
0.7 , !- Hour 20
0.7 , !- Hour 21
0.529375 , !- Hour 22
0.294765625 , !- Hour 23
0.1203125 ; !- Hour 24

Schedule:Day:Hourly ,
ExteriorLightingDay , !- Name
Fraction , !- Schedule Type Limits Name
1 , !- Hour 1
1 , !- Hour 2
1 , !- Hour 3
1 , !- Hour 4
1 , !- Hour 5

```

```

1,                      ! - Hour 6
0,                      ! - Hour 7
0,                      ! - Hour 8
0,                      ! - Hour 9
0,                      ! - Hour 10
0,                      ! - Hour 11
0,                      ! - Hour 12
0,                      ! - Hour 13
0,                      ! - Hour 14
0,                      ! - Hour 15
0,                      ! - Hour 16
0,                      ! - Hour 17
0,                      ! - Hour 18
1,                      ! - Hour 19
1,                      ! - Hour 20
1,                      ! - Hour 21
1,                      ! - Hour 22
1,                      ! - Hour 23
1;                      ! - Hour 24

```

```

Schedule:Day:Hourly,
LightingDay_EELighting,    ! - Name
Fraction,                  ! - Schedule Type Limits Name
0.06875,                  ! - Hour 1
0.06875,                  ! - Hour 2
0.06875,                  ! - Hour 3
0.06875,                  ! - Hour 4
0.20625,                  ! - Hour 5
0.4296875,                ! - Hour 6
0.48125,                  ! - Hour 7
0.4296875,                ! - Hour 8
0.1890625,                ! - Hour 9
0.12890625,               ! - Hour 10
0.12890625,               ! - Hour 11
0.12890625,               ! - Hour 12
0.12890625,               ! - Hour 13

```

0.12890625 ,	! - Hour 14
0.12890625 ,	! - Hour 15
0.2234375 ,	! - Hour 16
0.48125 ,	! - Hour 17
0.6703125 ,	! - Hour 18
0.90234375 ,	! - Hour 19
1 ,	! - Hour 20
1 ,	! - Hour 21
0.75625 ,	! - Hour 22
0.42109375 ,	! - Hour 23
0.171875 ;	! - Hour 24

Schedule:Day:Hourly ,

RefrigeratorDay ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.8 ,	! - Hour 1
0.782696177062374 ,	! - Hour 2
0.765593561368209 ,	! - Hour 3
0.742857142857143 ,	! - Hour 4
0.731388329979879 ,	! - Hour 5
0.731388329979879 ,	! - Hour 6
0.759959758551308 ,	! - Hour 7
0.8 ,	! - Hour 8
0.817102615694165 ,	! - Hour 9
0.828571428571429 ,	! - Hour 10
0.8 ,	! - Hour 11
0.8 ,	! - Hour 12
0.839839034205231 ,	! - Hour 13
0.839839034205231 ,	! - Hour 14
0.828571428571429 ,	! - Hour 15
0.839839034205231 ,	! - Hour 16
0.885714285714286 ,	! - Hour 17
0.971428571428572 ,	! - Hour 18
1 ,	! - Hour 19
0.971428571428572 ,	! - Hour 20
0.942857142857143 ,	! - Hour 21

```

0.925553319919517,           ! - Hour 22
0.885714285714286,           ! - Hour 23
0.828571428571429;          ! - Hour 24

Schedule:Day:Hourly,
  MiscPlugLoadDay,             ! - Name
  Fraction,                   ! - Schedule Type Limits Name
  0.607490272373541,          ! - Hour 1
  0.559338521400778,          ! - Hour 2
  0.552853437094682,          ! - Hour 3
  0.545071335927367,          ! - Hour 4
  0.524481193255512,          ! - Hour 5
  0.585278858625162,          ! - Hour 6
  0.676232166018158,          ! - Hour 7
  0.718547341115435,          ! - Hour 8
  0.607490272373541,          ! - Hour 9
  0.517023346303502,          ! - Hour 10
  0.529182879377432,          ! - Hour 11
  0.529345006485084,          ! - Hour 12
  0.520428015564202,          ! - Hour 13
  0.538424124513619,          ! - Hour 14
  0.568741893644617,          ! - Hour 15
  0.600356679636835,          ! - Hour 16
  0.71011673151751,          ! - Hour 17
  0.862678339818418,          ! - Hour 18
  0.936608300907912,          ! - Hour 19
  0.966763942931258,          ! - Hour 20
  1,                            ! - Hour 21
  0.976653696498055,          ! - Hour 22
  0.845168612191959,          ! - Hour 23
  0.73443579766537;          ! - Hour 24

Schedule:Day:Hourly,
  CookingRangeDay,             ! - Name
  Fraction,                   ! - Schedule Type Limits Name
  0.04715848452508,          ! - Hour 1

```

0.04715848452508 ,	! - Hour 2
0.0235458911419424 ,	! - Hour 3
0.0235458911419424 ,	! - Hour 4
0.04715848452508 ,	! - Hour 5
0.0707043756670224 ,	! - Hour 6
0.165088046958378 ,	! - Hour 7
0.283017609391676 ,	! - Hour 8
0.306563500533618 ,	! - Hour 9
0.320771077908218 ,	! - Hour 10
0.283017609391676 ,	! - Hour 11
0.330176093916756 ,	! - Hour 12
0.377334578441836 ,	! - Hour 13
0.306563500533618 ,	! - Hour 14
0.292422625400213 ,	! - Hour 15
0.377334578441836 ,	! - Hour 16
0.613193703308431 ,	! - Hour 17
1 ,	! - Hour 18
0.778348452508004 ,	! - Hour 19
0.400947171824973 ,	! - Hour 20
0.235859124866596 ,	! - Hour 21
0.165088046958378 ,	! - Hour 22
0.103721985058698 ,	! - Hour 23
0.0707043756670224 ;	! - Hour 24

Schedule:Day:Hourly ,	
DishwasherWeekday ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.115858456545258 ,	! - Hour 1
0.0514758745041469 ,	! - Hour 2
0.0385691669671833 ,	! - Hour 3
0.0257379372520738 ,	! - Hour 4
0.0257379372520738 ,	! - Hour 5
0.0772138117562207 ,	! - Hour 6
0.154503101334295 ,	! - Hour 7
0.23179239091237 ,	! - Hour 8
0.437922322394519 ,	! - Hour 9

0.489398196898665 ,	! - Hour 10
0.425015614857555 ,	! - Hour 11
0.360633032816445 ,	! - Hour 12
0.309081680490443 ,	! - Hour 13
0.347726325279481 ,	! - Hour 14
0.28334374323837 ,	! - Hour 15
0.270437035701407 ,	! - Hour 16
0.28334374323837 ,	! - Hour 17
0.373464262531554 ,	! - Hour 18
0.656883483591778 ,	! - Hour 19
0.837199999999997 ,	! - Hour 20
0.682621420843852 ,	! - Hour 21
0.502304904435629 ,	! - Hour 22
0.334819617742518 ,	! - Hour 23
0.23179239091237 ;	! - Hour 24

Schedule:Day:Hourly ,	
DishwasherWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.124134060584205 ,	! - Hour 1
0.0551527226830148 ,	! - Hour 2
0.0413241074648395 ,	! - Hour 3
0.0275763613415074 ,	! - Hour 4
0.0275763613415074 ,	! - Hour 5
0.0827290840245222 ,	! - Hour 6
0.165539037143888 ,	! - Hour 7
0.248348990263252 ,	! - Hour 8
0.469202488279841 ,	! - Hour 9
0.524355210962856 ,	! - Hour 10
0.455373873061666 ,	! - Hour 11
0.386392535160476 ,	! - Hour 12
0.331158943382618 ,	! - Hour 13
0.3725639199423 ,	! - Hour 14
0.303582582041111 ,	! - Hour 15
0.289753966822935 ,	! - Hour 16
0.303582582041111 ,	! - Hour 17

```
0.400140281283808,      !- Hour 18
0.703803732419762,      !- Hour 19
0.897,                   !- Hour 20
0.731380093761269,      !- Hour 21
0.538183826181031,      !- Hour 22
0.358735304724125,      !- Hour 23
0.248348990263252;      !- Hour 24
```

Schedule:Day:Hourly,

```
DishwasherVacation,      !- Name
Fraction,                 !- Schedule Type Limits Name
0,                        !- Hour 1
0,                        !- Hour 2
0,                        !- Hour 3
0,                        !- Hour 4
0,                        !- Hour 5
0,                        !- Hour 6
0,                        !- Hour 7
0,                        !- Hour 8
0,                        !- Hour 9
0,                        !- Hour 10
0,                        !- Hour 11
0,                        !- Hour 12
0,                        !- Hour 13
0,                        !- Hour 14
0,                        !- Hour 15
0,                        !- Hour 16
0,                        !- Hour 17
0,                        !- Hour 18
0,                        !- Hour 19
0,                        !- Hour 20
0,                        !- Hour 21
0,                        !- Hour 22
0,                        !- Hour 23
0;                       !- Hour 24
```

```

Schedule:Day:Hourly ,
ClothesWasherWeekday ,      !- Name
Fraction ,                  !- Schedule Type Limits Name
0.0796474528960224 ,      !- Hour 1
0.0637009071877185 ,      !- Hour 2
0.0318078157711097 ,      !- Hour 3
0.0318078157711097 ,      !- Hour 4
0.0637009071877185 ,      !- Hour 5
0.0955939986043261 ,      !- Hour 6
0.191187997208654 ,      !- Hour 7
0.414354361479414 ,      !- Hour 8
0.62157418004187 ,      !- Hour 9
0.7332 ,                  !- Hour 10
0.717253454291697 ,      !- Hour 11
0.637520725750175 ,      !- Hour 12
0.573734542916957 ,      !- Hour 13
0.510033635729239 ,      !- Hour 14
0.446247452896022 ,      !- Hour 15
0.414354361479414 ,      !- Hour 16
0.430300907187718 ,      !- Hour 17
0.414354361479414 ,      !- Hour 18
0.414354361479414 ,      !- Hour 19
0.414354361479414 ,      !- Hour 20
0.414354361479414 ,      !- Hour 21
0.398407815771109 ,      !- Hour 22
0.270920725750174 ,      !- Hour 23
0.143433635729239 ;     !- Hour 24

```

```

Schedule:Day:Hourly ,
ClothesWasherWeekend ,      !- Name
Fraction ,                  !- Schedule Type Limits Name
0.0974410327983253 ,      !- Hour 1
0.0779319609211445 ,      !- Hour 2
0.038913817166783 ,      !- Hour 3
0.038913817166783 ,      !- Hour 4
0.0779319609211445 ,      !- Hour 5

```

0.116950104675506 ,	! - Hour 6
0.233900209351012 ,	! - Hour 7
0.506922889043964 ,	! - Hour 8
0.760436496859734 ,	! - Hour 9
0.897 ,	! - Hour 10
0.877490928122819 ,	! - Hour 11
0.779945568736915 ,	! - Hour 12
0.701909281228193 ,	! - Hour 13
0.623977320307048 ,	! - Hour 14
0.545941032798325 ,	! - Hour 15
0.506922889043964 ,	! - Hour 16
0.526431960921144 ,	! - Hour 17
0.506922889043964 ,	! - Hour 18
0.506922889043964 ,	! - Hour 19
0.506922889043964 ,	! - Hour 20
0.506922889043964 ,	! - Hour 21
0.487413817166783 ,	! - Hour 22
0.331445568736915 ,	! - Hour 23
0.175477320307048 ;	! - Hour 24

Schedule:Day:Hourly ,

ClothesWasherVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8
0 ,	! - Hour 9
0 ,	! - Hour 10
0 ,	! - Hour 11
0 ,	! - Hour 12
0 ,	! - Hour 13

```

0,           ! - Hour 14
0,           ! - Hour 15
0,           ! - Hour 16
0,           ! - Hour 17
0,           ! - Hour 18
0,           ! - Hour 19
0,           ! - Hour 20
0,           ! - Hour 21
0,           ! - Hour 22
0,           ! - Hour 23
0;          ! - Hour 24

```

```

Schedule:Day:Hourly,
dhw_profile_day,           ! - Name
fraction,                  ! - Schedule Type Limits Name
0.006,                     ! - Hour 1
0.003,                     ! - Hour 2
0.001,                     ! - Hour 3
0.001,                     ! - Hour 4
0.003,                     ! - Hour 5
0.021,                     ! - Hour 6
0.075,                     ! - Hour 7
0.079,                     ! - Hour 8
0.076,                     ! - Hour 9
0.067,                     ! - Hour 10
0.061,                     ! - Hour 11
0.05,                      ! - Hour 12
0.042,                     ! - Hour 13
0.038,                     ! - Hour 14
0.033,                     ! - Hour 15
0.038,                     ! - Hour 16
0.043,                     ! - Hour 17
0.058,                     ! - Hour 18
0.068,                     ! - Hour 19
0.065,                     ! - Hour 20
0.06,                      ! - Hour 21

```

```
0.047,           ! - Hour 22
0.041,           ! - Hour 23
0.024;          ! - Hour 24
```

```
Schedule:Day:Hourly,
ClothesDryerWeekday,      ! - Name
Fraction,                ! - Schedule Type Limits Name
0.0996818663838815,    ! - Hour 1
0.0598091198303289,    ! - Hour 2
0.0398727465535526,    ! - Hour 3
0.0199363732767763,    ! - Hour 4
0.0398727465535526,    ! - Hour 5
0.0598091198303289,    ! - Hour 6
0.15949098621421,      ! - Hour 7
0.31898197242842,      ! - Hour 8
0.486427370202556,     ! - Hour 9
0.685791102970318,     ! - Hour 10
0.785472969354199,     ! - Hour 11
0.817391304347826,     ! - Hour 12
0.745600222800647,     ! - Hour 13
0.677836691410393,     ! - Hour 14
0.610073160020138,     ! - Hour 15
0.578154825026511,     ! - Hour 16
0.558218451749735,     ! - Hour 17
0.546236490032885,     ! - Hour 18
0.518345705196183,     ! - Hour 19
0.510391293636256,     ! - Hour 20
0.526300116756109,     ! - Hour 21
0.546236490032885,     ! - Hour 22
0.438600212089077,     ! - Hour 23
0.239236479321316;    ! - Hour 24
```

```
Schedule:Day:Hourly,
ClothesDryerWeekend,      ! - Name
Fraction,                ! - Schedule Type Limits Name
0.121951219512195,      ! - Hour 1
```

```

0.0731707317073171,      !- Hour 2
0.0487804878048781,      !- Hour 3
0.024390243902439,       !- Hour 4
0.0487804878048781,      !- Hour 5
0.0731707317073171,      !- Hour 6
0.195121951219512,       !- Hour 7
0.390243902439024,       !- Hour 8
0.59509731460951,        !- Hour 9
0.8389997536339,         !- Hour 10
0.960950973146095,       !- Hour 11
1,                          !- Hour 12
0.912170485341217,       !- Hour 13
0.829268292682927,       !- Hour 14
0.746366100024637,       !- Hour 15
0.707317073170732,       !- Hour 16
0.682926829268293,       !- Hour 17
0.668268046316827,       !- Hour 18
0.634146341463415,       !- Hour 19
0.624414880512441,       !- Hour 20
0.643877802414388,       !- Hour 21
0.668268046316827,       !- Hour 22
0.536585365853659,       !- Hour 23
0.292682926829268;       !- Hour 24

```

```

Schedule:Day:Hourly,
  ClothesDryerVacation,      !- Name
  Fraction,                  !- Schedule Type Limits Name
  0,                          !- Hour 1
  0,                          !- Hour 2
  0,                          !- Hour 3
  0,                          !- Hour 4
  0,                          !- Hour 5
  0,                          !- Hour 6
  0,                          !- Hour 7
  0,                          !- Hour 8
  0,                          !- Hour 9

```

```

0,                      !- Hour 10
0,                      !- Hour 11
0,                      !- Hour 12
0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
0,                      !- Hour 19
0,                      !- Hour 20
0,                      !- Hour 21
0,                      !- Hour 22
0,                      !- Hour 23
0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
SinksWeekday,           !- Name
Fraction,               !- Schedule Type Limits Name
0.160052687884461,    !- Hour 1
0.0767484287242575,   !- Hour 2
0.0575330636533838,   !- Hour 3
0.0575330636533838,   !- Hour 4
0.0767484287242575,   !- Hour 5
0.204926216902916,    !- Hour 6
0.480271095212623,    !- Hour 7
0.704412677186414,    !- Hour 8
0.742843407328163,    !- Hour 9
0.697969878309708,    !- Hour 10
0.614778650708746,    !- Hour 11
0.563462322813587,    !- Hour 12
0.550689756619418,    !- Hour 13
0.512259026477668,    !- Hour 14
0.467385497459214,    !- Hour 15
0.486600862530089,    !- Hour 16
0.544246957742712,    !- Hour 17

```

0.736400608451458 ,	! - Hour 18
0.84525 ,	! - Hour 19
0.781274137469912 ,	! - Hour 20
0.640323783097085 ,	! - Hour 21
0.544246957742712 ,	! - Hour 22
0.44828316394758 ,	! - Hour 23
0.307332809574753 ;	! - Hour 24

Schedule:Day:Hourly ,

SinksWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.169851832040653 ,	! - Hour 1
0.0814473121155389 ,	! - Hour 2
0.0610554961219577 ,	! - Hour 3
0.0610554961219577 ,	! - Hour 4
0.0814473121155389 ,	! - Hour 5
0.217472719978604 ,	! - Hour 6
0.509675447980744 ,	! - Hour 7
0.747539983952929 ,	! - Hour 8
0.788323615940091 ,	! - Hour 9
0.74070272800214 ,	! - Hour 10
0.652418159935812 ,	! - Hour 11
0.597960016047071 ,	! - Hour 12
0.58440545600428 ,	! - Hour 13
0.543621824017117 ,	! - Hour 14
0.496000936079166 ,	! - Hour 15
0.516392752072746 ,	! - Hour 16
0.57756820005349 ,	! - Hour 17
0.781486359989302 ,	! - Hour 18
0.897 ,	! - Hour 19
0.829107247927254 ,	! - Hour 20
0.679527280021396 ,	! - Hour 21
0.57756820005349 ,	! - Hour 22
0.47572907194437 ,	! - Hour 23
0.326149104038513 ;	! - Hour 24

```

Schedule:Day:Hourly,
    SinksVacation,           !- Name
    Fraction,                !- Schedule Type Limits Name
    0,                       !- Hour 1
    0,                       !- Hour 2
    0,                       !- Hour 3
    0,                       !- Hour 4
    0,                       !- Hour 5
    0,                       !- Hour 6
    0,                       !- Hour 7
    0,                       !- Hour 8
    0,                       !- Hour 9
    0,                       !- Hour 10
    0,                      !- Hour 11
    0,                      !- Hour 12
    0,                      !- Hour 13
    0,                      !- Hour 14
    0,                      !- Hour 15
    0,                      !- Hour 16
    0,                      !- Hour 17
    0,                      !- Hour 18
    0,                      !- Hour 19
    0,                      !- Hour 20
    0,                      !- Hour 21
    0,                      !- Hour 22
    0,                      !- Hour 23
    0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
    ShowersWeekday,          !- Name
    Fraction,                !- Schedule Type Limits Name
    0.076044361285933,     !- Hour 1
    0.0345332539547544,    !- Hour 2
    0.0242088790610646,    !- Hour 3
    0.0345332539547544,    !- Hour 4
    0.0968355162442594,    !- Hour 5

```

0.366693315189659 ,	! - Hour 6
0.837199999999997 ,	! - Hour 7
0.830293349209049 ,	! - Hour 8
0.674644497363497 ,	! - Hour 9
0.529320020411635 ,	! - Hour 10
0.425506650790951 ,	! - Hour 11
0.335577785337642 ,	! - Hour 12
0.242159993196122 ,	! - Hour 13
0.207555536655894 ,	! - Hour 14
0.179857730906617 ,	! - Hour 15
0.186764381697567 ,	! - Hour 16
0.214462187446844 ,	! - Hour 17
0.27676444973635 ,	! - Hour 18
0.300973328797414 ,	! - Hour 19
0.300973328797414 ,	! - Hour 20
0.297484402109202 ,	! - Hour 21
0.290577751318252 ,	! - Hour 22
0.207555536655894 ,	! - Hour 23
0.148742201054601 ;	! - Hour 24

Schedule:Day:Hourly ,

ShowersWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.0814761013777853 ,	! - Hour 1
0.0369999149515223 ,	! - Hour 2
0.0259380847082837 ,	! - Hour 3
0.0369999149515223 ,	! - Hour 4
0.103752338833135 ,	! - Hour 5
0.392885694846062 ,	! - Hour 6
0.897 ,	! - Hour 7
0.889600017009696 ,	! - Hour 8
0.722833390032318 ,	! - Hour 9
0.56712859329818 ,	! - Hour 10
0.455899982990304 ,	! - Hour 11
0.359547627147474 ,	! - Hour 12
0.259457135567274 ,	! - Hour 13

0.222380932131315 ,	! - Hour 14
0.19270471168566 ,	! - Hour 15
0.200104694675966 ,	! - Hour 16
0.229780915121619 ,	! - Hour 17
0.296533339003232 ,	! - Hour 18
0.322471423711515 ,	! - Hour 19
0.322471423711515 ,	! - Hour 20
0.318733287974145 ,	! - Hour 21
0.311333304983841 ,	! - Hour 22
0.222380932131315 ,	! - Hour 23
0.159366643987073 ;	! - Hour 24

Schedule:Day:Hourly ,	
ShowersVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8
0 ,	! - Hour 9
0 ,	! - Hour 10
0 ,	! - Hour 11
0 ,	! - Hour 12
0 ,	! - Hour 13
0 ,	! - Hour 14
0 ,	! - Hour 15
0 ,	! - Hour 16
0 ,	! - Hour 17
0 ,	! - Hour 18
0 ,	! - Hour 19
0 ,	! - Hour 20
0 ,	! - Hour 21

```

0,                      ! - Hour 22
0,                      ! - Hour 23
0;                      ! - Hour 24

```

```

Schedule:Day:Hourly,
BathsWeekday,           ! - Name
Fraction,               ! - Schedule Type Limits Name
0.0492758944582015,   ! - Hour 1
0.0246379472291013,   ! - Hour 2
0.0246379472291013,   ! - Hour 3
0.0246379472291013,   ! - Hour 4
0.0492758944582015,   ! - Hour 5
0.123189736145504,    ! - Hour 6
0.295719195628041,    ! - Hour 7
0.369633037315344,    ! - Hour 8
0.418908931773546,    ! - Hour 9
0.369633037315344,    ! - Hour 10
0.295719195628041,    ! - Hour 11
0.221741525061908,    ! - Hour 12
0.197103577832807,    ! - Hour 13
0.147827683374605,    ! - Hour 14
0.147827683374605,    ! - Hour 15
0.147827683374605,    ! - Hour 16
0.24644330116984,     ! - Hour 17
0.295719195628041,    ! - Hour 18
0.492886602339681,    ! - Hour 19
0.640714285714285,    ! - Hour 20
0.640714285714285,    ! - Hour 21
0.492886602339681,    ! - Hour 22
0.418908931773546,    ! - Hour 23
0.24644330116984;     ! - Hour 24

```

```

Schedule:Day:Hourly,
BathsWeekend,           ! - Name
Fraction,               ! - Schedule Type Limits Name
0.0689862522414824,   ! - Hour 1

```

0.0344931261207412 ,	! - Hour 2
0.0344931261207412 ,	! - Hour 3
0.0344931261207412 ,	! - Hour 4
0.0689862522414824 ,	! - Hour 5
0.172465630603706 ,	! - Hour 6
0.414006873879259 ,	! - Hour 7
0.517486252241482 ,	! - Hour 8
0.586472504482965 ,	! - Hour 9
0.517486252241482 ,	! - Hour 10
0.414006873879259 ,	! - Hour 11
0.310438135086671 ,	! - Hour 12
0.27594500896593 ,	! - Hour 13
0.206958756724447 ,	! - Hour 14
0.206958756724447 ,	! - Hour 15
0.206958756724447 ,	! - Hour 16
0.345020621637776 ,	! - Hour 17
0.414006873879259 ,	! - Hour 18
0.690041243275553 ,	! - Hour 19
0.897 ,	! - Hour 20
0.897 ,	! - Hour 21
0.690041243275553 ,	! - Hour 22
0.586472504482965 ,	! - Hour 23
0.345020621637776 ;	! - Hour 24

Schedule:Day:Hourly ,

BathsVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8
0 ,	! - Hour 9

```

0,                      !- Hour 10
0,                      !- Hour 11
0,                      !- Hour 12
0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
0,                      !- Hour 19
0,                      !- Hour 20
0,                      !- Hour 21
0,                      !- Hour 22
0,                      !- Hour 23
0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
DHWDistDay,           !- Name
Fraction,              !- Schedule Type Limits Name
0.142553149370226,   !- Hour 1
0.0764866759550322,   !- Hour 2
0.0516611840277747,   !- Hour 3
0.0584039294664903,   !- Hour 4
0.121469841058603,   !- Hour 5
0.366180268451559,   !- Hour 6
0.833258955739606,   !- Hour 7
0.99999987228391,   !- Hour 8
0.995483090581232,   !- Hour 9
0.916474762598139,   !- Hour 10
0.800898393293271,   !- Hour 11
0.682564390940485,   !- Hour 12
0.590066600109555,   !- Hour 13
0.522371887032053,   !- Hour 14
0.466005974303267,   !- Hour 15
0.46573704253214,   !- Hour 16
0.527514234916123,   !- Hour 17

```

0.637905701335668 ,	! - Hour 18
0.727588642310272 ,	! - Hour 19
0.732551127624518 ,	! - Hour 20
0.681468471942116 ,	! - Hour 21
0.610804704600985 ,	! - Hour 22
0.464292318119835 ,	! - Hour 23
0.299867724445383 ;	! - Hour 24

Schedule:Day:Hourly ,

WinterLoadDay ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8
0 ,	! - Hour 9
0 ,	! - Hour 10
0 ,	! - Hour 11
0 ,	! - Hour 12
0 ,	! - Hour 13
0 ,	! - Hour 14
0 ,	! - Hour 15
0 ,	! - Hour 16
0 ,	! - Hour 17
0 ,	! - Hour 18
0 ,	! - Hour 19
0 ,	! - Hour 20
0 ,	! - Hour 21
0 ,	! - Hour 22
0 ,	! - Hour 23
0 ;	! - Hour 24

```

Schedule:Day:Hourly ,
SummerLoadDay ,           ! - Name
Fraction ,                 ! - Schedule Type Limits Name
1 ,                        ! - Hour 1
1 ,                        ! - Hour 2
1 ,                        ! - Hour 3
1 ,                        ! - Hour 4
1 ,                        ! - Hour 5
1 ,                        ! - Hour 6
1 ,                        ! - Hour 7
1 ,                        ! - Hour 8
1 ,                        ! - Hour 9
1 ,                        ! - Hour 10
1 ,                        ! - Hour 11
1 ,                        ! - Hour 12
1 ,                        ! - Hour 13
1 ,                        ! - Hour 14
1 ,                        ! - Hour 15
1 ,                        ! - Hour 16
1 ,                        ! - Hour 17
1 ,                        ! - Hour 18
1 ,                        ! - Hour 19
1 ,                        ! - Hour 20
1 ,                        ! - Hour 21
1 ,                        ! - Hour 22
1 ,                        ! - Hour 23
1 ;                        ! - Hour 24

! - ===== ALL OBJECTS IN CLASS: SCHEDULE:WEEK:COMPACT
=====

Schedule:Week:Compact ,
RefrigeratorWeek ,          ! - Name
For: AllDays ,              ! - DayType List 1
RefrigeratorDay;            ! - Schedule:Day Name 1

```

```

Schedule:Week:Compact ,
    MiscPlugLoadWeek ,           !- Name
    For: AllDays ,              !- DayType List 1
    MiscPlugLoadDay;            !- Schedule:Day Name 1

Schedule:Week:Compact ,
    CookingRangeWeek ,          !- Name
    For: AllDays ,              !- DayType List 1
    CookingRangeDay;            !- Schedule:Day Name 1

Schedule:Week:Compact ,
    DishwasherWeek ,            !- Name
    For: Weekdays ,             !- DayType List 1
    DishwasherWeekday ,          !- Schedule:Day Name 1
    For: CustomDay1 ,            !- DayType List 2
    DishwasherVacation ,         !- Schedule:Day Name 2
    For: AllOtherDays ,          !- DayType List 3
    DishwasherWeekend;          !- Schedule:Day Name 3

Schedule:Week:Compact ,
    ClothesWasherWeek ,          !- Name
    For: Weekdays ,              !- DayType List 1
    ClothesWasherWeekday ,        !- Schedule:Day Name 1
    For: CustomDay1 ,            !- DayType List 2
    ClothesWasherVacation ,      !- Schedule:Day Name 2
    For: AllOtherDays ,          !- DayType List 3
    ClothesWasherWeekend;        !- Schedule:Day Name 3

Schedule:Week:Compact ,
    dhw_profile_week ,          !- Name
    AllDays ,                   !- DayType List 1
    dhw_profile_day;            !- Schedule:Day Name 1

Schedule:Week:Compact ,
    ClothesDryerWeek ,           !- Name

```

```

For: Weekdays ,           !- DayType List 1
ClothesDryerWeekday ,     !- Schedule:Day Name 1
For: CustomDay1 ,          !- DayType List 2
ClothesDryerVacation ,    !- Schedule:Day Name 2
For: AllOtherDays ,        !- DayType List 3
ClothesDryerWeekend;      !- Schedule:Day Name 3

Schedule:Week:Compact ,
SinksWeek ,                !- Name
For: Weekdays ,            !- DayType List 1
SinksWeekday ,              !- Schedule:Day Name 1
For: CustomDay1 ,            !- DayType List 2
SinksVacation ,             !- Schedule:Day Name 2
For: AllOtherDays ,          !- DayType List 3
SinksWeekend;               !- Schedule:Day Name 3

Schedule:Week:Compact ,
ShowersWeek ,                !- Name
For: Weekdays ,            !- DayType List 1
ShowersWeekday ,              !- Schedule:Day Name 1
For: CustomDay1 ,            !- DayType List 2
ShowersVacation ,             !- Schedule:Day Name 2
For: AllOtherDays ,          !- DayType List 3
ShowersWeekend;               !- Schedule:Day Name 3

Schedule:Week:Compact ,
BathsWeek ,                  !- Name
For: Weekdays ,            !- DayType List 1
BathsWeekday ,              !- Schedule:Day Name 1
For: CustomDay1 ,            !- DayType List 2
BathsVacation ,             !- Schedule:Day Name 2
For: AllOtherDays ,          !- DayType List 3
BathsWeekend;               !- Schedule:Day Name 3

Schedule:Week:Compact ,
DHWDistWeek ,                !- Name

```

```

For: AllDays,           !- DayType List 1
DHWDistDay;           !- Schedule:Day Name 1

Schedule:Week:Compact,
OccupancyWeek,         !- Name
AllDays,               !- DayType List 1
OccupancyDay;          !- Schedule:Day Name 1

Schedule:Week:Compact,
LightingProfileWeek,   !- Name
For: AllDays,           !- DayType List 1
LightingDay;            !- Schedule:Day Name 1

Schedule:Week:Compact,
LightingProfileWeek_EELighting,  !- Name
For: AllDays,           !- DayType List 1
LightingDay_EELighting;  !- Schedule:Day Name 1

Schedule:Week:Compact,
LightingProfileWeek_EELighting_interior_controls,  !- Name
For: AllDays,           !- DayType List 1
LightingDay_EELighting_OccSensors;  !- Schedule:Day Name 1

Schedule:Week:Compact,
LightingProfileWeek_EELighting_garage_controls,  !- Name
For: AllDays,           !- DayType List 1
LightingDay_EELighting_Garage_OccSensors;  !- Schedule:Day Name
1

Schedule:Week:Compact,
ExteriorLightingProfileWeek,  !- Name
For: AllDays,           !- DayType List 1
ExteriorLightingDay;      !- Schedule:Day Name 1

! - ===== ALL OBJECTS IN CLASS: SCHEDULE:YEAR =====

```

```

Schedule:Year,
    Occupancy,           !- Name
    Fraction,            !- Schedule Type Limits Name
    OccupancyWeek,       !- Schedule:Week Name 1
    1,                  !- Start Month 1
    1,                  !- Start Day 1
    12,                 !- End Month 1
    31;                !- End Day 1


Schedule:Year,
    InteriorLighting,   !- Name
    Fraction,            !- Schedule Type Limits Name
    LightingProfileWeek, !- Schedule:Week Name 1
    1,                  !- Start Month 1
    1,                  !- Start Day 1
    12,                 !- End Month 1
    31;                !- End Day 1


Schedule:Year,
    InteriorLightingHE, !- Name
    Fraction,            !- Schedule Type Limits Name
    LightingProfileWeek_EELighting, !- Schedule:Week Name 1
    1,                  !- Start Month 1
    1,                  !- Start Day 1
    12,                 !- End Month 1
    31;                !- End Day 1


Schedule:Year,
    InteriorLightingHE_OS, !- Name
    Fraction,             !- Schedule Type Limits Name
    LightingProfileWeek_EELighting_interior_controls, !- Schedule:
    Week Name 1
    1,                  !- Start Month 1
    1,                  !- Start Day 1
    12,                 !- End Month 1

```

```

31;                                !- End Day 1

Schedule:Year,
  InteriorLightingHE_VS,      !- Name
  Fraction,                  !- Schedule Type Limits Name
  LightingProfileWeek_EELighting_garage_controls, !- Schedule:
  Week Name 1
  1,                          !- Start Month 1
  1,                          !- Start Day 1
  12,                         !- End Month 1
  31;                        !- End Day 1

Schedule:Year,
  ExteriorLighting,          !- Name
  Fraction,                  !- Schedule Type Limits Name
  ExteriorLightingProfileWeek, !- Schedule:Week Name 1
  1,                          !- Start Month 1
  1,                          !- Start Day 1
  12,                         !- End Month 1
  31;                        !- End Day 1

Schedule:Year,
  Refrigerator,              !- Name
  Fraction,                  !- Schedule Type Limits Name
  RefrigeratorWeek,          !- Schedule:Week Name 1
  1,                          !- Start Month 1
  1,                          !- Start Day 1
  12,                         !- End Month 1
  31;                        !- End Day 1

Schedule:Year,
  MiscPlugLoad,               !- Name
  Fraction,                  !- Schedule Type Limits Name
  MiscPlugLoadWeek,           !- Schedule:Week Name 1
  1,                          !- Start Month 1
  1,                          !- Start Day 1

```

```

12,                                !- End Month 1
31;                                 !- End Day 1

Schedule:Year,
CookingRange,                         !- Name
Fraction,                             !- Schedule Type Limits Name
CookingRangeWeek,                      !- Schedule:Week Name 1
1,                                    !- Start Month 1
1,                                    !- Start Day 1
12,                                   !- End Month 1
31;                                  !- End Day 1

Schedule:Year,
dhw_sch,                            !- Name
fraction,                            !- Schedule Type Limits Name
dhw_profile_week,                     !- Schedule:Week Name 1
1,                                    !- Start Month 1
1,                                    !- Start Day 1
12,                                   !- End Month 1
31;                                  !- End Day 1

Schedule:Year,
Dishwasher,                           !- Name
Fraction,                            !- Schedule Type Limits Name
DishwasherWeek,                        !- Schedule:Week Name 1
1,                                    !- Start Month 1
1,                                    !- Start Day 1
12,                                   !- End Month 1
31;                                  !- End Day 1

Schedule:Year,
ClothesWasher,                        !- Name
Fraction,                            !- Schedule Type Limits Name
ClothesWasherWeek,                     !- Schedule:Week Name 1
1,                                    !- Start Month 1
1,                                    !- Start Day 1

```

```

12,                                !- End Month 1
31;                                 !- End Day 1

Schedule:Year,
  ClothesDryer,                      !- Name
  Fraction,                           !- Schedule Type Limits Name
  ClothesDryerWeek,                  !- Schedule:Week Name 1
  1,                                  !- Start Month 1
  1,                                  !- Start Day 1
  12,                                 !- End Month 1
  31;                                 !- End Day 1

Schedule:Year,
  Sinks,                             !- Name
  Fraction,                          !- Schedule Type Limits Name
  SinksWeek,                         !- Schedule:Week Name 1
  1,                                  !- Start Month 1
  1,                                  !- Start Day 1
  12,                                 !- End Month 1
  31;                                 !- End Day 1

Schedule:Year,
  Showers,                           !- Name
  Fraction,                          !- Schedule Type Limits Name
  ShowersWeek,                       !- Schedule:Week Name 1
  1,                                  !- Start Month 1
  1,                                  !- Start Day 1
  12,                                 !- End Month 1
  31;                                 !- End Day 1

Schedule:Year,
  Baths,                            !- Name
  Fraction,                          !- Schedule Type Limits Name
  BathsWeek,                         !- Schedule:Week Name 1
  1,                                  !- Start Month 1
  1,                                  !- Start Day 1

```

```

12,                                !- End Month 1
31;                                 !- End Day 1

Schedule:Year,
    DHWDist,                         !- Name
    Fraction,                          !- Schedule Type Limits Name
    DHWDistWeek,                      !- Schedule:Week Name 1
    1,                                 !- Start Month 1
    1,                                 !- Start Day 1
    12,                               !- End Month 1
    31;                               !- End Day 1

!- ===== ALL OBJECTS IN CLASS: SCHEDULE:COMPACT =====
Schedule:Compact,
    fan_sch,                          !- Name
    Fractional,                        !- Schedule Type Limits Name
    Through: 12/31,                   !- Field 1
    For: AllDays,                     !- Field 2
    Until: 24:00,                      !- Field 3
    0.5;                             !- Field 4

Schedule:Compact,
    BA_shower_sch,                  !- Name
    any number,                       !- Schedule Type Limits Name
    Through: 12/31,                   !- Field 1
    For: AllDays,                     !- Field 2
    Until: 1:00,                      !- Field 3
    0.001746824444444444,           !- Field 4
    Until: 2:00,                      !- Field 5
    0.000794011111111111,           !- Field 6
    Until: 3:00,                      !- Field 7
    0.000476406666666667,           !- Field 8
    Until: 4:00,                      !- Field 9
    0.000794011111111111,           !- Field 10
    Until: 5:00,                      !- Field 11

```

0.002223231111111111 ,	! - Field 12
Until: 6:00 ,	! - Field 13
0.00825771555555556 ,	! - Field 14
Until: 7:00 ,	! - Field 15
0.0187386622222222 ,	! - Field 16
Until: 8:00 ,	! - Field 17
0.01857986 ,	! - Field 18
Until: 9:00 ,	! - Field 19
0.0150862111111111 ,	! - Field 20
Until: 10:00 ,	! - Field 21
0.0117513644444444 ,	! - Field 22
Until: 11:00 ,	! - Field 23
0.0095281333333333 ,	! - Field 24
Until: 12:00 ,	! - Field 25
0.0074637044444444 ,	! - Field 26
Until: 13:00 ,	! - Field 27
0.00539927555555556 ,	! - Field 28
Until: 14:00 ,	! - Field 29
0.0046052644444444 ,	! - Field 30
Until: 15:00 ,	! - Field 31
0.00412885777777778 ,	! - Field 32
Until: 16:00 ,	! - Field 33
0.0039700555555556 ,	! - Field 34
Until: 17:00 ,	! - Field 35
0.00476406666666667 ,	! - Field 36
Until: 18:00 ,	! - Field 37
0.00619328666666667 ,	! - Field 38
Until: 19:00 ,	! - Field 39
0.0066696933333333 ,	! - Field 40
Until: 20:00 ,	! - Field 41
0.0066696933333333 ,	! - Field 42
Until: 21:00 ,	! - Field 43
0.0066696933333333 ,	! - Field 44
Until: 22:00 ,	! - Field 45
0.0065108911111111 ,	! - Field 46
Until: 23:00 ,	! - Field 47

```

0.0046052644444444 ,      !- Field 48
Until: 24:00 ,              !- Field 49
0.0033348466666667;      !- Field 50

Schedule:Compact ,
BA_bath_sch ,             !- Name
any number ,                !- Schedule Type Limits Name
Through: 12/31 ,            !- Field 1
For: AllDays ,              !- Field 2
Until: 1:00 ,                !- Field 3
0.000163090909090909 ,    !- Field 4
Until: 2:00 ,                !- Field 5
8.15454545454545e-05 ,    !- Field 6
Until: 3:00 ,                !- Field 7
8.15454545454545e-05 ,    !- Field 8
Until: 4:00 ,                !- Field 9
8.15454545454545e-05 ,    !- Field 10
Until: 5:00 ,                !- Field 11
0.000163090909090909 ,    !- Field 12
Until: 6:00 ,                !- Field 13
0.000387340909090909 ,    !- Field 14
Until: 7:00 ,                !- Field 15
0.000937772727272727 ,    !- Field 16
Until: 8:00 ,                !- Field 17
0.00118240909090909 ,     !- Field 18
Until: 9:00 ,                !- Field 19
0.0013455 ,                 !- Field 20
Until: 10:00 ,               !- Field 21
0.00118240909090909 ,     !- Field 22
Until: 11:00 ,               !- Field 23
0.000937772727272727 ,    !- Field 24
Until: 12:00 ,               !- Field 25
0.000713522727272727 ,    !- Field 26
Until: 13:00 ,               !- Field 27
0.000631977272727273 ,    !- Field 28
Until: 14:00 ,               !- Field 29

```

```

0.000468886363636364,      !- Field 30
Until: 15:00,                  !- Field 31
0.000468886363636364,      !- Field 32
Until: 16:00,                  !- Field 33
0.000468886363636364,      !- Field 34
Until: 17:00,                  !- Field 35
0.000795068181818182,      !- Field 36
Until: 18:00,                  !- Field 37
0.000937772727272727,      !- Field 38
Until: 19:00,                  !- Field 39
0.00156975,                  !- Field 40
Until: 20:00,                  !- Field 41
0.00203863636363636,       !- Field 42
Until: 21:00,                  !- Field 43
0.00203863636363636,       !- Field 44
Until: 22:00,                  !- Field 45
0.00156975,                  !- Field 46
Until: 23:00,                  !- Field 47
0.0013455,                   !- Field 48
Until: 24:00,                  !- Field 49
0.000795068181818182;      !- Field 50

```

```

Schedule:Compact,
  BA_sink_sch,           !- Name
  any number,             !- Schedule Type Limits Name
  Through: 12/31,         !- Field 1
  For: AllDays,           !- Field 2
  Until: 1:00,             !- Field 3
  0.00387388596491228,   !- Field 4
  Until: 2:00,             !- Field 5
  0.00193694298245614,   !- Field 6
  Until: 3:00,             !- Field 7
  0.00138353070175439,   !- Field 8
  Until: 4:00,             !- Field 9
  0.00138353070175439,   !- Field 10
  Until: 5:00,             !- Field 11

```

0.00193694298245614 ,	! - Field 12
Until: 6:00 ,	! - Field 13
0.00498071052631579 ,	! - Field 14
Until: 7:00 ,	! - Field 15
0.0116216578947368 ,	! - Field 16
Until: 8:00 ,	! - Field 17
0.0171557807017544 ,	! - Field 18
Until: 9:00 ,	! - Field 19
0.0182626052631579 ,	! - Field 20
Until: 10:00 ,	! - Field 21
0.0171557807017544 ,	! - Field 22
Until: 11:00 ,	! - Field 23
0.0149421315789474 ,	! - Field 24
Until: 12:00 ,	! - Field 25
0.0138353070175439 ,	! - Field 26
Until: 13:00 ,	! - Field 27
0.013558600877193 ,	! - Field 28
Until: 14:00 ,	! - Field 29
0.0124517763157895 ,	! - Field 30
Until: 15:00 ,	! - Field 31
0.0118983640350877 ,	! - Field 32
Until: 16:00 ,	! - Field 33
0.011344951754386 ,	! - Field 34
Until: 17:00 ,	! - Field 35
0.0132818947368421 ,	! - Field 36
Until: 18:00 ,	! - Field 37
0.017985899122807 ,	! - Field 38
Until: 19:00 ,	! - Field 39
0.0207529605263158 ,	! - Field 40
Until: 20:00 ,	! - Field 41
0.0190927236842105 ,	! - Field 42
Until: 21:00 ,	! - Field 43
0.01577225 ,	! - Field 44
Until: 22:00 ,	! - Field 45
0.0132818947368421 ,	! - Field 46
Until: 23:00 ,	! - Field 47

```

0.0110682456140351 ,           !- Field 48
Until: 24:00 ,                  !- Field 49
0.00747106578947368;         !- Field 50

Schedule:Compact ,
activity_sch ,                  !- Name
any number ,                     !- Schedule Type Limits Name
Through: 12/31 ,                !- Field 1
For: AllDays ,                  !- Field 2
Until: 24:00 ,                  !- Field 3
117.28;                         !- Field 4

Schedule:Compact ,
inf_sch ,                        !- Name
any number ,                     !- Schedule Type Limits Name
Through: 12/31 ,                !- Field 1
For: AllDays ,                  !- Field 2
Until: 24:00 ,                  !- Field 3
1;                               !- Field 4

Schedule:Compact ,
zone_control_type ,             !- Name
control_type ,                  !- Schedule Type Limits Name
Through: 12/31 ,                !- Field 1
For: AllDays ,                  !- Field 2
Until 24:00 ,                   !- Field 3
4;                               !- Field 4

Schedule:Compact ,
shading_2012iecc ,             !- Name
fraction ,                      !- Schedule Type Limits Name
Through: 12/31 ,                !- Field 1
For: AllDays ,                  !- Field 2
Until 24:00 ,                   !- Field 3
0;                               !- Field 4

```

```

Schedule:Compact ,
    shading_2009iecc ,           !- Name
    any number ,                 !- Schedule Type Limits Name
    Through: 5/30 ,             !- Field 1
    For: AllDays ,              !- Field 2
    Until 24:00 ,               !- Field 3
    0.85 ,                      !- Field 4
    Through: 8/31 ,             !- Field 5
    For: AllDays ,              !- Field 6
    Until 24:00 ,               !- Field 7
    0.7 ,                       !- Field 8
    Through: 12/31 ,            !- Field 9
    For: AllDays ,              !- Field 10
    Until: 24:00 ,              !- Field 11
    0.85;                      !- Field 12

```

```

Schedule:Compact ,
    dhw_setpt ,                !- Name
    Temperature ,               !- Schedule Type Limits Name
    Through: 12/31 ,            !- Field 1
    For: AllDays ,              !- Field 2
    Until 24:00 ,               !- Field 3
    48;                        !- Field 4

```

```

Schedule:Compact ,
    dhw_setpt_hpwh ,          !- Name
    Temperature ,              !- Schedule Type Limits Name
    Through: 12/31 ,            !- Field 1
    For: AllDays ,              !- Field 2
    Until 24:00 ,               !- Field 3
    44;                        !- Field 4

```

```

Schedule:Compact ,
    Supply-Air-Temp-Sch ,      !- Name
    Temperature ,              !- Schedule Type Limits Name
    Through: 12/31 ,            !- Field 1

```

```

For: AllDays,           !- Field 2
Until: 24:00,           !- Field 3
12;                   !- Field 4

Schedule:Compact,
    always_avail,      !- Name
    On/Off,             !- Schedule Type Limits Name
    Through: 12/31,     !- Field 1
    For: AllDays,       !- Field 2
    Until: 24:00,       !- Field 3
    1;                  !- Field 4

Schedule:Compact,
    always_off,         !- Name
    On/Off,              !- Schedule Type Limits Name
    Through: 12/31,      !- Field 1
    For: AllDays,        !- Field 2
    Until: 24:00,        !- Field 3
    0;                  !- Field 4

Schedule:Compact,
    heating_sch_HRef,   !- Name
    Temperature,         !- Schedule Type Limits Name
    Through: 12/31,      !- Field 1
    For: AllDays,        !- Field 2
    Until: 24:00,        !- Field 3
    17;                 !- Field 4

Schedule:Compact,
    cooling_sch_HRef,   !- Name
    Temperature,         !- Schedule Type Limits Name
    Through: 12/31,      !- Field 1
    For: AllDays,        !- Field 2
    Until: 24:00,        !- Field 3
    25.55;               !- Field 4

```

```

Schedule:Compact ,
    heating_sch ,           !- Name
    Temperature ,           !- Schedule Type Limits Name
    Through: 12/31 ,        !- Field 1
    For: AllDays ,          !- Field 2
    Until: 24:00 ,          !- Field 3
    17;                   !- Field 4

Schedule:Compact ,
    cooling_sch ,           !- Name
    Temperature ,           !- Schedule Type Limits Name
    Through: 12/31 ,        !- Field 1
    For: AllDays ,          !- Field 2
    Until: 24:00 ,          !- Field 3
    23.888888888889;      !- Field 4

Schedule:Compact ,
    fan_cycle ,             !- Name
    any number ,            !- Schedule Type Limits Name
    Through: 12/31 ,        !- Field 1
    For: AllDays ,          !- Field 2
    Until: 24:00 ,          !- Field 3
    0;                     !- Field 4

Schedule:Compact ,
    Clothing Sch ,          !- Name
    Fractional ,            !- Schedule Type Limits Name
    Through: 12/31 ,        !- Field 1
    For: AllDays ,          !- Field 2
    Until: 24:00 ,          !- Field 3
    0.45;                  !- Field 4

Schedule:Compact ,
    Air Velo Sch ,          !- Name
    Fractional ,            !- Schedule Type Limits Name
    Through: 12/31 ,        !- Field 1

```

```

For: AllDays,           !- Field 2
Until: 24:00,           !- Field 3
0.35;                  !- Field 4

Schedule:Compact,
Work Eff Sch,          !- Name
Fractional,             !- Schedule Type Limits Name
Through: 12/31,         !- Field 1
For: AllDays,           !- Field 2
Until: 24:00,           !- Field 3
0;                      !- Field 4

!- ===== ALL OBJECTS IN CLASS: SCHEDULE:CONSTANT
=====

Schedule:Constant,
DWWaterTempSchedule,   !- Name
Temperature,            !- Schedule Type Limits Name
48.888888888889;      !- Hourly Value

Schedule:Constant,
CWWaterTempSchedule,   !- Name
Temperature,            !- Schedule Type Limits Name
48.888888888889;      !- Hourly Value

Schedule:Constant,
SinkSensSchedule,       !- Name
Fraction,                !- Schedule Type Limits Name
0.6877777777777778;  !- Hourly Value

Schedule:Constant,
SinkLatSchedule,         !- Name
Fraction,                !- Schedule Type Limits Name
0.312222222222222;    !- Hourly Value

```

```

Schedule:Constant ,
    ShowerSensSchedule ,           !- Name
    Fraction ,                     !- Schedule Type Limits Name
    0.51280276816609;            !- Hourly Value

Schedule:Constant ,
    ShowerLatSchedule ,           !- Name
    Fraction ,                   !- Schedule Type Limits Name
    0.48719723183391;          !- Hourly Value

Schedule:Constant ,
    BathSensSchedule ,           !- Name
    Fraction ,                   !- Schedule Type Limits Name
    1;                           !- Hourly Value

Schedule:Constant ,
    BathLatSchedule ,           !- Name
    Fraction ,                   !- Schedule Type Limits Name
    0;                           !- Hourly Value

Schedule:Constant ,
    SSBWaterTempSchedule ,       !- Name
    Temperature ,                !- Schedule Type Limits Name
    40.5555555555556;          !- Hourly Value

Schedule:Constant ,
    WaterHeaterSP1Schedule ,     !- Name
    Temperature ,                !- Schedule Type Limits Name
    48.8888888888889;          !- Hourly Value

Schedule:Constant ,
    WaterHeaterSP2Schedule ,     !- Name
    Temperature ,                !- Schedule Type Limits Name
    40.5555555555556;          !- Hourly Value

```

```

Schedule:Constant ,
    DHWSupplySetpoint ,           !- Name
    Temperature ,                 !- Schedule Type Limits Name
    48.888888888889;            !- Hourly Value

Schedule:Constant ,
    boiler_setpt ,                !- Name
    Temperature ,                 !- Schedule Type Limits Name
    80;                           !- Hourly Value

Schedule:Constant ,
    Compressor Setpoint ,         !- Name
    Temperature ,                 !- Schedule Type Limits Name
    50;                           !- Hourly Value

Schedule:Constant ,
    DOAShightemp ,                !- Name
    Temperature ,                 !- Schedule Type Limits Name
    200;                          !- Hourly Value

Schedule:Constant ,
    DOASlowtemp ,                 !- Name
    Temperature ,                 !- Schedule Type Limits Name
    -60;                          !- Hourly Value

! - ===== ALL OBJECTS IN CLASS: MATERIAL =====

!Name
Material ,
    sheathing_consol_layer ,     !- Name
    Rough ,                      !- Roughness
    0.0127 ,                     !- Thickness {m}
    0.0940184 ,                  !- Conductivity {W/m-K}
    685.008 ,                    !- Density {kg/m3}
    1172.332;                   !- Specific Heat {J/kg-K}

```

```

! Name
Material ,
    ceil_consol_layer ,           ! - Name
    Rough ,                      ! - Roughness
    0.284817435151397 ,          ! - Thickness {m}
    0.0617176 ,                  ! - Conductivity {W/m-K}
    41.9286 ,                    ! - Density {kg/m3}
    776.25126 ;                 ! - Specific Heat {J/kg-K}

! Name
Material ,
    floor_consol_layer ,         ! - Name
    Rough ,                      ! - Roughness
    0.000254 ,                   ! - Thickness {m}
    12.989536 ,                  ! - Conductivity {W/m-K}
    55.074 ,                     ! - Density {kg/m3}
    916.9311 ;                  ! - Specific Heat {J/kg-K}

! Name
Material ,
    bsmtwall_consol_layer ,      ! - Name
    Rough ,                      ! - Roughness
    0.000254 ,                   ! - Thickness {m}
    10.84384 ,                  ! - Conductivity {W/m-K}
    120.801 ,                    ! - Density {kg/m3}
    1036.25775 ;                ! - Specific Heat {J/kg-K}

! Name
Material ,
    crawlwall_consol_layer ,     ! - Name
    Rough ,                      ! - Roughness
    0.000254 ,                   ! - Thickness {m}
    10.84384 ,                  ! - Conductivity {W/m-K}
    120.801 ,                    ! - Density {kg/m3}
    1036.25775 ;                ! - Specific Heat {J/kg-K}

```

```

! Name
Material ,
    wall_consol_layer ,           ! - Name
    Rough ,                      ! - Roughness
    0.0889 ,                     ! - Thickness {m}
    0.0579573076923077 ,        ! - Conductivity {W/m-K}
    120.801 ,                    ! - Density {kg/m3}
    1036.25775;                 ! - Specific Heat {J/kg-K}

Material ,
    Very High Reflectivity Surface , ! - Name
    Smooth ,                      ! - Roughness
    0.0005 ,                     ! - Thickness {m}
    237 ,                         ! - Conductivity {W/m-K}
    2702 ,                        ! - Density {kg/m3}
    903 ,                         ! - Specific Heat {J/kg-K}
    0.90 ,                        ! - Thermal Absorptance
    0.05 ,                        ! - Solar Absorptance
    0.05;                         ! - Visible Absorptance

Material ,
    GypsumBoard -5/16 in ,       ! - Name
    Rough ,                       ! - Roughness
    7.93953E-03 ,                ! - Thickness {m}
    0.1586200 ,                  ! - Conductivity {W/m-K}
    640 ,                         ! - Density {kg/m3}
    1129.6 ,                      ! - Specific Heat {J/kg-K}
    0.9 ,                          ! - Thermal Absorptance
    0.4 ,                          ! - Solar Absorptance
    0.1;                           ! - Visible Absorptance

Material ,
    CopperPipe ,                 ! - Name
    MediumRough ,                 ! - Roughness
    1.90500386169072E-02 ,       ! - Thickness {m}

```

```

401,                                     ! - Conductivity {W/m-K}
2243.000,                                 ! - Density {kg/m3}
837.0000,                                ! - Specific Heat {J/kg-K}
0.9000000,                               ! - Thermal Absorptance
0.6500000,                                ! - Solar Absorptance
0.6500000;                                ! - Visible Absorptance

Material,
F08 Metal surface,                      ! - Name
Smooth,                                    ! - Roughness
0.0008,                                    ! - Thickness {m}
45.28,                                     ! - Conductivity {W/m-K}
7824,                                      ! - Density {kg/m3}
500;                                       ! - Specific Heat {J/kg-K}

Material,
Concrete_4in,                            ! - Name
Rough,                                     ! - Roughness
0.1014984,                                ! - Thickness {m}
1.312098,                                 ! - Conductivity {W/m-K}
2242.8,                                    ! - Density {kg/m3}
465.2;                                     ! - Specific Heat {J/kg-K}

Material,
Asphalt_shingle,                         ! - Name
MediumRough,                               ! - Roughness
6.33985285170672E-03,                   ! - Thickness {m}
0.08186,                                   ! - Conductivity {W/m-K}
1121.2917044623,                         ! - Density {kg/m3}
1255.20000949809,                        ! - Specific Heat {J/kg-K}
,                                         ! - Thermal Absorptance
0.75;                                      ! - Solar Absorptance

Material,
Wood_shingle,                            ! - Name
MediumSmooth,                            ! - Roughness

```

```

1.27000257446048E-02,      ! - Thickness {m}
0.11388,                   ! - Conductivity {W/m-K}
426.090847695673,         ! - Density {kg/m3}
1631.76001234752;        ! - Specific Heat {J/kg-K}

Material,
Slate_shingle,             ! - Name
MediumSmooth,              ! - Roughness
1.27000257446048E-02,      ! - Thickness {m}
1.44219,                   ! - Conductivity {W/m-K}
1601.845292089,           ! - Density {kg/m3}
1255.20000949809;         ! - Specific Heat {J/kg-K}

Material,
cement_stucco,             ! - Name
MediumSmooth,              ! - Roughness
1.905E-02,                  ! - Thickness {m}
0.721,                      ! - Conductivity {W/m-K}
1865.58,                    ! - Density {kg/m3}
878.640006648665;          ! - Specific Heat {J/kg-K}

Material,
syn_stucco,                ! - Name
MediumSmooth,              ! - Roughness
0.3048E-02,                  ! - Thickness {m}
8.65E-02,                    ! - Conductivity {W/m-K}
400,                         ! - Density {kg/m3}
878.640006648665;          ! - Specific Heat {J/kg-K}

Material,
Drywall_1/2in,              ! - Name
MediumSmooth,              ! - Roughness
1.27000257446048E-02,      ! - Thickness {m}
0.16009,                     ! - Conductivity {W/m-K}
800.922646044499,           ! - Density {kg/m3}
1087.84000823168;          ! - Specific Heat {J/kg-K}

```

```

Material ,
OSB_5/8in , ! - Name
MediumSmooth , ! - Roughness
0.015875032180756 , ! - Thickness {m}
0.1163 , ! - Conductivity {W/m-K}
544.627399310259 , ! - Density {kg/m3}
1213.36000918149 ; ! - Specific Heat {J/kg-K}

Material ,
OSB_7/16in , ! - Name
MediumSmooth , ! - Roughness
0.0111125 , ! - Thickness {m}
0.1163 , ! - Conductivity {W/m-K}
544.627399310259 , ! - Density {kg/m3}
1213.36000918149 ; ! - Specific Heat {J/kg-K}

Material ,
Blown_R30 , ! - Name
MediumRough , ! - Roughness
0.212598430964684 , ! - Thickness {m}
0.04119 , ! - Conductivity {W/m-K}
9.61107175253399 , ! - Density {kg/m3}
836.800006332062 ; ! - Specific Heat {J/kg-K}

Material ,
Blown_R30_top , ! - Name
MediumRough , ! - Roughness
0.117348237880148 , ! - Thickness {m}
0.04119 , ! - Conductivity {W/m-K}
9.61107175253399 , ! - Density {kg/m3}
836.800006332062 , ! - Specific Heat {J/kg-K}
0.9 , ! - Thermal Absorptance
0.7 , ! - Solar Absorptance
0.7 ; ! - Visible Absorptance

```

```

Material ,
Plywood_3/4in , ! - Name
Rough , ! - Roughness
0.01905 , ! - Thickness {m}
0.1154577 , ! - Conductivity {W/m-K}
544.68 , ! - Density {kg/m3}
674.54 , ! - Specific Heat {J/kg-K}
0.9 , ! - Thermal Absorptance
0.7 , ! - Solar Absorptance
0.7; ! - Visible Absorptance

Material ,
Batt_R19 , ! - Name
MediumRough , ! - Roughness
2.54000514892096E-02 , ! - Thickness {m}
3.47522010738099E-03 , ! - Conductivity {W/m-K}
9.61107175253399 , ! - Density {kg/m3}
836.800006332062 , ! - Specific Heat {J/kg-K}
0.9 , ! - Thermal Absorptance
0.7 , ! - Solar Absorptance
0.7; ! - Visible Absorptance

Material ,
Lumber_2x4 , ! - Name
Rough , ! - Roughness
0.0890016 , ! - Thickness {m}
0.1154577 , ! - Conductivity {W/m-K}
512.64 , ! - Density {kg/m3}
767.58 , ! - Specific Heat {J/kg-K}
0.9 , ! - Thermal Absorptance
0.7 , ! - Solar Absorptance
0.7; ! - Visible Absorptance

Material ,
Carpet_n_pad , ! - Name
MediumSmooth , ! - Roughness

```

```

2.54000514892096E-02,      ! - Thickness {m}
6.01314018580031E-02,      ! - Conductivity {W/m-K}
32.03690584178,           ! - Density {kg/m3}
836.800006332062,          ! - Specific Heat {J/kg-K}
0.9,                         ! - Thermal Absorptance
0.7,                         ! - Solar Absorptance
0.7;                         ! - Visible Absorptance

Material,
Batt_R13,                   ! - Name
MediumRough,                 ! - Roughness
0.0889,                      ! - Thickness {m}
0.03876,                     ! - Conductivity {W/m-K}
9.61107175253399,           ! - Density {kg/m3}
836.800006332062,          ! - Specific Heat {J/kg-K}
0.9,                          ! - Thermal Absorptance
0.7,                          ! - Solar Absorptance
0.7;                          ! - Visible Absorptance

Material,
OSB_1/2in,                  ! - Name
MediumSmooth,                ! - Roughness
1.27000257446048E-02,       ! - Thickness {m}
0.1163,                      ! - Conductivity {W/m-K}
544.627399310259,           ! - Density {kg/m3}
1213.36000918149,           ! - Specific Heat {J/kg-K}
0.9,                          ! - Thermal Absorptance
0.7,                          ! - Solar Absorptance
0.7;                          ! - Visible Absorptance

Material,
soil_12in,                  ! - Name
Rough,                        ! - Roughness
0.3048,                      ! - Thickness {m}
1.731,                        ! - Conductivity {W/m-K}
1842.3,                       ! - Density {kg/m3}

```

```

232.6,                                     !- Specific Heat {J/kg-K}
0.9,                                         !- Thermal Absorptance
0.7,                                         !- Solar Absorptance
0.7;                                         !- Visible Absorptance

Material,
door_const,                                !- Name
Smooth,                                      !- Roughness
0.0253617440918536,                      !- Thickness {m}
0.0720096,                                   !- Conductivity {W/m-K}
512.64,                                      !- Density {kg/m3}
767.58;                                     !- Specific Heat {J/kg-K}

Material,
Gyp_board_1/2in,                            !- Name
Rough,                                       !- Roughness
0.01271016,                                 !- Thickness {m}
0.1586200,                                  !- Conductivity {W/m-K}
640,                                         !- Density {kg/m3}
1129.6,                                     !- Specific Heat {J/kg-K}
0.9,                                         !- Thermal Absorptance
0.4,                                         !- Solar Absorptance
0.1;                                         !- Visible Absorptance

Material,
Std Wood 6inch,                            !- Name
MediumSmooth,                               !- Roughness
0.15,                                       !- Thickness {m}
0.12,                                       !- Conductivity {W/m-K}
540.0000,                                  !- Density {kg/m3}
1210,                                       !- Specific Heat {J/kg-K}
0.9000000,                                 !- Thermal Absorptance
0.7000000,                                 !- Solar Absorptance
0.7000000;                                !- Visible Absorptance

Material,

```

```

Pipe Insulation,
VeryRough,
0.0127032520325203,
0.03317175,
91.0,
836.0,
0.9,
0.5,
0.5;

! - Name
! - Roughness
! - Thickness {m}
! - Conductivity {W/m-K}
! - Density {kg/m3}
! - Specific Heat {J/kg-K}
! - Thermal Absorptance
! - Solar Absorptance
! - Visible Absorptance

! - ===== ALL OBJECTS IN CLASS: MATERIAL:NOMASS =====

Material:NoMass,
Manf_wall_airgap,
Smooth,
0.12;

! - Name
! - Roughness
! - Thermal Resistance {m2-K/W}

Material:NoMass,
Bldg_paper_felt,
Smooth,
1.05666113069662E-02;

! - Name
! - Roughness
! - Thermal Resistance {m2-K/W}

Material:NoMass,
R_high,
MediumRough,
177;

! - Name
! - Roughness
! - Thermal Resistance {m2-K/W}

! - ===== ALL OBJECTS IN CLASS: MATERIAL:AIRGAP =====

Material:AirGap,
Air_4_in_vert,
0.158499169604493;

! - Name
! - Thermal Resistance {m2-K/W}

Material:AirGap,

```

```

3/4in_air_space,           ! - Name
0.08513;                  ! - Thermal Resistance {m2-K/W}

Material:AirGap,
3/4in_Reflective_air_space,  ! - Name
0.246554;                  ! - Thermal Resistance {m2-K/W}

! - ===== ALL OBJECTS IN CLASS: WINDOWMATERIAL:GLAZING
=====

WindowMaterial:Glazing,
Clear Acrylic Plastic,      ! - Name
SpectralAverage,             ! - Optical Data Type
,                           ! - Window Glass Spectral Data Set Name
0.003,                      ! - Thickness {m}
0.92,                        ! - Solar Transmittance at Normal
Incidence
0.05,                         ! - Front Side Solar Reflectance at
Normal Incidence
0.05,                         ! - Back Side Solar Reflectance at
Normal Incidence
0.92,                         ! - Visible Transmittance at Normal
Incidence
0.05,                         ! - Front Side Visible Reflectance at
Normal Incidence
0.05,                         ! - Back Side Visible Reflectance at
Normal Incidence
0.00,                         ! - Infrared Transmittance at Normal
Incidence
0.90,                         ! - Front Side Infrared Hemispherical
Emissivity
0.90,                         ! - Back Side Infrared Hemispherical
Emissivity
0.90;                        ! - Conductivity {W/m-K}

```

```

WindowMaterial:Glazing ,
    Diffusing Acrylic Plastic,      !- Name
    SpectralAverage,              !- Optical Data Type
    ,                            !- Window Glass Spectral Data Set Name
    0.0022,                      !- Thickness {m}
    0.90,                        !- Solar Transmittance at Normal
    Incidence
    0.08,                         !- Front Side Solar Reflectance at
    Normal Incidence
    0.08,                         !- Back Side Solar Reflectance at
    Normal Incidence
    0.90,                         !- Visible Transmittance at Normal
    Incidence
    0.08,                         !- Front Side Visible Reflectance at
    Normal Incidence
    0.08,                         !- Back Side Visible Reflectance at
    Normal Incidence
    0.00,                         !- Infrared Transmittance at Normal
    Incidence
    0.90,                         !- Front Side Infrared Hemispherical
    Emissivity
    0.90,                         !- Back Side Infrared Hemispherical
    Emissivity
    0.90;                         !- Conductivity {W/m-K}

! - ===== ALL OBJECTS IN CLASS: WINDOWMATERIAL:BLIND
=====

!*** Properties for blinds taken from E+ dataset for 'Blinds with
Medium Reflectivity Slats'***
!

WindowMaterial:Blind ,
    int_blind,                    ! - Name
    Horizontal,                  ! - Slat Orientation
    0.025,                       ! - Slat Width {m}

```

```

0.01875,           !- Slat Separation {m}
0.001,             !- Slat Thickness {m}
45.0,              !- Slat Angle {deg}
221,               !- Slat Conductivity {W/m-K}
0.0,               !- Slat Beam Solar Transmittance
0.5,               !- Front Side Slat Beam Solar
Reflectance
0.5,               !- Back Side Slat Beam Solar
Reflectance
0.0,               !- Slat Diffuse Solar Transmittance
0.5,               !- Front Side Slat Diffuse Solar
Reflectance
0.5,               !- Back Side Slat Diffuse Solar
Reflectance
0.0,               !- Slat Beam Visible Transmittance
0.5,               !- Front Side Slat Beam Visible
Reflectance
0.5,               !- Back Side Slat Beam Visible
Reflectance
0.0,               !- Slat Diffuse Visible Transmittance
0.5,               !- Front Side Slat Diffuse Visible
Reflectance
0.5,               !- Back Side Slat Diffuse Visible
Reflectance
0.0,               !- Slat Infrared Hemispherical
Transmittance
0.9,               !- Front Side Slat Infrared
Hemispherical Emissivity
0.9,               !- Back Side Slat Infrared
Hemispherical Emissivity
0.050,             !- Blind to Glass Distance {m}
0.5,               !- Blind Top Opening Multiplier
0.5,               !- Blind Bottom Opening Multiplier
0.5,               !- Blind Left Side Opening Multiplier
0.5,               !- Blind Right Side Opening Multiplier
,                 !- Minimum Slat Angle {deg}

```

```

;                                         ! - Maximum Slat Angle {deg}

! - ===== ALL OBJECTS IN CLASS: CONSTRUCTION =====

Construction,
    Exterior Wall,           ! - Name
    syn_stucco,              ! - Outside Layer
    sheathing_consol_layer,  ! - Layer 2
    OSB_7/16in,               ! - Layer 3
    wall_consol_layer,        ! - Layer 4
    Drywall_1/2in;            ! - Layer 5

Construction,
    InteriorFurnishings,     ! - Name
    Std Wood 6inch;          ! - Outside Layer

Construction,
    ceiling-floor-layer,     ! - Name
    Lumber_2x4;               ! - Outside Layer

Construction,
    Exterior Floor,           ! - Name
    floor_consol_layer,       ! - Outside Layer
    Plywood_3/4in,             ! - Layer 2
    Carpet_n_pad;              ! - Layer 3

Construction,
    Interior Floor,           ! - Name
    Plywood_3/4in,             ! - Outside Layer
    Carpet_n_pad;              ! - Layer 2

Construction,
    Interior Ceiling,          ! - Name
    ceil_consol_layer,         ! - Outside Layer
    Drywall_1/2in;              ! - Layer 2

```

```

Construction,
    attic_floor,           !- Name
    Drywall_1/2in,          !- Outside Layer
    ceil_consol_layer;      !- Layer 2

Construction,
    fndn_roof,             !- Name
    Carpet_n_pad,           !- Outside Layer
    Plywood_3/4in,          !- Layer 2
    ceil_consol_layer;      !- Layer 3

Construction,
    interiorwall,          !- Name
    Drywall_1/2in,          !- Outside Layer
    OSB_5/8in,              !- Layer 2
    Drywall_1/2in;          !- Layer 3

Construction,
    Interior_Wall,          !- Name
    Drywall_1/2in,           !- Outside Layer
    Air_4_in_vert,           !- Layer 2
    Drywall_1/2in;           !- Layer 3

Construction,
    Exterior_Roof,           !- Name
    Asphalt_shingle,         !- Outside Layer
    OSB_1/2in;                !- Layer 2

Construction,
    Exterior_Window,          !- Name
    Glass;                   !- Outside Layer

Construction,
    Interior_Window,          !- Name
    Glass;                   !- Outside Layer

```

```

Construction ,
    Exterior Door ,           !- Name
    door_const;               !- Outside Layer

Construction ,
    Interior Door ,          !- Name
    door_const;               !- Outside Layer

Construction ,
    Gable_end ,              !- Name
    cement_stucco ,           !- Outside Layer
    Bldg_paper_felt ,         !- Layer 2
    OSB_5/8in ,               !- Layer 3
    Air_4_in_vert ,           !- Layer 4
    Drywall_1/2in;            !- Layer 5

Construction ,
    crawl_floor ,             !- Name
    R_high ,                  !- Outside Layer
    soil_12in;                !- Layer 2

Construction ,
    window_w_blinds ,         !- Name
    Glass ,                   !- Outside Layer
    int_blind;                !- Layer 2

Construction ,
    Insulated Pipe ,          !- Name
    Pipe Insulation ,          !- Outside Layer
    CopperPipe;                !- Layer 2

Construction ,
    Plain Pipe ,              !- Name
    CopperPipe;               !- Outside Layer

```

```

Construction ,
    TDD Pipe ,           !- Name
    Very High Reflectivity Surface;  !- Outside Layer

Construction ,
    TDD Dome ,           !- Name
    Clear Acrylic Plastic;  !- Outside Layer

Construction ,
    TDD Diffuser ,        !- Name
    Diffusing Acrylic Plastic;  !- Outside Layer

!- ===== ALL OBJECTS IN CLASS: WINDOWMATERIAL:
SIMPLEGLAZINGSYSTEM =====

!Name
!U-Factor {W/m2-K}
!Solar Heat Gain Coefficient
!Visible Transmittance

WindowMaterial:SimpleGlazingSystem ,
    Glass ,           !- Name
    2.8393 ,          !- U-Factor {W/m2-K}
    0.216875 ,         !- Solar Heat Gain Coefficient
    0.88;             !- Visible Transmittance

!- ===== ALL OBJECTS IN CLASS: GLOBALGEOMETRYRULES
=====

GlobalGeometryRules ,
    LowerLeftCorner ,      !- Starting Vertex Position
    Counterclockwise ,     !- Vertex Entry Direction
    World;                !- Coordinate System

```

```

! - ===== ALL OBJECTS IN CLASS: ZONE =====

Zone,
    living_unit1,           ! - Name
    0.0,                   ! - Direction of Relative North {deg}
    0.0,                   ! - X Origin {m}
    0.0,                   ! - Y Origin {m}
    0.0,                   ! - Z Origin {m}
    ,                      ! - Type
    1;                     ! - Multiplier

Zone,
    attic_unit1,           ! - Name
    0.0,                   ! - Direction of Relative North {deg}
    0.0,                   ! - X Origin {m}
    0.0,                   ! - Y Origin {m}
    0.0,                   ! - Z Origin {m}
    ,                      ! - Type
    1;                     ! - Multiplier

! - ===== ALL OBJECTS IN CLASS: BUILDINGSURFACE:DETAILED
=====

BuildingSurface:Detailed,
    Inter zone floor 1,      ! - Name
    Floor,                  ! - Surface Type
    Interior Floor,         ! - Construction Name
    living_unit1,            ! - Zone Name
    Adiabatic,              ! - Outside Boundary Condition
    ,                       ! - Outside Boundary Condition Object
    NoSun,                  ! - Sun Exposure
    NoWind,                 ! - Wind Exposure
    0.0,                    ! - View Factor to Ground
    4,                      ! - Number of Vertices

```

```

0,                                     !- Vertex 1 X-coordinate {m}
0,                                     !- Vertex 1 Y-coordinate {m}
2.60156341463415,                     !- Vertex 1 Z-coordinate {m}
0,                                     !- Vertex 2 X-coordinate {m}
9.09981820971244,                     !- Vertex 2 Y-coordinate {m}
2.60156341463415,                     !- Vertex 2 Z-coordinate {m}
12.1330909462833,                    !- Vertex 3 X-coordinate {m}
9.09981820971244,                     !- Vertex 3 Y-coordinate {m}
2.60156341463415,                     !- Vertex 3 Z-coordinate {m}
12.1330909462833,                    !- Vertex 4 X-coordinate {m}
0,                                     !- Vertex 4 Y-coordinate {m}
2.60156341463415;                   !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
ceiling_unit1,                         !- Name
Ceiling,                                !- Surface Type
Interior Ceiling,                      !- Construction Name
living_unit1,                           !- Zone Name
Zone,                                   !- Outside Boundary Condition
attic_unit1,                            !- Outside Boundary Condition Object
NoSun,                                  !- Sun Exposure
NoWind,                                 !- Wind Exposure
0.0,                                    !- View Factor to Ground
4,                                      !- Number of Vertices
0,                                     !- Vertex 1 X-coordinate {m}
0,                                     !- Vertex 1 Y-coordinate {m}
5.19302682926829,                     !- Vertex 1 Z-coordinate {m}
12.1330909462833,                    !- Vertex 2 X-coordinate {m}
0,                                     !- Vertex 2 Y-coordinate {m}
5.19302682926829,                     !- Vertex 2 Z-coordinate {m}
12.1330909462833,                    !- Vertex 3 X-coordinate {m}
9.09981820971244,                     !- Vertex 3 Y-coordinate {m}
5.19302682926829,                     !- Vertex 3 Z-coordinate {m}
0,                                     !- Vertex 4 X-coordinate {m}
9.09981820971244,                     !- Vertex 4 Y-coordinate {m}
5.19302682926829;                   !- Vertex 4 Z-coordinate {m}

```

```

BuildingSurface:Detailed,
    Roof_front_unit1,           !- Name
    Roof,                      !- Surface Type
    Exterior_Roof,             !- Construction Name
    attic_unit1,               !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    0.0,                       !- View Factor to Ground
    4,                         !- Number of Vertices
    0,                         !- Vertex 1 X-coordinate {m}
    0,                         !- Vertex 1 Y-coordinate {m}
    5.19302682926829,         !- Vertex 1 Z-coordinate {m}
    12.1330909462833,         !- Vertex 2 X-coordinate {m}
    0,                         !- Vertex 2 Y-coordinate {m}
    5.19302682926829,         !- Vertex 2 Z-coordinate {m}
    12.1330909462833,         !- Vertex 3 X-coordinate {m}
    4.54990910485622,         !- Vertex 3 Y-coordinate {m}
    6.6995631975537,          !- Vertex 3 Z-coordinate {m}
    0,                         !- Vertex 4 X-coordinate {m}
    4.54990910485622,         !- Vertex 4 Y-coordinate {m}
    6.6995631975537;          !- Vertex 4 Z-coordinate {m}

```

```

BuildingSurface:Detailed,
    Roof_back_unit1,           !- Name
    Roof,                      !- Surface Type
    Exterior_Roof,             !- Construction Name
    attic_unit1,               !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    0.0,                       !- View Factor to Ground
    4,                         !- Number of Vertices

```

```

12.1330909462833 ,           !- Vertex 1 X-coordinate {m}
9.09981820971244 ,           !- Vertex 1 Y-coordinate {m}
5.19302682926829 ,           !- Vertex 1 Z-coordinate {m}
0 ,                           !- Vertex 2 X-coordinate {m}
9.09981820971244 ,           !- Vertex 2 Y-coordinate {m}
5.19302682926829 ,           !- Vertex 2 Z-coordinate {m}
0 ,                           !- Vertex 3 X-coordinate {m}
4.54990910485622 ,           !- Vertex 3 Y-coordinate {m}
6.6995631975537 ,           !- Vertex 3 Z-coordinate {m}
12.1330909462833 ,           !- Vertex 4 X-coordinate {m}
4.54990910485622 ,           !- Vertex 4 Y-coordinate {m}
6.6995631975537;          !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed ,
Roof_right_unit1 ,           !- Name
Wall ,                         !- Surface Type
Gable_end ,                    !- Construction Name
attic_unit1 ,                  !- Zone Name
Outdoors ,                     !- Outside Boundary Condition
,                               !- Outside Boundary Condition Object
SunExposed ,                   !- Sun Exposure
WindExposed ,                 !- Wind Exposure
,                               !- View Factor to Ground
3 ,                            !- Number of Vertices
12.1330909462833 ,           !- Vertex 1 X-coordinate {m}
0 ,                            !- Vertex 1 Y-coordinate {m}
5.19302682926829 ,           !- Vertex 1 Z-coordinate {m}
12.1330909462833 ,           !- Vertex 2 X-coordinate {m}
9.09981820971244 ,           !- Vertex 2 Y-coordinate {m}
5.19302682926829 ,           !- Vertex 2 Z-coordinate {m}
12.1330909462833 ,           !- Vertex 3 X-coordinate {m}
4.54990910485622 ,           !- Vertex 3 Y-coordinate {m}
6.6995631975537;          !- Vertex 3 Z-coordinate {m}

BuildingSurface:Detailed ,
Roof_left_unit1 ,            !- Name

```

```

Wall ,                                     !- Surface Type
Gable_end ,                                !- Construction Name
attic_unit1 ,                               !- Zone Name
Outdoors ,                                  !- Outside Boundary Condition
,                                         !- Outside Boundary Condition Object
SunExposed ,                                !- Sun Exposure
WindExposed ,                               !- Wind Exposure
,                                         !- View Factor to Ground
3 ,                                         !- Number of Vertices
0 ,                                         !- Vertex 1 X-coordinate {m}
9.09981820971244 ,                         !- Vertex 1 Y-coordinate {m}
5.19302682926829 ,                         !- Vertex 1 Z-coordinate {m}
0 ,                                         !- Vertex 2 X-coordinate {m}
0 ,                                         !- Vertex 2 Y-coordinate {m}
5.19302682926829 ,                         !- Vertex 2 Z-coordinate {m}
0 ,                                         !- Vertex 3 X-coordinate {m}
4.54990910485622 ,                         !- Vertex 3 Y-coordinate {m}
6.6995631975537;                          !- Vertex 3 Z-coordinate {m}

BuildingSurface:Detailed ,
Wall_ldf_1.unit1 ,                           !- Name
Wall ,                                     !- Surface Type
Exterior Wall ,                            !- Construction Name
living_unit1 ,                             !- Zone Name
Outdoors ,                                 !- Outside Boundary Condition
,                                         !- Outside Boundary Condition Object
SunExposed ,                                !- Sun Exposure
WindExposed ,                               !- Wind Exposure
,                                         !- View Factor to Ground
4 ,                                         !- Number of Vertices
0 ,                                         !- Vertex 1 X-coordinate {m}
0 ,                                         !- Vertex 1 Y-coordinate {m}
0.0101 ,                                    !- Vertex 1 Z-coordinate {m}
12.1330909462833 ,                        !- Vertex 2 X-coordinate {m}
0 ,                                         !- Vertex 2 Y-coordinate {m}
0.0101 ,                                    !- Vertex 2 Z-coordinate {m}

```

```

12.1330909462833 ,           !- Vertex 3 X-coordinate {m}
0 ,                           !- Vertex 3 Y-coordinate {m}
2.60156341463415 ,           !- Vertex 3 Z-coordinate {m}
0 ,                           !- Vertex 4 X-coordinate {m}
0 ,                           !- Vertex 4 Y-coordinate {m}
2.60156341463415;          !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Wall_sdr_1.unit1 ,           !- Name
Wall ,                         !- Surface Type
Exterior Wall ,               !- Construction Name
living_unit1 ,                !- Zone Name
Outdoors ,                     !- Outside Boundary Condition
,                             !- Outside Boundary Condition Object
SunExposed ,                  !- Sun Exposure
WindExposed ,                 !- Wind Exposure
,                             !- View Factor to Ground
4 ,                           !- Number of Vertices
12.1330909462833 ,           !- Vertex 1 X-coordinate {m}
0 ,                           !- Vertex 1 Y-coordinate {m}
0.0101 ,                      !- Vertex 1 Z-coordinate {m}
12.1330909462833 ,           !- Vertex 2 X-coordinate {m}
9.09981820971244 ,           !- Vertex 2 Y-coordinate {m}
0.0101 ,                      !- Vertex 2 Z-coordinate {m}
12.1330909462833 ,           !- Vertex 3 X-coordinate {m}
9.09981820971244 ,           !- Vertex 3 Y-coordinate {m}
2.60156341463415 ,           !- Vertex 3 Z-coordinate {m}
12.1330909462833 ,           !- Vertex 4 X-coordinate {m}
0 ,                           !- Vertex 4 Y-coordinate {m}
2.60156341463415;          !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Wall_ldb_1.unit1 ,           !- Name
Wall ,                         !- Surface Type
Exterior Wall ,               !- Construction Name
living_unit1 ,                !- Zone Name

```

```

Outdoors,
,
SunExposed,
WindExposed,
,
4,
12.1330909462833,
9.09981820971244,
0.0101,
0,
9.09981820971244,
0.0101,
0,
9.09981820971244,
2.60156341463415,
12.1330909462833,
9.09981820971244,
2.60156341463415;           !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Wall_sdl_1.unit1,          !- Name
Wall,                      !- Surface Type
Exterior Wall,            !- Construction Name
living_unit1,              !- Zone Name
Outdoors,                  !- Outside Boundary Condition
,
SunExposed,                !- Sun Exposure
WindExposed,               !- Wind Exposure
,
4,                         !- Number of Vertices
0,                         !- Vertex 1 X-coordinate {m}
9.09981820971244,         !- Vertex 1 Y-coordinate {m}
0.0101,                   !- Vertex 1 Z-coordinate {m}
0,                         !- Vertex 2 X-coordinate {m}
0,                         !- Vertex 2 Y-coordinate {m}
0.0101,                   !- Vertex 2 Z-coordinate {m}

```

```

0,                                     !- Vertex 3 X-coordinate {m}
0,                                     !- Vertex 3 Y-coordinate {m}
2.60156341463415,                     !- Vertex 3 Z-coordinate {m}
0,                                     !- Vertex 4 X-coordinate {m}
9.09981820971244,                     !- Vertex 4 Y-coordinate {m}
2.60156341463415;                     !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Wall_ldf_2.unit1,                      !- Name
Wall,                                    !- Surface Type
Exterior Wall,                          !- Construction Name
living_unit1,                           !- Zone Name
Outdoors,                               !- Outside Boundary Condition
,                                       !- Outside Boundary Condition Object
SunExposed,                            !- Sun Exposure
WindExposed,                           !- Wind Exposure
,                                       !- View Factor to Ground
4,                                      !- Number of Vertices
0,                                     !- Vertex 1 X-coordinate {m}
0,                                     !- Vertex 1 Y-coordinate {m}
2.60156341463415,                     !- Vertex 1 Z-coordinate {m}
12.1330909462833,                     !- Vertex 2 X-coordinate {m}
0,                                     !- Vertex 2 Y-coordinate {m}
2.60156341463415,                     !- Vertex 2 Z-coordinate {m}
12.1330909462833,                     !- Vertex 3 X-coordinate {m}
0,                                     !- Vertex 3 Y-coordinate {m}
5.19302682926829,                     !- Vertex 3 Z-coordinate {m}
0,                                     !- Vertex 4 X-coordinate {m}
0,                                     !- Vertex 4 Y-coordinate {m}
5.19302682926829;                   !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Wall_sdr_2.unit1,                      !- Name
Wall,                                    !- Surface Type
Exterior Wall,                          !- Construction Name
living_unit1,                           !- Zone Name

```

```

Outdoors,
,
SunExposed,
WindExposed,
,
4,
12.1330909462833,
0,
2.60156341463415,
12.1330909462833,
9.09981820971244,
2.60156341463415,
12.1330909462833,
9.09981820971244,
5.19302682926829,
12.1330909462833,
0,
5.19302682926829;

BuildingSurface:Detailed,
Wall_ldb_2.unit1,
Wall,
Exterior Wall,
living_unit1,
Outdoors,
,
SunExposed,
WindExposed,
,
4,
12.1330909462833,
9.09981820971244,
2.60156341463415,
0,
9.09981820971244,
2.60156341463415,

```

!- Outside Boundary Condition  
!- Outside Boundary Condition Object  
!- Sun Exposure  
!- Wind Exposure  
!- View Factor to Ground  
!- Number of Vertices  
!- Vertex 1 X-coordinate {m}  
!- Vertex 1 Y-coordinate {m}  
!- Vertex 1 Z-coordinate {m}  
!- Vertex 2 X-coordinate {m}  
!- Vertex 2 Y-coordinate {m}  
!- Vertex 2 Z-coordinate {m}  
!- Vertex 3 X-coordinate {m}  
!- Vertex 3 Y-coordinate {m}  
!- Vertex 3 Z-coordinate {m}  
!- Vertex 4 X-coordinate {m}  
!- Vertex 4 Y-coordinate {m}  
!- Vertex 4 Z-coordinate {m}

!- Name  
!- Surface Type  
!- Construction Name  
!- Zone Name  
!- Outside Boundary Condition  
!- Outside Boundary Condition Object  
!- Sun Exposure  
!- Wind Exposure  
!- View Factor to Ground  
!- Number of Vertices  
!- Vertex 1 X-coordinate {m}  
!- Vertex 1 Y-coordinate {m}  
!- Vertex 1 Z-coordinate {m}  
!- Vertex 2 X-coordinate {m}  
!- Vertex 2 Y-coordinate {m}  
!- Vertex 2 Z-coordinate {m}

```

0,                                     !- Vertex 3 X-coordinate {m}
9.09981820971244,                     !- Vertex 3 Y-coordinate {m}
5.19302682926829,                     !- Vertex 3 Z-coordinate {m}
12.1330909462833,                    !- Vertex 4 X-coordinate {m}
9.09981820971244,                     !- Vertex 4 Y-coordinate {m}
5.19302682926829;                   !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Wall_sdl_2.unit1,                      !- Name
Wall,                                    !- Surface Type
Exterior Wall,                         !- Construction Name
living_unit1,                           !- Zone Name
Outdoors,                               !- Outside Boundary Condition
,                                         !- Outside Boundary Condition Object
SunExposed,                            !- Sun Exposure
WindExposed,                           !- Wind Exposure
,                                         !- View Factor to Ground
4,                                         !- Number of Vertices
0,                                         !- Vertex 1 X-coordinate {m}
9.09981820971244,                     !- Vertex 1 Y-coordinate {m}
2.60156341463415,                     !- Vertex 1 Z-coordinate {m}
0,                                         !- Vertex 2 X-coordinate {m}
0,                                         !- Vertex 2 Y-coordinate {m}
2.60156341463415,                     !- Vertex 2 Z-coordinate {m}
0,                                         !- Vertex 3 X-coordinate {m}
0,                                         !- Vertex 3 Y-coordinate {m}
5.19302682926829,                     !- Vertex 3 Z-coordinate {m}
0,                                         !- Vertex 4 X-coordinate {m}
9.09981820971244,                     !- Vertex 4 Y-coordinate {m}
5.19302682926829;                   !- Vertex 4 Z-coordinate {m}

BuildingSurface:Detailed,
Floor_unit1,                            !- Name
Floor,                                   !- Surface Type
Interior Floor,                         !- Construction Name
living_unit1,                           !- Zone Name

```

```

Ground,
        !- Outside Boundary Condition
,
        !- Outside Boundary Condition Object
NoSun,
        !- Sun Exposure
NoWind,
        !- Wind Exposure
0.0,
        !- View Factor to Ground
4,
        !- Number of Vertices
0,
        !- Vertex 1 X-coordinate {m}
0,
        !- Vertex 1 Y-coordinate {m}
0.0101,
        !- Vertex 1 Z-coordinate {m}
0,
        !- Vertex 2 X-coordinate {m}
9.09981820971244,
        !- Vertex 2 Y-coordinate {m}
0.0101,
        !- Vertex 2 Z-coordinate {m}
12.1330909462833,
        !- Vertex 3 X-coordinate {m}
9.09981820971244,
        !- Vertex 3 Y-coordinate {m}
0.0101,
        !- Vertex 3 Z-coordinate {m}
12.1330909462833,
        !- Vertex 4 X-coordinate {m}
0,
        !- Vertex 4 Y-coordinate {m}
0.0101;
        !- Vertex 4 Z-coordinate {m}

!- ===== ALL OBJECTS IN CLASS: WINDOW =====

Window,
    Window_ldf_1.unit1,           !- Name
    Exterior Window,             !- Construction Name
    Wall_ldf_1.unit1,            !- Building Surface Name
,
        !- Frame and Divider Name
1,                                !- Multiplier
1,                                !- Starting X Coordinate {m}
0.914634146341463,               !- Starting Z Coordinate {m}
2.70719591738945,               !- Length {m}
1.52439024390244;              !- Height {m}

Window,
    Window_ldb_1.unit1,           !- Name
    Exterior Window,             !- Construction Name

```

```

Wall_ldb_1.unit1,           !- Building Surface Name
,
!- Frame and Divider Name
1,                          !- Multiplier
2.74190122145512,         !- Starting X Coordinate {m}
0.914634146341463,        !- Starting Z Coordinate {m}
2.70719591738945,         !- Length {m}
1.52439024390244;        !- Height {m}

Window,
Window_sdr_1.unit1,         !- Name
Exterior Window,            !- Construction Name
Wall_sdr_1.unit1,           !- Building Surface Name
,
!- Frame and Divider Name
1,                          !- Multiplier
1,                          !- Starting X Coordinate {m}
0.914634146341463,        !- Starting Z Coordinate {m}
2.70719591738945,         !- Length {m}
1.52439024390244;        !- Height {m}

Window,
Window_sdl_1.unit1,         !- Name
Exterior Window,            !- Construction Name
Wall_sdl_1.unit1,           !- Building Surface Name
,
!- Frame and Divider Name
1,                          !- Multiplier
1,                          !- Starting X Coordinate {m}
0.914634146341463,        !- Starting Z Coordinate {m}
2.70719591738945,         !- Length {m}
1.52439024390244;        !- Height {m}

Window,
Window_ldf_2.unit1,          !- Name
Exterior Window,             !- Construction Name
Wall_ldf_2.unit1,            !- Building Surface Name
,
!- Frame and Divider Name
1,                          !- Multiplier

```

```

1,                               !- Starting X Coordinate {m}
0.914634146341463,           !- Starting Z Coordinate {m}
2.70719591738945,           !- Length {m}
1.52439024390244;          !- Height {m}

Window,
  Window_ldb_2.unit1,          !- Name
  Exterior Window,            !- Construction Name
  Wall_ldb_2.unit1,           !- Building Surface Name
  ,                           !- Frame and Divider Name
  1,                           !- Multiplier
  2.74190122145512,          !- Starting X Coordinate {m}
  0.914634146341463,          !- Starting Z Coordinate {m}
  2.70719591738945,          !- Length {m}
  1.52439024390244;          !- Height {m}

Window,
  Window_sdr_2.unit1,          !- Name
  Exterior Window,            !- Construction Name
  Wall_sdr_2.unit1,           !- Building Surface Name
  ,                           !- Frame and Divider Name
  1,                           !- Multiplier
  1,                           !- Starting X Coordinate {m}
  0.914634146341463,          !- Starting Z Coordinate {m}
  2.70719591738945,          !- Length {m}
  1.52439024390244;          !- Height {m}

Window,
  Window_sdl_2.unit1,          !- Name
  Exterior Window,            !- Construction Name
  Wall_sdl_2.unit1,           !- Building Surface Name
  ,                           !- Frame and Divider Name
  1,                           !- Multiplier
  1,                           !- Starting X Coordinate {m}
  0.914634146341463,          !- Starting Z Coordinate {m}
  2.70719591738945,          !- Length {m}

```

```

1.52439024390244;           !- Height {m}

!- ===== ALL OBJECTS IN CLASS: DOOR =====

Door,
  Door_ldb_unit1,           !- Name
  Exterior Door,            !- Construction Name
  Wall_ldb_1.unit1,          !- Building Surface Name
  1,                         !- Multiplier
  0.5,                       !- Starting X Coordinate {m}
  0,                          !- Starting Z Coordinate {m}
  1.74190122145513,         !- Length {m}
  2.13414634146341;        !- Height {m}

!- ===== ALL OBJECTS IN CLASS: WINDOWSHADINGCONTROL
=====

WindowShadingControl,
  Shades-living_unit1,      !- Name
  living_unit1,              !- Zone Name
  1,                         !- Shading Control Sequence Number
  InteriorBlind,             !- Shading Type
  window_w_blinds,           !- Construction with Shading Name
  OnIfScheduleAllows,         !- Shading Control Type
  shading_2012iecc,           !- Schedule Name
  ,                           !- Setpoint {W/m2, W or deg C}
  Yes,                        !- Shading Control Is Scheduled
  No,                         !- Glare Control Is Active
  ,                           !- Shading Device Material Name
  ,                           !- Type of Slat Angle Control for
Blinds
  ,                           !- Slat Angle Schedule Name
  ,                           !- Setpoint 2 {W/m2 or deg C}
  ,                           !- Daylighting Control Object Name

```

```

Sequential,           !- Multiple Surface Control Type
Window_ldf_1.unit1, !- Fenestration Surface 1 Name
Window_ldb_1.unit1, !- Fenestration Surface 2 Name
Window_sdr_1.unit1, !- Fenestration Surface 3 Name
Window sdl_1.unit1, !- Fenestration Surface 4 Name
Window_ldf_2.unit1, !- Fenestration Surface 5 Name
Window_ldb_2.unit1, !- Fenestration Surface 6 Name
Window_sdr_2.unit1, !- Fenestration Surface 7 Name
Window sdl_2.unit1; !- Fenestration Surface 8 Name

! - ===== ALL OBJECTS IN CLASS: INTERNALMASS =====

InternalMass,
  Internalmass_unit1,      !- Name
  InteriorFurnishings,    !- Construction Name
  living_unit1,           !- Zone or ZoneList Name
  9.89591078066915;      !- Surface Area {m2}

! - ===== ALL OBJECTS IN CLASS: SHADING:OVERHANG =====

Shading:Overhang,
  Overhang_sdr_1.unit1,    !- Name
  Window_sdr_1.unit1,      !- Window or Door Name
  0,                      !- Height above Window or Door {m}
  90,                     !- Tilt Angle from Window/Door {deg}
  0,                      !- Left extension from Window/Door
  Width {m}
  0,                      !- Right extension from Window/Door
  Width {m}
  0.0152439024390244;   !- Depth {m}

Shading:Overhang,
  Overhang_sdr_2.unit1,    !- Name
  Window_sdr_2.unit1,      !- Window or Door Name

```

```

0,                               !- Height above Window or Door {m}
90,                             !- Tilt Angle from Window/Door {deg}
0,                               !- Left extension from Window/Door
Width {m}
0,                               !- Right extension from Window/Door
Width {m}
0.0152439024390244;          !- Depth {m}

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:CONTROL
=====

GroundHeatTransfer:Control,
gtp_control,                      !- Name
no,                                !- Run Basement Preprocessor
yes;                             !- Run Slab Preprocessor

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:SLAB:
MATERIALS =====

GroundHeatTransfer:Slab:Materials,
2,                                 !- NMAT: Number of materials
0.16,                            !- ALBEDO: Surface Albedo: No Snow
0.4,                             !- ALBEDO: Surface Albedo: Snow
0.9,                            !- EPSLW: Surface Emissivity: No Snow
0.9,                            !- EPSLW: Surface Emissivity: Snow
0.75,                            !- Z0: Surface Roughness: No Snow {cm}
0.05,                            !- Z0: Surface Roughness: Snow {cm}
6,                                !- HIN: Indoor HConv: Downward Flow {W/
m2-K}
9;                                !- HIN: Indoor HConv: Upward {W/m2-K}

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:SLAB:
MATLPROPS =====

```

```

GroundHeatTransfer:Slab:MatlProps ,
  2300,                               !- RHO: Slab Material density {kg/m3}
  1200,                               !- RHO: Soil Density {kg/m3}
  650,                                !- CP: Slab CP {J/kg-K}
  1200,                               !- CP: Soil CP {J/kg-K}
  0.9,                                 !- TCON: Slab k {W/m-K}
  1;                                   !- TCON: Soil k {W/m-K}

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:SLAB:
BOUNDCONDS =====

GroundHeatTransfer:Slab:BoundConds ,
  FALSE,                               !- EVTR: Is surface evapotranspiration
  modeled
  TRUE,                                !- FIXBC: is the lower boundary at a
  fixed temperature
  10,                                   !- TDEEPin {C}
  FALSE;                               !- USRHflag: Is the ground surface h
  specified by the user?

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:SLAB:
BLDGPROPS =====

GroundHeatTransfer:Slab:BldgProps ,
  10,                                    !- IYRS: Number of years to iterate
  0,                                     !- Shape: Slab shape
  4,                                      !- HBLDG: Building height {m}
  22.22,                                 !- TIN1: January Indoor Average
  Temperature Setpoint {C}
  22.22,                                 !- TIN2: February Indoor Average
  Temperature Setpoint {C}
  22.22,                                 !- TIN3: March Indoor Average
  Temperature Setpoint {C}

```

```

22.22,                                     !- TIN4: April Indoor Average
Temperature Setpoint {C}
22.22,                                     !- TIN5: May Indoor Average Temperature
Setpoint {C}
23.88,                                      !- TIN6: June Indoor Average
Temperature Setpoint {C}
23.88,                                      !- TIN7: July Indoor Average
Temperature Setpoint {C}
23.88,                                      !- TIN8: August Indoor Average
Temperature Setpoint {C}
23.88,                                      !- TIN9: September Indoor Average
Temperature Setpoint {C}
22.22,                                       !- TIN10: October Indoor Average
Temperature Setpoint {C}
22.22,                                       !- TIN11: November Indoor Average
Temperature Setpoint {C}
22.22,                                       !- TIN12: December Indoor Average
Temperature Setpoint {C}
0,                                            !- TINAmp: Daily Indoor sine wave
variation amplitude {deltaC}
0.1;                                         !- ConvTol: Convergence Tolerance

!- ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:SLAB:
INSULATION =====

GroundHeatTransfer:Slab:Insulation ,
0,                                              !- RINS: R value of under slab
insulation {m2-K/W}
0,                                              !- DINS: Width of strip of under slab
insulation {m}
0,                                              !- RVINS: R value of vertical
insulation {m2-K/W}
0.6,                                         !- ZVINS: Depth of vertical insulation
{m}

```

```

0;                                !- IVINS: Flag: Is there vertical
insulation

!- ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:SLAB:
EQUIVALENTSLAB =====

GroundHeatTransfer:Slab:EquivalentSlab,
2.59994805991784,           !- APRatio: The area to perimeter ratio
for this slab {m}
0.1,                         !- SLABDEPTH: Thickness of slab on
grade {m}
15,                           !- CLEARANCE: Distance from edge of
slab to domain edge {m}
15;                           !- ZCLEARANCE: Distance from bottom of
slab to domain bottom {m}

!- ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
SIMPARAMETERS =====

GroundHeatTransfer:Basement:SimParameters,
0.1,                         !- F: Multiplier for the ADI solution
15;                          !- IYRS: Maximum number of yearly
iterations:

!- ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
MATLPROPS =====

GroundHeatTransfer:Basement:MatlProps,
6,                            !- NMAT: Number of materials in this
domain
2243,                         !- Density for Foundation Wall {kg/m3}
2243,                         !- density for Floor Slab {kg/m3}
311,                          !- density for Ceiling {kg/m3}

```

```

1500,                                     !- density for Soil {kg/m3}
2000,                                     !- density for Gravel {kg/m3}
449,                                      !- density for Wood {kg/m3}
880,                                       !- Specific heat for foundation wall {J
/kg-K}
880,                                       !- Specific heat for floor slab {J/kg-K}
}
1530,                                     !- Specific heat for ceiling {J/kg-K}
840,                                      !- Specific heat for soil {J/kg-K}
720,                                      !- Specific heat for gravel {J/kg-K}
1530,                                     !- Specific heat for wood {J/kg-K}
1.4,                                       !- Thermal conductivity for foundation
wall {W/m-K}
1.4,                                       !- Thermal conductivity for floor slab
{W/m-K}
0.09,                                      !- Thermal conductivity for ceiling {W/
m-K}
1.1,                                       !- thermal conductivity for soil {W/m-K}
}
1.9,                                       !- thermal conductivity for gravel {W/m
-K}
0.12;                                      !- thermal conductivity for wood {W/m-K}
}

!- ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
INSULATION =====

GroundHeatTransfer:Basement:Insulation,
1.76099742894375e-05,      !- REXT: R Value of any exterior
insulation {m2-K/W}
True;                                    !- INSFULL: Flag: Is the wall fully
insulated?

```

```

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
SURFACEPROPS =====

GroundHeatTransfer:Basement:SurfaceProps ,
    0.16,                               !- ALBEDO: Surface albedo for No snow
conditions
    0.4,                                !- ALBEDO: Surface albedo for snow
conditions
    0.94,                               !- EPSLN: Surface emissivity No Snow
    0.86,                               !- EPSLN: Surface emissivity with Snow
    6,                                   !- VEGHT: Surface roughness No snow
conditions {cm}
    0.25,                               !- VEGHT: Surface roughness Snow
conditions {cm}
    False;                             !- PET: Flag , Potential
evapotranspiration on?

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
BLDGDATA =====

GroundHeatTransfer:Basement:BldgData ,
    0.20000006162114,                 !- DWALL: Wall thickness {m}
    0.243828108701145,                !- DSLAB: Floor slab thickness {m}
    0.3,                                !- DGRAVXY: Width of gravel pit beside
basement wall {m}
    0.2,                                !- DGRAVZN: Gravel depth extending
above the floor slab {m}
    0.1;                                !- DGRAVZP: Gravel depth below the
floor slab {m}

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
INTERIOR =====

GroundHeatTransfer:Basement:Interior ,

```

```

True,                                     !- COND: Flag: Is the basement
conditioned?

0.92,                                      !- HIN: Downward convection only heat
transfer coefficient {W/m2-K}

4.04,                                      !- HIN: Upward convection only heat
transfer coefficient {W/m2-K}

3.08,                                      !- HIN: Horizontal convection only heat
transfer coefficient {W/m2-K}

6.13,                                      !- HIN: Downward combined (convection
and radiation) heat transfer coefficient {W/m2-K}

9.26,                                      !- HIN: Upward combined (convection and
radiation) heat transfer coefficient {W/m2-K}

8.29;                                       !- HIN: Horizontal combined (convection
and radiation) heat transfer coefficient {W/m2-K}

!- ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
COMBLDG =====

GroundHeatTransfer:Basement:ComBldg,
21,                                         !- January average temperature {C}
21,                                         !- February average temperature {C}
21,                                         !- March average temperature {C}
21,                                         !- April average temperature {C}
24,                                         !- May average temperature {C}
24,                                         !- June average temperature {C}
24,                                         !- July average temperature {C}
24,                                         !- August average temperature {C}
24,                                         !- September average temperature {C}
24,                                         !- October average temperature {C}
21,                                         !- November average temperature {C}
21,                                         !- December average temperature {C}
21;                                         !- Daily variation sine wave amplitude
{deltaC}

```

```

! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
EQUIVSLAB =====

GroundHeatTransfer:Basement:EquivSlab,
2.59994805991784,           !- APRatio: The area to perimeter ratio
for this slab {m}
True;                      !- EquivSizing: Flag


! - ===== ALL OBJECTS IN CLASS: GROUNDHEATTRANSFER:BASEMENT:
EQUIVAUTOGRID =====

GroundHeatTransfer:Basement:EquivAutoGrid,
15,                         !- CLEARANCE: Distance from outside of
wall to edge of 3-D ground domain {m}
0.1,                         !- SlabDepth: Thickness of the floor
slab {m}
1.21914054350572;          !- BaseDepth: Depth of the basement
wall below grade {m}

! - ===== ALL OBJECTS IN CLASS: PEOPLE =====

People,
people_unit1,                !- Name
living_unit1,                 !- Zone or ZoneList Name
Occupancy,                    !- Number of People Schedule Name
People,                       !- Number of People Calculation Method
3,                            !- Number of People
,                             !- People per Zone Floor Area {person/
m2}
,                             !- Zone Floor Area per Person {m2/
person}
0,                            !- Fraction Radiant
autocalculate,               !- Sensible Heat Fraction
activity_sch,                !- Activity Level Schedule Name

```

```

        ,                               !- Carbon Dioxide Generation Rate {m3/s
-W}

No,                                !- Enable ASHRAE 55 Comfort Warnings

ZoneAveraged,                      !- Mean Radiant Temperature Calculation

Type

,                                   !- Surface Name/Angle Factor List Name

Work Eff Sch,                      !- Work Efficiency Schedule Name

ClothingInsulationSchedule,      !- Clothing Insulation Calculation

Method

,                                   !- Clothing Insulation Calculation

Method Schedule Name

Clothing Sch,                      !- Clothing Insulation Schedule Name

Air Velo Sch,                      !- Air Velocity Schedule Name

Fanger,                            !- Thermal Comfort Model 1 Type

Pierce,                            !- Thermal Comfort Model 2 Type

AdaptiveASH55,                     !- Thermal Comfort Model 3 Type

KSU;                               !- Thermal Comfort Model 4 Type

```

**!- ===== ALL OBJECTS IN CLASS: LIGHTS =====**

```

Lights,

Living Hardwired Lighting1,   !- Name

living_unit1,                   !- Zone or ZoneList Name

InteriorLightingHE,            !- Schedule Name

Watts/Area,                    !- Design Level Calculation Method

,                               !- Lighting Level {W}

1.05216214401829,            !- Watts per Zone Floor Area {W/m2}

,                               !- Watts per Person {W/person}

0,                             !- Return Air Fraction

0.6,                           !- Fraction Radianc

0.2,                           !- Fraction Visible

0;                            !- Fraction Replaceable

```

```

Lights,

Living Plug-in Lighting1,!- Name

```

```

living_unit1,           !- Zone or ZoneList Name
InteriorLightingHE,    !- Schedule Name
Watts/Area,             !- Design Level Calculation Method
,                      !- Lighting Level {W}
0.478467682251396,    !- Watts per Zone Floor Area {W/m2}
,                      !- Watts per Person {W/person}
0,                      !- Return Air Fraction
0.6,                   !- Fraction Radiant
0.2,                   !- Fraction Visible
0;                      !- Fraction Replaceable

! - ===== ALL OBJECTS IN CLASS: ELECTRICEQUIPMENT
=====

ElectricEquipment,
ceiling_fan,           !- Name
living_unit1,           !- Zone or ZoneList Name
fan_sch,                !- Schedule Name
EquipmentLevel,         !- Design Level Calculation Method
230,                   !- Design Level
,                      !- Watts per Zone Floor Area
,                      !- Watts per Person
0,                      !- Fraction Latent
0.4,                   !- Fraction Radiant
0,                      !- Fraction Lost
General;               !- EndUse Subcategory

ElectricEquipment,
dishwasher1,            !- Name
living_unit1,           !- Zone or ZoneList Name
DishWasher,              !- Schedule Name
EquipmentLevel,         !- Design Level Calculation Method
65.698787492023,        !- Design Level {W}
,                      !- Watts per Zone Floor Area {W/m2}
,                      !- Watts per Person {W/person}
0.15,                  !- Fraction Latent

```

```

0.6,                                     !- Fraction Radiant
0.25,                                     !- Fraction Lost
dishwasher;                                !- End-Use Subcategory

ElectricEquipment,
  refrigerator1,                         !- Name
  living_unit1,                           !- Zone or ZoneList Name
  Refrigerator,                           !- Schedule Name
  EquipmentLevel,                        !- Design Level Calculation Method
  91.0575745202123,                      !- Design Level {W}
  ,                                         !- Watts per Zone Floor Area {W/m2}
  ,                                         !- Watts per Person {W/person}
  0,                                         !- Fraction Latent
  1,                                         !- Fraction Radiant
  0,                                         !- Fraction Lost
  refrigerator;                          !- End-Use Subcategory

ElectricEquipment,
  clotheswasher1,                         !- Name
  living_unit1,                           !- Zone or ZoneList Name
  ClothesWasher,                          !- Schedule Name
  EquipmentLevel,                        !- Design Level Calculation Method
  28.4784377542718,                      !- Design Level {W}
  ,                                         !- Watts per Zone Floor Area {W/m2}
  ,                                         !- Watts per Person {W/person}
  0,                                         !- Fraction Latent
  0.8,                                       !- Fraction Radiant
  0.2,                                       !- Fraction Lost
  clotheswasher;                          !- End-Use Subcategory

ElectricEquipment,
  electric_dryer1,                        !- Name
  living_unit1,                           !- Zone or ZoneList Name
  ClothesDryer,                           !- Schedule Name
  EquipmentLevel,                        !- Design Level Calculation Method
  213.064557285022,                      !- Design Level {W}

```

```

        ,                                     !- Watts per Zone Floor Area {W/m2}
        ,                                     !- Watts per Person {W/person}
0.05,                                         !- Fraction Latent
0.15,                                         !- Fraction Radiant
0.8,                                          !- Fraction Lost
electric_dryer;                                !- End-Use Subcategory

ElectricEquipment,
electric_range1,                               !- Name
living_unit1,                                   !- Zone or ZoneList Name
CookingRange,                                    !- Schedule Name
EquipmentLevel,                                !- Design Level Calculation Method
248.154224774405,                            !- Design Level {W}
,                                               !- Watts per Zone Floor Area {W/m2}
,                                               !- Watts per Person {W/person}
0.3,                                            !- Fraction Latent
0.4,                                            !- Fraction Radiant
0.3,                                            !- Fraction Lost
electric_range;                                !- End-Use Subcategory

ElectricEquipment,
television1,                                    !- Name
living_unit1,                                   !- Zone or ZoneList Name
InteriorLighting,                             !- Schedule Name
EquipmentLevel,                                !- Design Level Calculation Method
0,                                              !- Design Level {W}
,                                               !- Watts per Zone Floor Area {W/m2}
,                                               !- Watts per Person {W/person}
0,                                              !- Fraction Latent
1,                                              !- Fraction Radiant
0,                                              !- Fraction Lost
television;                                    !- End-Use Subcategory

ElectricEquipment,
electric_mels1,                                !- Name
living_unit1,                                   !- Zone or ZoneList Name

```

```

MiscPlugLoad,           !- Schedule Name
EquipmentLevel,        !- Design Level Calculation Method
567.464237516869,     !- Design Level {W}
,                      !- Watts per Zone Floor Area {W/m2}
,                      !- Watts per Person {W/person}
0.06,                 !- Fraction Latent
0.69,                 !- Fraction Radiant
0.25,                 !- Fraction Lost
electric_mels;         !- End-Use Subcategory

ElectricEquipment,
IECC_Adj1,             !- Name
living_unit1,           !- Zone or ZoneList Name
MiscPlugLoad,           !- Schedule Name
Watts/Area,             !- Design Level Calculation Method
,                      !- Design Level {W}
1.54356736989469,     !- Watts per Zone Floor Area {W/m2}
,                      !- Watts per Person {W/person}
0.0624390461422629,   !- Fraction Latent
0.41190936353998,     !- Fraction Radiant
0.251045347957769,    !- Fraction Lost
IECC_adj;               !- End-Use Subcategory

!- ===== ALL OBJECTS IN CLASS: ZONEVENTILATION:
DESIGNFLOWRATE =====

ZoneVentilation:DesignFlowRate,
Ventilation_unit1,      !- Name
living_unit1,            !- Zone or ZoneList Name
always_avail,            !- Schedule Name
Flow/Zone,               !- Design Flow Rate Calculation Method
0,                      !- Design Flow Rate {m3/s}
,                      !- Flow Rate per Zone Floor Area {m3/s-
m2}
,                      !- Flow Rate per Person {m3/s-person}

```

```

        ,                               !- Air Changes per Hour {1/hr}
    Exhaust,                         !- Ventilation Type
    0,                                !- Fan Pressure Rise {Pa}
    0.6,                             !- Fan Total Efficiency
    1,                                !- Constant Term Coefficient
    0,                                !- Temperature Term Coefficient
    0,                                !- Velocity Term Coefficient
    0,                                !- Velocity Squared Term Coefficient
    -100,                            !- Minimum Indoor Temperature {C}
    ,                                 !- Minimum Indoor Temperature Schedule
Name
100,                             !- Maximum Indoor Temperature {C}
,
Name
-100,                            !- Delta Temperature {deltaC}
,
-100,                            !- Delta Temperature Schedule Name
,
Name
100,                             !- Minimum Outdoor Temperature {C}
,
Name
40;                              !- Maximum Wind Speed {m/s}

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:
SIMULATIONCONTROL =====

AirflowNetwork:SimulationControl,
    House AirflowNetwork,      !- Name
    MultizoneWithDistribution, !- AirflowNetwork Control
    SurfaceAverageCalculation, !- Wind Pressure Coefficient Type
    ,                          !- Height Selection for Local Wind
    Pressure Calculation
    LOWRISE,                  !- Building Type

```

```

      500,                               !- Maximum Number of Iterations {
dimensionless}

      ,                               !- Initialization Type

      0.001,                            !- Relative Airflow Convergence
Tolerance {dimensionless}

      0.00001,                           !- Absolute Airflow Convergence
Tolerance {kg/s}

      0,                                !- Convergence Acceleration Limit {
dimensionless}

      0,                                !- Azimuth Angle of Long Axis of
Building {deg}

      0.75,                             !- Ratio of Building Width Along Short
Axis to Width Along Long Axis

      ,                                !- Height Dependence of External Node
Temperature

      ,                                !- Solver

      Yes;                             !- Allow Unsupported Zone Equipment

! - ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:MULTIZONE:
ZONE =====

AirflowNetwork:MultiZone:Zone,
      living_unit1,                      !- Zone Name
NoVent,                                !- Ventilation Control Mode
      ,                                !- Ventilation Control Zone Temperature
Setpoint Schedule Name
      0,                                !- Minimum Venting Open Factor {
dimensionless}

      0.0,                             !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor {deltaC}
      100.0,                            !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor {deltaC}
      0.0,                             !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor {deltaJ/kg}
}

```

```

300000.0;                      !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor {deltaJ/kg
}

AirflowNetwork:MultiZone:Zone,
attic_unit1,                     !- Zone Name
Constant,                        !- Ventilation Control Mode
,                                !- Ventilation Control Zone Temperature
Setpoint Schedule Name
,                                !- Minimum Venting Open Factor {
dimensionless}
,                                !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor {deltaC}
100,                               !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor {deltaC}
,                                !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor {deltaJ/kg
}
300000,                            !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor {deltaJ/kg
}
inf_sch;                           !- Venting Availability Schedule Name

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:MULTIZONE:
SURFACE =====

AirflowNetwork:MultiZone:Surface,
Roof_front_unit1,                 !- Surface Name
AtticVent,                         !- Leakage Component Name
,                                !- External Node Name
1,                                !- Window/Door Opening Factor, or Crack
Factor {dimensionless}
Constant,                          !- Ventilation Control Mode
,                                !- Ventilation Control Zone Temperature
Setpoint Schedule Name

```

```

0,                                     !- Minimum Venting Open Factor {
dimensionless}

,                                         !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor {deltaC}
100,                                      !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor {deltaC}
,                                         !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor {deltaJ/kg}
}
300000,                                     !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor {deltaJ/kg}
}
inf_sch;                                    !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
Roof_back_unit1,                         !- Surface Name
AtticVent,                                !- Leakage Component Name
,
!- External Node Name
1,                                         !- Window/Door Opening Factor, or Crack
Factor {dimensionless}
Constant,                                 !- Ventilation Control Mode
,
!- Ventilation Control Zone Temperature
Setpoint Schedule Name
,
!- Minimum Venting Open Factor {
dimensionless}
,
!- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor {deltaC}
100,                                      !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor {deltaC}
,
!- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor {deltaJ/kg}
}
300000,                                     !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor {deltaJ/kg}
}
inf_sch;                                    !- Venting Availability Schedule Name

```

```

AirflowNetwork:MultiZone:Surface ,
    Roof_right_unit1 ,           !- Surface Name
    AtticVent ,                 !- Leakage Component Name
    ,                           !- External Node Name
    1 ,                         !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    Constant ,                  !- Ventilation Control Mode
    ,                           !- Ventilation Control Zone Temperature
    Setpoint Schedule Name
    ,                           !- Minimum Venting Open Factor {
    dimensionless}
    ,                           !- Indoor and Outdoor Temperature
    Difference Lower Limit For Maximum Venting Open Factor {deltaC}
    100 ,                      !- Indoor and Outdoor Temperature
    Difference Upper Limit for Minimum Venting Open Factor {deltaC}
    ,                           !- Indoor and Outdoor Enthalpy
    Difference Lower Limit For Maximum Venting Open Factor {deltaJ/kg}
}
    300000 ,                   !- Indoor and Outdoor Enthalpy
    Difference Upper Limit for Minimum Venting Open Factor {deltaJ/kg}
}
    inf_sch;                  !- Venting Availability Schedule Name

```

```

AirflowNetwork:MultiZone:Surface ,
    Roof_left_unit1 ,           !- Surface Name
    AtticVent ,                 !- Leakage Component Name
    ,                           !- External Node Name
    1 ,                         !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    Constant ,                  !- Ventilation Control Mode
    ,                           !- Ventilation Control Zone Temperature
    Setpoint Schedule Name
    ,                           !- Minimum Venting Open Factor {
    dimensionless}

```

```

        ,                               !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor {deltaC}
100,                               !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor {deltaC}
,                               !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor {deltaJ/kg}
}
300000,                               !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor {deltaJ/kg}
}
inf_sch;                               !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
ceiling_unit1,                         !- Surface Name
ZoneLeak_Ceiling,                       !- Leakage Component Name
,                                     !- External Node Name
1.0,                                   !- Window/Door Opening Factor, or Crack
Factor {dimensionless}
NoVent;                                !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
Wall_ldf_1.unit1,                      !- Surface Name
ZoneLeak_LongWall,                     !- Leakage Component Name
,                                     !- External Node Name
1.0,                                   !- Window/Door Opening Factor, or Crack
Factor {dimensionless}
NoVent;                                !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
Wall_ldb_1.unit1,                      !- Surface Name
ZoneLeak_LongWall,                     !- Leakage Component Name
,                                     !- External Node Name
1.0,                                   !- Window/Door Opening Factor, or Crack
Factor {dimensionless}
NoVent;                                !- Ventilation Control Mode

```

```

AirflowNetwork:MultiZone:Surface,
    Wall_sdl_1.unit1,           !- Surface Name
    ZoneLeak_ShortWall,        !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_sdr_1.unit1,           !- Surface Name
    ZoneLeak_ShortWall,        !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_ldf_2.unit1,           !- Surface Name
    ZoneLeak_LongWall,         !- Leakage Component Name
    ,                         !- External Node Name
    1.0,                      !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_ldb_2.unit1,           !- Surface Name
    ZoneLeak_LongWall,         !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_sdr_2.unit1,           !- Surface Name
    ZoneLeak_ShortWall,        !- Leakage Component Name
    ,                         !- External Node Name

```

```

1,                                     !- Window/Door Opening Factor, or Crack
Factor {dimensionless}
NoVent;                                !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_sdl_2.unit1,                  !- Surface Name
    ZoneLeak_ShortWall,               !- Leakage Component Name
    ,                                 !- External Node Name
    1,                                     !- Window/Door Opening Factor, or Crack
    Factor {dimensionless}
    NoVent;                                !- Ventilation Control Mode

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:MULTIZONE:
SURFACE:EFFECTIVELEAKAGEAREA =====

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    ZoneLeak_LongWall,                !- Name
    0.00566687461767392,            !- Effective Leakage Area {m2}
    1.15,                            !- Discharge Coefficient {dimensionless}
}
4,                                     !- Reference Pressure Difference {Pa}
0.65;                                !- Air Mass Flow Exponent {
dimensionless}

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    ZoneLeak_ShortWall,               !- Name
    0.00425015596325544,            !- Effective Leakage Area {m2}
    1.15,                            !- Discharge Coefficient {dimensionless}
}
4,                                     !- Reference Pressure Difference {Pa}
0.65;                                !- Air Mass Flow Exponent {
dimensionless}

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    ZoneLeak_Ceiling,                 !- Name

```

```

0.019898999363395 ,           !- Effective Leakage Area {m2}
1.15 ,                         !- Discharge Coefficient {dimensionless}
}
4 ,                            !- Reference Pressure Difference {Pa}
0.65;                          !- Air Mass Flow Exponent {
dimensionless}

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea ,
ZoneLeak_Floor ,               !- Name
0.00001 ,                      !- Effective Leakage Area {m2}
1.15 ,                         !- Discharge Coefficient {dimensionless}
}
4 ,                            !- Reference Pressure Difference {Pa}
0.65;                          !- Air Mass Flow Exponent {
dimensionless}

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea ,
AtticVent ,                     !- Name
0.37 ,                          !- Effective Leakage Area {m2}
1.15 ,                         !- Discharge Coefficient {dimensionless}
}
4 ,                            !- Reference Pressure Difference {Pa}
0.65;                          !- Air Mass Flow Exponent {
dimensionless}

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea ,
CrawlVent ,                     !- Name
0.37 ,                          !- Effective Leakage Area {m2}
1.15 ,                         !- Discharge Coefficient {dimensionless}
}
4 ,                            !- Reference Pressure Difference {Pa}
0.65;                          !- Air Mass Flow Exponent {
dimensionless}

```

```

! - ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:DISTRIBUTION:

NODE =====

! AirflowNetwork:MultiZone:Surface ,
!   Wall_sdr_2.unit1,           !- Surface Name
!   Zone Exhaust Fan_unit1,      !- Leakage Component
Name
!
,                           !- External Node Name
!
1,                         !- Window/Door Opening Factor, or
Crack Factor {dimensionless}
!
Constant;                  !- Ventilation Control Mode
!

! AirflowNetwork:MultiZone:Component:ZoneExhaustFan ,
!   Zone Exhaust Fan_unit1,      !- Name
!   0.01,                      !- Air Mass Flow Coefficient When the
Zone Exhaust Fan is Off at Reference Conditions {kg/s}
!
0.667;                     !- Air Mass Flow Exponent When the
Zone Exhaust Fan is Off {dimensionless}

AirflowNetwork:Distribution:Node ,
  EquipmentInletNode_unit1,!- Name
  Zone Equipment Inlet Node_unit1,  !- Component Name or Node Name
  Other,                      !- Component Object Type or Node Type
  3.0;                        !- Node Height {m}

AirflowNetwork:Distribution:Node ,
  SplitterNode_unit1,        !- Name
  ,                          !- Component Name or Node Name
  AirLoopHVAC:ZoneSplitter,!- Component Object Type or Node Type
  3.0;                      !- Node Height {m}

AirflowNetwork:Distribution:Node ,
  ZoneSupplyNode_unit1,      !- Name
  ,                          !- Component Name or Node Name
  Other,                      !- Component Object Type or Node Type
  3.0;                      !- Node Height {m}

```

```

AirflowNetwork:Distribution:Node ,
    ZoneSupplyRegisterNode_unit1 ATInlet ,   !- Name
    Zone Inlet Node_unit1 ATInlet ,   !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3.0;             !- Node Height {m}

AirflowNetwork:Distribution:Node ,
    ZoneSupplyRegisterNode_unit1 ,   !- Name
    Zone Inlet Node_unit1 ,   !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3.0;             !- Node Height {m}

AirflowNetwork:Distribution:Node ,
    ZoneOutletNode_unit1 ,   !- Name
    Zone Outlet node_unit1 ,   !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3.0;             !- Node Height {m}

AirflowNetwork:Distribution:Node ,
    ZoneReturnNode_unit1 ,   !- Name
    ,           !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3.0;             !- Node Height {m}

AirflowNetwork:Distribution:Node ,
    MixerNode_unit1 ,   !- Name
    ,           !- Component Name or Node Name
    AirLoopHVAC:ZoneMixer ,   !- Component Object Type or Node Type
    3.0;             !- Node Height {m}

AirflowNetwork:Distribution:Node ,
    MainReturnNode_unit1 ,   !- Name
    Return Air Mixer Outlet_unit1 ,   !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3.0;             !- Node Height {m}

```

```

AirflowNetwork:Distribution:Node,
    MainInletNode_unit1,      !- Name
    Air Loop Inlet Node_unit1,  !- Component Name or Node Name
    Other,                  !- Component Object Type or Node Type
    3.0;                   !- Node Height {m}

AirflowNetwork:Distribution:Node,
    FanOutletNode_unit1,     !- Name
    Cooling Coil Air Inlet Node_unit1,  !- Component Name or Node
    Name
    Other,                  !- Component Object Type or Node Type
    3.0;                   !- Node Height {m}

AirflowNetwork:Distribution:Node,
    HeatingInletNode_unit1,   !- Name
    Heating Coil Air Inlet Node_unit1,  !- Component Name or Node
    Name
    Other,                  !- Component Object Type or Node Type
    3.0;                   !- Node Height {m}

AirflowNetwork:Distribution:Node,
    HeatingOutletNode_unit1,  !- Name
    Air Loop Outlet Node_unit1, !- Component Name or Node Name
    Other,                  !- Component Object Type or Node Type
    3.0;                   !- Node Height {m}

AirflowNetwork:Distribution:Node,
    SuppHeatingInletNode_unit1, !- Name
    Supp Heating coil air inlet Node_unit1,  !- Component Name or
    Node Name
    Other,                  !- Component Object Type or Node Type
    3.0;                   !- Node Height {m}

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:DISTRIBUTION:
COMPONENT:LEAKAGERATIO =====

```

```

AirflowNetwork:Distribution:Component:LeakageRatio ,
    SupplyLeak ,                               !- Name
    0.0396 ,                                  !- Effective Leakage Ratio {
dimensionless}
    0.56034 ,                                 !- Maximum Flow Rate {m3/s}
    25 ,                                      !- Reference Pressure Difference {Pa}
    0.65;                                     !- Air Mass Flow Exponent {
dimensionless}

AirflowNetwork:Distribution:Component:LeakageRatio ,
    ReturnLeak ,                               !- Name
    0.0396 ,                                  !- Effective Leakage Ratio {
dimensionless}
    0.56034 ,                                 !- Maximum Flow Rate {m3/s}
    25 ,                                       !- Reference Pressure Difference {Pa}
    0.65;                                     !- Air Mass Flow Exponent {
dimensionless}

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:DISTRIBUTION:
COMPONENT:DUCT =====

AirflowNetwork:Distribution:Component:Duct ,
    MainTrunk_unit1 ,                         !- Name
    2.0 ,                                     !- Duct Length {m}
    0.591921113608382 ,                     !- Hydraulic Diameter {m}
    0.275216110019646 ,                     !- Cross Section Area {m2}
    0.0009 ,                                   !- Surface Roughness {m}
    0.01 ,                                     !- Coefficient for Local Dynamic Loss
Due to Fitting {dimensionless}
    0.709825 ,                                !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}
    0.0000001;                                !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

```

```

AirflowNetwork:Distribution:Component:Duct ,
    ZoneSupply_unit1 ,           !- Name
    15 ,                         !- Duct Length {m}
    0.591921113608382 ,         !- Hydraulic Diameter {m}
    0.275216110019646 ,         !- Cross Section Area {m2}
    0.0009 ,                      !- Surface Roughness {m}
    10 ,                          !- Coefficient for Local Dynamic Loss
    Due to Fitting {dimensionless}
    0.709825 ,                   !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}
    0.0000001;                  !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

```

```

AirflowNetwork:Distribution:Component:Duct ,
    ZoneSupplyLink2_unit1 ATInlet Duct ,  !- Name
    0.0001 ,                      !- Duct Length {m}
    0.591921113608382 ,          !- Hydraulic Diameter {m}
    0.275216110019646 ,          !- Cross Section Area {m2}
    0.0009 ,                      !- Surface Roughness {m}
    0 ,                            !- Coefficient for Local Dynamic Loss
    Due to Fitting {dimensionless}
    0.709825 ,                   !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}
    0.0000001;                  !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

```

```

AirflowNetwork:Distribution:Component:Duct ,
    ZoneReturn_unit1 ,           !- Name
    8.0 ,                        !- Duct Length {m}
    0.529430338938287 ,         !- Hydraulic Diameter {m}
    0.220172888015717 ,         !- Cross Section Area {m2}
    0.0009 ,                      !- Surface Roughness {m}
    9 ,                           !- Coefficient for Local Dynamic Loss
    Due to Fitting {dimensionless}
    0.709825 ,                   !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}

```

```

0.0000001;           !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

AirflowNetwork:Distribution:Component:Duct,
ZoneConnectionDuct_unit1,!- Name
0.1,                  !- Duct Length {m}
0.591921113608382,   !- Hydraulic Diameter {m}
0.275216110019646,   !- Cross Section Area {m2}
0.0001,                !- Surface Roughness {m}
0.00,                  !- Coefficient for Local Dynamic Loss
Due to Fitting {dimensionless}
0.709825,              !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}
0.0000001;           !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

AirflowNetwork:Distribution:Component:Duct,
MainReturn_unit1,      !- Name
1.0,                  !- Duct Length {m}
0.529430338938287,   !- Hydraulic Diameter {m}
0.220172888015717,   !- Cross Section Area {m2}
0.0009,                !- Surface Roughness {m}
0.01,                  !- Coefficient for Local Dynamic Loss
Due to Fitting {dimensionless}
0.709825,              !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}
0.0000001;           !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

AirflowNetwork:Distribution:Component:Duct,
AirLoopReturn_unit1,    !- Name
0.1,                  !- Duct Length {m}
0.529430338938287,   !- Hydraulic Diameter {m}
0.220172888015717,   !- Cross Section Area {m2}
0.0001,                !- Surface Roughness {m}

```

```

0.00,                                     !- Coefficient for Local Dynamic Loss
Due to Fitting {dimensionless}

0.709825,                                    !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}

0.0000001;                                    !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

AirflowNetwork:Distribution:Component:Duct,
    AirLoopSupply_unit1,          !- Name
    0.1,                         !- Duct Length {m}
    0.591921113608382,          !- Hydraulic Diameter {m}
    0.275216110019646,          !- Cross Section Area {m2}
    0.0001,                      !- Surface Roughness {m}
    0.00,                         !- Coefficient for Local Dynamic Loss
Due to Fitting {dimensionless}

0.709825,                                    !- Heat Transmittance Coefficient (U-
Factor) for Duct Wall Construction {W/m2-K}

0.0000001;                                    !- Overall Moisture Transmittance
Coefficient from Air to Air {kg/m2}

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:DISTRIBUTION:
COMPONENT:FAN =====

AirflowNetwork:Distribution:Component:Fan,
    Supply Fan_unit1,           !- Fan Name
    Fan:OnOff;                  !- Supply Fan Object Type

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:DISTRIBUTION:
COMPONENT:COIL =====

AirflowNetwork:Distribution:Component:Coil,
    DX Cooling Coil_unit1,     !- Coil Name
    Coil:Cooling:DX:SingleSpeed, !- Coil Object Type
    0.1,                        !- Air Path Length {m}

```

```

1.000;                               !- Air Path Hydraulic Diameter {m}

AirflowNetwork:Distribution:Component:Coil,
    Main DX Heating Coil_unit1,   !- Coil Name
    Coil:Heating:DX:SingleSpeed,  !- Coil Object Type
    0.1,                           !- Air Path Length {m}
    1.000;                          !- Air Path Hydraulic Diameter {m}

AirflowNetwork:Distribution:Component:Coil,
    Supp Heating Coil_unit1,   !- Coil Name
    Coil:Heating:Electric,     !- Coil Object Type
    0.1,                           !- Air Path Length {m}
    1.000;                          !- Air Path Hydraulic Diameter {m}

!- ===== ALL OBJECTS IN CLASS: AIRFLOWNETWORK:DISTRIBUTION:
LINKAGE =====

AirflowNetwork:Distribution:Linkage,
    MainSupplyLink_unit1,        !- Name
    EquipmentInletNode_unit1,   !- Node 1 Name
    SplitterNode_unit1,         !- Node 2 Name
    MainTrunk_unit1,            !- Component Name
    attic_unit1;                !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
    ZoneSupplyLink_unit1,       !- Name
    SplitterNode_unit1,         !- Node 1 Name
    ZoneSupplyNode_unit1,       !- Node 2 Name
    ZoneSupply_unit1,           !- Component Name
    attic_unit1;                !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
    ZoneSupplyLink2_unit1 ATInlet, !- Name
    ZoneSupplyRegisterNode_unit1 ATInlet, !- Node 1 Name
    ZoneSupplyRegisterNode_unit1,   !- Node 2 Name

```

```

ZoneSupplyLink2_unit1 ATInlet Duct,   !- Component Name
attic_unit1;           !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage ,
    ZoneSupplyLink2_unit1,      !- Name
    ZoneSupplyNode_unit1,      !- Node 1 Name
    ZoneSupplyRegisterNode_unit1 ATInlet,   !- Node 2 Name
    ZoneSupply_unit1,          !- Component Name
    attic_unit1;              !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage ,
    ZoneSupplyConnectionLink_unit1,   !- Name
    ZoneSupplyRegisterNode_unit1,   !- Node 1 Name
    living_unit1,                !- Node 2 Name
    ZoneConnectionDuct_unit1; !- Component Name

AirflowNetwork:Distribution:Linkage ,
    ZoneReturnConnectionLink_unit1,   !- Name
    living_unit1,                  !- Node 1 Name
    ZoneOutletNode_unit1,          !- Node 2 Name
    ZoneConnectionDuct_unit1; !- Component Name

AirflowNetwork:Distribution:Linkage ,
    ZoneReturnLink1_unit1,      !- Name
    Zoneoutletnode_unit1,       !- Node 1 Name
    ZoneReturnNode_unit1,       !- Node 2 Name
    ZoneReturn_unit1,          !- Component Name
    attic_unit1;              !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage ,
    ZoneReturnLink2_unit1,      !- Name
    ZoneReturnNode_unit1,       !- Node 1 Name
    MixerNode_unit1,           !- Node 2 Name
    ZoneReturn_unit1,          !- Component Name
    attic_unit1;              !- Thermal Zone Name

```

```

AirflowNetwork:Distribution:Linkage ,
    MainReturnLink_unit1,      !- Name
    MixerNode_unit1,          !- Node 1 Name
    MainReturnNode_unit1,     !- Node 2 Name
    MainReturn_unit1,         !- Component Name
    attic_unit1;              !- Thermal Zone Name


AirflowNetwork:Distribution:Linkage ,
    SystemReturnLink_unit1,   !- Name
    MainReturnNode_unit1,     !- Node 1 Name
    MainInletNode_unit1,      !- Node 2 Name
    AirLoopReturn_unit1;      !- Component Name


AirflowNetwork:Distribution:Linkage ,
    SupplyFanLink_unit1,     !- Name
    MainInletNode_unit1,      !- Node 1 Name
    FanOutletNode_unit1,      !- Node 2 Name
    Supply_Fan_unit1;        !- Component Name


AirflowNetwork:Distribution:Linkage ,
    CoolingCoilLink_unit1,   !- Name
    FanOutletNode_unit1,      !- Node 1 Name
    HeatingInletNode_unit1,   !- Node 2 Name
    DX_Cooling_Coil_unit1;   !- Component Name


AirflowNetwork:Distribution:Linkage ,
    EquipmentAirLoopLink_unit1, !- Name
    HeatingOutletNode_unit1,   !- Node 1 Name
    EquipmentInletNode_unit1,!- Node 2 Name
    AirLoopSupply_unit1;       !- Component Name


AirflowNetwork:Distribution:Linkage ,
    HeatingCoilLink_unit1,   !- Name
    HeatingInletNode_unit1,   !- Node 1 Name
    SuppHeatingInletNode_unit1, !- Node 2 Name
    Main_DX_Heating_Coil_unit1; !- Component Name

```

```

AirflowNetwork:Distribution:Linkage ,
    SuppHeatingCoilLink_unit1,    !- Name
    SuppHeatingInletNode_unit1,   !- Node 1 Name
    HeatingOutletNode_unit1,    !- Node 2 Name
    Supp Heating Coil_unit1;   !- Component Name

AirflowNetwork:Distribution:Linkage ,
    ZoneSupplyLeakLink_unit1,!- Name
    ZoneSupplyNode_unit1,      !- Node 1 Name
    attic_unit1,              !- Node 2 Name
    SupplyLeak;              !- Component Name

AirflowNetwork:Distribution:Linkage ,
    ZoneReturnLeakLink_unit1,!- Name
    attic_unit1,              !- Node 1 Name
    ZoneReturnNode_unit1,     !- Node 2 Name
    ReturnLeak;              !- Component Name

!- ===== ALL OBJECTS IN CLASS: EXTERIOR:LIGHTS =====

Exterior:Lights ,
    Exterior-Lights_unit1,    !- Name
    ExteriorLighting,         !- Schedule Name
    43.2424607481559,        !- Design Level {W}
    ,                         !- Control Option
    Exterior-Lights;         !- End-Use Subcategory

Exterior:Lights ,
    Garage-Lights_unit1,     !- Name
    InteriorLightingHE,       !- Schedule Name
    7.16294617434682,        !- Design Level {W}
    ,                         !- Control Option
    Garage-Lights;           !- End-Use Subcategory

```

```

!- ===== ALL OBJECTS IN CLASS: DESIGNSPECIFICATION:
OUTDOORAIR =====

DesignSpecification:OutdoorAir ,
    SZ_DSOA_living_unit1,      !- Name
    Flow/Zone,                !- Outdoor Air Method
    0,                        !- Outdoor Air Flow per Person {m3/s-
person}
    ,                         !- Outdoor Air Flow per Zone Floor Area
{m3/s-m2}
    0.0283168464628752;     !- Outdoor Air Flow per Zone {m3/s}

!- ===== ALL OBJECTS IN CLASS: SIZING:ZONE =====

Sizing:Zone ,
    living_unit1,            !- Zone or ZoneList Name
    SupplyAirTemperature,   !- Zone Cooling Design Supply Air
    Temperature Input Method
    12,                      !- Zone Cooling Design Supply Air
    Temperature {C}
    ,                         !- Zone Cooling Design Supply Air
    Temperature Difference {deltaC}
    SupplyAirTemperature,   !- Zone Heating Design Supply Air
    Temperature Input Method
    50,                      !- Zone Heating Design Supply Air
    Temperature {C}
    ,                         !- Zone Heating Design Supply Air
    Temperature Difference {deltaC}
    0.008,                   !- Zone Cooling Design Supply Air
    Humidity Ratio {kgWater/kgDryAir}
    0.008,                   !- Zone Heating Design Supply Air
    Humidity Ratio {kgWater/kgDryAir}
    SZ_DSOA_living_unit1,    !- Design Specification Outdoor Air
    Object Name

```

```

        ,                                     !- Zone Heating Sizing Factor
        ,                                     !- Zone Cooling Sizing Factor
DesignDay,                                     !- Cooling Design Air Flow Method
        ,                                     !- Cooling Design Air Flow Rate {m3/s}
0.000762,                                     !- Cooling Minimum Air Flow per Zone

Floor Area {m3/s-m2}

        ,                                     !- Cooling Minimum Air Flow {m3/s}
        ,                                     !- Cooling Minimum Air Flow Fraction
DesignDay,                                     !- Heating Design Air Flow Method
        ,                                     !- Heating Design Air Flow Rate {m3/s}
0.002032,                                     !- Heating Maximum Air Flow per Zone

Floor Area {m3/s-m2}

0.1415762,                                    !- Heating Maximum Air Flow {m3/s}
0.3,                                         !- Heating Maximum Air Flow Fraction
        ,                                     !- Design Specification Zone Air

Distribution Object Name

        ,                                     !- Account for Dedicated Outdoor Air

System

        ,                                     !- Dedicated Outdoor Air System Control

Strategy

        ,                                     !- Dedicated Outdoor Air Low Setpoint

Temperature for Design {C}

        ;                                     !- Dedicated Outdoor Air High Setpoint

Temperature for Design {C}

```

```

!- ===== ALL OBJECTS IN CLASS: SIZING:SYSTEM =====

Sizing:System,
    Central System_unit1,      !- AirLoop Name
    Sensible,                 !- Type of Load to Size On
    autosize,                 !- Design Outdoor Air Flow Rate {m3/s}
    1,                         !- Central Heating Maximum System Air
Flow Ratio
    7,                         !- Preheat Design Temperature {C}

```

```

0.008,                                     !- Preheat Design Humidity Ratio {
kgWater/kgDryAir}

11,                                         !- Precool Design Temperature {C}
0.008,                                     !- Precool Design Humidity Ratio {
kgWater/kgDryAir}

12,                                         !- Central Cooling Design Supply Air
Temperature {C}

50,                                         !- Central Heating Design Supply Air
Temperature {C}

NonCoincident,                            !- Type of Zone Sum to Use
No,                                         !- 100% Outdoor Air in Cooling
No,                                         !- 100% Outdoor Air in Heating
0.008,                                     !- Central Cooling Design Supply Air
Humidity Ratio {kgWater/kgDryAir}

0.008,                                     !- Central Heating Design Supply Air
Humidity Ratio {kgWater/kgDryAir}

DesignDay,                                  !- Cooling Supply Air Flow Rate Method
,                                           !- Cooling Supply Air Flow Rate {m3/s}
,                                           !- Cooling Supply Air Flow Rate Per
Floor Area {m3/s-m2}

,                                           !- Cooling Fraction of Autosized
Cooling Supply Air Flow Rate

,                                           !- Cooling Supply Air Flow Rate Per
Unit Cooling Capacity {m3/s-W}

DesignDay,                                  !- Heating Supply Air Flow Rate Method
,                                           !- Heating Supply Air Flow Rate {m3/s}
,                                           !- Heating Supply Air Flow Rate Per
Floor Area {m3/s-m2}

,                                           !- Heating Fraction of Autosized
Heating Supply Air Flow Rate

,                                           !- Heating Fraction of Autosized
Cooling Supply Air Flow Rate

,                                           !- Heating Supply Air Flow Rate Per
Unit Heating Capacity {m3/s-W}

,                                           !- System Outdoor Air Method

```

```

1.0,                                     !- Zone Maximum Outdoor Air Fraction {
dimensionless}

CoolingDesignCapacity,      !- Cooling Design Capacity Method
autosize,                   !- Cooling Design Capacity {W}
,
!- Cooling Design Capacity Per Floor
Area {W/m2}

,
!- Fraction of Autosized Cooling Design
Capacity

HeatingDesignCapacity,     !- Heating Design Capacity Method
autosize,                  !- Heating Design Capacity {W}
,
!- Heating Design Capacity Per Floor
Area {W/m2}

,
!- Fraction of Autosized Heating Design
Capacity

OnOff;                     !- Central Cooling Capacity Control
Method

! - ===== ALL OBJECTS IN CLASS: SIZING:PLANT =====

Sizing:Plant,
DHW_Loop_unit1,           !- Plant or Condenser Loop Name
Heating,                  !- Loop Type
48.88888888888889,       !- Design Loop Exit Temperature {C}
5.55555555555556;        !- Loop Design Temperature Difference {
deltaC}

! - ===== ALL OBJECTS IN CLASS: ZONECONTROL:THERMOSTAT
=====

ZoneControl:Thermostat,
Zone_Thermostat_unit1,    !- Name
living_unit1,              !- Zone or ZoneList Name
zone_control_type,         !- Control Type Schedule Name
ThermostatSetpoint:DualSetpoint, !- Control 1 Object Type

```

```

thermostat_living Dual SP Control; !- Control 1 Name

!- ===== ALL OBJECTS IN CLASS: THERMOSTATSETPOINT:
DUALSETPOINT =====

ThermostatSetpoint:DualSetpoint,
    thermostat_living Dual SP Control, !- Name
    heating_sch,           !- Heating Setpoint Temperature
    Schedule Name
    cooling_sch;          !- Cooling Setpoint Temperature
    Schedule Name

!- ===== ALL OBJECTS IN CLASS: ZONEHVAC:
ENERGYRECOVERYVENTILATOR =====

ZoneHVAC:EnergyRecoveryVentilator,
    ERV_unit1,           !- Name
    always_avail,         !- Availability Schedule Name
    OA_Heat_Recovery_Unit1, !- Heat Exchanger Name
    0.0283168464628752, !- Supply Air Flow Rate {m3/s}
    0.0283168464628752, !- Exhaust Air Flow Rate {m3/s}
    OASupplyFan_unit1,   !- Supply Air Fan Name
    OAExhaustFan_unit1; !- Exhaust Air Fan Name

!- ===== ALL OBJECTS IN CLASS: AIRTERMINAL:SINGLEDUCT:
CONSTANTVOLUME:NOREHEAT =====

AirTerminal:SingleDuct:ConstantVolume:NoReheat,
    ZoneDirectAir_unit1, !- Name
    always_avail,        !- Availability Schedule Name
    Zone Inlet Node_unit1 ATInlet, !- Air Inlet Node Name
    Zone Inlet Node_unit1,   !- Air Outlet Node Name
    autosize;            !- Maximum Air Flow Rate {m3/s}

```

```

!- ===== ALL OBJECTS IN CLASS: ZONEHVAC:AIRDISTRIBUTIONUNIT
=====

ZoneHVAC:AirDistributionUnit,
    ZoneDirectAir_unit1 ADU, !- Name
    Zone Inlet Node_unit1, !- Air Distribution Unit Outlet Node
Name
    AirTerminal:SingleDuct:ConstantVolume:NoReheat, !- Air Terminal
Object Type
    ZoneDirectAir_unit1;      !- Air Terminal Name


!- ===== ALL OBJECTS IN CLASS: ZONEHVAC:EQUIPMENTLIST
=====

!   Fan:ZoneExhaust,           !- Zone Equipment 2 Object Type
!   Zone Exhaust Fan_unit1,    !- Zone Equipment 2 Name
!   4,                         !- Zone Equipment 2 Cooling Sequence
!   4,                         !- Zone Equipment 2 Heating or No-
Load Sequence
!   ,                          !- Zone Equipment 1 Sequential
Cooling Fraction Schedule Name
!   ,                          !- Zone Equipment 1 Sequential
Heating Fraction Schedule Name

ZoneHVAC:EquipmentList,
    ZoneEquipment_unit1,      !- Name
    SequentialLoad,           !- Load Distribution Scheme
    ZoneHVAC:AirDistributionUnit, !- Zone Equipment 1 Object Type
    ZoneDirectAir_unit1 ADU, !- Zone Equipment 1 Name
    3,                         !- Zone Equipment 1 Cooling Sequence
    3,                         !- Zone Equipment 1 Heating or No-Load
Sequence
    ,                          !- Zone Equipment 1 Sequential Cooling
Fraction Schedule Name

```

```

        ,                               !- Zone Equipment 1 Sequential Heating
Fraction Schedule Name
WaterHeater:HeatPump:WrappedCondenser,   !- Zone Equipment 2
Object Type
Water Heater_unit1,           !- Zone Equipment 2 Name
1,                           !- Zone Equipment 2 Cooling Sequence
1,                           !- Zone Equipment 2 Heating or No-Load
Sequence
,                               !- Zone Equipment 2 Sequential Cooling
Fraction Schedule Name
,                               !- Zone Equipment 2 Sequential Heating
Fraction Schedule Name
ZoneHVAC:EnergyRecoveryVentilator, !- Zone Equipment 3 Object
Type
ERV_unit1,           !- Zone Equipment 3 Name
2,                           !- Zone Equipment 3 Cooling Sequence
2;                          !- Zone Equipment 3 Heating or No-Load
Sequence

!- ===== ALL OBJECTS IN CLASS: ZONEHVAC:
EQUIPMENTCONNECTIONS =====

ZoneHVAC:EquipmentConnections ,
living_unit1,           !- Zone Name
ZoneEquipment_unit1,     !- Zone Conditioning Equipment List
Name
zone inlet nodes_unit1,  !- Zone Air Inlet Node or NodeList Name
Zone Exhaust Node_list_unit1, !- Zone Air Exhaust Node or
NodeList Name
Zone Node_unit1,          !- Zone Air Node Name
Zone Outlet Node_unit1;  !- Zone Return Air Node or NodeList
Name

!- ===== ALL OBJECTS IN CLASS: FAN:ONOFF =====

```

```

Fan:OnOff ,
  Supply Fan_unit1 ,           !- Name
  always_avail ,               !- Availability Schedule Name
  0.50054 ,                   !- Fan Total Efficiency
  400 ,                       !- Pressure Rise {Pa}
  autosize ,                  !- Maximum Flow Rate {m3/s}
  0.863 ,                     !- Motor Efficiency
  1 ,                          !- Motor In Airstream Fraction
  air loop inlet node_unit1 , !- Air Inlet Node Name
  cooling coil air inlet node_unit1 , !- Air Outlet Node Name
  ,
  !- Fan Power Ratio Function of Speed
Ratio Curve Name
,
  !- Fan Efficiency Ratio Function of
Speed Ratio Curve Name
General;                      !- End-Use Subcategory

Fan:OnOff ,
  OASupplyFan_unit1 ,          !- Name
  always_avail ,               !- Availability Schedule Name
  0.6 ,                        !- Fan Total Efficiency
  227.022858530508 ,          !- Pressure Rise {Pa}
  0.0283168464628752 ,        !- Maximum Flow Rate {m3/s}
  1 ,                          !- Motor Efficiency
  0 ,                          !- Motor In Airstream Fraction
  OA fan inlet node_unit1 ,   !- Air Inlet Node Name
  OA inlet node_unit1 ,        !- Air Outlet Node Name
  ,
  !- Fan Power Ratio Function of Speed
Ratio Curve Name
,
  !- Fan Efficiency Ratio Function of
Speed Ratio Curve Name
Ventilation;                  !- End-Use Subcategory

Fan:OnOff ,
  OAExhaustFan_unit1 ,         !- Name
  always_avail ,               !- Availability Schedule Name

```

```

0.6,                                     !- Fan Total Efficiency
227.022858530508,                      !- Pressure Rise {Pa}
0.0283168464628752,                     !- Maximum Flow Rate {m3/s}
1,                                         !- Motor Efficiency
0,                                         !- Motor In Airstream Fraction
ERVexhaustnode_unit1,                    !- Air Inlet Node Name
exhaust outlet node_unit1,   !- Air Outlet Node Name
,
!- Fan Power Ratio Function of Speed
Ratio Curve Name
,
!- Fan Efficiency Ratio Function of
Speed Ratio Curve Name
Ventilation;                         !- End-Use Subcategory

Fan:OnOff,
Heat Pump Water Heater Fan_unit1,   !- Name
always_avail,                        !- Availability Schedule Name
0.7,                                 !- Fan Total Efficiency
100.0,                               !- Pressure Rise {Pa}
autosize,                            !- Maximum Flow Rate {m3/s}
0.9,                                 !- Motor Efficiency
1.0,                                 !- Motor In Airstream Fraction
Heat Pump Water Heater Fan Inlet Node_unit1,  !- Air Inlet Node
Name
HPWH zone inlet node_unit1,   !- Air Outlet Node Name
,
!- Fan Power Ratio Function of Speed
Ratio Curve Name
,
!- Fan Efficiency Ratio Function of
Speed Ratio Curve Name
General;                           !- End-Use Subcategory

!- ===== ALL OBJECTS IN CLASS: COIL:COOLING:DX:SINGLESPEED
=====

Coil:Cooling:DX:SingleSpeed,
DX Cooling Coil_unit1,   !- Name

```

```

    always_avail,           !- Availability Schedule Name
    autosize,              !- Gross Rated Total Cooling Capacity {W}
W}

    autosize,              !- Gross Rated Sensible Heat Ratio
    4.06853019625951,     !- Gross Rated Cooling COP {W/W}
    autosize,              !- Rated Air Flow Rate {m3/s}
    ,                     !- Rated Evaporator Fan Power Per
Volume Flow Rate {W/(m3/s)}

    Cooling Coil Air Inlet Node_unit1,  !- Air Inlet Node Name
    Heating Coil Air Inlet Node_unit1,  !- Air Outlet Node Name
    HPACCoolCapFT,            !- Total Cooling Capacity Function of
Temperature Curve Name
    HPACCoolCapFFF,          !- Total Cooling Capacity Function of
Flow Fraction Curve Name
    HPACCOOLEIRFT,           !- Energy Input Ratio Function of
Temperature Curve Name
    HPACCOOLEIRFFF,          !- Energy Input Ratio Function of Flow
Fraction Curve Name
    HPACCOOLPLFFPLR;        !- Part Load Fraction Correlation Curve
Name

!- ===== ALL OBJECTS IN CLASS: COIL:HEATING:ELECTRIC
=====

Coil:Heating:Electric,
    Supp Heating Coil_unit1, !- Name
    always_avail,           !- Availability Schedule Name
    1,                      !- Efficiency
    autosize,               !- Nominal Capacity {W}
    Supp Heating Coil Air Inlet Node_unit1,  !- Air Inlet Node Name
    Air Loop Outlet Node_unit1;   !- Air Outlet Node Name

!- ===== ALL OBJECTS IN CLASS: COIL:HEATING:DX:SINGLESPEED
=====
```

```

Coil:Heating:DX:SingleSpeed ,
  Main DX Heating Coil_unit1,   !- Name
  always_avail,           !- Availability Schedule Name
  autosize,             !- Gross Rated Heating Capacity {W}
  3.69308080013886,      !- Gross Rated Heating COP {W/W}
  autosize,             !- Rated Air Flow Rate {m3/s}
  ,                     !- Rated Supply Fan Power Per Volume
  Flow Rate {W/(m3/s)}
  Heating Coil Air Inlet Node_unit1,  !- Air Inlet Node Name
  Supp Heating Coil Air Inlet Node_unit1,  !- Air Outlet Node Name
  HPACHeatCapFT,          !- Heating Capacity Function of
  Temperature Curve Name
  HPACHeatCapFFF,         !- Heating Capacity Function of Flow
  Fraction Curve Name
  HPACHeatEIRFT,          !- Energy Input Ratio Function of
  Temperature Curve Name
  HPACHeatEIRFFF,         !- Energy Input Ratio Function of Flow
  Fraction Curve Name
  HPACCOOLPLFFPLR,        !- Part Load Fraction Correlation Curve
  Name
  Defrost_EIR_FT,         !- Defrost Energy Input Ratio Function
  of Temperature Curve Name
  -17.78,                 !- Minimum Outdoor Dry-Bulb Temperature
  for Compressor Operation {C}
  ,                       !- Outdoor Dry-Bulb Temperature to Turn
  On Compressor {C}
  5.0,                    !- Maximum Outdoor Dry-Bulb Temperature
  for Defrost Operation {C}
  200.0,                  !- Crankcase Heater Capacity {W}
  10.0,                   !- Maximum Outdoor Dry-Bulb Temperature
  for Crankcase Heater Operation {C}
  ReverseCycle,           !- Defrost Strategy
  OnDemand;               !- Defrost Control

```

```

! - ===== ALL OBJECTS IN CLASS: COIL:WATERHEATING:
AIRTOWATERHEATPUMP:WRAPPED =====

Coil:WaterHeating:AirToWaterHeatPump:Wrapped ,
    Heat Pump Water Heater Evaporator_unit1,  !- Name
    1500,                      !- Rated Heating Capacity {W}
    3.0,                       !- Rated COP {W/W}
    0.981,                     !- Rated Sensible Heat Ratio
    19.7,                      !- Rated Evaporator Inlet Air Dry-Bulb
    Temperature {C}
    13.5,                      !- Rated Evaporator Inlet Air Wet-Bulb
    Temperature {C}
    48.89,                     !- Rated Condenser Water Temperature {C
    }
    0.189,                     !- Rated Evaporator Air Flow Rate {m3/s
    }
    yes,                        !- Evaporator Fan Power Included in
    Rated COP
    Zone Exhaust Node1_unit1,!- Evaporator Air Inlet Node Name
    Heat Pump Water Heater Fan Inlet Node_unit1,  !- Evaporator Air
    Outlet Node Name
    ,                           !- Crankcase Heater Capacity {W}
    10,                         !- Maximum Ambient Temperature for
    Crankcase Heater Operation {C}
    WetBulbTemperature,        !- Evaporator Air Temperature Type for
    Curve Objects
    HPWH-Htg-Cap-fT,          !- Heating Capacity Function of
    Temperature Curve Name
    ,                           !- Heating Capacity Function of Air
    Flow Fraction Curve Name
    HPWH-Htg-COP-fT,          !- Heating COP Function of Temperature
    Curve Name
    ,                           !- Heating COP Function of Air Flow
    Fraction Curve Name
    HPWH-COP-fPLR;           !- Part Load Fraction Correlation Curve
    Name

```

```

!- ===== ALL OBJECTS IN CLASS: HEATEXCHANGER:AIRTOAIR:
SENSIBLEANDLATENT =====

HeatExchanger:AirToAir:SensibleAndLatent ,
    OA_Heat_Recovery_Unit1,      !- Name
    always_off,                  !- Availability Schedule Name
    0.0283168464628752,        !- Nominal Supply Air Flow Rate {m3/s}
    0.65,                      !- Sensible Effectiveness at 100%
    Heating Air Flow {dimensionless}
    0,                          !- Latent Effectiveness at 100% Heating
    Air Flow {dimensionless}
    0.65,                      !- Sensible Effectiveness at 75%
    Heating Air Flow {dimensionless}
    0,                          !- Latent Effectiveness at 75% Heating
    Air Flow {dimensionless}
    0.65,                      !- Sensible Effectiveness at 100%
    Cooling Air Flow {dimensionless}
    0,                          !- Latent Effectiveness at 100% Cooling
    Air Flow {dimensionless}
    0.65,                      !- Sensible Effectiveness at 75%
    Cooling Air Flow {dimensionless}
    0,                          !- Latent Effectiveness at 75% Cooling
    Air Flow {dimensionless}
    outdoor air node_unit1,    !- Supply Air Inlet Node Name
    OA fan inlet node_unit1,   !- Supply Air Outlet Node Name
    Zone Exhaust Node_unit1,   !- Exhaust Air Inlet Node Name
    ERVExhaustnode_unit1,     !- Exhaust Air Outlet Node Name
    0,                          !- Nominal Electric Power {W}
    No,                        !- Supply Air Outlet Temperature
    Control
    Plate,                     !- Heat Exchanger Type
    None,                      !- Frost Control Type
    -16.8333337792644,       !- Threshold Temperature {C}

```

```

0.083,                                !- Initial Defrost Time Fraction {
dimensionless}

2.15999989700318E-02,      !- Rate of Defrost Time Fraction
Increase {1/K}

No;                                     !- Economizer Lockout

! - ===== ALL OBJECTS IN CLASS: AIRLOOPHVAC:UNITARYHEATPUMP:
AIRTOAIR =====

AirLoopHVAC:UnitaryHeatPump:AirToAir,
Heat Pump_unit1,                      !- Name
always_avail,                         !- Availability Schedule Name
Air Loop Inlet node_unit1,   !- Air Inlet Node Name
Air Loop Outlet Node_unit1, !- Air Outlet Node Name
autosize,                             !- Cooling Supply Air Flow Rate {m3/s}
autosize,                             !- Heating Supply Air Flow Rate {m3/s}
0.0,                                  !- No Load Supply Air Flow Rate {m3/s}
living_unit1,                         !- Controlling Zone or Thermostat
Location
Fan:OnOff,                            !- Supply Air Fan Object Type
Supply Fan_unit1,                     !- Supply Air Fan Name
Coil:Heating:DX:SingleSpeed, !- Heating Coil Object Type
Main DX Heating Coil_unit1,   !- Heating Coil Name
Coil:Cooling:DX:SingleSpeed, !- Cooling Coil Object Type
DX Cooling Coil_unit1,    !- Cooling Coil Name
Coil:Heating:Electric,   !- Supplemental Heating Coil Object
Type
Supp Heating Coil_unit1, !- Supplemental Heating Coil Name
50,                                    !- Maximum Supply Air Temperature from
Supplemental Heater {C}
10,                                     !- Maximum Outdoor Dry-Bulb Temperature
for Supplemental Heater Operation {C}
BlowThrough,                           !- Fan Placement
fan_cycle;                            !- Supply Air Fan Operating Mode
Schedule Name

```

```

! - ===== ALL OBJECTS IN CLASS: AIRLOOPHVAC =====

! Fan:ZoneExhaust ,
!   Zone Exhaust Fan_unit1,           !- Name
!   always_avail,                  !- Availability Schedule Name
!   0.6,                           !- Fan Total Efficiency
!   0.00001,                      !- Pressure Rise {Pa}
!   0.000001,         !- Maximum Flow Rate {m3/s}
!   Zone Exhaust Node_unit1,   !- Air Inlet Node Name
!   zone exhaust fan outlet nodes_unit1, !- Air Outlet Node Name
!   Ventilation,                 !- End-Use Subcategory
!   ,                            !- Flow Fraction Schedule Name
!   Decoupled;                  !- System Availability Manager
      Coupling Mode

AirLoopHVAC ,
  Central System_unit1,       !- Name
  ,
  availability list,        !- Availability Manager List Name
  autosize,                  !- Design Supply Air Flow Rate {m3/s}
  Air Loop Branches_unit1, !- Branch List Name
  ,
  Air Loop Inlet Node_unit1, !- Supply Side Inlet Node Name
  Return Air Mixer Outlet_unit1, !- Demand Side Outlet Node Name
  Zone Equipment Inlet Node_unit1, !- Demand Side Inlet Node
  Names
  Air Loop Outlet Node_unit1; !- Supply Side Outlet Node Names

! - ===== ALL OBJECTS IN CLASS: AIRLOOPHVAC:ZONEPLITTER
=====

AirLoopHVAC:ZoneSplitter ,
  Zone Supply Air Splitter_unit1, !- Name
  Zone Equipment Inlet Node_unit1, !- Inlet Node Name

```

```

Zone Inlet Node_unit1 ATInlet;  !- Outlet 1 Node Name

! - ===== ALL OBJECTS IN CLASS: AIRLOOPHVAC:SUPPLYPATH
=====

AirLoopHVAC:SupplyPath,
    SupplyPath_unit1,           !- Name
    Zone Equipment Inlet Node_unit1,  !- Supply Air Path Inlet Node
    Name
    AirLoopHVAC:ZoneSplitter,!- Component 1 Object Type
    Zone Supply Air Splitter_unit1;  !- Component 1 Name


! - ===== ALL OBJECTS IN CLASS: AIRLOOPHVAC:ZONEMIXER
=====

AirLoopHVAC:ZoneMixer,
    Zone Return Air Mixer_unit1,   !- Name
    Return Air Mixer Outlet_unit1,  !- Outlet Node Name
    Zone Outlet Node_unit1;   !- Inlet 1 Node Name


! - ===== ALL OBJECTS IN CLASS: AIRLOOPHVAC:RETURNPATH
=====

AirLoopHVAC:ReturnPath,
    ReturnPath_unit1,           !- Name
    Return Air Mixer Outlet_unit1,  !- Return Air Path Outlet Node
    Name
    AirLoopHVAC:ZoneMixer,     !- Component 1 Object Type
    Zone Return Air Mixer_unit1;  !- Component 1 Name


! - ===== ALL OBJECTS IN CLASS: BRANCH =====

```

```

Branch,
    Air Loop Main Branch_unit1,   !- Name
        ,                         !- Pressure Drop Curve Name
    AirLoopHVAC:UnitaryHeatPump:AirtoAir,   !- Component 1 Object
Type
    Heat Pump_unit1,           !- Component 1 Name
    Air Loop Inlet Node_unit1,   !- Component 1 Inlet Node Name
    Air Loop Outlet Node_unit1; !- Component 1 Outlet Node Name

Branch,
    Mains Inlet Branch_unit1,!- Name
        ,                         !- Pressure Drop Curve Name
    Pump:VariableSpeed,         !- Component 1 Object Type
    Mains Pressure_unit1,       !- Component 1 Name
    Mains Inlet Node_unit1,     !- Component 1 Inlet Node Name
    Mains Pressure Outlet Node_unit1; !- Component 1 Outlet Node
Name

Branch,
    DHW Supply Outlet Branch_unit1,   !- Name
        ,                         !- Pressure Drop Curve Name
    Pipe:Adiabatic,             !- Component 1 Object Type
    DHW Supply Outlet Pipe_unit1,   !- Component 1 Name
    DHW Supply Outlet Pipe Inlet Node_unit1,   !- Component 1 Inlet
Node Name
    DHW Supply Outlet Node_unit1;   !- Component 1 Outlet Node Name

Branch,
    DHW Demand Inlet Branch_unit1,   !- Name
        ,                         !- Pressure Drop Curve Name
    Pipe:Adiabatic,             !- Component 1 Object Type
    DHW Demand Inlet Pipe_unit1,   !- Component 1 Name
    DHW Demand Inlet Node_unit1,   !- Component 1 Inlet Node Name
    DHW Demand Inlet Pipe Outlet Node_unit1; !- Component 1 Outlet
Node Name

```

```

Branch,
    Water Sink Branch_unit1, !- Name
        ,                               !- Pressure Drop Curve Name
    WaterUse:Connections,      !- Component 1 Object Type
    DHW Sinks_unit1,          !- Component 1 Name
    Water Sink Inlet Node_unit1, !- Component 1 Inlet Node Name
    Water Sink outlet Node_unit1; !- Component 1 Outlet Node Name


Branch,
    Water Shower Branch_unit1,   !- Name
        ,                           !- Pressure Drop Curve Name
    WaterUse:Connections,      !- Component 1 Object Type
    DHW Showers_unit1,         !- Component 1 Name
    Water Shower Inlet Node_unit1, !- Component 1 Inlet Node Name
    Water Shower Outlet Node_unit1; !- Component 1 Outlet Node Name


Branch,
    Water ClothesWasher Branch_unit1,   !- Name
        ,                           !- Pressure Drop Curve Name
    WaterUse:Connections,      !- Component 1 Object Type
    DHW ClothesWasher_unit1, !- Component 1 Name
    Water ClothesWasher Inlet Node_unit1, !- Component 1 Inlet Node
    Name
    Water ClothesWasher Outlet Node_unit1; !- Component 1 Outlet
    Node Name


Branch,
    Water Dishwasher Branch_unit1,   !- Name
        ,                           !- Pressure Drop Curve Name
    WaterUse:Connections,      !- Component 1 Object Type
    DHW DishWasher_unit1,       !- Component 1 Name
    Water DishWasher Inlet Node_unit1, !- Component 1 Inlet Node
    Name
    Water DishWasher outlet Node_unit1; !- Component 1 Outlet Node
    Name

```

```

Branch,
    Water Bath Branch_unit1, !- Name
        ,                               !- Pressure Drop Curve Name
    WaterUse:Connections,      !- Component 1 Object Type
    DHW Baths_unit1,          !- Component 1 Name
    Water Bath Inlet Node_unit1,   !- Component 1 Inlet Node Name
    Water bath Outlet Node_unit1; !- Component 1 Outlet Node Name

Branch,
    Mains Makeup Branch_unit1,   !- Name
        ,                               !- Pressure Drop Curve Name
    Pipe:Adiabatic,            !- Component 1 Object Type
    Mains Makeup Pipe_unit1,   !- Component 1 Name
    Mains Makeup Pipe Inlet Node_unit1,   !- Component 1 Inlet Node
Name
    Mains Makeup Node_unit1; !- Component 1 Outlet Node Name

Branch,
    Water Heater Branch_unit1,   !- Name
        ,                               !- Pressure Drop Curve Name
    WaterHeater:HeatPump:WrappedCondenser,   !- Component 1 Object
Type
    Water Heater_unit1,         !- Component 1 Name
    Water Heater Use Inlet Node_unit1,   !- Component 1 Inlet Node
Name
    Water Heater Use Outlet Node_unit1; !- Component 1 Outlet Node
Name

!- ===== ALL OBJECTS IN CLASS: BRANCHLIST =====

BranchList,
    Air Loop Branches_unit1, !- Name
    Air Loop Main Branch_unit1; !- Branch 1 Name

BranchList,

```

```

DHW Supply Branches_unit1,  !- Name
Mains Inlet Branch_unit1,!- Branch 1 Name
Water Heater Branch_unit1,  !- Branch 2 Name
DHW Supply Outlet Branch_unit1;  !- Branch 3 Name

BranchList,
    DHW Demand Branches_unit1,  !- Name
    DHW Demand Inlet Branch_unit1,  !- Branch 1 Name
    Water Sink Branch_unit1, !- Branch 2 Name
    Water Shower Branch_unit1,  !- Branch 3 Name
    Water ClothesWasher Branch_unit1,  !- Branch 4 Name
    Water Dishwasher Branch_unit1,  !- Branch 5 Name
    Water Bath Branch_unit1, !- Branch 6 Name
    Mains Makeup Branch_unit1;  !- Branch 7 Name

!- ===== ALL OBJECTS IN CLASS: CONNECTOR:SPLITTER
=====

Connector:Splitter,
    DHW Demand Splitter_unit1,  !- Name
    DHW Demand Inlet Branch_unit1,  !- Inlet Branch Name
    Water Sink Branch_unit1, !- Outlet Branch 1 Name
    Water Shower Branch_unit1,  !- Outlet Branch 2 Name
    Water ClothesWasher Branch_unit1,  !- Outlet Branch 3 Name
    Water Dishwasher Branch_unit1,  !- Outlet Branch 4 Name
    Water Bath Branch_unit1; !- Outlet Branch 5 Name

Connector:Splitter,
    DHW Supply Splitter_unit1,  !- Name
    Mains Inlet Branch_unit1,!- Inlet Branch Name
    Water Heater Branch_unit1;  !- Outlet Branch 1 Name

!- ===== ALL OBJECTS IN CLASS: CONNECTOR:MIXER =====

```

```

Connector:Mixer,
    DHW Demand Mixer_unit1,   !- Name
    Mains Makeup Branch_unit1,   !- Outlet Branch Name
    Water Sink Branch_unit1,   !- Inlet Branch 1 Name
    Water Shower Branch_unit1,   !- Inlet Branch 2 Name
    Water ClothesWasher Branch_unit1,   !- Inlet Branch 3 Name
    Water Dishwasher Branch_unit1,   !- Inlet Branch 4 Name
    Water Bath Branch_unit1; !- Inlet Branch 5 Name

Connector:Mixer,
    DHW Supply Mixer_unit1,   !- Name
    DHW Supply Outlet Branch_unit1,   !- Outlet Branch Name
    Water Heater Branch_unit1;   !- Inlet Branch 1 Name

!- ===== ALL OBJECTS IN CLASS: CONNECTORLIST =====

ConnectorList,
    DHW Demand Connectors_unit1,   !- Name
    Connector:Splitter,      !- Connector 1 Object Type
    DHW Demand Splitter_unit1,   !- Connector 1 Name
    Connector:Mixer,        !- Connector 2 Object Type
    DHW Demand Mixer_unit1;   !- Connector 2 Name

ConnectorList,
    DHW Supply Connectors_unit1,   !- Name
    Connector:Splitter,      !- Connector 1 Object Type
    DHW Supply Splitter_unit1,   !- Connector 1 Name
    Connector:Mixer,        !- Connector 2 Object Type
    DHW Supply Mixer_unit1;   !- Connector 2 Name

!- ===== ALL OBJECTS IN CLASS: NODELIST =====

NodeList,
    Zone Inlet Nodes_unit1,   !- Name

```

```

Zone Inlet Node_unit1,    !- Node 1 Name
HPWH Zone Inlet Node_unit1,  !- Node 2 Name
OA Inlet Node_unit1;      !- Node 3 Name

NodeList,
  Zone Exhaust Node_list_unit1,  !- Name
  Zone Exhaust Node_unit1, !- Node 1 Name
  Zone Exhaust Node1_unit1;!- Node 2 Name

! - ===== ALL OBJECTS IN CLASS: OUTDOORAIR:NODE =====

OutdoorAir:Node,
  outside air inlet node_unit1,  !- Name
  0.914355407629293;          !- Height Above Ground {m}

! - ===== ALL OBJECTS IN CLASS: OUTDOORAIR:NODELIST
=====

OutdoorAir:NodeList,
  outdoor air node_unit1;  !- Node or NodeList Name 1

! - ===== ALL OBJECTS IN CLASS: PIPE:ADIABATIC =====

Pipe:Adiabatic,
  DHW Supply Outlet Pipe_unit1,  !- Name
  DHW Supply Outlet Pipe Inlet Node_unit1,  !- Inlet Node Name
  DHW Supply Outlet Node_unit1;  !- Outlet Node Name

Pipe:Adiabatic,
  Mains Makeup Pipe_unit1, !- Name
  Mains Makeup Pipe Inlet Node_unit1,  !- Inlet Node Name
  Mains Makeup Node_unit1; !- Outlet Node Name

```

```

Pipe:Adiabatic,
    DHW Demand Inlet Pipe_unit1,   !- Name
    DHW Demand Inlet Node_unit1,   !- Inlet Node Name
    DHW Demand Inlet Pipe Outlet Node_unit1;   !- Outlet Node Name

!- ===== ALL OBJECTS IN CLASS: PUMP:VARIABLESPEED
=====

Pump:VariableSpeed,
    Mains Pressure_unit1,      !- Name
    Mains Inlet Node_unit1,   !- Inlet Node Name
    Mains Pressure Outlet Node_unit1,   !- Outlet Node Name
    autosize,                  !- Design Maximum Flow Rate {m3/s}
    1,                         !- Design Pump Head {Pa}
    0,                         !- Design Power Consumption {W}
    1,                         !- Motor Efficiency
    0,                         !- Fraction of Motor Inefficiencies to
Fluid Stream
    0,                         !- Coefficient 1 of the Part Load
Performance Curve
    1,                         !- Coefficient 2 of the Part Load
Performance Curve
    0,                         !- Coefficient 3 of the Part Load
Performance Curve
    0,                         !- Coefficient 4 of the Part Load
Performance Curve
    0,                         !- Design Minimum Flow Rate {m3/s}
    Intermittent;             !- Pump Control Type

!- ===== ALL OBJECTS IN CLASS: WATERHEATER:STRATIFIED
=====

WaterHeater:Stratified,
    Water Heater_Tank_unit1, !- Name

```

```

Water Heater,
0.196841372,
1.594,
VerticalCylinder,
,
51,
MasterSlave,
dhw_setpt_hpwh,
Schedule Name
2,
Difference {deltaC}
autosize,
1.129,
dhw_setpt_hpwh,
Schedule Name
2,
Difference {deltaC}
0,
0.266,
electricity,
1,
8.3,
Rate {W}
Electricity,
0,
Tank
1,
8.3,
Rate {W}
Electricity,
0,
Tank
1,
Zone,
,
living_unit1,

```

!- End-Use Subcategory  
!- Tank Volume {m3}  
!- Tank Height {m}  
!- Tank Shape  
!- Tank Perimeter {m}  
!- Maximum Temperature Limit {C}  
!- Heater Priority Control  
!- Heater 1 Setpoint Temperature  
!- Heater 1 Deadband Temperature  
!- Heater 1 Capacity {W}  
!- Heater 1 Height {m}  
!- Heater 2 Setpoint Temperature  
!- Heater 2 Deadband Temperature  
!- Heater 2 Capacity {W}  
!- Heater 2 Height {m}  
!- Heater Fuel Type  
!- Heater Thermal Efficiency  
!- Off Cycle Parasitic Fuel Consumption  
!- Off Cycle Parasitic Fuel Type  
!- Off Cycle Parasitic Heat Fraction to  
!- Off Cycle Parasitic Height {m}  
!- On Cycle Parasitic Fuel Consumption  
!- On Cycle Parasitic Fuel Type  
!- On Cycle Parasitic Heat Fraction to  
!- On Cycle Parasitic Height {m}  
!- Ambient Temperature Indicator  
!- Ambient Temperature Schedule Name  
!- Ambient Temperature Zone Name

```

        ,                               !- Ambient Temperature Outdoor Air Node
Name
0.730336050939686 ,           !- Uniform Skin Loss Coefficient per
Unit Area to Ambient Temperature {W/m2-K}
1,                               !- Skin Loss Fraction to Zone
,                               !- Off Cycle Flue Loss Coefficient to
Ambient Temperature {W/K}
1,                               !- Off Cycle Flue Loss Fraction to Zone
,                               !- Peak Use Flow Rate {m3/s}
,                               !- Use Flow Rate Fraction Schedule Name
,                               !- Cold Water Supply Temperature

Schedule Name
Water Heater use inlet node_unit1,  !- Use Side Inlet Node Name
Water Heater use outlet node_unit1,  !- Use Side Outlet Node
Name
1,                               !- Use Side Effectiveness
0,                               !- Use Side Inlet Height {m}
autocalculate,                 !- Use Side Outlet Height {m}
,                               !- Source Side Inlet Node Name
,                               !- Source Side Outlet Node Name
1,                               !- Source Side Effectiveness
0.7,                            !- Source Side Inlet Height {m}
0,                               !- Source Side Outlet Height {m}
Fixed,                           !- Inlet Mode
autosize,                        !- Use Side Design Flow Rate {m3/s}
autosize,                        !- Source Side Design Flow Rate {m3/s}
1.5,                            !- Indirect Water Heating Recovery Time
{hr}
1;                               !- Number of Nodes

!- ===== ALL OBJECTS IN CLASS: WATERHEATER:SIZING
=====

WaterHeater:Sizing,
Water Heater_Tank_unit1 , !- WaterHeater Name

```

```

ResidentialHUD-FHAMinimum,      !- Design Mode
,
                                !- Time Storage Can Meet Peak Draw {hr}
,
                                !- Time for Tank Recovery {hr}
,
                                !- Nominal Tank Volume for Autosizing
Plant Connections {m3}
3,                               !- Number of Bedrooms
3;                               !- Number of Bathrooms

!- ===== ALL OBJECTS IN CLASS: WATERHEATER:HEATPUMP:
WRAPPEDCONDENSER =====

WaterHeater:HeatPump:WrappedCondenser,
    Water Heater_unit1,          !- Name
    always_avail,                !- Availability Schedule Name
    Compressor Setpoint,         !- Compressor Setpoint Temperature
    Schedule Name
    5,                           !- Dead Band Temperature Difference {
    deltaC}
    0.0664166667,              !- Condenser Bottom Location {m}
    0.8634166667,              !- Condenser Top Location {m}
    autocalculate,              !- Evaporator Air Flow Rate {m3/s}
    ZoneAirOnly,                !- Inlet Air Configuration
    Zone Exhaust Node1_unit1,!- Air Inlet Node Name
    HPWH Zone Inlet Node_unit1, !- Air Outlet Node Name
    ,
                                !- Outdoor Air Node Name
    ,
                                !- Exhaust Air Node Name
    ,
                                !- Inlet Air Temperature Schedule Name
    ,
                                !- Inlet Air Humidity Schedule Name
    living_unit1,               !- Inlet Air Zone Name
    WaterHeater:Stratified,     !- Tank Object Type
    Water Heater_Tank_unit1,   !- Tank Name
    Water Heater use inlet node_unit1, !- Tank Use Side Inlet Node
    Name
    Water Heater use outlet node_unit1, !- Tank Use Side Outlet
    Node Name

```

```

Coil:WaterHeating:AirToWaterHeatPump:Wrapped, !- DX Coil Object
Type

Heat Pump Water Heater Evaporator_unit1, !- DX Coil Name
10.0, !- Minimum Inlet Air Temperature for
Compressor Operation {C}
48.89, !- Maximum Inlet Air Temperature for
Compressor Operation {C}
Zone, !- Compressor Location
, !- Compressor Ambient Temperature
Schedule Name

Fan:OnOff, !- Fan Object Type
Heat Pump Water Heater Fan_unit1, !- Fan Name
DrawThrough, !- Fan Placement
0, !- On Cycle Parasitic Electric Load {W}
0, !- Off Cycle Parasitic Electric Load {W}
}
, !- Parasitic Heat Rejection Location
, !- Inlet Air Mixer Node Name
, !- Outlet Air Splitter Node Name
, !- Inlet Air Mixer Schedule Name
MutuallyExclusive, !- Tank Element Control Logic
1.262, !- Control Sensor 1 Height In
Stratified Tank {m}
0.75, !- Control Sensor 1 Weight {
dimensionless}
0.464; !- Control Sensor 2 Height In
Stratified Tank {m}

!- ===== ALL OBJECTS IN CLASS: PLANTLOOP =====

PlantLoop,
DHW Loop_unit1, !- Name
Water, !- Fluid Type
, !- User Defined Fluid Type

```

```

DHW Loop Operation_unit1,!- Plant Equipment Operation Scheme
Name

DHW Supply Outlet Node_unit1, !- Loop Temperature Setpoint Node
Name

100,                                !- Maximum Loop Temperature {C}
0,                                    !- Minimum Loop Temperature {C}
autosize,                            !- Maximum Loop Flow Rate {m3/s}
0,                                    !- Minimum Loop Flow Rate {m3/s}
autocalculate,                      !- Plant Loop Volume {m3}

Mains Inlet Node_unit1, !- Plant Side Inlet Node Name

DHW Supply Outlet Node_unit1, !- Plant Side Outlet Node Name

DHW Supply Branches_unit1, !- Plant Side Branch List Name

DHW Supply Connectors_unit1, !- Plant Side Connector List Name

DHW Demand Inlet Node_unit1, !- Demand Side Inlet Node Name

Mains Makeup Node_unit1, !- Demand Side Outlet Node Name

DHW Demand Branches_unit1, !- Demand Side Branch List Name

DHW Demand Connectors_unit1, !- Demand Side Connector List Name

Optimal;                           !- Load Distribution Scheme

!- ===== ALL OBJECTS IN CLASS: PLANTEQUIPMENTLIST
=====

PlantEquipmentList,
    DHW Plant Equipment_unit1, !- Name
    WaterHeater:HeatPump:WrappedCondenser, !- Equipment 1 Object
    Type
    Water Heater_unit1;      !- Equipment 1 Name

!- ===== ALL OBJECTS IN CLASS: PLANTEQUIPMENTOPERATION:
HEATINGLOAD =====

PlantEquipmentOperation:HeatingLoad,
    DHW Control Scheme_unit1,!- Name
    0.0,                      !- Load Range 1 Lower Limit {W}

```

```

10000000000000000000 ,           !- Load Range 1 Upper Limit {W}
DHW Plant Equipment_unit1;   !- Range 1 Equipment List Name

! - ===== ALL OBJECTS IN CLASS:
PLANTEQUIPMENTOPERATIONSCHMES =====

PlantEquipmentOperationSchemes ,
DHW Loop Operation_unit1,!- Name
PlantEquipmentOperation:HeatingLoad ,   !- Control Scheme 1 Object
Type
DHW Control Scheme_unit1,!- Control Scheme 1 Name
always_avail;           !- Control Scheme 1 Schedule Name

! - ===== ALL OBJECTS IN CLASS: AVAILABILITYMANAGER:
SCHEDULED =====

AvailabilityManager:Scheduled ,
System availability ,      !- Name
always_avail;           !- Schedule Name

! - ===== ALL OBJECTS IN CLASS:
AVAILABILITYMANAGERASSIGNMENTLIST =====

AvailabilityManagerAssignmentList ,
availability list ,        !- Name
AvailabilityManager:Scheduled ,   !- Availability Manager 1 Object
Type
System availability;       !- Availability Manager 1 Name

! - ===== ALL OBJECTS IN CLASS: SETPOINTMANAGER:SCHEDULED
=====
```

```

SetpointManager:Scheduled ,
  DHW Loop Setpoint Manager_unit1,   !- Name
  Temperature,                      !- Control Variable
  DHWSupplySetpoint,                !- Schedule Name
  DHW Supply Outlet Node_unit1;    !- Setpoint Node or NodeList Name

!- ===== ALL OBJECTS IN CLASS: WATERUSE:EQUIPMENT
=====

WaterUse:Equipment ,
  Clothes Washer_unit1,      !- Name
  Domestic Hot Water,       !- End-Use Subcategory
  1.6219189818e-06,         !- Peak Flow Rate {m3/s}
  ClothesWasher,            !- Flow Rate Fraction Schedule Name
  CWWaterTempSchedule;      !- Target Temperature Schedule Name

WaterUse:Equipment ,
  Dishwasher_unit1,          !- Name
  Domestic Hot Water,        !- End-Use Subcategory
  6.36685353e-07,           !- Peak Flow Rate {m3/s}
  Dishwasher,                !- Flow Rate Fraction Schedule Name
  DWWaterTempSchedule;       !- Target Temperature Schedule Name

WaterUse:Equipment ,
  Sinks_unit1,               !- Name
  Domestic Hot Water,        !- End-Use Subcategory
  7.1934e-05,                !- Peak Flow Rate {m3/s}
  BA_sink_sch,               !- Flow Rate Fraction Schedule Name
  SSBWaterTempSchedule;      !- Target Temperature Schedule Name

WaterUse:Equipment ,
  Showers_unit1,              !- Name
  Domestic Hot Water,        !- End-Use Subcategory
  0.000141975,               !- Peak Flow Rate {m3/s}
  BA_shower_sch,              !- Flow Rate Fraction Schedule Name

```

```

SSBWATERTEMPCHEDULE;      !- Target Temperature Schedule Name

Wateruse:Equipment,
    Baths_unit1,           !- Name
    Domestic Hot Water,    !- End-Use Subcategory
    0.00027764,            !- Peak Flow Rate {m3/s}
    BA_bath_sch,           !- Flow Rate Fraction Schedule Name
    SSBWATERTEMPCHEDULE;   !- Target Temperature Schedule Name

! - ===== ALL OBJECTS IN CLASS: WATERUSE:CONNECTIONS
=====

Wateruse:Connections,
    DHW_Sinks_unit1,        !- Name
    Water Sink Inlet Node_unit1, !- Inlet Node Name
    Water Sink Outlet Node_unit1, !- Outlet Node Name
    ,                       !- Supply Water Storage Tank Name
    ,                       !- Reclamation Water Storage Tank Name
    ,                       !- Hot Water Supply Temperature
    Schedule Name
    ,                       !- Cold Water Supply Temperature
    Schedule Name
    None,                  !- Drain Water Heat Exchanger Type
    ,                       !- Drain Water Heat Exchanger
    Destination
    ,                       !- Drain Water Heat Exchanger U-Factor
    Times Area {W/K}
    Sinks_unit1;            !- Water Use Equipment 1 Name

Wateruse:Connections,
    DHW_Showers_unit1,       !- Name
    Water Shower Inlet Node_unit1, !- Inlet Node Name
    Water Shower Outlet Node_unit1, !- Outlet Node Name
    ,                       !- Supply Water Storage Tank Name
    ,                       !- Reclamation Water Storage Tank Name

```

```

        ,                               !- Hot Water Supply Temperature
Schedule Name

        ,                               !- Cold Water Supply Temperature
Schedule Name

None,                                !- Drain Water Heat Exchanger Type
,                                     !- Drain Water Heat Exchanger
Destination

        ,                               !- Drain Water Heat Exchanger U-Factor
Times Area {W/K}

Showers_unit1;                      !- Water Use Equipment 1 Name

WaterUse:Connections ,
DHW ClothesWasher_unit1, !- Name
Water ClothesWasher Inlet Node_unit1, !- Inlet Node Name
Water ClothesWasher Outlet Node_unit1, !- Outlet Node Name
,                                     !- Supply Water Storage Tank Name
,                                     !- Reclamation Water Storage Tank Name
,                                     !- Hot Water Supply Temperature
Schedule Name

        ,                               !- Cold Water Supply Temperature
Schedule Name

None,                                !- Drain Water Heat Exchanger Type
,                                     !- Drain Water Heat Exchanger
Destination

        ,                               !- Drain Water Heat Exchanger U-Factor
Times Area {W/K}

Clothes Washer_unit1;                !- Water Use Equipment 1 Name

WaterUse:Connections ,
DHW DishWasher_unit1,      !- Name
Water DishWasher Inlet Node_unit1, !- Inlet Node Name
Water DishWasher Outlet Node_unit1, !- Outlet Node Name
,                                     !- Supply Water Storage Tank Name
,                                     !- Reclamation Water Storage Tank Name
,                                     !- Hot Water Supply Temperature
Schedule Name

```

```

        ,                               !- Cold Water Supply Temperature
Schedule Name

None,                                !- Drain Water Heat Exchanger Type
,
                               !- Drain Water Heat Exchanger

Destination

,
                               !- Drain Water Heat Exchanger U-Factor

Times Area {W/K}

Dishwasher_unit1;                   !- Water Use Equipment 1 Name


WaterUse:Connections ,

DHW_Baths_unit1,                  !- Name
Water Bath Inlet Node_unit1,    !- Inlet Node Name
Water Bath Outlet Node_unit1,   !- Outlet Node Name
,
                               !- Supply Water Storage Tank Name
,
                               !- Reclamation Water Storage Tank Name
,
                               !- Hot Water Supply Temperature

Schedule Name

,
                               !- Cold Water Supply Temperature

Schedule Name

None,                                !- Drain Water Heat Exchanger Type
,
                               !- Drain Water Heat Exchanger

Destination

,
                               !- Drain Water Heat Exchanger U-Factor

Times Area {W/K}

Baths_unit1;                      !- Water Use Equipment 1 Name


!- ===== ALL OBJECTS IN CLASS: CURVE:QUADRATIC =====

Curve:Quadratic ,

HPWH-COP-fPLR,                    !- Name
1,                                 !- Coefficient1 Constant
0,                                 !- Coefficient2 x
0,                                 !- Coefficient3 x**2
0,                                 !- Minimum Value of x
1;                                 !- Maximum Value of x

```

```

Curve:Quadratic ,
    HPACCoolCapFFF ,           !- Name
    0.8 ,                      !- Coefficient1 Constant
    0.2 ,                      !- Coefficient2 x
    0.0 ,                      !- Coefficient3 x**2
    0.5 ,                      !- Minimum Value of x
    1.5;                      !- Maximum Value of x

Curve:Quadratic ,
    HPACCOOLEIRFFF ,          !- Name
    1.156 ,                    !- Coefficient1 Constant
    -0.1816 ,                  !- Coefficient2 x
    0.0256 ,                  !- Coefficient3 x**2
    0.5 ,                      !- Minimum Value of x
    1.5;                      !- Maximum Value of x

Curve:Quadratic ,
    HPACCOOLPLFFPLR ,         !- Name
    0.85 ,                     !- Coefficient1 Constant
    0.15 ,                     !- Coefficient2 x
    0.0 ,                      !- Coefficient3 x**2
    0.0 ,                      !- Minimum Value of x
    1.0;                      !- Maximum Value of x

Curve:Quadratic ,
    HPACHEateEIRFFF ,          !- Name
    1.3824 ,                   !- Coefficient1 Constant
    -0.4336 ,                  !- Coefficient2 x
    0.0512 ,                  !- Coefficient3 x**2
    0.0 ,                      !- Minimum Value of x
    1.0;                      !- Maximum Value of x

Curve:Quadratic ,
    ACCoolingCAPFFF ,          !- Name
    0.718605468 ,             !- Coefficient1 Constant

```

```

0.410099989 ,           !- Coefficient2 x
-0.128705457 ,          !- Coefficient3 x**2
0 ,                      !- Minimum Value of x
1.5 ,                   !- Maximum Value of x
0 ,                      !- Minimum Curve Output
2 ,                      !- Maximum Curve Output
Dimensionless ,          !- Input Unit Type for X
Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
ACCoolingEIRFFF ,        !- Name
1.32299905 ,             !- Coefficient1 Constant
-0.477711207 ,           !- Coefficient2 x
0.154712157 ,            !- Coefficient3 x**2
0 ,                      !- Minimum Value of x
1.5 ,                   !- Maximum Value of x
0 ,                      !- Minimum Curve Output
2 ,                      !- Maximum Curve Output
Dimensionless ,           !- Input Unit Type for X
Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
ACCoolingPLFFPLR ,       !- Name
0.90 ,                   !- Coefficient1 Constant
0.10 ,                  !- Coefficient2 x
0.0 ,                   !- Coefficient3 x**2
0.0 ,                   !- Minimum Value of x
1.0;                     !- Maximum Value of x

Curve:Quadratic ,
HPCoolingCAPFFF ,        !- Name
0.718664047 ,            !- Coefficient1 Constant
0.41797409 ,             !- Coefficient2 x
-0.136638137 ,           !- Coefficient3 x**2
0 ,                      !- Minimum Value of x
1.5 ,                   !- Maximum Value of x

```

```

0,                               ! - Minimum Curve Output
2,                               ! - Maximum Curve Output
Dimensionless,                  ! - Input Unit Type for X
Dimensionless;                  ! - Output Unit Type

Curve:Quadratic,
HPCoolingEIRFFF,              ! - Name
1.143487507,                  ! - Coefficient1 Constant
-0.13943972,                  ! - Coefficient2 x
-0.004047787,                 ! - Coefficient3 x**2
0,                               ! - Minimum Value of x
1.5,                             ! - Maximum Value of x
0,                               ! - Minimum Curve Output
2,                               ! - Maximum Curve Output
Dimensionless,                  ! - Input Unit Type for X
Dimensionless;                  ! - Output Unit Type

Curve:Quadratic,
HPCOOLPLFFPLR,                ! - Name
0.90,                            ! - Coefficient1 Constant
0.10,                            ! - Coefficient2 x
0.0,                             ! - Coefficient3 x**2
0.0,                             ! - Minimum Value of x
1.0;                            ! - Maximum Value of x

Curve:Quadratic,
HPHeatingCAPFFF,               ! - Name
0.694045465,                  ! - Coefficient1 Constant
0.474207981,                  ! - Coefficient2 x
-0.168253446,                 ! - Coefficient3 x**2
0,                               ! - Minimum Value of x
1.5,                             ! - Maximum Value of x
0,                               ! - Minimum Curve Output
2,                               ! - Maximum Curve Output
Dimensionless,                  ! - Input Unit Type for X
Dimensionless;                  ! - Output Unit Type

```

```

Curve:Quadratic ,
    HPHeatingEIRFFF ,           !- Name
    2.185418751 ,              !- Coefficient1 Constant
    -1.942827919 ,             !- Coefficient2 x
    0.757409168 ,              !- Coefficient3 x**2
    0 ,                         !- Minimum Value of x
    1.5 ,                        !- Maximum Value of x
    0 ,                         !- Minimum Curve Output
    2 ,                         !- Maximum Curve Output
    Dimensionless ,              !- Input Unit Type for X
    Dimensionless ;              !- Output Unit Type

Curve:Quadratic ,
    HPHeatPLFFPLR ,            !- Name
    0.90 ,                      !- Coefficient1 Constant
    0.10 ,                      !- Coefficient2 x
    0.0 ,                        !- Coefficient3 x**2
    0.0 ,                        !- Minimum Value of x
    1.0 ;                       !- Maximum Value of x

Curve:Quadratic ,
    HPLowStageHeatingCAPFFF , !- Name
    0.741466907 ,              !- Coefficient1 Constant
    0.378645444 ,              !- Coefficient2 x
    -0.119754733 ,             !- Coefficient3 x**2
    0 ,                         !- Minimum Value of x
    1.5 ,                        !- Maximum Value of x
    0 ,                         !- Minimum Curve Output
    2 ,                         !- Maximum Curve Output
    Dimensionless ,              !- Input Unit Type for X
    Dimensionless ;              !- Output Unit Type

Curve:Quadratic ,
    HPLowStageHeatingEIRFFF , !- Name
    2.153618211 ,              !- Coefficient1 Constant

```

```

-1.737190609,           !- Coefficient2 x
0.584269478,           !- Coefficient3 x**2
0,                      !- Minimum Value of x
1.5,                     !- Maximum Value of x
0,                      !- Minimum Curve Output
2,                      !- Maximum Curve Output
Dimensionless,          !- Input Unit Type for X
Dimensionless;          !- Output Unit Type

Curve:Quadratic,
HPHighStageHeatingCAPFFF,!- Name
0.76634609,             !- Coefficient1 Constant
0.32840943,             !- Coefficient2 x
-0.094701495,           !- Coefficient3 x**2
0,                      !- Minimum Value of x
1.5,                     !- Maximum Value of x
0,                      !- Minimum Curve Output
2,                      !- Maximum Curve Output
Dimensionless,          !- Input Unit Type for X
Dimensionless;          !- Output Unit Type

Curve:Quadratic,
HPHighStageHeatingEIRFFF,!- Name
2.001041353,            !- Coefficient1 Constant
-1.58869128,            !- Coefficient2 x
0.587593517,            !- Coefficient3 x**2
0,                      !- Minimum Value of x
1.5,                     !- Maximum Value of x
0,                      !- Minimum Curve Output
2,                      !- Maximum Curve Output
Dimensionless,          !- Input Unit Type for X
Dimensionless;          !- Output Unit Type

Curve:Quadratic,
HP2StageHeatingPLFFPLR, !- Name
0.93,                   !- Coefficient1 Constant

```

```

0.07,                               !- Coefficient2 x
0.0,                                !- Coefficient3 x**2
0.0,                                !- Minimum Value of x
1.0;                                 !- Maximum Value of x

Curve:Quadratic,
HPLowStageCoolingCAPFFF, !- Name
0.655239515,                      !- Coefficient1 Constant
0.511655216,                      !- Coefficient2 x
-0.166894731,                     !- Coefficient3 x**2
0,                                   !- Minimum Value of x
1.5,                                !- Maximum Value of x
0,                                   !- Minimum Curve Output
2,                                   !- Maximum Curve Output
Dimensionless,                      !- Input Unit Type for X
Dimensionless;                      !- Output Unit Type

Curve:Quadratic,
HPLowStageCoolingEIRFFF, !- Name
1.639108268,                      !- Coefficient1 Constant
-0.998953996,                     !- Coefficient2 x
0.359845728,                      !- Coefficient3 x**2
0,                                   !- Minimum Value of x
1.5,                                !- Maximum Value of x
0,                                   !- Minimum Curve Output
2,                                   !- Maximum Curve Output
Dimensionless,                      !- Input Unit Type for X
Dimensionless;                      !- Output Unit Type

Curve:Quadratic,
HPHighStageCoolingCAPFFF,!- Name
0.618281092,                      !- Coefficient1 Constant
0.569060264,                      !- Coefficient2 x
-0.187341356,                     !- Coefficient3 x**2
0,                                   !- Minimum Value of x
1.5,                                !- Maximum Value of x

```

```

0,                               !- Minimum Curve Output
2,                               !- Maximum Curve Output
Dimensionless,                  !- Input Unit Type for X
Dimensionless;                  !- Output Unit Type

Curve:Quadratic,
HPHighStageCoolingEIRFFF,!- Name
1.570774717,                   !- Coefficient1 Constant
-0.914152018,                  !- Coefficient2 x
0.343377302,                   !- Coefficient3 x**2
0,                               !- Minimum Value of x
1.5,                            !- Maximum Value of x
0,                               !- Minimum Curve Output
2,                               !- Maximum Curve Output
Dimensionless,                  !- Input Unit Type for X
Dimensionless;                  !- Output Unit Type

Curve:Quadratic,
HP2StageCoolingPLFFPLR,!- Name
0.93,                           !- Coefficient1 Constant
0.07,                           !- Coefficient2 x
0.0,                            !- Coefficient3 x**2
0.0,                            !- Minimum Value of x
1.0;                            !- Maximum Value of x

Curve:Quadratic,
ACLowStageCoolingCAPFFF,!- Name
0.65673024,                     !- Coefficient1 Constant
0.516470835,                    !- Coefficient2 x
-0.172887149,                   !- Coefficient3 x**2
0,                               !- Minimum Value of x
1.5,                            !- Maximum Value of x
0,                               !- Minimum Curve Output
2,                               !- Maximum Curve Output
Dimensionless,                  !- Input Unit Type for X
Dimensionless;                  !- Output Unit Type

```

```

Curve:Quadratic ,
    ACLowStageCoolingEIRFFF , !- Name
    1.562945114 ,           !- Coefficient1 Constant
    -0.791859997 ,         !- Coefficient2 x
    0.230030877 ,          !- Coefficient3 x**2
    0 ,                      !- Minimum Value of x
    1.5 ,                    !- Maximum Value of x
    0 ,                      !- Minimum Curve Output
    2 ,                      !- Maximum Curve Output
    Dimensionless ,          !- Input Unit Type for X
    Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
    ACHighStageCoolingCAPFFF ,!- Name
    0.690334551 ,           !- Coefficient1 Constant
    0.464383753 ,           !- Coefficient2 x
    -0.154507638 ,          !- Coefficient3 x**2
    0 ,                      !- Minimum Value of x
    1.5 ,                    !- Maximum Value of x
    0 ,                      !- Minimum Curve Output
    2 ,                      !- Maximum Curve Output
    Dimensionless ,          !- Input Unit Type for X
    Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
    ACHighStageCoolingEIRFFF,!- Name
    1.31565404 ,            !- Coefficient1 Constant
    -0.482467162 ,          !- Coefficient2 x
    0.166239001 ,           !- Coefficient3 x**2
    0 ,                      !- Minimum Value of x
    1.5 ,                    !- Maximum Value of x
    0 ,                      !- Minimum Curve Output
    2 ,                      !- Maximum Curve Output
    Dimensionless ,          !- Input Unit Type for X
    Dimensionless;           !- Output Unit Type

```

```

Curve:Quadratic ,
    AC2StageCoolingPLFFPLR ,      !- Name
    0.93 ,                         !- Coefficient1 Constant
    0.07 ,                         !- Coefficient2 x
    0.0 ,                           !- Coefficient3 x**2
    0.0 ,                           !- Minimum Value of x
    1.0;                            !- Maximum Value of x

Curve:Quadratic ,
    Cool-PLF-fPLR ,              !- Name
    0.80141423 ,                 !- Coefficient1 Constant
    0.23744685 ,                 !- Coefficient2 x
    -0.0393773 ,                 !- Coefficient3 x**2
    0 ,                            !- Minimum Value of x
    1 ,                            !- Maximum Value of x
    0.7 ,                          !- Minimum Curve Output
    1;                            !- Maximum Curve Output

! - ===== ALL OBJECTS IN CLASS: CURVE:CUBIC =====

Curve:Cubic ,
    HPACHeatCapFT ,              !- Name
    0.758746 ,                   !- Coefficient1 Constant
    0.027626 ,                   !- Coefficient2 x
    0.000148716 ,                !- Coefficient3 x**2
    0.0000034992 ,               !- Coefficient4 x**3
    -20.0 ,                       !- Minimum Value of x
    20.0;                         !- Maximum Value of x

Curve:Cubic ,
    HPACHeatCapFFF ,             !- Name
    0.84 ,                        !- Coefficient1 Constant
    0.16 ,                        !- Coefficient2 x
    0.0 ,                          !- Coefficient3 x**2

```

```

0.0,                               !- Coefficient4 ***3
0.5,                               !- Minimum Value of x
1.5;                               !- Maximum Value of x

Curve:Cubic,
    HPACHeatEIRFT,                !- Name
    1.19248,                         !- Coefficient1 Constant
    -0.0300438,                      !- Coefficient2 x
    0.00103745,                      !- Coefficient3 ***2
    -0.000023328,                    !- Coefficient4 ***3
    -20.0,                            !- Minimum Value of x
    20.0;                            !- Maximum Value of x

Curve:Cubic,
    Fan-EIR-fPLR,                  !- Name
    0.00000000,                      !- Coefficient1 Constant
    1.00000000,                      !- Coefficient2 x
    0.00000000,                      !- Coefficient3 ***2
    0.00000000,                      !- Coefficient4 ***3
    0,                                !- Minimum Value of x
    1,                                !- Maximum Value of x
    0,                                !- Minimum Curve Output
    1;                                !- Maximum Curve Output

Curve:Cubic,
    ConstantCubic,                  !- Name
    1,                                !- Coefficient1 Constant
    0,                                !- Coefficient2 x
    0,                                !- Coefficient3 ***2
    0,                                !- Coefficient4 ***3
    -100,                             !- Minimum Value of x
    100;                             !- Maximum Value of x

!- ===== ALL OBJECTS IN CLASS: CURVE:BICUBIC
=====
```

```

!

Curve:Biquadratic,
    HPWH-Htg-Cap-fT,           ! - Name
    0.563,                      ! - Coefficient1 Constant
    0.0437,                     ! - Coefficient2 x
    0.000039,                   ! - Coefficient3 x**2
    0.0055,                     ! - Coefficient4 y
    -.000148,                   ! - Coefficient5 y**2
    -.000145,                   ! - Coefficient6 x*y
    0,                           ! - Minimum Value of x
    100,                         ! - Maximum Value of x
    0,                           ! - Minimum Value of y
    100,                         ! - Maximum Value of y
    0;                           ! - Minimum Curve Output

Curve:Biquadratic,
    HPWH-Htg-COP-fT,           ! - Name
    1.1332,                     ! - Coefficient1 Constant
    0.063,                      ! - Coefficient2 x
    -.0000979,                  ! - Coefficient3 x**2
    -.00972,                    ! - Coefficient4 y
    -.0000214,                  ! - Coefficient5 y**2
    -.000686,                   ! - Coefficient6 x*y
    0,                           ! - Minimum Value of x
    100,                         ! - Maximum Value of x
    0,                           ! - Minimum Value of y
    100;                        ! - Maximum Value of y

Curve:Biquadratic,
    HPWHHeatingCapFTemp,        ! - Name
    0.369827,                   ! - Coefficient1 Constant
    0.043341,                   ! - Coefficient2 x
    -.000023,                   ! - Coefficient3 x**2
    0.000466,                   ! - Coefficient4 y
    0.000026,                   ! - Coefficient5 y**2

```

```

-0.00027 ,                               !- Coefficient6 x*y
0.0 ,                                     !- Minimum Value of x
40.0 ,                                    !- Maximum Value of x
20.0 ,                                    !- Minimum Value of y
90.0 ,                                    !- Maximum Value of y
,                                         !- Minimum Curve Output
,                                         !- Maximum Curve Output
Temperature ,                            !- Input Unit Type for X
Temperature ,                            !- Input Unit Type for Y
Dimensionless;                           !- Output Unit Type

Curve:Biquadratic ,
HPWHHeatingCOPFTemp ,                  !- Name
1.19713 ,                                !- Coefficient1 Constant
0.077849 ,                               !- Coefficient2 x
-0.0000016 ,                             !- Coefficient3 x**2
-0.02675 ,                               !- Coefficient4 y
0.000296 ,                               !- Coefficient5 y**2
-0.00112 ,                               !- Coefficient6 x*y
0.0 ,                                     !- Minimum Value of x
40.0 ,                                    !- Maximum Value of x
20.0 ,                                    !- Minimum Value of y
90.0 ,                                    !- Maximum Value of y
,                                         !- Minimum Curve Output
,                                         !- Maximum Curve Output
Temperature ,                            !- Input Unit Type for X
Temperature ,                            !- Input Unit Type for Y
Dimensionless;                           !- Output Unit Type

Curve:Biquadratic ,
HPACCoolCapFT ,                          !- Name
0.766956 ,                               !- Coefficient1 Constant
0.0107756 ,                             !- Coefficient2 x
-0.0000414703 ,                         !- Coefficient3 x**2
0.00134961 ,                            !- Coefficient4 y
-0.000261144 ,                           !- Coefficient5 y**2

```

```

0.000457488 ,                               !- Coefficient6 x*y
12.77778 ,                                 !- Minimum Value of x
23.88889 ,                                 !- Maximum Value of x
21.11111 ,                                 !- Minimum Value of y
46.11111;                                  !- Maximum Value of y

Curve:Biquadratic ,
HPACCOOLEIRFT ,                           !- Name
0.297145 ,                                !- Coefficient1 Constant
0.0430933 ,                               !- Coefficient2 x
-0.000748766 ,                            !- Coefficient3 ***2
0.00597727 ,                             !- Coefficient4 y
0.000482112 ,                            !- Coefficient5 y**2
-0.000956448 ,                           !- Coefficient6 x*y
12.77778 ,                                !- Minimum Value of x
23.88889 ,                                !- Maximum Value of x
21.11111 ,                                !- Minimum Value of y
46.11111;                                  !- Maximum Value of y

Curve:Biquadratic ,
Defrost_EIR_FT ,                           !- Name
1 ,                                       !- Coefficient1 Constant
0 ,                                       !- Coefficient2 x
0 ,                                       !- Coefficient3 ***2
0 ,                                       !- Coefficient4 y
0 ,                                       !- Coefficient5 y**2
0 ,                                       !- Coefficient6 x*y
0 ,                                       !- Minimum Value of x
100 ,                                      !- Maximum Value of x
0 ,                                       !- Minimum Value of y
100;                                      !- Maximum Value of y

! This is a dummy waste heat function of temp curve required for the
! multispeed coils. The curve is set as a constant curve that would
! yield
! a factor of 1 at all temperatures for simplicity.

```

```

! However, this curve is not used if the fuel type is electricity (
which is

! what we limit ourselves to in terms of multispeed DX equipment)

per

! the E+ version 8.0 I/O reference Page 1301.

Curve:Biquadratic,
    dummy-waste-heat-curve,      ! - Name
    1,                            ! - Coefficient1 Constant
    0,                            ! - Coefficient2 x
    0,                            ! - Coefficient3 x**2
    0,                            ! - Coefficient4 y
    0,                            ! - Coefficient5 y**2
    0,                            ! - Coefficient6 x*y
    0,                            ! - Minimum Value of x
    50,                           ! - Maximum Value of x
    0,                            ! - Minimum Value of y
    50,                           ! - Maximum Value of y
    1,                            ! - Minimum Curve Output
    1,                            ! - Maximum Curve Output
    Dimensionless,               ! - Input Unit Type for X
    Dimensionless,               ! - Input Unit Type for Y
    Dimensionless;              ! - Output Unit Type

!
!
!
!

Curve:Biquadratic,
    ACCoolingCAPFTemp,          ! - Name
    1.5509,                     ! - Coefficient1 Constant
    -0.07505,                   ! - Coefficient2 x
    0.0031,                     ! - Coefficient3 x**2
    0.0024,                     ! - Coefficient4 y
    -0.00005,                   ! - Coefficient5 y**2
    -0.00043,                   ! - Coefficient6 x*y
    0,                            ! - Minimum Value of x

```

```

50,                                     ! - Maximum Value of x
0,                                      ! - Minimum Value of y
50,                                     ! - Maximum Value of y
0,                                      ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
ACCoolingEIRFTemp,                     ! - Name
-0.30428,                               ! - Coefficient1 Constant
0.11805,                                ! - Coefficient2 x
-0.00342,                               ! - Coefficient3 x**2
-0.00626,                               ! - Coefficient4 y
0.0007,                                 ! - Coefficient5 y**2
-0.00047,                               ! - Coefficient6 x*y
0,                                       ! - Minimum Value of x
50,                                      ! - Maximum Value of x
0,                                       ! - Minimum Value of y
50,                                      ! - Maximum Value of y
0,                                       ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPCoolingCAPFTemp,                     ! - Name
1.55736,                                ! - Coefficient1 Constant
-0.074448,                              ! - Coefficient2 x
0.003099,                               ! - Coefficient3 x**2
0.00146,                                 ! - Coefficient4 y
-0.000041,                               ! - Coefficient5 y**2
-0.000427,                               ! - Coefficient6 x*y
0,                                       ! - Minimum Value of x

```

```

50,                                     ! - Maximum Value of x
0,                                      ! - Minimum Value of y
50,                                     ! - Maximum Value of y
0,                                      ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPCoolingEIRFTemp,                    ! - Name
-0.350448,                             ! - Coefficient1 Constant
0.11681,                               ! - Coefficient2 x
-0.0034,                                ! - Coefficient3 x**2
-0.001226,                             ! - Coefficient4 y
0.000601,                               ! - Coefficient5 y**2
-0.000467,                             ! - Coefficient6 x*y
0,                                      ! - Minimum Value of x
50,                                     ! - Maximum Value of x
0,                                      ! - Minimum Value of y
50,                                     ! - Maximum Value of y
0,                                      ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPHeatingCAPFTemp,                     ! - Name
0.876825,                              ! - Coefficient1 Constant
-0.002955,                             ! - Coefficient2 x
-0.000058,                             ! - Coefficient3 x**2
0.025335,                               ! - Coefficient4 y
0.000196,                               ! - Coefficient5 y**2
-0.000043,                             ! - Coefficient6 x*y
0,                                      ! - Minimum Value of x

```

```

50,                                     ! - Maximum Value of x
0,                                      ! - Minimum Value of y
50,                                     ! - Maximum Value of y
0,                                      ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPHeatingEIRFTemp,                     ! - Name
0.704658,                               ! - Coefficient1 Constant
0.008767,                               ! - Coefficient2 x
0.000625,                               ! - Coefficient3 x**2
-0.009037,                             ! - Coefficient4 y
0.000738,                               ! - Coefficient5 y**2
-0.001025,                             ! - Coefficient6 x*y
0,                                       ! - Minimum Value of x
50,                                      ! - Maximum Value of x
0,                                       ! - Minimum Value of y
50,                                      ! - Maximum Value of y
0,                                       ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPLowStageHeatingCAPFTemp,   ! - Name
0.84613,                                ! - Coefficient1 Constant
-0.002279,                              ! - Coefficient2 x
-0.000047,                              ! - Coefficient3 x**2
0.026703,                               ! - Coefficient4 y
0.000201,                               ! - Coefficient5 y**2
-0.000079,                             ! - Coefficient6 x*y
0,                                       ! - Minimum Value of x

```

```

50,                                     !- Maximum Value of x
0,                                      !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                      !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPLowStageHeatingEIRFTemp,   !- Name
0.551837,                               !- Coefficient1 Constant
0.02038,                                !- Coefficient2 x
0.000546,                               !- Coefficient3 x**2
-0.009638,                              !- Coefficient4 y
0.000785,                               !- Coefficient5 y**2
-0.00125,                               !- Coefficient6 x*y
0,                                       !- Minimum Value of x
50,                                      !- Maximum Value of x
0,                                       !- Minimum Value of y
50,                                      !- Maximum Value of y
0,                                       !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPHighStageHeatingCAPFTemp,  !- Name
0.818223,                               !- Coefficient1 Constant
0.001981,                                !- Coefficient2 x
-0.000203,                              !- Coefficient3 x**2
0.028703,                               !- Coefficient4 y
0.000207,                               !- Coefficient5 y**2
-0.000071,                              !- Coefficient6 x*y
0,                                       !- Minimum Value of x

```

```

50,                                     ! - Maximum Value of x
0,                                      ! - Minimum Value of y
50,                                     ! - Maximum Value of y
0,                                      ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPHighStageHeatingEIRFTemp,   ! - Name
0.81584,                                ! - Coefficient1 Constant
-0.00615,                                ! - Coefficient2 x
0.001021,                                ! - Coefficient3 x**2
-0.001301,                                ! - Coefficient4 y
0.001083,                                ! - Coefficient5 y**2
-0.001487,                                ! - Coefficient6 x*y
0,                                         ! - Minimum Value of x
50,                                        ! - Maximum Value of x
0,                                         ! - Minimum Value of y
50,                                        ! - Maximum Value of y
0,                                         ! - Minimum Curve Output
5,                                           ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
HPLowStageCoolingCAPFTemp,   ! - Name
1.658788,                                ! - Coefficient1 Constant
-0.083453,                                ! - Coefficient2 x
0.003424,                                ! - Coefficient3 x**2
0.002433,                                ! - Coefficient4 y
-0.000045,                                ! - Coefficient5 y**2
-0.000534,                                ! - Coefficient6 x*y
0,                                         ! - Minimum Value of x

```

```

50,                                     !- Maximum Value of x
0,                                      !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                      !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPLowStageCoolingEIRFTemp,   !- Name
-0.582916,                           !- Coefficient1 Constant
0.158101,                            !- Coefficient2 x
-0.004398,                           !- Coefficient3 x**2
-0.020335,                           !- Coefficient4 y
0.00108,                             !- Coefficient5 y**2
-0.00064,                            !- Coefficient6 x*y
0,                                     !- Minimum Value of x
50,                                    !- Maximum Value of x
0,                                     !- Minimum Value of y
50,                                    !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                      !- Maximum Curve Output
Temperature,                           !- Input Unit Type for X
Temperature,                           !- Input Unit Type for Y
Dimensionless;                        !- Output Unit Type

Curve:Biquadratic,
HPHighStageCoolingCAPFTemp,  !- Name
1.472738,                            !- Coefficient1 Constant
-0.067222,                           !- Coefficient2 x
0.00292,                            !- Coefficient3 x**2
0.000052,                            !- Coefficient4 y
-0.00003,                           !- Coefficient5 y**2
-0.000359,                           !- Coefficient6 x*y
0,                                     !- Minimum Value of x

```

```

50,                                     !- Maximum Value of x
0,                                      !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                      !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPHighStageCoolingEIRFTemp,   !- Name
-0.488196,                           !- Coefficient1 Constant
0.099162,                            !- Coefficient2 x
-0.00237,                            !- Coefficient3 x**2
0.019503,                            !- Coefficient4 y
0.00043,                             !- Coefficient5 y**2
-0.001097,                           !- Coefficient6 x*y
0,                                     !- Minimum Value of x
50,                                    !- Maximum Value of x
0,                                     !- Minimum Value of y
50,                                    !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                      !- Maximum Curve Output
Temperature,                           !- Input Unit Type for X
Temperature,                           !- Input Unit Type for Y
Dimensionless;                        !- Output Unit Type

Curve:Biquadratic,
ACLowStageCoolingCAPFTemp,  !- Name
1.66458,                            !- Coefficient1 Constant
-0.08039,                           !- Coefficient2 x
0.0033,                             !- Coefficient3 x**2
0.00124,                            !- Coefficient4 y
-0.00003,                           !- Coefficient5 y**2
-0.00052,                           !- Coefficient6 x*y
0,                                     !- Minimum Value of x

```

```

50,                                     !- Maximum Value of x
0,                                      !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                      !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
ACLowStageCoolingEIRFTemp,   !- Name
-0.42738,                                !- Coefficient1 Constant
0.14191,                                 !- Coefficient2 x
-0.00412,                                !- Coefficient3 x**2
-0.01406,                                !- Coefficient4 y
0.00083,                                 !- Coefficient5 y**2
-0.00043,                                !- Coefficient6 x*y
0,                                         !- Minimum Value of x
50,                                        !- Maximum Value of x
0,                                         !- Minimum Value of y
50,                                        !- Maximum Value of y
0,                                         !- Minimum Curve Output
5,                                          !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
ACHighStageCoolingCAPFTemp,  !- Name
1.36788,                                 !- Coefficient1 Constant
-0.06257,                                !- Coefficient2 x
0.0028,                                  !- Coefficient3 x**2
0.00504,                                 !- Coefficient4 y
-0.00007,                                !- Coefficient5 y**2
-0.00045,                                !- Coefficient6 x*y
0,                                         !- Minimum Value of x

```

```

50,                                     ! - Maximum Value of x
0,                                      ! - Minimum Value of y
50,                                     ! - Maximum Value of y
0,                                      ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
ACHighStageCoolingEIRFTemp,   ! - Name
0.04232,                                ! - Coefficient1 Constant
0.07892,                                ! - Coefficient2 x
-0.00238,                               ! - Coefficient3 x**2
-0.00304,                               ! - Coefficient4 y
0.00053,                                ! - Coefficient5 y**2
-0.00032,                               ! - Coefficient6 x*y
0,                                       ! - Minimum Value of x
50,                                      ! - Maximum Value of x
0,                                       ! - Minimum Value of y
50,                                      ! - Maximum Value of y
0,                                       ! - Minimum Curve Output
5,                                       ! - Maximum Curve Output
Temperature,                            ! - Input Unit Type for X
Temperature,                            ! - Input Unit Type for Y
Dimensionless;                         ! - Output Unit Type

Curve:Biquadratic,
Cool-Cap-fT,                           ! - Name
1.26489391,                            ! - Coefficient1 Constant
-0.035054982,                           ! - Coefficient2 x
0.00211086,                            ! - Coefficient3 x**2
-0.001526886,                           ! - Coefficient4 y
-0.0000070308,                          ! - Coefficient5 y**2
-0.0004691844,                           ! - Coefficient6 x*y
-100,                                     ! - Minimum Value of x

```

```

100,                                     ! - Maximum Value of x
-100,                                     ! - Minimum Value of y
100;                                      ! - Maximum Value of y

Curve:Biquadratic,
  Cool-EIR-fT,                           ! - Name
  0.38402403,                            ! - Coefficient1 Constant
  0.029696724,                           ! - Coefficient2 x
  -0.0011329308,                         ! - Coefficient3 x**2
  0.006490674,                           ! - Coefficient4 y
  0.0002626992,                           ! - Coefficient5 y**2
  -0.0001207224,                          ! - Coefficient6 x*y
  -100,                                    ! - Minimum Value of x
  100,                                     ! - Maximum Value of x
  -100,                                    ! - Minimum Value of y
  100;                                     ! - Maximum Value of y

! - ===== ALL OBJECTS IN CLASS: OUTPUT:VARIABLEDICTIONARY
=====

Output:VariableDictionary,
  IDF;                                     ! - Key Field
Output:Surfaces:Drawing, DXF;

! - ===== ALL OBJECTS IN CLASS: OUTPUT:VARIABLE =====

Output:Variable,
  *,                                         ! - Key Value
  Site Outdoor Air Drybulb Temperature,   ! - Variable Name
  hourly;                                    ! - Reporting Frequency

Output:Variable,
  *,                                         ! - Key Value
  Zone Air Temperature,        ! - Variable Name

```

```

hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value
Zone Air Relative Humidity,  !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value
Zone Mean Radiant Temperature,  !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value
Zone Thermostat Cooling Setpoint Temperature,  !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value
Zone Thermal Comfort Pierce Model Standard Effective Temperature
,  !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value
Facility Total Building Electricity Demand Rate,  !- Variable
Name
hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value
Facility Total HVAC Electricity Demand Rate,  !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,             !- Key Value

```

```

Facility Total Electricity Demand Rate,  !- Variable Name
hourly;                                !- Reporting Frequency

! GPARAM parameters as run:
!
! ID = US+SF+CZ1AWH+hp+slab+IECC_2021
! weatherfile = USA_FL_Miami.Intl.AP.722020_TMY3.epw
! climate_zone = 1
! moisture_regime = A
! humidity_designation = WH
! tropical_designation =
! bldg_type = Single-Family
! fndn_type = slab
! system_tag = Heat Pump
! code = IECC_2021
! permits = 21846.545507574
! vent_fan_efficiency = 2.8
! cfm25 = 4
! afn_control = MultizoneWithDistribution
! is_duct_base = no
! leakage_ratio = 0.0792
! dhw_type = heatpump
! TEMPLATE_PATH = template/v9.5

! Default values:
!
! ach50 = 5
! afue = 1
! heating_coil =
! heating_fuel = electricity
! hspf =
! leakage_ratio = 0.0792
! seer =
! system = heatpump
! ua_si = 2.07415438466871

! GPARAM computed values:
!
! cfa_per_unit = 2376

```

```

!    efficacy_ratio_cfl = 0.272727272727273
!
!    efficacy_ratio_inc = 1
!
!    efficacy_ratio_led = 0.230769230769231
!
!    efficacy_ratio_lf = 0.170454545454545
!
!    ela = 92.3292232734708
!
!    f_cfl_hw = 0.2
!
!    f_inc_hw = 0
!
!    f_led_hw = 0.8
!
!    f_lf_hw = 0
!
!    gtp_filename =
!
!    internal_gains = 86760.8
!
!    internal_gains_W = 1059.19523390956
!
!    internal_gains_kWhyr = 9278.55024904776
!
!    long_dim =
!
!    ltg_exterior = 189.401978076923
!
!    ltg_exterior_benchmark = 344.52
!
!    ltg_garage = 21.9902447552448
!
!    ltg_garage_benchmark = 40
!
!    ltg_hardwired = 713.272060441958
!
!    ltg_hw_benchmark = 1297.4336
!
!    ltg_plugin = 324.3584
!
!    ltg_plugin_benchmark = 324.3584
!
!    n_bedrooms = 3
!
!    n_ppl = 3
!
!    short_dim =
!
!    window_area = 355.236927696469

!
! Code requirements: IECC_2021
!
!    r_bsmtwall = 0
!
!    r_ceiling = 30
!
!    r_crawlwall = 0
!
!    r_floor = 13
!
!    r_masswall = 3
!
!    r_sheathing = 0
!
!    r_slab = 0
!
!    r_wall = 13

```

```

!     shgc_skylight = 0.25
!     shgc_window = 0.25
!     u_skylight = 0.75
!     u_window = 0.5
!
! GPARM parameters as run:
!
!     ID = US+SF+CZ1AWH+hp+slab+IECC_2021
!     weatherfile = USA_FL_Miami.Intl.AP.722020_TMY3.epw
!     climate_zone = 1
!     moisture_regime = A
!     humidity_designation = WH
!     tropical_designation =
!     bldg_type = Single-Family
!     fndn_type = slab
!     system_tag = Heat Pump
!     code = IECC_2021
!     permits = 21846.545507574
!     vent_fan_efficiency = 2.8
!     cfm25 = 4
!     afn_control = MultizoneWithDistribution
!     is_duct_base = no
!     leakage_ratio = 0.0792
!     dhw_type = heatpump
!
!     TEMPLATE_PATH = template/v9.5

!
! =====
!
!             Report on template variables
!
! -----
!
! Variables changed in template:
! -----
!
! CHILD_ERROR:   '-1' --> '0'
! ERRNO:   'Inappropriate ioctl for device' --> ''
! EXTENDED_OS_ERROR:  'Inappropriate ioctl for device' --> ''
! LIST_SEPARATOR:   ' ' --> ','
! OS_ERROR:   'Inappropriate ioctl for device' --> ''

```

```

! climate_zone:  'Climate Zone 1' --> '1'
! dhw_type:    '' --> 'heatpump'
! fndn_type:   'Slab' --> 'slab'
! humidity_designation: 'Warm-Humid' --> 'WH'
! moisture_regime: 'Moist' --> 'A'
! tropical_designation: 'Not Tropical' --> ''
! vent_fan_efficiency: '1.4' --> '2.8'
!
! -----
! New variables created in template:
! -----
!
! LPD_hardwired:  '1.05216214401829'
! LPD_plugin:    '0.478467682251396'
! SAF:          '1'
! SAF_ext:       '1'
! SAF_gar:       '1'
! S_overhang:    '0.0152439024390244'
! S_overhang_pf: '0.01'
! ach50:         '5'
! afue:          '1'
! aspect_ratio:  '1.333333333333333'
! atticvent:     '0.37'
! atticvent_cm2: '3700'
! bare_masonry:  'no'
! base_watts:    '400'
! bath_gpm:      '4.4'
! bath_peak_flow: '0.00027764'
! bldg_azimuth:  '0'
! branch_tag:    'AirLoopHVAC:UnitaryHeatPump:AirToAir'
! ceil_area:     '110.408921933086'
! ceil_insulation: 'fiberglass_blown'
! ceiling_framing_fraction: '0.07'
! ceiling_ht:    '2.59146341463415'
! cfa_per_unit:  '2376'
! cfa_per_unit_sqmt: '220.817843866171'

```

```

! cfa_total:    '2376'
! cfa_total_sqmt:   '220.817843866171'
! clotheswasher_peak_flow:   '1.6219189818e-06'
! concrete_density:   '135'
! cond_crawlspacel:  'no'
! conv_accel_limit:  '0'
! cooling_setpt:    '75'
! cop_cooling:     '4.06853019625951'
! cop_heating:     '3.69308080013886'
! crawlvent:       '0.37'
! daily_bath_gal:   '6'
! daily_shower_gal: '23.9'
! daily_sink_gal:   '21.1'
! dday_sched_type:  'annual'
! dhw_heater_control:  'Cycle'
! dhw_heater_eff:    '1'
! dhw_multiplier:    '0.897'
! dhw_pipe_const:    'Insulated pipe'
! dhw_pipe_loc_unit: 'living_unit1'
! dhw_savings_factor: '0.103'
! dhw_savings_mult:  '1'
! dhw_setpt_sch:     'dhw_setpt_hpwh'
! dhw_source_fuel:   'electricity'
! dhw_tank_loss_SI:  '0.730336050939686'
! dhw_tank_size:     '52'
! dhw_tank_size_SI:  '0.196841372'
! dishwasher_peak_flow:  '6.36685353e-07'
! door_area:        '3.71747211895911'
! door_ht:          '2.13414634146341'
! door_ldb_l:        '1.74190122145513'
! door_t:           '0.0253617440918536'
! duct_loc:          'attic'
! ef:               '2'
! efficacy_ratio_cfl:  '0.272727272727273'
! efficacy_ratio_inc: '1'
! efficacy_ratio_led: '0.230769230769231'

```

```

! efficacy_ratio_lf:  '0.17045454545454545',
! ela:  '92.3292232734708',
! ela_ceil:  '0.019898999363395',
! ela_floor:  '0.019898999363395',
! ela_longdim_wall:  '0.00566687461767392',
! ela_shortdim_wall:  '0.00425015596325544',
! ela_sqcm:  '595.671216871124',
! ela_sqm:  '0.0595671216871124',
! erv:  'no'
! estar_appl:  'none'
! ext_ltg_control:  ''
! ext_ltg_sch:  'ExteriorLighting'
! ext_wall_type:  'wood_framed'
! f_cfl_ext:  '0.2'
! f_cfl_gar:  '0.2'
! f_cfl_hw:  '0.2'
! f_inc_ext:  '0'
! f_inc_gar:  '0'
! f_inc_hw:  '0'
! f_led_ext:  '0.8'
! f_led_gar:  '0.8'
! f_led_hw:  '0.8'
! f_lf_ext:  '0'
! f_lf_gar:  '0'
! f_lf_hw:  '0'
! facade_watts:  '63.975'
! fan_eff:  '0.58'
! fan_power_per_ton:  '112'
! fan_total_eff:  '0.50054'
! floor_area:  '110.408921933086'
! fndn_zone:  'living'
! fndn_zone_unit:  'living_unit1'
! force_other_fndn_R0:  'yes'
! foundn_depth:  '0'
! fraction_ceil_under_attic:  '0.7'
! framing:  'hardwood'

```

```

! furred_framing_fraction:  '0.25'
! gain_pp1:  '2120.48051567536'
! gar_ltg_sch:  'InteriorLightingHE'
! garage_area:  '400'
! grout_cell_spacing:  '96'
! gtp_filename:  ''
! gtp_ref_floor:  'GroundSlabPreprocessorAverage'
! gtp_ref_floor_obj:  'surfProp0thSdCoefSlabAverage'
! has_ext_ltg_control:  'no'
! has_occ_sensors:  'no'
! has_ventilation:  'yes'
! heat_avail_sched:  'always_avail'
! heating_coil:  'electric'
! heating_fuel:  'electricity'
! heating_setpt:  '72'
! hers_dhw_gains_W:  '1.04420541093893'
! hourly_output:  'No'
! house:  'sitebuilt'
! hrv:  'no'
! hrv_aval:  'always_off'
! hrv_sensible_eff:  '0.65'
! hspf:  '8.2'
! hvac_type:  'heatpump'
! hw_ltg_sch:  'InteriorLightingHE'
! iecc_mels_adj_W_m2:  '1.54356736989469'
! iecc_mels_adj_kWhyr:  '1515.4067333724'
! ins_sheathing:  'eps'
! insulation_loc:  'exterior'
! is_HRef:  'no'
! is_HRtd:  'no'
! is_ISRD:  'yes'
! long_dim:  '12.1330909462833'
! longdim_wall_area:  '31.4424612937218'
! ltg_exterior:  '189.401978076923'
! ltg_exterior_W:  '43.2424607481559'
! ltg_exterior_benchmark:  '344.52'

```

```

! ltg_garage:    '21.9902447552448'
! ltg_garage_W:   '7.16294617434682'
! ltg_garage_benchmark:  '40'
! ltg_hardwired:  '713.272060441958'
! ltg_hw_benchmark:  '1297.4336'
! ltg_plugin:     '324.3584'
! ltg_plugin_benchmark:  '324.3584'
! max_dhw_temp:   '51'
! max_supply:     '0.56034'
! misc_eqpmt2_type:  'ElectricEquipment'
! motor_eff:      '0.863'
! my_coil_type:   'Coil:Cooling:DX:SingleSpeed'
! my_coil_type_heating:  'Coil:Heating:DX:SingleSpeed'
! n_bedrooms:     '3'
! n_doors:        '1'
! n_ppl:          '3'
! n_stories_per_unit:  '2'
! n_units:         '1'
! n_units_modeled:  '1'
! option:          ''
! p:               '5118'
! parkinglot_watts:  '793.72'
! pipe_ins_R:      '2'
! pipe_ins_k_SI:   '0.03317175'
! pipe_ins_thickness_SI:  '0.0127032520325203'
! plugin_ltg_sch:  'InteriorLightingHE'
! plugload_usage_factor:  '0.67553'
! prototype:       'singlefamily'
! r_bsmtwall:     '0.0001'
! r_ceiling:      '30'
! r_crawlwall:    '0'
! r_duct:          '8'
! r_fiberglass_blown:  '2.5'
! r_floor:         '0'
! r_masswall:     '3'
! r_returnduct:   '8'

```

```

! r_sheathing:   '0'
! r_slab:      '0'
! r_wall:      '13'
! re:          '2.75'
! return_duct_loc:  'attic'
! return_duct_loc_unit: 'attic_unit1'
! roof_const:    'Gable_end'
! roof_pitch:    '0.3333333333333333'
! roof_pk_ht:    '1.51663636828541'
! roof_surface:   'Wall'
! runbsmt:       'no'
! runslab:       'yes'
! seer:          '14'
! semi_conditioned: 'no'
! sensitivity_analysis: 'no'
! shading_frac:   '0'
! shgc_skylight:  '0.25'
! shgc_window:    '0.25'
! short_dim:      '9.09981820971244'
! shortdim_wall_area: '23.5818459702914'
! shower_gpm:     '2.25'
! shower_peak_flow: '0.000141975'
! sink_gpm:       '1.14'
! sink_peak_flow: '7.1934e-05'
! source_inlet_node: 'Condenser water outlet node_unit1'
! source_outlet_node: 'Condenser water inlet node_unit1'
! stack_coeff:    '0.00029'
! statfile:        'USA_FL_Miami.Intl.AP.722020_TMY3.stat'
! style_ceiling:   'attic'
! style_roof:      'gable'
! supply_duct_loc: 'attic'
! supply_duct_loc_unit: 'attic_unit1'
! supply_leak_ratio_of_total: '0.5'
! system:          'heatpump'
! temp_vent_cms:   '0'
! thermostat_setpt: 'iecc'

```

```

! total_area:    '330.506150989138'
! u_door:      '0.5'
! u_duct_SI:    '0.709825'
! u_returnduct_SI:  '0.709825'
! u_skylight:   '0.75'
! u_window:     '0.5'
! ua:          '3.93819693017048'
! ua_si:        '2.07415438466871'
! unit_id:      '1'
! vent_cfm:     '60'
! vent_clearance: '0.0101'
! vent cms:     '0.0283168464628752'
! vent_fan_prs:  '227.022858530508'
! vent_fan_total_eff: '0.6'
! vent_sch:      'always_avail'
! wall_framing_fraction: '0.25'
! wall_ht:       '8.5'
! waterheater_loc_unit: 'living_unit1'
! weatherdir:    './tools/epw/'
! wind_coeff:    '0.000231'
! window_dist:   'equal'
! window_ht:     '1.52439024390244'
! window_ldb_1:   '2.70719591738945'
! window_ldf_1:   '2.70719591738945'
! window_sdl_1:   '2.70719591738945'
! window_sdr_1:   '2.70719591738945'
! wwr:          '0.15'
!
! =====

```

same idf as the one above with battery and PV system implemented.

## D.2 MIAMIPNNLB5PV90opt idf

```
!- Darwin Line endings

Version,
 9.5;                                !- Version Identifier

SimulationControl,
  Yes,                                  !- Do Zone Sizing Calculation
  Yes,                                  !- Do System Sizing Calculation
  No,                                   !- Do Plant Sizing Calculation
  Yes,                                  !- Run Simulation for Sizing Periods
  Yes,                                  !- Run Simulation for Weather File Run
  Periods
  ,                                     !- Do HVAC Sizing Simulation for
  Sizing Periods
  ;                                     !- Maximum Number of HVAC Sizing
  Simulation Passes

Building,
  US+SF+CZ1AWH+hp+slab+IECC_2021,      !- Name
  0,                                     !- North Axis
  Suburbs,                               !- Terrain
  0.04,                                  !- Loads Convergence Tolerance Value
  0.4,                                   !- Temperature Convergence Tolerance
  Value
  FullExterior,                         !- Solar Distribution
  25,                                    !- Maximum Number of Warmup Days
  6;                                     !- Minimum Number of Warmup Days

SurfaceConvectionAlgorithm:Inside,
  TARP;                                  !- Algorithm

Timestep,
  6;                                     !- Number of Timesteps per Hour
```

```

Site:Location ,
  Miami Intl Ap_FL_USA Design_Conditions ,      !- Name
  25.82 ,                               !- Latitude
  -80.3 ,                                !- Longitude
  -5 ,                                    !- Time Zone
  11;                                     !- Elevation

SizingPeriod:DesignDay ,
  Miami Intl Ap Ann Htg 99.6% Condns DB ,      !- Name
  1 ,                                      !- Month
  21 ,                                     !- Day of Month
  WinterDesignDay ,                      !- Day Type
  8.7 ,                                    !- Maximum DryBulb Temperature
  0 ,                                       !- Daily DryBulb Temperature Range
  DefaultMultipliers ,                  !- DryBulb Temperature Range Modifier
  Type
  ,                                         !- DryBulb Temperature Range Modifier
  Day Schedule Name
  Wetbulb ,                                !- Humidity Condition Type
  8.7 ,                                    !- Wetbulb or DewPoint at Maximum
  DryBulb
  ,                                         !- Humidity Condition Day Schedule
  Name
  ,                                         !- Humidity Ratio at Maximum DryBulb
  ,                                         !- Enthalpy at Maximum DryBulb
  ,                                         !- Daily WetBulb Temperature Range
  101193 ,                                 !- Barometric Pressure
  3.8 ,                                    !- Wind Speed
  340 ,                                    !- Wind Direction
  No ,                                     !- Rain Indicator
  No ,                                     !- Snow Indicator
  No ,                                    !- Daylight Saving Time Indicator
  ASHRAEClearSky ,                      !- Solar Model Indicator
  ,                                         !- Beam Solar Day Schedule Name
  ,                                         !- Diffuse Solar Day Schedule Name
  ,                                         !- ASHRAE Clear Sky Optical Depth for

```

```

Beam Irradiance taub
,
                               !- ASHRAE Clear Sky Optical Depth for

Diffuse Irradiance taud
0;                                !- Sky Clearness

SizingPeriod:DesignDay ,
Miami Intl Ap Ann Clg .4% Condns DB=>MWB ,      !- Name
7,                                !- Month
21,                                !- Day of Month
SummerDesignDay,                  !- Day Type
33.2,                                !- Maximum DryBulb Temperature
6.7,                                !- Daily DryBulb Temperature Range
DefaultMultipliers,                !- DryBulb Temperature Range Modifier
Type
,
                               !- DryBulb Temperature Range Modifier

Day Schedule Name
Wetbulb,                            !- Humidity Condition Type
25.3,                                !- Wetbulb or DewPoint at Maximum

DryBulb
,
                               !- Humidity Condition Day Schedule

Name
,
                               !- Humidity Ratio at Maximum DryBulb
,
                               !- Enthalpy at Maximum DryBulb
,
                               !- Daily WetBulb Temperature Range
101193,                                !- Barometric Pressure
4.5,                                !- Wind Speed
140,                                !- Wind Direction
No,                                 !- Rain Indicator
No,                                 !- Snow Indicator
No,                                 !- Daylight Saving Time Indicator
ASHRAETau,                            !- Solar Model Indicator
,
                               !- Beam Solar Day Schedule Name
,
                               !- Diffuse Solar Day Schedule Name
0.528,                                !- ASHRAE Clear Sky Optical Depth for

Beam Irradiance taub
1.905;                                !- ASHRAE Clear Sky Optical Depth for

```

```

Diffuse Irradiance taud

RunPeriod,
    annual,                               !- Name
    7,                                     !- Begin Month
    12,                                    !- Begin Day of Month
    ,                                       !- Begin Year
    8,                                     !- End Month
    15,                                    !- End Day of Month
    ,                                       !- End Year
    Sunday,                                 !- Day of Week for Start Day
    Yes,                                    !- Use Weather File Holidays and
Special Days
    Yes,                                   !- Use Weather File Daylight Saving
Period
    No,                                     !- Apply Weekend Holiday Rule
    Yes,                                    !- Use Weather File Rain Indicators
    Yes;                                    !- Use Weather File Snow Indicators

Site:WaterMainsTemperature,
    Correlation,                           !- Calculation Method
    ,                                      !- Temperature Schedule Name
    24.4916666666667,                     !- Annual Average Outdoor Air
Temperature
    8.7;                                   !- Maximum Difference In Monthly
Average Outdoor Air Temperatures

ScheduleTypeLimits,
    any number;                            !- Name

ScheduleTypeLimits,
    On/Off,                                !- Name
    0,                                      !- Lower Limit Value
    1,                                      !- Upper Limit Value
    Discrete;                               !- Numeric Type

```

```

ScheduleTypeLimits ,
control_type ,                               !- Name
0 ,                                         !- Lower Limit Value
4 ,                                         !- Upper Limit Value
Discrete;                                    !- Numeric Type

ScheduleTypeLimits ,
fraction ,                                 !- Name
0 ,                                         !- Lower Limit Value
1 ,                                         !- Upper Limit Value
Continuous;                                !- Numeric Type

ScheduleTypeLimits ,
Temperature ,                                !- Name
-60 ,                                       !- Lower Limit Value
200 ,                                       !- Upper Limit Value
Continuous;                                !- Numeric Type

ScheduleTypeLimits ,
Fractional ,                                !- Name
0 ,                                         !- Lower Limit Value
1 ,                                         !- Upper Limit Value
Continuous ,                                !- Numeric Type
dimensionless;                            !- Unit Type

Schedule:Day:Hourly ,
OccupancyDay ,                                !- Name
Fraction ,                                   !- Schedule Type Limits Name
1 ,                                         !- Hour 1
1 ,                                         !- Hour 2
1 ,                                         !- Hour 3
1 ,                                         !- Hour 4
1 ,                                         !- Hour 5
1 ,                                         !- Hour 6
1 ,                                         !- Hour 7
0.8831 ,                                    !- Hour 8

```

0.40861 ,	! - Hour 9
0.24189 ,	! - Hour 10
0.24189 ,	! - Hour 11
0.24189 ,	! - Hour 12
0.24189 ,	! - Hour 13
0.24189 ,	! - Hour 14
0.24189 ,	! - Hour 15
0.24189 ,	! - Hour 16
0.29498 ,	! - Hour 17
0.5531 ,	! - Hour 18
0.89693 ,	! - Hour 19
0.89693 ,	! - Hour 20
0.89693 ,	! - Hour 21
1 ,	! - Hour 22
1 ,	! - Hour 23
1 ;	! - Hour 24

Schedule:Day:Hourly ,	
LightingDay ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.0625 ,	! - Hour 1
0.0625 ,	! - Hour 2
0.0625 ,	! - Hour 3
0.0625 ,	! - Hour 4
0.1875 ,	! - Hour 5
0.390625 ,	! - Hour 6
0.4375 ,	! - Hour 7
0.390625 ,	! - Hour 8
0.171875 ,	! - Hour 9
0.1171875 ,	! - Hour 10
0.1171875 ,	! - Hour 11
0.1171875 ,	! - Hour 12
0.1171875 ,	! - Hour 13
0.1171875 ,	! - Hour 14
0.1171875 ,	! - Hour 15
0.203125 ,	! - Hour 16

```

0.4375 ,           !- Hour 17
0.609375 ,         !- Hour 18
0.8203125 ,        !- Hour 19
0.984375 ,         !- Hour 20
1 ,                !- Hour 21
0.6875 ,           !- Hour 22
0.3828125 ,        !- Hour 23
0.15625;           !- Hour 24

```

```

Schedule:Day:Hourly ,
LightingDay_EELighting_OccSensors ,      !- Name
Fraction ,             !- Schedule Type Limits Name
0.065170403 ,         !- Hour 1
0.065170403 ,         !- Hour 2
0.065170403 ,         !- Hour 3
0.065170403 ,         !- Hour 4
0.195511208 ,         !- Hour 5
0.407315016 ,         !- Hour 6
0.456192818 ,         !- Hour 7
0.407315016 ,         !- Hour 8
0.179218607 ,         !- Hour 9
0.122194505 ,         !- Hour 10
0.122194505 ,         !- Hour 11
0.122194505 ,         !- Hour 12
0.122194505 ,         !- Hour 13
0.122194505 ,         !- Hour 14
0.122194505 ,         !- Hour 15
0.211803808 ,         !- Hour 16
0.456192818 ,         !- Hour 17
0.635411425 ,         !- Hour 18
0.855361533 ,         !- Hour 19
0.947933128 ,         !- Hour 20
0.947933128 ,         !- Hour 21
0.716874428 ,         !- Hour 22
0.399168715 ,         !- Hour 23
0.162926006;          !- Hour 24

```

```

Schedule:Day:Hourly,
    LightingDay_EELighting_Garage_OccSensors ,      !- Name
    Fraction ,          !- Schedule Type Limits Name
    0.048125 ,        !- Hour 1
    0.048125 ,        !- Hour 2
    0.048125 ,        !- Hour 3
    0.048125 ,        !- Hour 4
    0.144375 ,        !- Hour 5
    0.30078125 ,      !- Hour 6
    0.336875 ,        !- Hour 7
    0.30078125 ,      !- Hour 8
    0.13234375 ,      !- Hour 9
    0.090234375 ,     !- Hour 10
    0.090234375 ,     !- Hour 11
    0.090234375 ,     !- Hour 12
    0.090234375 ,     !- Hour 13
    0.090234375 ,     !- Hour 14
    0.090234375 ,     !- Hour 15
    0.15640625 ,      !- Hour 16
    0.336875 ,        !- Hour 17
    0.46921875 ,      !- Hour 18
    0.631640625 ,     !- Hour 19
    0.7 ,              !- Hour 20
    0.7 ,              !- Hour 21
    0.529375 ,        !- Hour 22
    0.294765625 ,     !- Hour 23
    0.1203125 ;       !- Hour 24

```

```

Schedule:Day:Hourly,
    ExteriorLightingDay ,      !- Name
    Fraction ,          !- Schedule Type Limits Name
    1 ,                !- Hour 1
    1 ,                !- Hour 2
    1 ,                !- Hour 3
    1 ,                !- Hour 4

```

```

1,                      !- Hour 5
1,                      !- Hour 6
0,                      !- Hour 7
0,                      !- Hour 8
0,                      !- Hour 9
0,                      !- Hour 10
0,                      !- Hour 11
0,                      !- Hour 12
0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
1,                      !- Hour 19
1,                      !- Hour 20
1,                      !- Hour 21
1,                      !- Hour 22
1,                      !- Hour 23
1;                      !- Hour 24

```

```

Schedule:Day:Hourly,
  LightingDay_EELighting,      !- Name
  Fraction,                  !- Schedule Type Limits Name
  0.06875,                   !- Hour 1
  0.06875,                   !- Hour 2
  0.06875,                   !- Hour 3
  0.06875,                   !- Hour 4
  0.20625,                   !- Hour 5
  0.4296875,                 !- Hour 6
  0.48125,                   !- Hour 7
  0.4296875,                 !- Hour 8
  0.1890625,                 !- Hour 9
  0.12890625,                !- Hour 10
  0.12890625,                !- Hour 11
  0.12890625,                !- Hour 12

```

0.12890625 ,	! - Hour 13
0.12890625 ,	! - Hour 14
0.12890625 ,	! - Hour 15
0.2234375 ,	! - Hour 16
0.48125 ,	! - Hour 17
0.6703125 ,	! - Hour 18
0.90234375 ,	! - Hour 19
1 ,	! - Hour 20
1 ,	! - Hour 21
0.75625 ,	! - Hour 22
0.42109375 ,	! - Hour 23
0.171875 ;	! - Hour 24

Schedule:Day:Hourly ,

RefrigeratorDay ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.8 ,	! - Hour 1
0.782696177062374 ,	! - Hour 2
0.765593561368209 ,	! - Hour 3
0.742857142857143 ,	! - Hour 4
0.731388329979879 ,	! - Hour 5
0.731388329979879 ,	! - Hour 6
0.759959758551308 ,	! - Hour 7
0.8 ,	! - Hour 8
0.817102615694165 ,	! - Hour 9
0.828571428571429 ,	! - Hour 10
0.8 ,	! - Hour 11
0.8 ,	! - Hour 12
0.839839034205231 ,	! - Hour 13
0.839839034205231 ,	! - Hour 14
0.828571428571429 ,	! - Hour 15
0.839839034205231 ,	! - Hour 16
0.885714285714286 ,	! - Hour 17
0.971428571428572 ,	! - Hour 18
1 ,	! - Hour 19
0.971428571428572 ,	! - Hour 20

0.942857142857143 ,	! - Hour 21
0.925553319919517 ,	! - Hour 22
0.885714285714286 ,	! - Hour 23
0.828571428571429 ;	! - Hour 24
 Schedule:Day:Hourly ,	
MiscPlugLoadDay ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.607490272373541 ,	! - Hour 1
0.559338521400778 ,	! - Hour 2
0.552853437094682 ,	! - Hour 3
0.545071335927367 ,	! - Hour 4
0.524481193255512 ,	! - Hour 5
0.585278858625162 ,	! - Hour 6
0.676232166018158 ,	! - Hour 7
0.718547341115435 ,	! - Hour 8
0.607490272373541 ,	! - Hour 9
0.517023346303502 ,	! - Hour 10
0.529182879377432 ,	! - Hour 11
0.529345006485084 ,	! - Hour 12
0.520428015564202 ,	! - Hour 13
0.538424124513619 ,	! - Hour 14
0.568741893644617 ,	! - Hour 15
0.600356679636835 ,	! - Hour 16
0.71011673151751 ,	! - Hour 17
0.862678339818418 ,	! - Hour 18
0.936608300907912 ,	! - Hour 19
0.966763942931258 ,	! - Hour 20
1 ,	! - Hour 21
0.976653696498055 ,	! - Hour 22
0.845168612191959 ,	! - Hour 23
0.73443579766537 ;	! - Hour 24

 Schedule:Day:Hourly ,	
CookingRangeDay ,	! - Name
Fraction ,	! - Schedule Type Limits Name

0.04715848452508 ,	! - Hour 1
0.04715848452508 ,	! - Hour 2
0.0235458911419424 ,	! - Hour 3
0.0235458911419424 ,	! - Hour 4
0.04715848452508 ,	! - Hour 5
0.0707043756670224 ,	! - Hour 6
0.165088046958378 ,	! - Hour 7
0.283017609391676 ,	! - Hour 8
0.306563500533618 ,	! - Hour 9
0.320771077908218 ,	! - Hour 10
0.283017609391676 ,	! - Hour 11
0.330176093916756 ,	! - Hour 12
0.377334578441836 ,	! - Hour 13
0.306563500533618 ,	! - Hour 14
0.292422625400213 ,	! - Hour 15
0.377334578441836 ,	! - Hour 16
0.613193703308431 ,	! - Hour 17
1 ,	! - Hour 18
0.778348452508004 ,	! - Hour 19
0.400947171824973 ,	! - Hour 20
0.235859124866596 ,	! - Hour 21
0.165088046958378 ,	! - Hour 22
0.103721985058698 ,	! - Hour 23
0.0707043756670224 ;	! - Hour 24

Schedule:Day:Hourly ,

DishwasherWeekday ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.115858456545258 ,	! - Hour 1
0.0514758745041469 ,	! - Hour 2
0.0385691669671833 ,	! - Hour 3
0.0257379372520738 ,	! - Hour 4
0.0257379372520738 ,	! - Hour 5
0.0772138117562207 ,	! - Hour 6
0.154503101334295 ,	! - Hour 7
0.23179239091237 ,	! - Hour 8

0.437922322394519 ,	! - Hour 9
0.489398196898665 ,	! - Hour 10
0.425015614857555 ,	! - Hour 11
0.360633032816445 ,	! - Hour 12
0.309081680490443 ,	! - Hour 13
0.347726325279481 ,	! - Hour 14
0.28334374323837 ,	! - Hour 15
0.270437035701407 ,	! - Hour 16
0.28334374323837 ,	! - Hour 17
0.373464262531554 ,	! - Hour 18
0.656883483591778 ,	! - Hour 19
0.837199999999997 ,	! - Hour 20
0.682621420843852 ,	! - Hour 21
0.502304904435629 ,	! - Hour 22
0.334819617742518 ,	! - Hour 23
0.23179239091237 ;	! - Hour 24

Schedule:Day:Hourly ,

DishwasherWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.124134060584205 ,	! - Hour 1
0.0551527226830148 ,	! - Hour 2
0.0413241074648395 ,	! - Hour 3
0.0275763613415074 ,	! - Hour 4
0.0275763613415074 ,	! - Hour 5
0.0827290840245222 ,	! - Hour 6
0.165539037143888 ,	! - Hour 7
0.248348990263252 ,	! - Hour 8
0.469202488279841 ,	! - Hour 9
0.524355210962856 ,	! - Hour 10
0.455373873061666 ,	! - Hour 11
0.386392535160476 ,	! - Hour 12
0.331158943382618 ,	! - Hour 13
0.3725639199423 ,	! - Hour 14
0.303582582041111 ,	! - Hour 15
0.289753966822935 ,	! - Hour 16

```
0.303582582041111,      !- Hour 17
0.400140281283808,      !- Hour 18
0.703803732419762,      !- Hour 19
0.897,                   !- Hour 20
0.731380093761269,      !- Hour 21
0.538183826181031,      !- Hour 22
0.358735304724125,      !- Hour 23
0.248348990263252;      !- Hour 24
```

```
Schedule:Day:Hourly,
DishwasherVacation,          !- Name
Fraction,                    !- Schedule Type Limits Name
0,                           !- Hour 1
0,                           !- Hour 2
0,                           !- Hour 3
0,                           !- Hour 4
0,                           !- Hour 5
0,                           !- Hour 6
0,                           !- Hour 7
0,                           !- Hour 8
0,                           !- Hour 9
0,                           !- Hour 10
0,                           !- Hour 11
0,                           !- Hour 12
0,                           !- Hour 13
0,                           !- Hour 14
0,                           !- Hour 15
0,                           !- Hour 16
0,                           !- Hour 17
0,                           !- Hour 18
0,                           !- Hour 19
0,                           !- Hour 20
0,                           !- Hour 21
0,                           !- Hour 22
0,                           !- Hour 23
0;                          !- Hour 24
```

Schedule:Day:Hourly,

ClothesWasherWeekday ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.0796474528960224 ,	! - Hour 1
0.0637009071877185 ,	! - Hour 2
0.0318078157711097 ,	! - Hour 3
0.0318078157711097 ,	! - Hour 4
0.0637009071877185 ,	! - Hour 5
0.0955939986043261 ,	! - Hour 6
0.191187997208654 ,	! - Hour 7
0.414354361479414 ,	! - Hour 8
0.62157418004187 ,	! - Hour 9
0.7332 ,	! - Hour 10
0.717253454291697 ,	! - Hour 11
0.637520725750175 ,	! - Hour 12
0.573734542916957 ,	! - Hour 13
0.510033635729239 ,	! - Hour 14
0.446247452896022 ,	! - Hour 15
0.414354361479414 ,	! - Hour 16
0.430300907187718 ,	! - Hour 17
0.414354361479414 ,	! - Hour 18
0.414354361479414 ,	! - Hour 19
0.414354361479414 ,	! - Hour 20
0.414354361479414 ,	! - Hour 21
0.398407815771109 ,	! - Hour 22
0.270920725750174 ,	! - Hour 23
0.143433635729239 ;	! - Hour 24

Schedule:Day:Hourly,

ClothesWasherWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.0974410327983253 ,	! - Hour 1
0.0779319609211445 ,	! - Hour 2
0.038913817166783 ,	! - Hour 3
0.038913817166783 ,	! - Hour 4

0.0779319609211445 ,	! - Hour 5
0.116950104675506 ,	! - Hour 6
0.233900209351012 ,	! - Hour 7
0.506922889043964 ,	! - Hour 8
0.760436496859734 ,	! - Hour 9
0.897 ,	! - Hour 10
0.877490928122819 ,	! - Hour 11
0.779945568736915 ,	! - Hour 12
0.701909281228193 ,	! - Hour 13
0.623977320307048 ,	! - Hour 14
0.545941032798325 ,	! - Hour 15
0.506922889043964 ,	! - Hour 16
0.526431960921144 ,	! - Hour 17
0.506922889043964 ,	! - Hour 18
0.506922889043964 ,	! - Hour 19
0.506922889043964 ,	! - Hour 20
0.506922889043964 ,	! - Hour 21
0.487413817166783 ,	! - Hour 22
0.331445568736915 ,	! - Hour 23
0.175477320307048 ;	! - Hour 24

Schedule:Day:Hourly ,

ClothesWasherVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8
0 ,	! - Hour 9
0 ,	! - Hour 10
0 ,	! - Hour 11
0 ,	! - Hour 12

```

0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
0,                      !- Hour 19
0,                      !- Hour 20
0,                      !- Hour 21
0,                      !- Hour 22
0,                      !- Hour 23
0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
dhw_profile_day,          !- Name
fraction,                 !- Schedule Type Limits Name
0.006,                   !- Hour 1
0.003,                   !- Hour 2
0.001,                   !- Hour 3
0.001,                   !- Hour 4
0.003,                   !- Hour 5
0.021,                   !- Hour 6
0.075,                   !- Hour 7
0.079,                   !- Hour 8
0.076,                   !- Hour 9
0.067,                   !- Hour 10
0.061,                   !- Hour 11
0.05,                     !- Hour 12
0.042,                   !- Hour 13
0.038,                   !- Hour 14
0.033,                   !- Hour 15
0.038,                   !- Hour 16
0.043,                   !- Hour 17
0.058,                   !- Hour 18
0.068,                   !- Hour 19
0.065,                   !- Hour 20

```

0.06 ,	! - Hour 21
0.047 ,	! - Hour 22
0.041 ,	! - Hour 23
0.024 ;	! - Hour 24

Schedule:Day:Hourly ,

ClothesDryerWeekday ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.0996818663838815 ,	! - Hour 1
0.0598091198303289 ,	! - Hour 2
0.0398727465535526 ,	! - Hour 3
0.0199363732767763 ,	! - Hour 4
0.0398727465535526 ,	! - Hour 5
0.0598091198303289 ,	! - Hour 6
0.15949098621421 ,	! - Hour 7
0.31898197242842 ,	! - Hour 8
0.486427370202556 ,	! - Hour 9
0.685791102970318 ,	! - Hour 10
0.785472969354199 ,	! - Hour 11
0.817391304347826 ,	! - Hour 12
0.745600222800647 ,	! - Hour 13
0.677836691410393 ,	! - Hour 14
0.610073160020138 ,	! - Hour 15
0.578154825026511 ,	! - Hour 16
0.558218451749735 ,	! - Hour 17
0.546236490032885 ,	! - Hour 18
0.518345705196183 ,	! - Hour 19
0.510391293636256 ,	! - Hour 20
0.526300116756109 ,	! - Hour 21
0.546236490032885 ,	! - Hour 22
0.438600212089077 ,	! - Hour 23
0.239236479321316 ;	! - Hour 24

Schedule:Day:Hourly ,

ClothesDryerWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name

0.121951219512195 ,	! - Hour 1
0.0731707317073171 ,	! - Hour 2
0.0487804878048781 ,	! - Hour 3
0.024390243902439 ,	! - Hour 4
0.0487804878048781 ,	! - Hour 5
0.0731707317073171 ,	! - Hour 6
0.195121951219512 ,	! - Hour 7
0.390243902439024 ,	! - Hour 8
0.59509731460951 ,	! - Hour 9
0.8389997536339 ,	! - Hour 10
0.960950973146095 ,	! - Hour 11
1 ,	! - Hour 12
0.912170485341217 ,	! - Hour 13
0.829268292682927 ,	! - Hour 14
0.746366100024637 ,	! - Hour 15
0.707317073170732 ,	! - Hour 16
0.682926829268293 ,	! - Hour 17
0.668268046316827 ,	! - Hour 18
0.634146341463415 ,	! - Hour 19
0.624414880512441 ,	! - Hour 20
0.643877802414388 ,	! - Hour 21
0.668268046316827 ,	! - Hour 22
0.536585365853659 ,	! - Hour 23
0.292682926829268 ;	! - Hour 24

Schedule:Day:Hourly ,

ClothesDryerVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8

```

0,                      !- Hour 9
0,                      !- Hour 10
0,                      !- Hour 11
0,                      !- Hour 12
0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
0,                      !- Hour 19
0,                      !- Hour 20
0,                      !- Hour 21
0,                      !- Hour 22
0,                      !- Hour 23
0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
  SinksWeekday,          !- Name
  Fraction,              !- Schedule Type Limits Name
  0.160052687884461,    !- Hour 1
  0.0767484287242575,  !- Hour 2
  0.0575330636533838,  !- Hour 3
  0.0575330636533838,  !- Hour 4
  0.0767484287242575,  !- Hour 5
  0.204926216902916,   !- Hour 6
  0.480271095212623,   !- Hour 7
  0.704412677186414,   !- Hour 8
  0.742843407328163,   !- Hour 9
  0.697969878309708,   !- Hour 10
  0.614778650708746,   !- Hour 11
  0.563462322813587,   !- Hour 12
  0.550689756619418,   !- Hour 13
  0.512259026477668,   !- Hour 14
  0.467385497459214,   !- Hour 15
  0.486600862530089,   !- Hour 16

```

0.544246957742712 ,	! - Hour 17
0.736400608451458 ,	! - Hour 18
0.84525 ,	! - Hour 19
0.781274137469912 ,	! - Hour 20
0.640323783097085 ,	! - Hour 21
0.544246957742712 ,	! - Hour 22
0.44828316394758 ,	! - Hour 23
0.307332809574753 ;	! - Hour 24

Schedule:Day:Hourly ,	
SinksWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.169851832040653 ,	! - Hour 1
0.0814473121155389 ,	! - Hour 2
0.0610554961219577 ,	! - Hour 3
0.0610554961219577 ,	! - Hour 4
0.0814473121155389 ,	! - Hour 5
0.217472719978604 ,	! - Hour 6
0.509675447980744 ,	! - Hour 7
0.747539983952929 ,	! - Hour 8
0.788323615940091 ,	! - Hour 9
0.74070272800214 ,	! - Hour 10
0.652418159935812 ,	! - Hour 11
0.597960016047071 ,	! - Hour 12
0.58440545600428 ,	! - Hour 13
0.543621824017117 ,	! - Hour 14
0.496000936079166 ,	! - Hour 15
0.516392752072746 ,	! - Hour 16
0.57756820005349 ,	! - Hour 17
0.781486359989302 ,	! - Hour 18
0.897 ,	! - Hour 19
0.829107247927254 ,	! - Hour 20
0.679527280021396 ,	! - Hour 21
0.57756820005349 ,	! - Hour 22
0.47572907194437 ,	! - Hour 23
0.326149104038513 ;	! - Hour 24

```

Schedule:Day:Hourly,
    SinksVacation,           !- Name
    Fraction,                !- Schedule Type Limits Name
    0,                       !- Hour 1
    0,                       !- Hour 2
    0,                       !- Hour 3
    0,                       !- Hour 4
    0,                       !- Hour 5
    0,                       !- Hour 6
    0,                       !- Hour 7
    0,                       !- Hour 8
    0,                       !- Hour 9
    0,                       !- Hour 10
    0,                      !- Hour 11
    0,                      !- Hour 12
    0,                      !- Hour 13
    0,                      !- Hour 14
    0,                      !- Hour 15
    0,                      !- Hour 16
    0,                      !- Hour 17
    0,                      !- Hour 18
    0,                      !- Hour 19
    0,                      !- Hour 20
    0,                      !- Hour 21
    0,                      !- Hour 22
    0,                      !- Hour 23
    0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
    ShowersWeekday,          !- Name
    Fraction,                !- Schedule Type Limits Name
    0.076044361285933,     !- Hour 1
    0.0345332539547544,    !- Hour 2
    0.0242088790610646,    !- Hour 3
    0.0345332539547544,    !- Hour 4

```

0.0968355162442594 ,	! - Hour 5
0.366693315189659 ,	! - Hour 6
0.837199999999997 ,	! - Hour 7
0.830293349209049 ,	! - Hour 8
0.674644497363497 ,	! - Hour 9
0.529320020411635 ,	! - Hour 10
0.425506650790951 ,	! - Hour 11
0.335577785337642 ,	! - Hour 12
0.242159993196122 ,	! - Hour 13
0.207555536655894 ,	! - Hour 14
0.179857730906617 ,	! - Hour 15
0.186764381697567 ,	! - Hour 16
0.214462187446844 ,	! - Hour 17
0.27676444973635 ,	! - Hour 18
0.300973328797414 ,	! - Hour 19
0.300973328797414 ,	! - Hour 20
0.297484402109202 ,	! - Hour 21
0.290577751318252 ,	! - Hour 22
0.207555536655894 ,	! - Hour 23
0.148742201054601 ;	! - Hour 24

Schedule:Day:Hourly ,

ShowersWeekend ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0.0814761013777853 ,	! - Hour 1
0.0369999149515223 ,	! - Hour 2
0.0259380847082837 ,	! - Hour 3
0.0369999149515223 ,	! - Hour 4
0.103752338833135 ,	! - Hour 5
0.392885694846062 ,	! - Hour 6
0.897 ,	! - Hour 7
0.889600017009696 ,	! - Hour 8
0.722833390032318 ,	! - Hour 9
0.56712859329818 ,	! - Hour 10
0.455899982990304 ,	! - Hour 11
0.359547627147474 ,	! - Hour 12

0.259457135567274 ,	! - Hour 13
0.222380932131315 ,	! - Hour 14
0.19270471168566 ,	! - Hour 15
0.200104694675966 ,	! - Hour 16
0.229780915121619 ,	! - Hour 17
0.296533339003232 ,	! - Hour 18
0.322471423711515 ,	! - Hour 19
0.322471423711515 ,	! - Hour 20
0.318733287974145 ,	! - Hour 21
0.311333304983841 ,	! - Hour 22
0.222380932131315 ,	! - Hour 23
0.159366643987073 ;	! - Hour 24

Schedule:Day:Hourly ,

ShowersVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8
0 ,	! - Hour 9
0 ,	! - Hour 10
0 ,	! - Hour 11
0 ,	! - Hour 12
0 ,	! - Hour 13
0 ,	! - Hour 14
0 ,	! - Hour 15
0 ,	! - Hour 16
0 ,	! - Hour 17
0 ,	! - Hour 18
0 ,	! - Hour 19
0 ,	! - Hour 20

```
0,           !- Hour 21
0,           !- Hour 22
0,           !- Hour 23
0;          !- Hour 24
```

Schedule:Day:Hourly ,

BathsWeekday ,	!- Name
Fraction ,	!- Schedule Type Limits Name
0.0492758944582015 ,	!- Hour 1
0.0246379472291013 ,	!- Hour 2
0.0246379472291013 ,	!- Hour 3
0.0246379472291013 ,	!- Hour 4
0.0492758944582015 ,	!- Hour 5
0.123189736145504 ,	!- Hour 6
0.295719195628041 ,	!- Hour 7
0.369633037315344 ,	!- Hour 8
0.418908931773546 ,	!- Hour 9
0.369633037315344 ,	!- Hour 10
0.295719195628041 ,	!- Hour 11
0.221741525061908 ,	!- Hour 12
0.197103577832807 ,	!- Hour 13
0.147827683374605 ,	!- Hour 14
0.147827683374605 ,	!- Hour 15
0.147827683374605 ,	!- Hour 16
0.24644330116984 ,	!- Hour 17
0.295719195628041 ,	!- Hour 18
0.492886602339681 ,	!- Hour 19
0.640714285714285 ,	!- Hour 20
0.640714285714285 ,	!- Hour 21
0.492886602339681 ,	!- Hour 22
0.418908931773546 ,	!- Hour 23
0.24644330116984 ;	!- Hour 24

Schedule:Day:Hourly ,

BathsWeekend ,	!- Name
Fraction ,	!- Schedule Type Limits Name

0.0689862522414824 ,	! - Hour 1
0.0344931261207412 ,	! - Hour 2
0.0344931261207412 ,	! - Hour 3
0.0344931261207412 ,	! - Hour 4
0.0689862522414824 ,	! - Hour 5
0.172465630603706 ,	! - Hour 6
0.414006873879259 ,	! - Hour 7
0.517486252241482 ,	! - Hour 8
0.586472504482965 ,	! - Hour 9
0.517486252241482 ,	! - Hour 10
0.414006873879259 ,	! - Hour 11
0.310438135086671 ,	! - Hour 12
0.27594500896593 ,	! - Hour 13
0.206958756724447 ,	! - Hour 14
0.206958756724447 ,	! - Hour 15
0.206958756724447 ,	! - Hour 16
0.345020621637776 ,	! - Hour 17
0.414006873879259 ,	! - Hour 18
0.690041243275553 ,	! - Hour 19
0.897 ,	! - Hour 20
0.897 ,	! - Hour 21
0.690041243275553 ,	! - Hour 22
0.586472504482965 ,	! - Hour 23
0.345020621637776 ;	! - Hour 24

Schedule:Day:Hourly ,

BathsVacation ,	! - Name
Fraction ,	! - Schedule Type Limits Name
0 ,	! - Hour 1
0 ,	! - Hour 2
0 ,	! - Hour 3
0 ,	! - Hour 4
0 ,	! - Hour 5
0 ,	! - Hour 6
0 ,	! - Hour 7
0 ,	! - Hour 8

```

0,                      !- Hour  9
0,                      !- Hour 10
0,                      !- Hour 11
0,                      !- Hour 12
0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
0,                      !- Hour 19
0,                      !- Hour 20
0,                      !- Hour 21
0,                      !- Hour 22
0,                      !- Hour 23
0;                      !- Hour 24

```

```

Schedule:Day:Hourly,
  DHWDistDay,           !- Name
  Fraction,             !- Schedule Type Limits Name
  0.142553149370226,   !- Hour  1
  0.0764866759550322,   !- Hour  2
  0.0516611840277747,   !- Hour  3
  0.0584039294664903,   !- Hour  4
  0.121469841058603,   !- Hour  5
  0.366180268451559,   !- Hour  6
  0.833258955739606,   !- Hour  7
  0.999999987228391,   !- Hour  8
  0.995483090581232,   !- Hour  9
  0.916474762598139,   !- Hour 10
  0.800898393293271,   !- Hour 11
  0.682564390940485,   !- Hour 12
  0.590066600109555,   !- Hour 13
  0.522371887032053,   !- Hour 14
  0.466005974303267,   !- Hour 15
  0.46573704253214,   !- Hour 16

```

```

0.527514234916123,      !- Hour 17
0.637905701335668,      !- Hour 18
0.727588642310272,      !- Hour 19
0.732551127624518,      !- Hour 20
0.681468471942116,      !- Hour 21
0.610804704600985,      !- Hour 22
0.464292318119835,      !- Hour 23
0.299867724445383;     !- Hour 24

```

```

Schedule:Day:Hourly,
WinterLoadDay,           !- Name
Fraction,                !- Schedule Type Limits Name
0,                       !- Hour 1
0,                       !- Hour 2
0,                       !- Hour 3
0,                       !- Hour 4
0,                       !- Hour 5
0,                       !- Hour 6
0,                       !- Hour 7
0,                       !- Hour 8
0,                       !- Hour 9
0,                       !- Hour 10
0,                      !- Hour 11
0,                      !- Hour 12
0,                      !- Hour 13
0,                      !- Hour 14
0,                      !- Hour 15
0,                      !- Hour 16
0,                      !- Hour 17
0,                      !- Hour 18
0,                      !- Hour 19
0,                      !- Hour 20
0,                      !- Hour 21
0,                      !- Hour 22
0,                      !- Hour 23
0;                      !- Hour 24

```

```

Schedule:Day:Hourly ,
    SummerLoadDay ,           !- Name
    Fraction ,                !- Schedule Type Limits Name
    1 ,                       !- Hour 1
    1 ,                       !- Hour 2
    1 ,                       !- Hour 3
    1 ,                       !- Hour 4
    1 ,                       !- Hour 5
    1 ,                       !- Hour 6
    1 ,                       !- Hour 7
    1 ,                       !- Hour 8
    1 ,                       !- Hour 9
    1 ,                       !- Hour 10
    1 ,                      !- Hour 11
    1 ,                      !- Hour 12
    1 ,                      !- Hour 13
    1 ,                      !- Hour 14
    1 ,                      !- Hour 15
    1 ,                      !- Hour 16
    1 ,                      !- Hour 17
    1 ,                      !- Hour 18
    1 ,                      !- Hour 19
    1 ,                      !- Hour 20
    1 ,                      !- Hour 21
    1 ,                      !- Hour 22
    1 ,                      !- Hour 23
    1;                      !- Hour 24

```

```

Schedule:Week:Compact ,
    RefrigeratorWeek ,        !- Name
    For: AllDays ,            !- DayType List 1
    RefrigeratorDay;          !- ScheduleDay Name 1

```

```

Schedule:Week:Compact ,
    MiscPlugLoadWeek ,         !- Name

```

```

For: AllDays,           !- DayType List 1
MiscPlugLoadDay;       !- ScheduleDay Name 1

Schedule:Week:Compact,
CookingRangeWeek,      !- Name
For: AllDays,           !- DayType List 1
CookingRangeDay;        !- ScheduleDay Name 1

Schedule:Week:Compact,
DishwasherWeek,         !- Name
For: Weekdays,          !- DayType List 1
DishwasherWeekday,      !- ScheduleDay Name 1
For: CustomDay1,         !- DayType List 2
DishwasherVacation,     !- ScheduleDay Name 2
For: AllOtherDays,       !- DayType List 3
DishwasherWeekend;      !- ScheduleDay Name 3

Schedule:Week:Compact,
ClothesWasherWeek,      !- Name
For: Weekdays,          !- DayType List 1
ClothesWasherWeekday,    !- ScheduleDay Name 1
For: CustomDay1,         !- DayType List 2
ClothesWasherVacation,   !- ScheduleDay Name 2
For: AllOtherDays,       !- DayType List 3
ClothesWasherWeekend;    !- ScheduleDay Name 3

Schedule:Week:Compact,
dhw_profile_week,       !- Name
AllDays,                 !- DayType List 1
dhw_profile_day;         !- ScheduleDay Name 1

Schedule:Week:Compact,
ClothesDryerWeek,        !- Name
For: Weekdays,            !- DayType List 1
ClothesDryerWeekday,      !- ScheduleDay Name 1
For: CustomDay1,          !- DayType List 2

```

```

ClothesDryerVacation,           !- ScheduleDay Name 2
For: AllOtherDays,              !- DayType List 3
ClothesDryerWeekend;            !- ScheduleDay Name 3

Schedule:Week:Compact,
SinksWeek,                      !- Name
For: Weekdays,                  !- DayType List 1
SinksWeekday,                   !- ScheduleDay Name 1
For: CustomDay1,                !- DayType List 2
SinksVacation,                 !- ScheduleDay Name 2
For: AllOtherDays,              !- DayType List 3
SinksWeekend;                  !- ScheduleDay Name 3

Schedule:Week:Compact,
ShowersWeek,                    !- Name
For: Weekdays,                  !- DayType List 1
ShowersWeekday,                 !- ScheduleDay Name 1
For: CustomDay1,                !- DayType List 2
ShowersVacation,               !- ScheduleDay Name 2
For: AllOtherDays,              !- DayType List 3
ShowersWeekend;                !- ScheduleDay Name 3

Schedule:Week:Compact,
BathsWeek,                      !- Name
For: Weekdays,                  !- DayType List 1
BathsWeekday,                   !- ScheduleDay Name 1
For: CustomDay1,                !- DayType List 2
BathsVacation,                 !- ScheduleDay Name 2
For: AllOtherDays,              !- DayType List 3
BathsWeekend;                  !- ScheduleDay Name 3

Schedule:Week:Compact,
DHWDistWeek,                   !- Name
For: AllDays,                   !- DayType List 1
DHWDistDay;                    !- ScheduleDay Name 1

```

```

Schedule:Week:Compact ,
    OccupancyWeek ,           !- Name
    AllDays ,                 !- DayType List 1
    OccupancyDay;             !- ScheduleDay Name 1

Schedule:Week:Compact ,
    LightingProfileWeek ,      !- Name
    For: AllDays ,            !- DayType List 1
    LightingDay;              !- ScheduleDay Name 1

Schedule:Week:Compact ,
    LightingProfileWeek_EELighting ,      !- Name
    For: AllDays ,            !- DayType List 1
    LightingDay_EELighting;        !- ScheduleDay Name 1

Schedule:Week:Compact ,
    LightingProfileWeek_EELighting_interior_controls ,      !- Name
    For: AllDays ,            !- DayType List 1
    LightingDay_EELighting_OccSensors;        !- ScheduleDay Name 1

Schedule:Week:Compact ,
    LightingProfileWeek_EELighting_garage_controls ,      !- Name
    For: AllDays ,            !- DayType List 1
    LightingDay_EELighting_Garage_OccSensors;        !- ScheduleDay Name
    1

Schedule:Week:Compact ,
    ExteriorLightingProfileWeek ,      !- Name
    For: AllDays ,                !- DayType List 1
    ExteriorLightingDay;          !- ScheduleDay Name 1

Schedule:Year ,
    Occupancy ,                 !- Name
    Fraction ,                  !- Schedule Type Limits Name
    OccupancyWeek ,             !- ScheduleWeek Name 1
    1 ,                         !- Start Month 1

```

```

1,                      !- Start Day 1
12,                     !- End Month 1
31;                     !- End Day 1

Schedule:Year,
    InteriorLighting,      !- Name
    Fraction,               !- Schedule Type Limits Name
    LightingProfileWeek,   !- ScheduleWeek Name 1
    1,                      !- Start Month 1
    1,                      !- Start Day 1
    12,                     !- End Month 1
    31;                     !- End Day 1

Schedule:Year,
    InteriorLightingHE,    !- Name
    Fraction,               !- Schedule Type Limits Name
    LightingProfileWeek_EELighting, !- ScheduleWeek Name 1
    1,                      !- Start Month 1
    1,                      !- Start Day 1
    12,                     !- End Month 1
    31;                     !- End Day 1

Schedule:Year,
    InteriorLightingHE_OS, !- Name
    Fraction,               !- Schedule Type Limits Name
    LightingProfileWeek_EELighting_interior_controls, !-
    ScheduleWeek Name 1
    1,                      !- Start Month 1
    1,                      !- Start Day 1
    12,                     !- End Month 1
    31;                     !- End Day 1

Schedule:Year,
    InteriorLightingHE_VS, !- Name
    Fraction,               !- Schedule Type Limits Name
    LightingProfileWeek_EELighting_garage_controls, !-

```

```

ScheduleWeek Name 1
1,                         !- Start Month 1
1,                         !- Start Day 1
12,                        !- End Month 1
31;                        !- End Day 1

Schedule:Year,
ExteriorLighting,          !- Name
Fraction,                   !- Schedule Type Limits Name
ExteriorLightingProfileWeek, !- ScheduleWeek Name 1
1,                          !- Start Month 1
1,                          !- Start Day 1
12,                         !- End Month 1
31;                        !- End Day 1

Schedule:Year,
Refrigerator,               !- Name
Fraction,                   !- Schedule Type Limits Name
RefrigeratorWeek,           !- ScheduleWeek Name 1
1,                          !- Start Month 1
1,                          !- Start Day 1
12,                         !- End Month 1
31;                        !- End Day 1

Schedule:Year,
MiscPlugLoad,                !- Name
Fraction,                   !- Schedule Type Limits Name
MiscPlugLoadWeek,            !- ScheduleWeek Name 1
1,                          !- Start Month 1
1,                          !- Start Day 1
12,                         !- End Month 1
31;                        !- End Day 1

Schedule:Year,
CookingRange,                !- Name
Fraction,                   !- Schedule Type Limits Name

```

```

CookingRangeWeek ,           !- ScheduleWeek Name 1
1 ,                         !- Start Month 1
1 ,                         !- Start Day 1
12 ,                        !- End Month 1
31;                         !- End Day 1

Schedule:Year ,
dhw_sch ,                  !- Name
fraction ,                  !- Schedule Type Limits Name
dhw_profile_week ,         !- ScheduleWeek Name 1
1 ,                         !- Start Month 1
1 ,                         !- Start Day 1
12 ,                        !- End Month 1
31;                         !- End Day 1

Schedule:Year ,
Dishwasher ,                !- Name
Fraction ,                  !- Schedule Type Limits Name
DishwasherWeek ,            !- ScheduleWeek Name 1
1 ,                         !- Start Month 1
1 ,                         !- Start Day 1
12 ,                        !- End Month 1
31;                         !- End Day 1

Schedule:Year ,
ClothesWasher ,             !- Name
Fraction ,                  !- Schedule Type Limits Name
ClothesWasherWeek ,         !- ScheduleWeek Name 1
1 ,                         !- Start Month 1
1 ,                         !- Start Day 1
12 ,                        !- End Month 1
31;                         !- End Day 1

Schedule:Year ,
ClothesDryer ,               !- Name
Fraction ,                  !- Schedule Type Limits Name

```

```

ClothesDryerWeek ,           ! - ScheduleWeek Name 1
1 ,                         ! - Start Month 1
1 ,                         ! - Start Day 1
12 ,                        ! - End Month 1
31;                         ! - End Day 1

Schedule:Year ,
Sinks ,                      ! - Name
Fraction ,                   ! - Schedule Type Limits Name
SinksWeek ,                  ! - ScheduleWeek Name 1
1 ,                          ! - Start Month 1
1 ,                          ! - Start Day 1
12 ,                        ! - End Month 1
31;                         ! - End Day 1

Schedule:Year ,
Showers ,                    ! - Name
Fraction ,                   ! - Schedule Type Limits Name
ShowersWeek ,                ! - ScheduleWeek Name 1
1 ,                          ! - Start Month 1
1 ,                          ! - Start Day 1
12 ,                        ! - End Month 1
31;                         ! - End Day 1

Schedule:Year ,
Baths ,                      ! - Name
Fraction ,                   ! - Schedule Type Limits Name
BathsWeek ,                 ! - ScheduleWeek Name 1
1 ,                          ! - Start Month 1
1 ,                          ! - Start Day 1
12 ,                        ! - End Month 1
31;                         ! - End Day 1

Schedule:Year ,
DHWDist ,                    ! - Name
Fraction ,                   ! - Schedule Type Limits Name

```

```

DHWDistWeek ,           !- ScheduleWeek Name 1
1 ,                     !- Start Month 1
1 ,                     !- Start Day 1
12 ,                    !- End Month 1
31;                     !- End Day 1

Schedule:Compact ,
fan_sch ,               !- Name
Fractional ,             !- Schedule Type Limits Name
Through: 12/31 ,         !- Field 1
For: AllDays ,            !- Field 2
Until: 24:00 ,             !- Field 3
0.5;                     !- Field 4

Schedule:Compact ,
BA_shower_sch ,          !- Name
any number ,              !- Schedule Type Limits Name
Through: 12/31 ,           !- Field 1
For: AllDays ,              !- Field 2
Until: 1:00 ,                !- Field 3
0.00174682444444444 ,      !- Field 4
Until: 2:00 ,                !- Field 5
0.000794011111111111 ,      !- Field 6
Until: 3:00 ,                !- Field 7
0.000476406666666667 ,      !- Field 8
Until: 4:00 ,                !- Field 9
0.000794011111111111 ,      !- Field 10
Until: 5:00 ,                !- Field 11
0.002223231111111111 ,      !- Field 12
Until: 6:00 ,                !- Field 13
0.00825771555555556 ,      !- Field 14
Until: 7:00 ,                !- Field 15
0.0187386622222222 ,      !- Field 16
Until: 8:00 ,                !- Field 17
0.01857986 ,                  !- Field 18
Until: 9:00 ,                !- Field 19

```

0.0150862111111111 ,	!- Field 20
Until: 10:00 ,	!- Field 21
0.0117513644444444 ,	!- Field 22
Until: 11:00 ,	!- Field 23
0.0095281333333333 ,	!- Field 24
Until: 12:00 ,	!- Field 25
0.0074637044444444 ,	!- Field 26
Until: 13:00 ,	!- Field 27
0.00539927555555556 ,	!- Field 28
Until: 14:00 ,	!- Field 29
0.0046052644444444 ,	!- Field 30
Until: 15:00 ,	!- Field 31
0.00412885777777778 ,	!- Field 32
Until: 16:00 ,	!- Field 33
0.00397005555555556 ,	!- Field 34
Until: 17:00 ,	!- Field 35
0.00476406666666667 ,	!- Field 36
Until: 18:00 ,	!- Field 37
0.00619328666666667 ,	!- Field 38
Until: 19:00 ,	!- Field 39
0.0066696933333333 ,	!- Field 40
Until: 20:00 ,	!- Field 41
0.0066696933333333 ,	!- Field 42
Until: 21:00 ,	!- Field 43
0.0066696933333333 ,	!- Field 44
Until: 22:00 ,	!- Field 45
0.0065108911111111 ,	!- Field 46
Until: 23:00 ,	!- Field 47
0.0046052644444444 ,	!- Field 48
Until: 24:00 ,	!- Field 49
0.00333484666666667 ;	!- Field 50

Schedule:Compact ,	
BA_bath_sch ,	!- Name
any number ,	!- Schedule Type Limits Name
Through: 12/31 ,	!- Field 1

```

For: AllDays,           !- Field 2
Until: 1:00,            !- Field 3
0.000163090909090909, !- Field 4
Until: 2:00,            !- Field 5
8.15454545454545e-05, !- Field 6
Until: 3:00,            !- Field 7
8.15454545454545e-05, !- Field 8
Until: 4:00,            !- Field 9
8.15454545454545e-05, !- Field 10
Until: 5:00,            !- Field 11
0.000163090909090909, !- Field 12
Until: 6:00,            !- Field 13
0.000387340909090909, !- Field 14
Until: 7:00,            !- Field 15
0.000937772727272727, !- Field 16
Until: 8:00,            !- Field 17
0.00118240909090909, !- Field 18
Until: 9:00,            !- Field 19
0.0013455,             !- Field 20
Until: 10:00,           !- Field 21
0.00118240909090909, !- Field 22
Until: 11:00,           !- Field 23
0.000937772727272727, !- Field 24
Until: 12:00,           !- Field 25
0.000713522727272727, !- Field 26
Until: 13:00,           !- Field 27
0.000631977272727273, !- Field 28
Until: 14:00,           !- Field 29
0.000468886363636364, !- Field 30
Until: 15:00,           !- Field 31
0.000468886363636364, !- Field 32
Until: 16:00,           !- Field 33
0.000468886363636364, !- Field 34
Until: 17:00,           !- Field 35
0.000795068181818182, !- Field 36
Until: 18:00,           !- Field 37

```

```

0.000937772727272727 ,      !- Field 38
Until: 19:00 ,                !- Field 39
0.00156975 ,                !- Field 40
Until: 20:00 ,                !- Field 41
0.00203863636363636 ,      !- Field 42
Until: 21:00 ,                !- Field 43
0.00203863636363636 ,      !- Field 44
Until: 22:00 ,                !- Field 45
0.00156975 ,                !- Field 46
Until: 23:00 ,                !- Field 47
0.0013455 ,                 !- Field 48
Until: 24:00 ,                !- Field 49
0.000795068181818182;      !- Field 50

```

```

Schedule:Compact ,
BA_sink_sch ,                  !- Name
any number ,                   !- Schedule Type Limits Name
Through: 12/31 ,               !- Field 1
For: AllDays ,                 !- Field 2
Until: 1:00 ,                  !- Field 3
0.00387388596491228 ,        !- Field 4
Until: 2:00 ,                  !- Field 5
0.00193694298245614 ,        !- Field 6
Until: 3:00 ,                  !- Field 7
0.00138353070175439 ,        !- Field 8
Until: 4:00 ,                  !- Field 9
0.00138353070175439 ,        !- Field 10
Until: 5:00 ,                  !- Field 11
0.00193694298245614 ,        !- Field 12
Until: 6:00 ,                  !- Field 13
0.00498071052631579 ,        !- Field 14
Until: 7:00 ,                  !- Field 15
0.0116216578947368 ,         !- Field 16
Until: 8:00 ,                  !- Field 17
0.0171557807017544 ,         !- Field 18
Until: 9:00 ,                  !- Field 19

```

0.0182626052631579 ,	!- Field 20
Until: 10:00 ,	!- Field 21
0.0171557807017544 ,	!- Field 22
Until: 11:00 ,	!- Field 23
0.0149421315789474 ,	!- Field 24
Until: 12:00 ,	!- Field 25
0.0138353070175439 ,	!- Field 26
Until: 13:00 ,	!- Field 27
0.013558600877193 ,	!- Field 28
Until: 14:00 ,	!- Field 29
0.0124517763157895 ,	!- Field 30
Until: 15:00 ,	!- Field 31
0.0118983640350877 ,	!- Field 32
Until: 16:00 ,	!- Field 33
0.011344951754386 ,	!- Field 34
Until: 17:00 ,	!- Field 35
0.0132818947368421 ,	!- Field 36
Until: 18:00 ,	!- Field 37
0.017985899122807 ,	!- Field 38
Until: 19:00 ,	!- Field 39
0.0207529605263158 ,	!- Field 40
Until: 20:00 ,	!- Field 41
0.0190927236842105 ,	!- Field 42
Until: 21:00 ,	!- Field 43
0.01577225 ,	!- Field 44
Until: 22:00 ,	!- Field 45
0.0132818947368421 ,	!- Field 46
Until: 23:00 ,	!- Field 47
0.0110682456140351 ,	!- Field 48
Until: 24:00 ,	!- Field 49
0.00747106578947368 ;	!- Field 50

Schedule:Compact ,	
activity_sch ,	!- Name
any number ,	!- Schedule Type Limits Name
Through: 12/31 ,	!- Field 1

```

For: AllDays,                                !- Field 2
Until: 24:00,                                 !- Field 3
117.28;                                     !- Field 4

Schedule:Compact,
inf_sch,                                      !- Name
any number,                                    !- Schedule Type Limits Name
Through: 12/31,                                !- Field 1
For: AllDays,                                  !- Field 2
Until: 24:00,                                  !- Field 3
1;                                            !- Field 4

Schedule:Compact,
zone_control_type,                            !- Name
control_type,                                 !- Schedule Type Limits Name
Through: 12/31,                                !- Field 1
For: AllDays,                                  !- Field 2
Until 24:00,                                   !- Field 3
4;                                            !- Field 4

Schedule:Compact,
shading_2012iecc,                            !- Name
fraction,                                     !- Schedule Type Limits Name
Through: 12/31,                                !- Field 1
For: AllDays,                                  !- Field 2
Until 24:00,                                   !- Field 3
0;                                            !- Field 4

Schedule:Compact,
shading_2009iecc,                            !- Name
any number,                                    !- Schedule Type Limits Name
Through: 5/30,                                 !- Field 1
For: AllDays,                                  !- Field 2
Until 24:00,                                   !- Field 3
0.85,                                         !- Field 4
Through: 8/31,                                 !- Field 5

```

```

For: AllDays,                               !- Field 6
Until 24:00,                                !- Field 7
0.7,                                         !- Field 8
Through: 12/31,                               !- Field 9
For: AllDays,                               !- Field 10
Until: 24:00,                                !- Field 11
0.85;                                         !- Field 12

Schedule:Compact,
dhw_setpt,                                     !- Name
Temperature,                                    !- Schedule Type Limits Name
Through: 12/31,                               !- Field 1
For: AllDays,                               !- Field 2
Until 24:00,                                !- Field 3
48;                                           !- Field 4

Schedule:Compact,
dhw_setpt_hpwh,                                !- Name
Temperature,                                    !- Schedule Type Limits Name
Through: 12/31,                               !- Field 1
For: AllDays,                               !- Field 2
Until 24:00,                                !- Field 3
44;                                           !- Field 4

Schedule:Compact,
Supply-Air-Temp-Sch,                           !- Name
Temperature,                                    !- Schedule Type Limits Name
Through: 12/31,                               !- Field 1
For: AllDays,                               !- Field 2
Until: 24:00,                                !- Field 3
12;                                           !- Field 4

Schedule:Compact,
always_avail,                                   !- Name
On/Off,                                         !- Schedule Type Limits Name
Through: 12/31,                               !- Field 1

```

```

For: AllDays,                                !- Field 2
Until: 24:00,                                  !- Field 3
1;                                              !- Field 4

Schedule:Compact,
  ALWAYS_ON,                                    !- Name
  On/Off,                                         !- Schedule Type Limits Name
  Through: 12/31,                               !- Field 1
  For: AllDays,                                !- Field 2
  Until: 24:00,                                  !- Field 3
  1;                                              !- Field 4

Schedule:Compact,
  always_off,                                   !- Name
  On/Off,                                         !- Schedule Type Limits Name
  Through: 12/31,                               !- Field 1
  For: AllDays,                                !- Field 2
  Until: 24:00,                                  !- Field 3
  0;                                              !- Field 4

Schedule:Compact,
  heating_sch_HRef,                            !- Name
  Temperature,                                 !- Schedule Type Limits Name
  Through: 12/31,                               !- Field 1
  For: AllDays,                                !- Field 2
  Until: 24:00,                                  !- Field 3
  17;                                             !- Field 4

Schedule:Compact,
  cooling_sch_HRef,                            !- Name
  Temperature,                                 !- Schedule Type Limits Name
  Through: 12/31,                               !- Field 1
  For: AllDays,                                !- Field 2
  Until: 24:00,                                  !- Field 3
  25.55;                                         !- Field 4

```

```

Schedule:Compact ,
heating_sch ,                               !- Name
Temperature ,                                !- Schedule Type Limits Name
Through: 12/31 ,                             !- Field 1
For: AllDays ,                               !- Field 2
Until: 24:00 ,                               !- Field 3
17;                                         !- Field 4

Schedule:Compact ,
charge_sch ,                               !- Name
Any Number ,                                !- Schedule Type Limits Name
Through: 12/31 ,                             !- Field 1
For: AllDays ,                               !- Field 2
Until: 1:00 ,                                 !- Field 3
0 ,                                         !- Field 4
Until: 2:00 ,                                 !- Field 5
0 ,                                         !- Field 6
Until: 3:00 ,                                 !- Field 7
0 ,                                         !- Field 8
Until: 4:00 ,                                 !- Field 9
0 ,                                         !- Field 10
Until: 5:00 ,                                 !- Field 11
0 ,                                         !- Field 12
Until: 6:00 ,                                 !- Field 13
0 ,                                         !- Field 14
Until: 7:00 ,                                 !- Field 15
0.07338484488253715 ,                      !- Field 16
Until: 8:00 ,                                 !- Field 17
0.7962221805360203 ,                      !- Field 18
Until: 9:00 ,                                 !- Field 19
1 ,                                         !- Field 20
Until: 10:00 ,                                !- Field 21
0 ,                                         !- Field 22
Until: 11:00 ,                                !- Field 23
0 ,                                         !- Field 24
Until: 12:00 ,                                !- Field 25

```

```

0,                                !- Field 26
Until: 13:00,                      !- Field 27
0,                                !- Field 28
Until: 14:00,                      !- Field 29
0,                                !- Field 30
Until: 15:00,                      !- Field 31
0,                                !- Field 32
Until: 16:00,                      !- Field 33
0,                                !- Field 34
Until: 17:00,                      !- Field 35
0,                                !- Field 36
Until: 18:00,                      !- Field 37
0,                                !- Field 38
Until: 19:00,                      !- Field 39
0,                                !- Field 40
Until: 20:00,                      !- Field 41
0,                                !- Field 42
Until: 21:00,                      !- Field 43
0,                                !- Field 44
Until: 22:00,                      !- Field 45
0,                                !- Field 46
Until: 23:00,                      !- Field 47
0,                                !- Field 48
Until: 24:00,                      !- Field 49
0;                                !- Field 50

```

```

Schedule:Compact,
discharge_sch,                     !- Name
Any Number,                        !- Schedule Type Limits Name
Through: 12/31,                     !- Field 1
For: AllDays,                       !- Field 2
Until: 1:00,                         !- Field 3
0,                                 !- Field 4
Until: 2:00,                         !- Field 5
0,                                 !- Field 6
Until: 3:00,                         !- Field 7

```

0,	!- Field 8
Until: 4:00,	!- Field 9
0,	!- Field 10
Until: 5:00,	!- Field 11
0,	!- Field 12
Until: 6:00,	!- Field 13
0,	!- Field 14
Until: 7:00,	!- Field 15
0,	!- Field 16
Until: 8:00,	!- Field 17
0,	!- Field 18
Until: 9:00,	!- Field 19
0,	!- Field 20
Until: 10:00,	!- Field 21
0,	!- Field 22
Until: 11:00,	!- Field 23
0,	!- Field 24
Until: 12:00,	!- Field 25
0,	!- Field 26
Until: 13:00,	!- Field 27
0,	!- Field 28
Until: 14:00,	!- Field 29
0,	!- Field 30
Until: 15:00,	!- Field 31
0,	!- Field 32
Until: 16:00,	!- Field 33
0,	!- Field 34
Until: 17:00,	!- Field 35
0,	!- Field 36
Until: 18:00,	!- Field 37
0.2728391119512886 ,	!- Field 38
Until: 19:00,	!- Field 39
0.7846101510027408 ,	!- Field 40
Until: 20:00,	!- Field 41
0.7720685536374493 ,	!- Field 42
Until: 21:00 ,	!- Field 43

```

0,                                !- Field 44
Until: 22:00,                      !- Field 45
0,                                !- Field 46
Until: 23:00,                      !- Field 47
0,                                !- Field 48
Until: 24:00,                      !- Field 49
0;                                !- Field 50

Schedule:Compact,
cooling_sch,                         !- Name
Temperature,                          !- Schedule Type Limits Name
Through: 12/31,                        !- Field 1
For: AllDays,                          !- Field 2
Until: 24:00,                          !- Field 3
23.888888888889;                    !- Field 4

Schedule:Compact,
fan_cycle,                           !- Name
any number,                           !- Schedule Type Limits Name
Through: 12/31,                        !- Field 1
For: AllDays,                          !- Field 2
Until: 24:00,                          !- Field 3
0;                                  !- Field 4

Schedule:Compact,
Clothing Sch,                         !- Name
Fractional,                           !- Schedule Type Limits Name
Through: 12/31,                        !- Field 1
For: AllDays,                          !- Field 2
Until: 24:00,                          !- Field 3
0.45;                                !- Field 4

Schedule:Compact,
Air Velo Sch,                         !- Name
Fractional,                           !- Schedule Type Limits Name
Through: 12/31,                        !- Field 1

```

```

For: AllDays,                                !- Field 2
Until: 24:00,                                 !- Field 3
0.35;                                         !- Field 4

Schedule:Compact,
Work Eff Sch,                               !- Name
Fractional,                                  !- Schedule Type Limits Name
Through: 12/31,                               !- Field 1
For: AllDays,                                !- Field 2
Until: 24:00,                                 !- Field 3
0;                                            !- Field 4

Schedule:Constant,
DWWaterTempSchedule,                         !- Name
Temperature,                                 !- Schedule Type Limits Name
48.888888888889;                           !- Hourly Value

Schedule:Constant,
CWWaterTempSchedule,                         !- Name
Temperature,                                 !- Schedule Type Limits Name
48.888888888889;                           !- Hourly Value

Schedule:Constant,
SinkSensSchedule,                            !- Name
Fraction,                                    !- Schedule Type Limits Name
0.6877777777777778;                      !- Hourly Value

Schedule:Constant,
SinkLatSchedule,                            !- Name
Fraction,                                    !- Schedule Type Limits Name
0.3122222222222222;                      !- Hourly Value

Schedule:Constant,
ShowerSensSchedule,                         !- Name
Fraction,                                    !- Schedule Type Limits Name
0.51280276816609;                          !- Hourly Value

```

```

Schedule:Constant ,
    ShowerLatSchedule ,           !- Name
    Fraction ,                   !- Schedule Type Limits Name
    0.48719723183391;          !- Hourly Value

Schedule:Constant ,
    BathSensSchedule ,          !- Name
    Fraction ,                   !- Schedule Type Limits Name
    1;                          !- Hourly Value

Schedule:Constant ,
    BathLatSchedule ,           !- Name
    Fraction ,                   !- Schedule Type Limits Name
    0;                          !- Hourly Value

Schedule:Constant ,
    SSBWaterTempSchedule ,       !- Name
    Temperature ,                !- Schedule Type Limits Name
    40.5555555555556;          !- Hourly Value

Schedule:Constant ,
    WaterHeaterSP1Schedule ,     !- Name
    Temperature ,                !- Schedule Type Limits Name
    48.888888888889;           !- Hourly Value

Schedule:Constant ,
    WaterHeaterSP2Schedule ,     !- Name
    Temperature ,                !- Schedule Type Limits Name
    40.5555555555556;          !- Hourly Value

Schedule:Constant ,
    DHWSupplySetpoint ,          !- Name
    Temperature ,                !- Schedule Type Limits Name
    48.888888888889;           !- Hourly Value

```

```

Schedule:Constant ,
    boiler_setpt ,                         !- Name
    Temperature ,                           !- Schedule Type Limits Name
    80;                                     !- Hourly Value

Schedule:Constant ,
    Compressor Setpoint ,                  !- Name
    Temperature ,                           !- Schedule Type Limits Name
    50;                                     !- Hourly Value

Schedule:Constant ,
    DOAShightemp ,                        !- Name
    Temperature ,                           !- Schedule Type Limits Name
    200;                                    !- Hourly Value

Schedule:Constant ,
    DOASlowtemp ,                         !- Name
    Temperature ,                           !- Schedule Type Limits Name
    -60;                                   !- Hourly Value

Material ,
    sheathing_consol_layer ,              !- Name
    Rough ,                                !- Roughness
    0.0127 ,                               !- Thickness
    0.0940184 ,                            !- Conductivity
    685.008 ,                              !- Density
    1172.332;                             !- Specific Heat

Material ,
    ceil_consol_layer ,                  !- Name
    Rough ,                                !- Roughness
    0.284817435151397 ,                 !- Thickness
    0.0617176 ,                            !- Conductivity
    41.9286 ,                             !- Density
    776.25126;                            !- Specific Heat

```

```

Material ,
    floor_consol_layer ,      !- Name
    Rough ,                   !- Roughness
    0.000254 ,                !- Thickness
    12.989536 ,               !- Conductivity
    55.074 ,                  !- Density
    916.9311;                 !- Specific Heat

Material ,
    bsmtwall_consol_layer ,   !- Name
    Rough ,                   !- Roughness
    0.000254 ,                !- Thickness
    10.84384 ,               !- Conductivity
    120.801 ,                 !- Density
    1036.25775;              !- Specific Heat

Material ,
    crawlwall_consol_layer ,  !- Name
    Rough ,                   !- Roughness
    0.000254 ,                !- Thickness
    10.84384 ,               !- Conductivity
    120.801 ,                 !- Density
    1036.25775;              !- Specific Heat

Material ,
    wall_consol_layer ,       !- Name
    Rough ,                   !- Roughness
    0.0889 ,                  !- Thickness
    0.0579573076923077 ,     !- Conductivity
    120.801 ,                 !- Density
    1036.25775;              !- Specific Heat

Material ,
    Very High Reflectivity Surface , !- Name
    Smooth ,                  !- Roughness
    0.0005 ,                  !- Thickness

```

```
237,           !- Conductivity
2702,          !- Density
903,           !- Specific Heat
0.9,            !- Thermal Absorptance
0.05,           !- Solar Absorptance
0.05;          !- Visible Absorptance
```

```
Material,
GypsumBoard -5/16 in,      !- Name
Rough,                  !- Roughness
0.00793953,             !- Thickness
0.15862,                !- Conductivity
640,                     !- Density
1129.6,                 !- Specific Heat
0.9,                     !- Thermal Absorptance
0.4,                     !- Solar Absorptance
0.1;                     !- Visible Absorptance
```

```
Material,
CopperPipe,           !- Name
MediumRough,          !- Roughness
0.0190500386169072, !- Thickness
401,                  !- Conductivity
2243,                !- Density
837,                  !- Specific Heat
0.9,                  !- Thermal Absorptance
0.65,                !- Solar Absorptance
0.65;                !- Visible Absorptance
```

```
Material,
F08 Metal surface,     !- Name
Smooth,                !- Roughness
0.0008,               !- Thickness
45.28,                !- Conductivity
7824,                 !- Density
500;                  !- Specific Heat
```

```

Material ,
    Concrete_4in ,           ! - Name
    Rough ,                  ! - Roughness
    0.1014984 ,              ! - Thickness
    1.312098 ,               ! - Conductivity
    2242.8 ,                 ! - Density
    465.2;                   ! - Specific Heat

Material ,
    Asphalt_shingle ,        ! - Name
    MediumRough ,             ! - Roughness
    0.00633985285170672 ,   ! - Thickness
    0.08186 ,                ! - Conductivity
    1121.2917044623 ,       ! - Density
    1255.20000949809 ,      ! - Specific Heat
    ,                        ! - Thermal Absorptance
    0.75;                   ! - Solar Absorptance

Material ,
    Wood_shingle ,           ! - Name
    MediumSmooth ,            ! - Roughness
    0.0127000257446048 ,   ! - Thickness
    0.11388 ,                ! - Conductivity
    426.090847695673 ,      ! - Density
    1631.76001234752;       ! - Specific Heat

Material ,
    Slate_shingle ,          ! - Name
    MediumSmooth ,            ! - Roughness
    0.0127000257446048 ,   ! - Thickness
    1.44219 ,                ! - Conductivity
    1601.845292089 ,        ! - Density
    1255.20000949809;       ! - Specific Heat

Material ,

```

```

cement_stucco ,           ! - Name
MediumSmooth ,            ! - Roughness
0.01905 ,                ! - Thickness
0.721 ,                  ! - Conductivity
1865.58 ,                ! - Density
878.640006648665;       ! - Specific Heat

Material ,
syn_stucco ,             ! - Name
MediumSmooth ,            ! - Roughness
0.003048 ,               ! - Thickness
0.0865 ,                 ! - Conductivity
400 ,                    ! - Density
878.640006648665;       ! - Specific Heat

Material ,
Drywall_1/2in ,          ! - Name
MediumSmooth ,            ! - Roughness
0.0127000257446048 ,    ! - Thickness
0.16009 ,                ! - Conductivity
800.922646044499 ,      ! - Density
1087.84000823168;       ! - Specific Heat

Material ,
OSB_5/8in ,              ! - Name
MediumSmooth ,            ! - Roughness
0.015875032180756 ,     ! - Thickness
0.1163 ,                 ! - Conductivity
544.627399310259 ,      ! - Density
1213.36000918149;       ! - Specific Heat

Material ,
OSB_7/16in ,             ! - Name
MediumSmooth ,            ! - Roughness
0.0111125 ,              ! - Thickness
0.1163 ,                 ! - Conductivity

```

```

544.627399310259 ,           ! - Density
1213.36000918149;          ! - Specific Heat

Material ,
Blown_R30 ,                  ! - Name
MediumRough ,                 ! - Roughness
0.212598430964684 ,         ! - Thickness
0.04119 ,                     ! - Conductivity
9.61107175253399 ,          ! - Density
836.800006332062;          ! - Specific Heat

Material ,
Blown_R30_top ,              ! - Name
MediumRough ,                 ! - Roughness
0.117348237880148 ,         ! - Thickness
0.04119 ,                     ! - Conductivity
9.61107175253399 ,          ! - Density
836.800006332062 ,          ! - Specific Heat
0.9 ,                         ! - Thermal Absorptance
0.7 ,                         ! - Solar Absorptance
0.7;                          ! - Visible Absorptance

Material ,
Plywood_3/4in ,               ! - Name
Rough ,                        ! - Roughness
0.01905 ,                      ! - Thickness
0.1154577 ,                   ! - Conductivity
544.68 ,                       ! - Density
674.54 ,                       ! - Specific Heat
0.9 ,                           ! - Thermal Absorptance
0.7 ,                           ! - Solar Absorptance
0.7;                           ! - Visible Absorptance

Material ,
Batt_R19 ,                    ! - Name
MediumRough ,                  ! - Roughness

```

```

0.0254000514892096 ,      !- Thickness
0.00347522010738099 ,    !- Conductivity
9.61107175253399 ,      !- Density
836.800006332062 ,      !- Specific Heat
0.9 ,                     !- Thermal Absorptance
0.7 ,                     !- Solar Absorptance
0.7;                      !- Visible Absorptance

```

Material ,

```

Lumber_2x4 ,              !- Name
Rough ,                   !- Roughness
0.0890016 ,               !- Thickness
0.1154577 ,               !- Conductivity
512.64 ,                  !- Density
767.58 ,                  !- Specific Heat
0.9 ,                     !- Thermal Absorptance
0.7 ,                     !- Solar Absorptance
0.7;                      !- Visible Absorptance

```

Material ,

```

Carpet_n_pad ,             !- Name
MediumSmooth ,             !- Roughness
0.0254000514892096 ,     !- Thickness
0.0601314018580031 ,     !- Conductivity
32.03690584178 ,         !- Density
836.800006332062 ,       !- Specific Heat
0.9 ,                     !- Thermal Absorptance
0.7 ,                     !- Solar Absorptance
0.7;                      !- Visible Absorptance

```

Material ,

```

Batt_R13 ,                !- Name
MediumRough ,              !- Roughness
0.0889 ,                  !- Thickness
0.03876 ,                 !- Conductivity
9.61107175253399 ,       !- Density

```

```

836.800006332062 ,           ! - Specific Heat
0.9 ,                         ! - Thermal Absorptance
0.7 ,                         ! - Solar Absorptance
0.7;                          ! - Visible Absorptance

Material ,
OSB_1/2in ,                   ! - Name
MediumSmooth ,                 ! - Roughness
0.0127000257446048 ,         ! - Thickness
0.1163 ,                       ! - Conductivity
544.627399310259 ,           ! - Density
1213.36000918149 ,           ! - Specific Heat
0.9 ,                          ! - Thermal Absorptance
0.7 ,                          ! - Solar Absorptance
0.7;                          ! - Visible Absorptance

Material ,
soil_12in ,                   ! - Name
Rough ,                        ! - Roughness
0.3048 ,                       ! - Thickness
1.731 ,                        ! - Conductivity
1842.3 ,                       ! - Density
232.6 ,                        ! - Specific Heat
0.9 ,                          ! - Thermal Absorptance
0.7 ,                          ! - Solar Absorptance
0.7;                          ! - Visible Absorptance

Material ,
door_const ,                  ! - Name
Smooth ,                        ! - Roughness
0.0253617440918536 ,          ! - Thickness
0.0720096 ,                     ! - Conductivity
512.64 ,                        ! - Density
767.58;                        ! - Specific Heat

Material ,

```

```

Gyp_board_1/2in,
Rough,
0.01271016,
0.15862,
640,
1129.6,
0.9,
0.4,
0.1;                                !- Visible Absorptance

Material,
Std Wood 6inch,
MediumSmooth,
0.15,
0.12,
540,
1210,
0.9,
0.7,
0.7;                                !- Visible Absorptance

Material,
Pipe Insulation,
VeryRough,
0.0127032520325203,
0.03317175,
91,
836,
0.9,
0.5,
0.5;                                !- Visible Absorptance

Material:NoMass,
Manf_wall_airgap,
Smooth,
0.12;                                !- Thermal Resistance

```

```

Material:NoMass ,
    Bldg_paper_felt ,           !- Name
    Smooth ,                   !- Roughness
    0.0105666113069662;       !- Thermal Resistance

Material:NoMass ,
    R_high ,                  !- Name
    MediumRough ,             !- Roughness
    177;                      !- Thermal Resistance

Material:AirGap ,
    Air_4_in_vert ,          !- Name
    0.158499169604493;       !- Thermal Resistance

Material:AirGap ,
    3/4in_air_space ,        !- Name
    0.08513;                 !- Thermal Resistance

Material:AirGap ,
    3/4in_Reflective_air_space ,   !- Name
    0.246554;                !- Thermal Resistance

WindowMaterial:SimpleGlazingSystem ,
    Glass ,                   !- Name
    2.8393 ,                 !- UFactor
    0.216875 ,               !- Solar Heat Gain Coefficient
    0.88;                     !- Visible Transmittance

WindowMaterial:Glazing ,
    Clear Acrylic Plastic ,   !- Name
    SpectralAverage ,         !- Optical Data Type
    ,                         !- Window Glass Spectral Data Set Name
    0.003 ,                   !- Thickness
    0.92 ,                     !- Solar Transmittance at Normal
    Incidence

```

```

    0.05,                                     !- Front Side Solar Reflectance at
Normal Incidence

    0.05,                                     !- Back Side Solar Reflectance at
Normal Incidence

    0.92,                                      !- Visible Transmittance at Normal
Incidence

    0.05,                                      !- Front Side Visible Reflectance at
Normal Incidence

    0.05,                                      !- Back Side Visible Reflectance at
Normal Incidence

    0,                                         !- Infrared Transmittance at Normal
Incidence

    0.9,                                       !- Front Side Infrared Hemispherical
Emissivity

    0.9,                                       !- Back Side Infrared Hemispherical
Emissivity

    0.9;                                       !- Conductivity

WindowMaterial:Glazing,
    Diffusing Acrylic Plastic,      !- Name
    SpectralAverage,                !- Optical Data Type
    ,                               !- Window Glass Spectral Data Set Name
    0.0022,                         !- Thickness
    0.9,                            !- Solar Transmittance at Normal
Incidence

    0.08,                           !- Front Side Solar Reflectance at
Normal Incidence

    0.08,                           !- Back Side Solar Reflectance at
Normal Incidence

    0.9,                            !- Visible Transmittance at Normal
Incidence

    0.08,                           !- Front Side Visible Reflectance at
Normal Incidence

    0.08,                           !- Back Side Visible Reflectance at
Normal Incidence

    0,                               !- Infrared Transmittance at Normal

```

```

Incidence
0.9,                                     !- Front Side Infrared Hemispherical

Emissivity
0.9,                                     !- Back Side Infrared Hemispherical

Emissivity
0.9;                                      !- Conductivity

WindowMaterial:Blind,
int_blind,                                !- Name
Horizontal,                                !- Slat Orientation
0.025,                                     !- Slat Width
0.01875,                                   !- Slat Separation
0.001,                                     !- Slat Thickness
45,                                         !- Slat Angle
221,                                        !- Slat Conductivity
0,                                           !- Slat Beam Solar Transmittance
0.5,                                         !- Front Side Slat Beam Solar
Reflectance
0.5,                                         !- Back Side Slat Beam Solar
Reflectance
0,                                           !- Slat Diffuse Solar Transmittance
0.5,                                         !- Front Side Slat Diffuse Solar
Reflectance
0.5,                                         !- Back Side Slat Diffuse Solar
Reflectance
0,                                           !- Slat Beam Visible Transmittance
0.5,                                         !- Front Side Slat Beam Visible
Reflectance
0.5,                                         !- Back Side Slat Beam Visible
Reflectance
0,                                           !- Slat Diffuse Visible Transmittance
0.5,                                         !- Front Side Slat Diffuse Visible
Reflectance
0.5,                                         !- Back Side Slat Diffuse Visible
Reflectance
0,                                           !- Slat Infrared Hemispherical

```

```

Transmittance
  0.9,                               !- Front Side Slat Infrared
Hemispherical Emissivity
  0.9,                               !- Back Side Slat Infrared
Hemispherical Emissivity
  0.05,                             !- Blind to Glass Distance
  0.5,                              !- Blind Top Opening Multiplier
  0.5,                              !- Blind Bottom Opening Multiplier
  0.5,                             !- Blind Left Side Opening Multiplier
  0.5,                            !- Blind Right Side Opening Multiplier
  ,                                !- Minimum Slat Angle
;                                !- Maximum Slat Angle

Construction,
  Exterior Wall,                      !- Name
  syn_stucco,                         !- Outside Layer
  sheathing_consol_layer,             !- Layer 2
  OSB_7/16in,                          !- Layer 3
  wall_consol_layer,                  !- Layer 4
  Drywall_1/2in;                     !- Layer 5

Construction,
  InteriorFurnishings,               !- Name
  Std Wood 6inch;                   !- Outside Layer

Construction,
  ceiling-floor-layer,                !- Name
  Lumber_2x4;                        !- Outside Layer

Construction,
  Exterior Floor,                    !- Name
  floor_consol_layer,                !- Outside Layer
  Plywood_3/4in,                     !- Layer 2
  Carpet_n_pad;                     !- Layer 3

Construction ,

```

```

Interior Floor,           !- Name
Plywood_3/4in,            !- Outside Layer
Carpet_n_pad;             !- Layer 2

Construction,
Interior Ceiling,        !- Name
ceil_consol_layer,        !- Outside Layer
Drywall_1/2in;            !- Layer 2

Construction,
attic floor,              !- Name
Drywall_1/2in,             !- Outside Layer
ceil_consol_layer;         !- Layer 2

Construction,
fndn_roof,                !- Name
Carpet_n_pad,               !- Outside Layer
Plywood_3/4in,              !- Layer 2
ceil_consol_layer;          !- Layer 3

Construction,
interiorwall,              !- Name
Drywall_1/2in,               !- Outside Layer
OSB_5/8in,                  !- Layer 2
Drywall_1/2in;                !- Layer 3

Construction,
Interior Wall,             !- Name
Drywall_1/2in,               !- Outside Layer
Air_4_in_vert,              !- Layer 2
Drywall_1/2in;                !- Layer 3

Construction,
Exterior Roof,              !- Name
Asphalt_shingle,             !- Outside Layer
OSB_1/2in;                   !- Layer 2

```

```
Construction,
    Exterior Window,           !- Name
    Glass;                   !- Outside Layer

Construction,
    Interior Window,          !- Name
    Glass;                   !- Outside Layer

Construction,
    Exterior Door,            !- Name
    door_const;              !- Outside Layer

Construction,
    Interior Door,            !- Name
    door_const;              !- Outside Layer

Construction,
    Gable_end,                !- Name
    cement_stucco,            !- Outside Layer
    Bldg_paper_felt,          !- Layer 2
    OSB_5/8in,                !- Layer 3
    Air_4_in_vert,            !- Layer 4
    Drywall_1/2in;            !- Layer 5

Construction,
    crawl_floor,              !- Name
    R_high,                   !- Outside Layer
    soil_12in;                !- Layer 2

Construction,
    window_w_blinds,          !- Name
    Glass,                    !- Outside Layer
    int_blind;                !- Layer 2

Construction,
```

```

    Insulated Pipe,           !- Name
    Pipe Insulation,          !- Outside Layer
    CopperPipe;              !- Layer 2

Construction,
    Plain Pipe,             !- Name
    CopperPipe;              !- Outside Layer

Construction,
    TDD Pipe,                !- Name
    Very High Reflectivity Surface;      !- Outside Layer

Construction,
    TDD Dome,                !- Name
    Clear Acrylic Plastic;      !- Outside Layer

Construction,
    TDD Diffuser,            !- Name
    Diffusing Acrylic Plastic;  !- Outside Layer

GlobalGeometryRules,
    LowerLeftCorner,          !- Starting Vertex Position
    Counterclockwise,          !- Vertex Entry Direction
    World;                   !- Coordinate System

Zone,
    living_unit1,             !- Name
    0,                        !- Direction of Relative North
    0,                        !- X Origin
    0,                        !- Y Origin
    0,                        !- Z Origin
    ,                         !- Type
    1;                       !- Multiplier

Zone,
    attic_unit1,              !- Name

```

```

0,                                     !- Direction of Relative North
0,                                     !- X Origin
0,                                     !- Y Origin
0,                                     !- Z Origin
,                                       !- Type
1;                                      !- Multiplier

BuildingSurface:Detailed,
Inter zone floor 1,                  !- Name
Floor,                                !- Surface Type
Interior Floor,                      !- Construction Name
living_unit1,                         !- Zone Name
Adiabatic,                            !- Outside Boundary Condition
,                                     !- Outside Boundary Condition Object
NoSun,                                !- Sun Exposure
NoWind,                               !- Wind Exposure
0,                                     !- View Factor to Ground
4,                                     !- Number of Vertices
0,                                     !- Vertex 1 Xcoordinate
0,                                     !- Vertex 1 Ycoordinate
2.60156341463415,                   !- Vertex 1 Zcoordinate
0,                                     !- Vertex 2 Xcoordinate
9.09981820971244,                   !- Vertex 2 Ycoordinate
2.60156341463415,                   !- Vertex 2 Zcoordinate
12.1330909462833,                  !- Vertex 3 Xcoordinate
9.09981820971244,                   !- Vertex 3 Ycoordinate
2.60156341463415,                   !- Vertex 3 Zcoordinate
12.1330909462833,                  !- Vertex 4 Xcoordinate
0,                                     !- Vertex 4 Ycoordinate
2.60156341463415;                  !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
ceiling_unit1,                        !- Name
Ceiling,                              !- Surface Type
Interior Ceiling,                    !- Construction Name
living_unit1,                         !- Zone Name

```

```

Zone ,                                     !- Outside Boundary Condition
attic_unit1 ,                               !- Outside Boundary Condition Object
NoSun ,                                      !- Sun Exposure
NoWind ,                                     !- Wind Exposure
0 ,                                         !- View Factor to Ground
4 ,                                         !- Number of Vertices
0 ,                                         !- Vertex 1 Xcoordinate
0 ,                                         !- Vertex 1 Ycoordinate
5.19302682926829 ,                         !- Vertex 1 Zcoordinate
12.1330909462833 ,                         !- Vertex 2 Xcoordinate
0 ,                                         !- Vertex 2 Ycoordinate
5.19302682926829 ,                         !- Vertex 2 Zcoordinate
12.1330909462833 ,                         !- Vertex 3 Xcoordinate
9.09981820971244 ,                         !- Vertex 3 Ycoordinate
5.19302682926829 ,                         !- Vertex 3 Zcoordinate
0 ,                                         !- Vertex 4 Xcoordinate
9.09981820971244 ,                         !- Vertex 4 Ycoordinate
5.19302682926829;                          !- Vertex 4 Zcoordinate

BuildingSurface:Detailed ,
Roof_front_unit1 ,                         !- Name
Roof ,                                       !- Surface Type
Exterior_Roof ,                            !- Construction Name
attic_unit1 ,                               !- Zone Name
Outdoors ,                                    !- Outside Boundary Condition
,                                           !- Outside Boundary Condition Object
SunExposed ,                                !- Sun Exposure
WindExposed ,                               !- Wind Exposure
0 ,                                         !- View Factor to Ground
4 ,                                         !- Number of Vertices
0 ,                                         !- Vertex 1 Xcoordinate
0 ,                                         !- Vertex 1 Ycoordinate
5.19302682926829 ,                         !- Vertex 1 Zcoordinate
12.1330909462833 ,                         !- Vertex 2 Xcoordinate
0 ,                                         !- Vertex 2 Ycoordinate
5.19302682926829 ,                         !- Vertex 2 Zcoordinate

```

```

12.1330909462833 ,           !- Vertex 3 Xcoordinate
4.54990910485622 ,           !- Vertex 3 Ycoordinate
6.6995631975537 ,           !- Vertex 3 Zcoordinate
0 ,                           !- Vertex 4 Xcoordinate
4.54990910485622 ,           !- Vertex 4 Ycoordinate
6.6995631975537;            !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
Roof_back_unit1 ,             !- Name
Roof ,                         !- Surface Type
Exterior Roof ,                !- Construction Name
attic_unit1 ,                  !- Zone Name
Outdoors ,                     !- Outside Boundary Condition
,                               !- Outside Boundary Condition Object
SunExposed ,                   !- Sun Exposure
WindExposed ,                  !- Wind Exposure
0 ,                            !- View Factor to Ground
4 ,                            !- Number of Vertices
12.1330909462833 ,           !- Vertex 1 Xcoordinate
9.09981820971244 ,           !- Vertex 1 Ycoordinate
5.19302682926829 ,           !- Vertex 1 Zcoordinate
0 ,                            !- Vertex 2 Xcoordinate
9.09981820971244 ,           !- Vertex 2 Ycoordinate
5.19302682926829 ,           !- Vertex 2 Zcoordinate
0 ,                            !- Vertex 3 Xcoordinate
4.54990910485622 ,           !- Vertex 3 Ycoordinate
6.6995631975537 ,           !- Vertex 3 Zcoordinate
12.1330909462833 ,           !- Vertex 4 Xcoordinate
4.54990910485622 ,           !- Vertex 4 Ycoordinate
6.6995631975537;            !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
Roof_right_unit1 ,            !- Name
Wall ,                          !- Surface Type
Gable_end ,                     !- Construction Name
attic_unit1 ,                  !- Zone Name

```

```

Outdoors,
,                                     !- Outside Boundary Condition
SunExposed,
WindExposed,
,                                     !- View Factor to Ground
3,                                     !- Number of Vertices
12.1330909462833,                     !- Vertex 1 Xcoordinate
0,                                     !- Vertex 1 Ycoordinate
5.19302682926829,                     !- Vertex 1 Zcoordinate
12.1330909462833,                     !- Vertex 2 Xcoordinate
9.09981820971244,                     !- Vertex 2 Ycoordinate
5.19302682926829,                     !- Vertex 2 Zcoordinate
12.1330909462833,                     !- Vertex 3 Xcoordinate
4.54990910485622,                     !- Vertex 3 Ycoordinate
6.6995631975537;                      !- Vertex 3 Zcoordinate

BuildingSurface:Detailed,
Roof_left_unit1,                         !- Name
Wall,                                     !- Surface Type
Gable_end,                                !- Construction Name
attic_unit1,                               !- Zone Name
Outdoors,
,                                     !- Outside Boundary Condition
SunExposed,
WindExposed,
,                                     !- View Factor to Ground
3,                                     !- Number of Vertices
0,                                     !- Vertex 1 Xcoordinate
9.09981820971244,                     !- Vertex 1 Ycoordinate
5.19302682926829,                     !- Vertex 1 Zcoordinate
0,                                     !- Vertex 2 Xcoordinate
0,                                     !- Vertex 2 Ycoordinate
5.19302682926829,                     !- Vertex 2 Zcoordinate
0,                                     !- Vertex 3 Xcoordinate
4.54990910485622,                     !- Vertex 3 Ycoordinate
6.6995631975537;                      !- Vertex 3 Zcoordinate

```

```

BuildingSurface:Detailed,
    Wall_ldf_1.unit1,           !- Name
    Wall,                      !- Surface Type
    Exterior Wall,             !- Construction Name
    living_unit1,              !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    ,                          !- View Factor to Ground
    4,                         !- Number of Vertices
    0,                         !- Vertex 1 Xcoordinate
    0,                         !- Vertex 1 Ycoordinate
    0.0101,                   !- Vertex 1 Zcoordinate
    12.1330909462833,         !- Vertex 2 Xcoordinate
    0,                         !- Vertex 2 Ycoordinate
    0.0101,                   !- Vertex 2 Zcoordinate
    12.1330909462833,         !- Vertex 3 Xcoordinate
    0,                         !- Vertex 3 Ycoordinate
    2.60156341463415,         !- Vertex 3 Zcoordinate
    0,                         !- Vertex 4 Xcoordinate
    0,                         !- Vertex 4 Ycoordinate
    2.60156341463415;        !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
    Wall_sdr_1.unit1,           !- Name
    Wall,                      !- Surface Type
    Exterior Wall,             !- Construction Name
    living_unit1,              !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    ,                          !- View Factor to Ground
    4,                         !- Number of Vertices

```

```

12.1330909462833 ,           !- Vertex 1 Xcoordinate
0 ,                           !- Vertex 1 Ycoordinate
0.0101 ,                      !- Vertex 1 Zcoordinate
12.1330909462833 ,           !- Vertex 2 Xcoordinate
9.09981820971244 ,           !- Vertex 2 Ycoordinate
0.0101 ,                      !- Vertex 2 Zcoordinate
12.1330909462833 ,           !- Vertex 3 Xcoordinate
9.09981820971244 ,           !- Vertex 3 Ycoordinate
2.60156341463415 ,           !- Vertex 3 Zcoordinate
12.1330909462833 ,           !- Vertex 4 Xcoordinate
0 ,                           !- Vertex 4 Ycoordinate
2.60156341463415;          !- Vertex 4 Zcoordinate

BuildingSurface:Detailed ,
Wall_ldb_1.unit1 ,            !- Name
Wall ,                         !- Surface Type
Exterior Wall ,               !- Construction Name
living_unit1 ,                !- Zone Name
Outdoors ,                     !- Outside Boundary Condition
,                             !- Outside Boundary Condition Object
SunExposed ,                  !- Sun Exposure
WindExposed ,                 !- Wind Exposure
,                             !- View Factor to Ground
4 ,                           !- Number of Vertices
12.1330909462833 ,           !- Vertex 1 Xcoordinate
9.09981820971244 ,           !- Vertex 1 Ycoordinate
0.0101 ,                      !- Vertex 1 Zcoordinate
0 ,                           !- Vertex 2 Xcoordinate
9.09981820971244 ,           !- Vertex 2 Ycoordinate
0.0101 ,                      !- Vertex 2 Zcoordinate
0 ,                           !- Vertex 3 Xcoordinate
9.09981820971244 ,           !- Vertex 3 Ycoordinate
2.60156341463415 ,           !- Vertex 3 Zcoordinate
12.1330909462833 ,           !- Vertex 4 Xcoordinate
9.09981820971244 ,           !- Vertex 4 Ycoordinate
2.60156341463415;          !- Vertex 4 Zcoordinate

```

```

BuildingSurface:Detailed,
    Wall_sdl_1.unit1,           !- Name
    Wall,                      !- Surface Type
    Exterior Wall,             !- Construction Name
    living_unit1,              !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    ,                          !- View Factor to Ground
    4,                         !- Number of Vertices
    0,                         !- Vertex 1 Xcoordinate
    9.09981820971244,         !- Vertex 1 Ycoordinate
    0.0101,                   !- Vertex 1 Zcoordinate
    0,                         !- Vertex 2 Xcoordinate
    0,                         !- Vertex 2 Ycoordinate
    0.0101,                   !- Vertex 2 Zcoordinate
    0,                         !- Vertex 3 Xcoordinate
    0,                         !- Vertex 3 Ycoordinate
    2.60156341463415,         !- Vertex 3 Zcoordinate
    0,                         !- Vertex 4 Xcoordinate
    9.09981820971244,         !- Vertex 4 Ycoordinate
    2.60156341463415;        !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
    Wall_ldf_2.unit1,          !- Name
    Wall,                      !- Surface Type
    Exterior Wall,             !- Construction Name
    living_unit1,              !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    ,                          !- View Factor to Ground
    4,                         !- Number of Vertices

```

```

0,                                     !- Vertex 1 Xcoordinate
0,                                     !- Vertex 1 Ycoordinate
2.60156341463415,                     !- Vertex 1 Zcoordinate
12.1330909462833,                     !- Vertex 2 Xcoordinate
0,                                     !- Vertex 2 Ycoordinate
2.60156341463415,                     !- Vertex 2 Zcoordinate
12.1330909462833,                     !- Vertex 3 Xcoordinate
0,                                     !- Vertex 3 Ycoordinate
5.19302682926829,                     !- Vertex 3 Zcoordinate
0,                                     !- Vertex 4 Xcoordinate
0,                                     !- Vertex 4 Ycoordinate
5.19302682926829;                    !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
    Wall_sdr_2.unit1,                  !- Name
    Wall,                                !- Surface Type
    Exterior Wall,                      !- Construction Name
    living_unit1,                       !- Zone Name
    Outdoors,                            !- Outside Boundary Condition
    ,                                     !- Outside Boundary Condition Object
    SunExposed,                          !- Sun Exposure
    WindExposed,                         !- Wind Exposure
    ,                                     !- View Factor to Ground
    4,                                    !- Number of Vertices
    12.1330909462833,                  !- Vertex 1 Xcoordinate
    0,                                     !- Vertex 1 Ycoordinate
    2.60156341463415,                  !- Vertex 1 Zcoordinate
    12.1330909462833,                  !- Vertex 2 Xcoordinate
    9.09981820971244,                  !- Vertex 2 Ycoordinate
    2.60156341463415,                  !- Vertex 2 Zcoordinate
    12.1330909462833,                  !- Vertex 3 Xcoordinate
    9.09981820971244,                  !- Vertex 3 Ycoordinate
    5.19302682926829,                  !- Vertex 3 Zcoordinate
    12.1330909462833,                  !- Vertex 4 Xcoordinate
    0,                                     !- Vertex 4 Ycoordinate
    5.19302682926829;                 !- Vertex 4 Zcoordinate

```

```

BuildingSurface:Detailed,
    Wall_ldb_2.unit1,           !- Name
    Wall,                      !- Surface Type
    Exterior Wall,             !- Construction Name
    living_unit1,              !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    ,                          !- View Factor to Ground
    4,                         !- Number of Vertices
    12.1330909462833,         !- Vertex 1 Xcoordinate
    9.09981820971244,         !- Vertex 1 Ycoordinate
    2.60156341463415,         !- Vertex 1 Zcoordinate
    0,                         !- Vertex 2 Xcoordinate
    9.09981820971244,         !- Vertex 2 Ycoordinate
    2.60156341463415,         !- Vertex 2 Zcoordinate
    0,                         !- Vertex 3 Xcoordinate
    9.09981820971244,         !- Vertex 3 Ycoordinate
    5.19302682926829,         !- Vertex 3 Zcoordinate
    12.1330909462833,         !- Vertex 4 Xcoordinate
    9.09981820971244,         !- Vertex 4 Ycoordinate
    5.19302682926829;        !- Vertex 4 Zcoordinate

```

```

BuildingSurface:Detailed,
    Wall_sdl_2.unit1,           !- Name
    Wall,                      !- Surface Type
    Exterior Wall,             !- Construction Name
    living_unit1,              !- Zone Name
    Outdoors,                  !- Outside Boundary Condition
    ,                          !- Outside Boundary Condition Object
    SunExposed,                !- Sun Exposure
    WindExposed,               !- Wind Exposure
    ,                          !- View Factor to Ground
    4,                         !- Number of Vertices

```

```

0,                                     !- Vertex 1 Xcoordinate
9.09981820971244,                     !- Vertex 1 Ycoordinate
2.60156341463415,                     !- Vertex 1 Zcoordinate
0,                                     !- Vertex 2 Xcoordinate
0,                                     !- Vertex 2 Ycoordinate
2.60156341463415,                     !- Vertex 2 Zcoordinate
0,                                     !- Vertex 3 Xcoordinate
0,                                     !- Vertex 3 Ycoordinate
5.19302682926829,                     !- Vertex 3 Zcoordinate
0,                                     !- Vertex 4 Xcoordinate
9.09981820971244,                     !- Vertex 4 Ycoordinate
5.19302682926829;                    !- Vertex 4 Zcoordinate

BuildingSurface:Detailed,
Floor_unit1,                           !- Name
Floor,                                  !- Surface Type
Interior Floor,                        !- Construction Name
living_unit1,                          !- Zone Name
Ground,                                 !- Outside Boundary Condition
,                                      !- Outside Boundary Condition Object
NoSun,                                 !- Sun Exposure
NoWind,                                !- Wind Exposure
0,                                     !- View Factor to Ground
4,                                     !- Number of Vertices
0,                                     !- Vertex 1 Xcoordinate
0,                                     !- Vertex 1 Ycoordinate
0.0101,                               !- Vertex 1 Zcoordinate
0,                                     !- Vertex 2 Xcoordinate
9.09981820971244,                     !- Vertex 2 Ycoordinate
0.0101,                               !- Vertex 2 Zcoordinate
12.1330909462833,                    !- Vertex 3 Xcoordinate
9.09981820971244,                     !- Vertex 3 Ycoordinate
0.0101,                               !- Vertex 3 Zcoordinate
12.1330909462833,                    !- Vertex 4 Xcoordinate
0,                                     !- Vertex 4 Ycoordinate
0.0101;                               !- Vertex 4 Zcoordinate

```

```

Window ,
    Window_ldf_1.unit1,           !- Name
    Exterior Window,             !- Construction Name
    Wall_ldf_1.unit1,            !- Building Surface Name
    ,                           !- Frame and Divider Name
    1,                           !- Multiplier
    1,                           !- Starting X Coordinate
    0.914634146341463,          !- Starting Z Coordinate
    2.70719591738945,           !- Length
    1.52439024390244;          !- Height

Window ,
    Window_ldb_1.unit1,           !- Name
    Exterior Window,             !- Construction Name
    Wall_ldb_1.unit1,            !- Building Surface Name
    ,                           !- Frame and Divider Name
    1,                           !- Multiplier
    2.74190122145512,           !- Starting X Coordinate
    0.914634146341463,          !- Starting Z Coordinate
    2.70719591738945,           !- Length
    1.52439024390244;          !- Height

Window ,
    Window_sdr_1.unit1,           !- Name
    Exterior Window,             !- Construction Name
    Wall_sdr_1.unit1,            !- Building Surface Name
    ,                           !- Frame and Divider Name
    1,                           !- Multiplier
    1,                           !- Starting X Coordinate
    0.914634146341463,          !- Starting Z Coordinate
    2.70719591738945,           !- Length
    1.52439024390244;          !- Height

Window ,
    Window_sdl_1.unit1,           !- Name

```

```

Exterior Window,
Wall_sdl_1.unit1,
,
1,
1,
0.914634146341463,
2.70719591738945,
1.52439024390244;           !- Construction Name
                               !- Building Surface Name
                               !- Frame and Divider Name
                               !- Multiplier
                               !- Starting X Coordinate
                               !- Starting Z Coordinate
                               !- Length
                               !- Height

Window,
Window_ldf_2.unit1,
Exterior Window,
Wall_ldf_2.unit1,
,
1,
1,
0.914634146341463,
2.70719591738945,
1.52439024390244;           !- Name
                               !- Construction Name
                               !- Building Surface Name
                               !- Frame and Divider Name
                               !- Multiplier
                               !- Starting X Coordinate
                               !- Starting Z Coordinate
                               !- Length
                               !- Height

Window,
Window_ldb_2.unit1,
Exterior Window,
Wall_ldb_2.unit1,
,
1,
2.74190122145512,
0.914634146341463,
2.70719591738945,
1.52439024390244;           !- Name
                               !- Construction Name
                               !- Building Surface Name
                               !- Frame and Divider Name
                               !- Multiplier
                               !- Starting X Coordinate
                               !- Starting Z Coordinate
                               !- Length
                               !- Height

Window,
Window_sdr_2.unit1,
Exterior Window,
Wall_sdr_2.unit1,
,                           !- Name
                               !- Construction Name
                               !- Building Surface Name
                               !- Frame and Divider Name

```

```

1,                                !- Multiplier
1,                                !- Starting X Coordinate
0.914634146341463,               !- Starting Z Coordinate
2.70719591738945,                !- Length
1.52439024390244;               !- Height

Window,
  Window_sdl_2.unit1,             !- Name
  Exterior Window,               !- Construction Name
  Wall_sdl_2.unit1,              !- Building Surface Name
  ,                               !- Frame and Divider Name
  1,                                !- Multiplier
  1,                                !- Starting X Coordinate
  0.914634146341463,              !- Starting Z Coordinate
  2.70719591738945,                !- Length
  1.52439024390244;               !- Height

Door,
  Door_ldb_unit1,                !- Name
  Exterior Door,                  !- Construction Name
  Wall_ldb_1.unit1,               !- Building Surface Name
  1,                                !- Multiplier
  0.5,                               !- Starting X Coordinate
  0,                                !- Starting Z Coordinate
  1.74190122145513,                !- Length
  2.13414634146341;               !- Height

WindowShadingControl ,
  Shades-living_unit1,            !- Name
  living_unit1,                   !- Zone Name
  1,                                !- Shading Control Sequence Number
  InteriorBlind,                  !- Shading Type
  window_w_blinds,                 !- Construction with Shading Name
  OnIfScheduleAllows,              !- Shading Control Type
  shading_2012iecc,                !- Schedule Name
  ,                                !- Setpoint

```

```

Yes,                                     !- Shading Control Is Scheduled
No,                                      !- Glare Control Is Active
,                                         !- Shading Device Material Name
,                                         !- Type of Slat Angle Control for
Blinds

,                                         !- Slat Angle Schedule Name
,                                         !- Setpoint 2
,                                         !- Daylighting Control Object Name
Sequential,                                !- Multiple Surface Control Type
Window_ldf_1.unit1,                         !- Fenestration Surface 1 Name
Window_ldb_1.unit1,                         !- Fenestration Surface 2 Name
Window_sdr_1.unit1,                         !- Fenestration Surface 3 Name
Window sdl_1.unit1,                         !- Fenestration Surface 4 Name
Window_ldf_2.unit1,                         !- Fenestration Surface 5 Name
Window_ldb_2.unit1,                         !- Fenestration Surface 6 Name
Window_sdr_2.unit1,                         !- Fenestration Surface 7 Name
Window sdl_2.unit1;                         !- Fenestration Surface 8 Name

InternalMass,
Internalmass_unit1,                        !- Name
InteriorFurnishings,                      !- Construction Name
living_unit1,                               !- Zone or ZoneList Name
9.89591078066915;                        !- Surface Area

Shading:Overhang,
Overhang_sdr_1.unit1,                      !- Name
Window_sdr_1.unit1,                         !- Window or Door Name
0,                                         !- Height above Window or Door
90,                                        !- Tilt Angle from WindowDoor
0,                                         !- Left extension from WindowDoor
Width
0,                                         !- Right extension from WindowDoor
Width
0.0152439024390244;                      !- Depth

Shading:Overhang ,

```

```

Overhang_sdr_2.unit1,      !- Name
Window_sdr_2.unit1,        !- Window or Door Name
0,                         !- Height above Window or Door
90,                        !- Tilt Angle from WindowDoor
0,                         !- Left extension from WindowDoor
Width
0,                         !- Right extension from WindowDoor
Width
0.0152439024390244;     !- Depth

GroundHeatTransfer:Control,
gtp_control,               !- Name
no,                        !- Run Basement Preprocessor
yes;                       !- Run Slab Preprocessor

GroundHeatTransfer:Slab:Materials,
2,                          !- NMAT Number of materials
0.16,                      !- ALBEDO Surface Albedo No Snow
0.4,                       !- ALBEDO Surface Albedo Snow
0.9,                       !- EPSLW Surface Emissivity No Snow
0.9,                       !- EPSLW Surface Emissivity Snow
0.75,                      !- Z0 Surface Roughness No Snow
0.05,                      !- Z0 Surface Roughness Snow
6,                          !- HIN Indoor HConv Downward Flow
9;                         !- HIN Indoor HConv Upward

GroundHeatTransfer:Slab:Mat1Props,
2300,                      !- RHO Slab Material density
1200,                      !- RHO Soil Density
650,                       !- CP Slab CP
1200,                      !- CP Soil CP
0.9,                       !- TCON Slab k
1;                          !- TCON Soil k

GroundHeatTransfer:Slab:BoundConds,
FALSE,                     !- EVTR Is surface evapotranspiration

```

```

modeled

    TRUE,                                !- FIXBC is the lower boundary at a
fixed temperature

    10,                                   !- TDEEPin

    FALSE;                                !- USRHflag Is the ground surface h
specified by the user

GroundHeatTransfer:Slab:BldgProps ,
    10,                                     !- IYRS Number of years to iterate
    0,                                      !- Shape Slab shape
    4,                                      !- HBLDG Building height
    22.22,                                  !- TIN1 January Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN2 February Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN3 March Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN4 April Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN5 May Indoor Average Temperature

Setpoint
    23.88,                                  !- TIN6 June Indoor Average

Temperature Setpoint
    23.88,                                  !- TIN7 July Indoor Average

Temperature Setpoint
    23.88,                                  !- TIN8 August Indoor Average

Temperature Setpoint
    23.88,                                  !- TIN9 September Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN10 October Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN11 November Indoor Average

Temperature Setpoint
    22.22,                                  !- TIN12 December Indoor Average

Temperature Setpoint
    0,                                      !- TINAmp Daily Indoor sine wave

```

```

variation amplitude
0.1;                                !- ConvTol Convergence Tolerance

GroundHeatTransfer:Slab:Insulation ,
0,                                     !- RINS R value of under slab
insulation
0,                                     !- DINS Width of strip of under slab
insulation
0,                                     !- RVINS R value of vertical
insulation
0.6,                                    !- ZVINS Depth of vertical insulation
0;                                     !- IVINS Flag Is there vertical
insulation

GroundHeatTransfer:Slab:EquivalentSlab ,
2.59994805991784,                      !- APRatio The area to perimeter ratio
for this slab
0.1,                                    !- SLABDEPTH Thickness of slab on
grade
15,                                     !- CLEARANCE Distance from edge of
slab to domain edge
15;                                     !- ZCLEARANCE Distance from bottom of
slab to domain bottom

GroundHeatTransfer:Basement:SimParameters ,
0.1,                                    !- F Multiplier for the ADI solution
15;                                     !- IYRS Maximum number of yearly
iterations

GroundHeatTransfer:Basement:MatlProps ,
6,                                      !- NMAT Number of materials in this
domain
2243,                                    !- Density for Foundation Wall
2243,                                    !- density for Floor Slab
311,                                     !- density for Ceiling
1500,                                    !- density for Soil

```

```

2000,                               !- density for Gravel
449,                                !- density for Wood
880,                                !- Specific heat for foundation wall
880,                                !- Specific heat for floor slab
1530,                               !- Specific heat for ceiling
840,                                !- Specific heat for soil
720,                                !- Specific heat for gravel
1530,                               !- Specific heat for wood
1.4,                                 !- Thermal conductivity for foundation
wall
1.4,                                !- Thermal conductivity for floor slab
0.09,                               !- Thermal conductivity for ceiling
1.1,                                 !- thermal conductivity for soil
1.9,                                 !- thermal conductivity for gravel
0.12;                               !- thermal conductivity for wood

GroundHeatTransfer:Basement:Insulation,
1.76099742894375e-05,           !- REXT R Value of any exterior
insulation
True;                            !- INSFULL Flag Is the wall fully
insulated

GroundHeatTransfer:Basement:SurfaceProps ,
0.16,                               !- ALBEDO Surface albedo for No snow
conditions
0.4,                                !- ALBEDO Surface albedo for snow
conditions
0.94,                               !- EPSLN Surface emissivity No Snow
0.86,                               !- EPSLN Surface emissivity with Snow
6,                                    !- VEGHT Surface roughness No snow
conditions
0.25,                               !- VEGHT Surface roughness Snow
conditions
False;                            !- PET Flag Potential
evapotranspiration on

```

```

GroundHeatTransfer:Basement:BldgData ,
  0.200000006162114 ,           !- DWALL Wall thickness
  0.243828108701145 ,           !- DSLAB Floor slab thickness
  0.3 ,                          !- DGRAVXY Width of gravel pit beside
  basement wall
  0.2 ,                          !- DGRAVZN Gravel depth extending
  above the floor slab
  0.1;                           !- DGRAVZP Gravel depth below the
  floor slab

GroundHeatTransfer:Basement:Interior ,
  True ,                         !- COND Flag Is the basement
  conditioned
  0.92 ,                          !- HIN Downward convection only heat
  transfer coefficient
  4.04 ,                          !- HIN Upward convection only heat
  transfer coefficient
  3.08 ,                          !- HIN Horizontal convection only heat
  transfer coefficient
  6.13 ,                          !- HIN Downward combined convection
  and radiation heat transfer coefficient
  9.26 ,                          !- HIN Upward combined convection and
  radiation heat transfer coefficient
  8.29;                           !- HIN Horizontal combined convection
  and radiation heat transfer coefficient

GroundHeatTransfer:Basement:ComBldg ,
  21 ,                            !- January average temperature
  21 ,                            !- February average temperature
  21 ,                            !- March average temperature
  21 ,                            !- April average temperature
  24 ,                            !- May average temperature
  24 ,                            !- June average temperature
  24 ,                            !- July average temperature
  24 ,                            !- August average temperature
  24 ,                            !- September average temperature

```

```

24,                                     !- October average temperature
21,                                     !- November average temperature
21,                                     !- December average temperature
21;                                     !- Daily variation sine wave amplitude

GroundHeatTransfer:Basement:EquivSlab,
2.59994805991784,           !- APRatio The area to perimeter ratio
for this slab
True;                         !- EquivSizing Flag

GroundHeatTransfer:Basement:EquivAutoGrid,
15,                           !- CLEARANCE Distance from outside of
wall to edge of 3D ground domain
0.1,                          !- SlabDepth Thickness of the floor
slab
1.21914054350572;          !- BaseDepth Depth of the basement
wall below grade

People,
people_unit1,                !- Name
living_unit1,                !- Zone or ZoneList Name
Occupancy,                   !- Number of People Schedule Name
People,                      !- Number of People Calculation Method
3,                           !- Number of People
,                            !- People per Zone Floor Area
,                            !- Zone Floor Area per Person
0,                           !- Fraction Radian
autocalculate,              !- Sensible Heat Fraction
activity_sch,                !- Activity Level Schedule Name
,                            !- Carbon Dioxide Generation Rate
No,                          !- Enable ASHRAE 55 Comfort Warnings
ZoneAveraged,               !- Mean Radian Temperature
Calculation Type
,                            !- Surface NameAngle Factor List Name
Work Eff Sch,                !- Work Efficiency Schedule Name
ClothingInsulationSchedule, !- Clothing Insulation

```

```

Calculation Method
,
                               !- Clothing Insulation Calculation

Method Schedule Name
Clothing Sch,                  !- Clothing Insulation Schedule Name
Air Velo Sch,                 !- Air Velocity Schedule Name
Fanger,                        !- Thermal Comfort Model 1 Type
Pierce,                         !- Thermal Comfort Model 2 Type
AdaptiveASH55,                !- Thermal Comfort Model 3 Type
KSU;                            !- Thermal Comfort Model 4 Type

Lights,
Living Hardwired Lighting1,    !- Name
living_unit1,                  !- Zone or ZoneList Name
InteriorLightingHE,            !- Schedule Name
Watts/Area,                    !- Design Level Calculation Method
,
                               !- Lighting Level
1.05216214401829,            !- Watts per Zone Floor Area
,
                               !- Watts per Person
0,                             !- Return Air Fraction
0.6,                           !- Fraction Radiant
0.2,                           !- Fraction Visible
0;                            !- Fraction Replaceable

Lights,
Living Plug-in Lighting1,     !- Name
living_unit1,                  !- Zone or ZoneList Name
InteriorLightingHE,            !- Schedule Name
Watts/Area,                    !- Design Level Calculation Method
,
                               !- Lighting Level
0.478467682251396,            !- Watts per Zone Floor Area
,
                               !- Watts per Person
0,                             !- Return Air Fraction
0.6,                           !- Fraction Radiant
0.2,                           !- Fraction Visible
0;                            !- Fraction Replaceable

```

```

ElectricEquipment ,
  ceiling_fan ,                               !- Name
  living_unit1 ,                             !- Zone or ZoneList Name
  fan_sch ,                                !- Schedule Name
  EquipmentLevel ,                          !- Design Level Calculation Method
  230 ,                                     !- Design Level
  ,                                         !- Watts per Zone Floor Area
  ,                                         !- Watts per Person
  0 ,                                       !- Fraction Latent
  0.4 ,                                     !- Fraction Radiant
  0 ,                                       !- Fraction Lost
  General;                                  !- EndUse Subcategory

ElectricEquipment ,
  dishwasher1 ,                               !- Name
  living_unit1 ,                             !- Zone or ZoneList Name
  DishWasher ,                            !- Schedule Name
  EquipmentLevel ,                          !- Design Level Calculation Method
  65.698787492023 ,                      !- Design Level
  ,                                         !- Watts per Zone Floor Area
  ,                                         !- Watts per Person
  0.15 ,                                    !- Fraction Latent
  0.6 ,                                     !- Fraction Radiant
  0.25 ,                                    !- Fraction Lost
  dishwasher;                            !- EndUse Subcategory

ElectricEquipment ,
  refrigerator1 ,                           !- Name
  living_unit1 ,                            !- Zone or ZoneList Name
  Refrigerator ,                           !- Schedule Name
  EquipmentLevel ,                         !- Design Level Calculation Method
  91.0575745202123 ,                      !- Design Level
  ,                                         !- Watts per Zone Floor Area
  ,                                         !- Watts per Person
  0 ,                                       !- Fraction Latent
  1 ,                                       !- Fraction Radiant

```

```

0,                                     !- Fraction Lost
refrigerator;                           !- EndUse Subcategory

ElectricEquipment,
clotheswasher1,                         !- Name
living_unit1,                            !- Zone or ZoneList Name
ClothesWasher,                           !- Schedule Name
EquipmentLevel,                         !- Design Level Calculation Method
28.4784377542718,                      !- Design Level
,                                         !- Watts per Zone Floor Area
,                                         !- Watts per Person
0,                                         !- Fraction Latent
0.8,                                       !- Fraction Radiant
0.2,                                       !- Fraction Lost
clotheswasher;                           !- EndUse Subcategory

ElectricEquipment,
electric_dryer1,                         !- Name
living_unit1,                            !- Zone or ZoneList Name
ClothesDryer,                            !- Schedule Name
EquipmentLevel,                         !- Design Level Calculation Method
213.064557285022,                      !- Design Level
,                                         !- Watts per Zone Floor Area
,                                         !- Watts per Person
0.05,                                      !- Fraction Latent
0.15,                                      !- Fraction Radiant
0.8,                                       !- Fraction Lost
electric_dryer;                          !- EndUse Subcategory

ElectricEquipment,
electric_range1,                         !- Name
living_unit1,                            !- Zone or ZoneList Name
CookingRange,                            !- Schedule Name
EquipmentLevel,                         !- Design Level Calculation Method
248.154224774405,                      !- Design Level
,                                         !- Watts per Zone Floor Area

```

```

        ,                               !- Watts per Person
0.3,                                !- Fraction Latent
0.4,                                !- Fraction Radiant
0.3,                                !- Fraction Lost
electric_range;                      !- EndUse Subcategory

ElectricEquipment,
    television1,                     !- Name
    living_unit1,                    !- Zone or ZoneList Name
    InteriorLighting,               !- Schedule Name
    EquipmentLevel,                !- Design Level Calculation Method
    0,                                !- Design Level
    ,                                !- Watts per Zone Floor Area
    ,                                !- Watts per Person
    0,                                !- Fraction Latent
    1,                                !- Fraction Radiant
    0,                                !- Fraction Lost
    television;                      !- EndUse Subcategory

ElectricEquipment,
    electric_mels1,                 !- Name
    living_unit1,                    !- Zone or ZoneList Name
    MiscPlugLoad,                   !- Schedule Name
    EquipmentLevel,                !- Design Level Calculation Method
    567.464237516869,              !- Design Level
    ,                                !- Watts per Zone Floor Area
    ,                                !- Watts per Person
    0.06,                             !- Fraction Latent
    0.69,                             !- Fraction Radiant
    0.25,                             !- Fraction Lost
    electric_mels;                  !- EndUse Subcategory

ElectricEquipment,
    IECC_Adj1,                      !- Name
    living_unit1,                    !- Zone or ZoneList Name
    MiscPlugLoad,                   !- Schedule Name

```

```

Watts/Area,
,                                     !- Design Level Calculation Method
,                                     !- Design Level
1.54356736989469,                     !- Watts per Zone Floor Area
,                                     !- Watts per Person
0.0624390461422629,                   !- Fraction Latent
0.41190936353998,                     !- Fraction Radiant
0.251045347957769,                   !- Fraction Lost
IECC_adj;                                !- EndUse Subcategory

ZoneVentilation:DesignFlowRate,
Ventilation_unit1,                      !- Name
living_unit1,                            !- Zone or ZoneList Name
always_avail,                            !- Schedule Name
Flow/Zone,                               !- Design Flow Rate Calculation Method
0,                                      !- Design Flow Rate
,                                      !- Flow Rate per Zone Floor Area
,                                      !- Flow Rate per Person
,                                      !- Air Changes per Hour
Exhaust,                                 !- Ventilation Type
0,                                      !- Fan Pressure Rise
0.6,                                     !- Fan Total Efficiency
1,                                      !- Constant Term Coefficient
0,                                      !- Temperature Term Coefficient
0,                                      !- Velocity Term Coefficient
0,                                      !- Velocity Squared Term Coefficient
-100,                                    !- Minimum Indoor Temperature
,                                      !- Minimum Indoor Temperature Schedule
Name
100,                                     !- Maximum Indoor Temperature
,                                      !- Maximum Indoor Temperature Schedule
Name
-100,                                    !- Delta Temperature
,                                      !- Delta Temperature Schedule Name
-100,                                    !- Minimum Outdoor Temperature
,                                      !- Minimum Outdoor Temperature
Schedule Name

```

```

100,                                     !- Maximum Outdoor Temperature
,
!- Maximum Outdoor Temperature

Schedule Name

40;                                      !- Maximum Wind Speed

AirflowNetwork:SimulationControl,
    House AirflowNetwork,      !- Name
    MultizoneWithDistribution, !- AirflowNetwork Control
    SurfaceAverageCalculation, !- Wind Pressure Coefficient Type
    ,                         !- Height Selection for Local Wind
    Pressure Calculation
    LOWRISE,                  !- Building Type
    500,                      !- Maximum Number of Iterations
    ,                         !- Initialization Type
    0.001,                    !- Relative Airflow Convergence
    Tolerance
    1e-05,                   !- Absolute Airflow Convergence
    Tolerance
    0,                        !- Convergence Acceleration Limit
    0,                        !- Azimuth Angle of Long Axis of
    Building
    0.75,                     !- Ratio of Building Width Along Short
    Axis to Width Along Long Axis
    ,                         !- Height Dependence of External Node
    Temperature
    ,                         !- Solver
    Yes;                      !- Allow Unsupported Zone Equipment

AirflowNetwork:MultiZone:Zone ,
    living_unit1,            !- Zone Name
    NoVent,                 !- Ventilation Control Mode
    ,                       !- Ventilation Control Zone
    Temperature Setpoint Schedule Name
    0,                      !- Minimum Venting Open Factor
    0,                      !- Indoor and Outdoor Temperature
    Difference Lower Limit For Maximum Venting Open Factor

```

```

100,                               !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor
0,                                    !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor
300000;                             !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor

AirflowNetwork:MultiZone:Zone,
attic_unit1,                         !- Zone Name
Constant,                            !- Ventilation Control Mode
,                                     !- Ventilation Control Zone
Temperature Setpoint Schedule Name
,                                     !- Minimum Venting Open Factor
,                                     !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor
100,                                 !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor
,                                     !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor
300000,                             !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor
inf_sch;                            !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
Roof_front_unit1,                   !- Surface Name
AtticVent,                           !- Leakage Component Name
,                                     !- External Node Name
1,                                    !- WindowDoor Opening Factor or Crack
Factor
Constant,                            !- Ventilation Control Mode
,                                     !- Ventilation Control Zone
Temperature Setpoint Schedule Name
0,                                    !- Minimum Venting Open Factor
,                                     !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor
100,                                !- Indoor and Outdoor Temperature

```

```

Difference Upper Limit for Minimum Venting Open Factor
,
          !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor
300000,
          !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor
inf_sch;           !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
Roof_back_unit1,           !- Surface Name
AtticVent,                 !- Leakage Component Name
,
          !- External Node Name
1,                         !- WindowDoor Opening Factor or Crack
Factor
Constant,                  !- Ventilation Control Mode
,
          !- Ventilation Control Zone
Temperature Setpoint Schedule Name
,
          !- Minimum Venting Open Factor
,
          !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor
100,                        !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor
,
          !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor
300000,
          !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor
inf_sch;           !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
Roof_right_unit1,           !- Surface Name
AtticVent,                 !- Leakage Component Name
,
          !- External Node Name
1,                         !- WindowDoor Opening Factor or Crack
Factor
Constant,                  !- Ventilation Control Mode
,
          !- Ventilation Control Zone
Temperature Setpoint Schedule Name

```

```

        ,                               !- Minimum Venting Open Factor
        ,                               !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor
100,                                !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor
        ,                               !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor
300000,                                !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor
inf_sch;                               !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
Roof_left_unit1,                      !- Surface Name
AtticVent,                            !- Leakage Component Name
        ,                           !- External Node Name
1,                                    !- WindowDoor Opening Factor or Crack
Factor
Constant,                            !- Ventilation Control Mode
        ,                           !- Ventilation Control Zone
Temperature Setpoint Schedule Name
        ,                               !- Minimum Venting Open Factor
        ,                               !- Indoor and Outdoor Temperature
Difference Lower Limit For Maximum Venting Open Factor
100,                                !- Indoor and Outdoor Temperature
Difference Upper Limit for Minimum Venting Open Factor
        ,                               !- Indoor and Outdoor Enthalpy
Difference Lower Limit For Maximum Venting Open Factor
300000,                                !- Indoor and Outdoor Enthalpy
Difference Upper Limit for Minimum Venting Open Factor
inf_sch;                               !- Venting Availability Schedule Name

AirflowNetwork:MultiZone:Surface,
ceiling_unit1,                      !- Surface Name
ZoneLeak_Ceiling,                    !- Leakage Component Name
        ,                           !- External Node Name
1,                                    !- WindowDoor Opening Factor or Crack

```

```

Factor
NoVent;                      !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_ldf_1.unit1,           !- Surface Name
    ZoneLeak_LongWall,         !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                      !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_ldb_1.unit1,           !- Surface Name
    ZoneLeak_LongWall,         !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                      !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_sdl_1.unit1,           !- Surface Name
    ZoneLeak_ShortWall,        !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                      !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
    Wall_sdr_1.unit1,           !- Surface Name
    ZoneLeak_ShortWall,        !- Leakage Component Name
    ,                         !- External Node Name
    1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                      !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,

```

```

Wall_ldf_2.unit1,           !- Surface Name
ZoneLeak_LongWall,         !- Leakage Component Name
,                         !- External Node Name
1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
Wall_ldb_2.unit1,           !- Surface Name
ZoneLeak_LongWall,          !- Leakage Component Name
,                         !- External Node Name
1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
Wall_sdr_2.unit1,           !- Surface Name
ZoneLeak_ShortWall,         !- Leakage Component Name
,                         !- External Node Name
1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface,
Wall_sdl_2.unit1,           !- Surface Name
ZoneLeak_ShortWall,         !- Leakage Component Name
,                         !- External Node Name
1,                         !- WindowDoor Opening Factor or Crack
Factor
NoVent;                   !- Ventilation Control Mode

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
ZoneLeak_LongWall,          !- Name
0.00566687461767392,       !- Effective Leakage Area
1.15,                      !- Discharge Coefficient
4,                         !- Reference Pressure Difference

```

```

0.65;                               !- Air Mass Flow Exponent

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    ZoneLeak_ShortWall,           !- Name
    0.00425015596325544,         !- Effective Leakage Area
    1.15,                         !- Discharge Coefficient
    4,                            !- Reference Pressure Difference
    0.65;                         !- Air Mass Flow Exponent

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    ZoneLeak_Ceiling,            !- Name
    0.019898999363395,          !- Effective Leakage Area
    1.15,                         !- Discharge Coefficient
    4,                            !- Reference Pressure Difference
    0.65;                         !- Air Mass Flow Exponent

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    ZoneLeak_Floor,              !- Name
    1e-05,                        !- Effective Leakage Area
    1.15,                         !- Discharge Coefficient
    4,                            !- Reference Pressure Difference
    0.65;                         !- Air Mass Flow Exponent

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    AtticVent,                   !- Name
    0.37,                         !- Effective Leakage Area
    1.15,                         !- Discharge Coefficient
    4,                            !- Reference Pressure Difference
    0.65;                         !- Air Mass Flow Exponent

AirflowNetwork:MultiZone:Surface:EffectiveLeakageArea,
    CrawlVent,                   !- Name
    0.37,                         !- Effective Leakage Area
    1.15,                         !- Discharge Coefficient
    4,                            !- Reference Pressure Difference
    0.65;                         !- Air Mass Flow Exponent

```

```

AirflowNetwork:Distribution:Node ,
    EquipmentInletNode_unit1 ,      !- Name
    Zone Equipment Inlet Node_unit1 ,      !- Component Name or Node
Name
    Other ,                      !- Component Object Type or Node Type
    3;                          !- Node Height


AirflowNetwork:Distribution:Node ,
    SplitterNode_unit1 ,      !- Name
    ,                         !- Component Name or Node Name
    AirLoopHVAC:ZoneSplitter ,      !- Component Object Type or Node
Type
    3;                          !- Node Height


AirflowNetwork:Distribution:Node ,
    ZoneSupplyNode_unit1 ,      !- Name
    ,                         !- Component Name or Node Name
    Other ,                      !- Component Object Type or Node Type
    3;                          !- Node Height


AirflowNetwork:Distribution:Node ,
    ZoneSupplyRegisterNode_unit1 ATInlet ,      !- Name
    Zone Inlet Node_unit1 ATInlet ,      !- Component Name or Node Name
    Other ,                      !- Component Object Type or Node Type
    3;                          !- Node Height


AirflowNetwork:Distribution:Node ,
    ZoneSupplyRegisterNode_unit1 ,      !- Name
    Zone Inlet Node_unit1 ,      !- Component Name or Node Name
    Other ,                      !- Component Object Type or Node Type
    3;                          !- Node Height


AirflowNetwork:Distribution:Node ,
    ZoneOutletNode_unit1 ,      !- Name
    Zone Outlet node_unit1 ,      !- Component Name or Node Name

```

```

    Other ,           !- Component Object Type or Node Type
    3;               !- Node Height

AirflowNetwork:Distribution:Node ,
    ZoneReturnNode_unit1 ,      !- Name
    ,
    !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3;               !- Node Height

AirflowNetwork:Distribution:Node ,
    MixerNode_unit1 ,      !- Name
    ,
    !- Component Name or Node Name
    AirLoopHVAC:ZoneMixer , !- Component Object Type or Node Type
    3;               !- Node Height

AirflowNetwork:Distribution:Node ,
    MainReturnNode_unit1 ,      !- Name
    Return Air Mixer Outlet_unit1 ,   !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3;               !- Node Height

AirflowNetwork:Distribution:Node ,
    MainInletNode_unit1 ,      !- Name
    Air Loop Inlet Node_unit1 ,   !- Component Name or Node Name
    Other ,           !- Component Object Type or Node Type
    3;               !- Node Height

AirflowNetwork:Distribution:Node ,
    FanOutletNode_unit1 ,      !- Name
    Cooling Coil Air Inlet Node_unit1 ,   !- Component Name or Node
    Name
    Other ,           !- Component Object Type or Node Type
    3;               !- Node Height

AirflowNetwork:Distribution:Node ,
    HeatingInletNode_unit1 ,      !- Name

```

```

    Heating Coil Air Inlet Node_unit1,      !- Component Name or Node
Name

    Other,                      !- Component Object Type or Node Type
3;                           !- Node Height


AirflowNetwork:Distribution:Node,
    HeatingOutletNode_unit1,      !- Name
    Air Loop Outlet Node_unit1,   !- Component Name or Node Name
    Other,                      !- Component Object Type or Node Type
3;                           !- Node Height


AirflowNetwork:Distribution:Node,
    SuppHeatingInletNode_unit1,   !- Name
    Supp Heating coil air inlet Node_unit1,   !- Component Name or
Node Name
    Other,                      !- Component Object Type or Node Type
3;                           !- Node Height


AirflowNetwork:Distribution:Component:LeakageRatio,
    SupplyLeak,                !- Name
    0.0396,                    !- Effective Leakage Ratio
    0.56034,                  !- Maximum Flow Rate
    25,                        !- Reference Pressure Difference
    0.65;                     !- Air Mass Flow Exponent


AirflowNetwork:Distribution:Component:LeakageRatio,
    ReturnLeak,                !- Name
    0.0396,                    !- Effective Leakage Ratio
    0.56034,                  !- Maximum Flow Rate
    25,                        !- Reference Pressure Difference
    0.65;                     !- Air Mass Flow Exponent


AirflowNetwork:Distribution:Component:Duct,
    MainTrunk_unit1,           !- Name
    2,                          !- Duct Length
    0.591921113608382,        !- Hydraulic Diameter

```

```

0.275216110019646 ,           !- Cross Section Area
0.0009 ,                      !- Surface Roughness
0.01 ,                         !- Coefficient for Local Dynamic Loss
Due to Fitting
0.709825 ,                     !- Heat Transmittance Coefficient
UFactor for Duct Wall Construction
1e-07;                          !- Overall Moisture Transmittance
Coefficient from Air to Air

```

```

AirflowNetwork:Distribution:Component:Duct ,
ZoneSupply_unit1 ,             !- Name
15 ,                           !- Duct Length
0.591921113608382 ,          !- Hydraulic Diameter
0.275216110019646 ,          !- Cross Section Area
0.0009 ,                       !- Surface Roughness
10 ,                           !- Coefficient for Local Dynamic Loss
Due to Fitting
0.709825 ,                     !- Heat Transmittance Coefficient
UFactor for Duct Wall Construction
1e-07;                          !- Overall Moisture Transmittance
Coefficient from Air to Air

```

```

AirflowNetwork:Distribution:Component:Duct ,
ZoneSupplyLink2_unit1 ATInlet Duct ,      !- Name
0.0001 ,                        !- Duct Length
0.591921113608382 ,          !- Hydraulic Diameter
0.275216110019646 ,          !- Cross Section Area
0.0009 ,                        !- Surface Roughness
0 ,                            !- Coefficient for Local Dynamic Loss
Due to Fitting
0.709825 ,                     !- Heat Transmittance Coefficient
UFactor for Duct Wall Construction
1e-07;                          !- Overall Moisture Transmittance
Coefficient from Air to Air

```

```

AirflowNetwork:Distribution:Component:Duct ,

```

```

ZoneReturn_unit1 ,           !- Name
8,                         !- Duct Length
0.529430338938287 ,       !- Hydraulic Diameter
0.220172888015717 ,       !- Cross Section Area
0.0009 ,                   !- Surface Roughness
9,                         !- Coefficient for Local Dynamic Loss

Due to Fitting
0.709825 ,                 !- Heat Transmittance Coefficient

UFactor for Duct Wall Construction
1e-07;                      !- Overall Moisture Transmittance

Coefficient from Air to Air

AirflowNetwork:Distribution:Component:Duct ,
ZoneConnectionDuct_unit1 ,   !- Name
0.1 ,                        !- Duct Length
0.591921113608382 ,        !- Hydraulic Diameter
0.275216110019646 ,        !- Cross Section Area
0.0001 ,                    !- Surface Roughness
0 ,                          !- Coefficient for Local Dynamic Loss

Due to Fitting
0.709825 ,                 !- Heat Transmittance Coefficient

UFactor for Duct Wall Construction
1e-07;                      !- Overall Moisture Transmittance

Coefficient from Air to Air

AirflowNetwork:Distribution:Component:Duct ,
MainReturn_unit1 ,          !- Name
1 ,                          !- Duct Length
0.529430338938287 ,        !- Hydraulic Diameter
0.220172888015717 ,        !- Cross Section Area
0.0009 ,                    !- Surface Roughness
0.01 ,                      !- Coefficient for Local Dynamic Loss

Due to Fitting
0.709825 ,                 !- Heat Transmittance Coefficient

UFactor for Duct Wall Construction
1e-07;                      !- Overall Moisture Transmittance

```

```
Coefficient from Air to Air
```

```
AirflowNetwork:Distribution:Component:Duct ,  
    AirLoopReturn_unit1 ,      !- Name  
    0.1 ,                    !- Duct Length  
    0.529430338938287 ,     !- Hydraulic Diameter  
    0.220172888015717 ,     !- Cross Section Area  
    0.0001 ,                 !- Surface Roughness  
    0 ,                      !- Coefficient for Local Dynamic Loss
```

```
Due to Fitting
```

```
    0.709825 ,                !- Heat Transmittance Coefficient
```

```
UFactor for Duct Wall Construction
```

```
    1e-07;                   !- Overall Moisture Transmittance
```

```
Coefficient from Air to Air
```

```
AirflowNetwork:Distribution:Component:Duct ,
```

```
    AirLoopSupply_unit1 ,      !- Name  
    0.1 ,                    !- Duct Length  
    0.591921113608382 ,     !- Hydraulic Diameter  
    0.275216110019646 ,     !- Cross Section Area  
    0.0001 ,                 !- Surface Roughness  
    0 ,                      !- Coefficient for Local Dynamic Loss
```

```
Due to Fitting
```

```
    0.709825 ,                !- Heat Transmittance Coefficient
```

```
UFactor for Duct Wall Construction
```

```
    1e-07;                   !- Overall Moisture Transmittance
```

```
Coefficient from Air to Air
```

```
AirflowNetwork:Distribution:Component:Fan ,
```

```
    Supply Fan_unit1 ,        !- Fan Name  
    Fan:OnOff;               !- Supply Fan Object Type
```

```
AirflowNetwork:Distribution:Component:Coil ,
```

```
    DX Cooling Coil_unit1 ,   !- Coil Name  
    Coil:Cooling:DX:SingleSpeed , !- Coil Object Type  
    0.1 ,                    !- Air Path Length
```

```

1;                               !- Air Path Hydraulic Diameter

AirflowNetwork:Distribution:Component:Coil,
    Main DX Heating Coil_unit1,      !- Coil Name
    Coil:Heating:DX:SingleSpeed,    !- Coil Object Type
    0.1,                            !- Air Path Length
    1;                               !- Air Path Hydraulic Diameter

AirflowNetwork:Distribution:Component:Coil,
    Supp Heating Coil_unit1,       !- Coil Name
    Coil:Heating:Electric,        !- Coil Object Type
    0.1,                            !- Air Path Length
    1;                               !- Air Path Hydraulic Diameter

AirflowNetwork:Distribution:Linkage,
    MainSupplyLink_unit1,          !- Name
    EquipmentInletNode_unit1,      !- Node 1 Name
    SplitterNode_unit1,            !- Node 2 Name
    MainTrunk_unit1,               !- Component Name
    attic_unit1;                  !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
    ZoneSupplyLink_unit1,          !- Name
    SplitterNode_unit1,            !- Node 1 Name
    ZoneSupplyNode_unit1,          !- Node 2 Name
    ZoneSupply_unit1,              !- Component Name
    attic_unit1;                  !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
    ZoneSupplyLink2_unit1 ATInlet,   !- Name
    ZoneSupplyRegisterNode_unit1 ATInlet, !- Node 1 Name
    ZoneSupplyRegisterNode_unit1,      !- Node 2 Name
    ZoneSupplyLink2_unit1 ATInlet Duct, !- Component Name
    attic_unit1;                  !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage ,

```

```

ZoneSupplyLink2_unit1,      !- Name
ZoneSupplyNode_unit1,       !- Node 1 Name
ZoneSupplyRegisterNode_unit1 ATInlet,      !- Node 2 Name
ZoneSupply_unit1,           !- Component Name
attic_unit1;               !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
ZoneSupplyConnectionLink_unit1,      !- Name
ZoneSupplyRegisterNode_unit1,       !- Node 1 Name
living_unit1,                  !- Node 2 Name
ZoneConnectionDuct_unit1;        !- Component Name

AirflowNetwork:Distribution:Linkage,
ZoneReturnConnectionLink_unit1,      !- Name
living_unit1,                  !- Node 1 Name
ZoneOutletNode_unit1,            !- Node 2 Name
ZoneConnectionDuct_unit1;        !- Component Name

AirflowNetwork:Distribution:Linkage,
ZoneReturnLink1_unit1,      !- Name
Zoneoutletnode_unit1,        !- Node 1 Name
ZoneReturnNode_unit1,         !- Node 2 Name
ZoneReturn_unit1,             !- Component Name
attic_unit1;                !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
ZoneReturnLink2_unit1,      !- Name
ZoneReturnNode_unit1,        !- Node 1 Name
MixerNode_unit1,             !- Node 2 Name
ZoneReturn_unit1,             !- Component Name
attic_unit1;                !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
MainReturnLink_unit1,        !- Name
MixerNode_unit1,              !- Node 1 Name
MainReturnNode_unit1,         !- Node 2 Name

```

```

MainReturn_unit1,           !- Component Name
attic_unit1;               !- Thermal Zone Name

AirflowNetwork:Distribution:Linkage,
SystemReturnLink_unit1,     !- Name
MainReturnNode_unit1,       !- Node 1 Name
MainInletNode_unit1,        !- Node 2 Name
AirLoopReturn_unit1;        !- Component Name

AirflowNetwork:Distribution:Linkage,
SupplyFanLink_unit1,        !- Name
MainInletNode_unit1,        !- Node 1 Name
FanOutletNode_unit1,         !- Node 2 Name
Supply Fan_unit1;           !- Component Name

AirflowNetwork:Distribution:Linkage,
CoolingCoilLink_unit1,      !- Name
FanOutletNode_unit1,         !- Node 1 Name
HeatingInletNode_unit1,      !- Node 2 Name
DX Cooling Coil_unit1;      !- Component Name

AirflowNetwork:Distribution:Linkage,
EquipmentAirLoopLink_unit1, !- Name
HeatingOutletNode_unit1,     !- Node 1 Name
EquipmentInletNode_unit1,    !- Node 2 Name
AirLoopSupply_unit1;         !- Component Name

AirflowNetwork:Distribution:Linkage,
HeatingCoilLink_unit1,       !- Name
HeatingInletNode_unit1,      !- Node 1 Name
SuppHeatingInletNode_unit1,   !- Node 2 Name
Main DX Heating Coil_unit1; !- Component Name

AirflowNetwork:Distribution:Linkage,
SuppHeatingCoilLink_unit1,   !- Name
SuppHeatingInletNode_unit1,   !- Node 1 Name

```

```

HeatingOutletNode_unit1,      !- Node 2 Name
Supp Heating Coil_unit1;     !- Component Name

AirflowNetwork:Distribution:Linkage,
ZoneSupplyLeakLink_unit1,    !- Name
ZoneSupplyNode_unit1,        !- Node 1 Name
attic_unit1,                !- Node 2 Name
SupplyLeak;                 !- Component Name

AirflowNetwork:Distribution:Linkage,
ZoneReturnLeakLink_unit1,   !- Name
attic_unit1,                !- Node 1 Name
ZoneReturnNode_unit1,        !- Node 2 Name
ReturnLeak;                 !- Component Name

Exterior:Lights,
Exterior-Lights_unit1,      !- Name
ExteriorLighting,            !- Schedule Name
43.2424607481559,           !- Design Level
,                           !- Control Option
Exterior-Lights;             !- EndUse Subcategory

Exterior:Lights,
Garage-Lights_unit1,         !- Name
InteriorLightingHE,          !- Schedule Name
7.16294617434682,            !- Design Level
,                           !- Control Option
Garage-Lights;               !- EndUse Subcategory

DesignSpecification:OutdoorAir,
SZ_DSOA_living_unit1,        !- Name
Flow/Zone,                   !- Outdoor Air Method
0,                           !- Outdoor Air Flow per Person
,                           !- Outdoor Air Flow per Zone Floor
Area
0.0283168464628752;        !- Outdoor Air Flow per Zone

```

```

Sizing:Zone ,
    living_unit1,                               !- Zone or ZoneList Name
    SupplyAirTemperature,                      !- Zone Cooling Design Supply Air
    Temperature Input Method
    12,                                         !- Zone Cooling Design Supply Air
    Temperature
    ,                                            !- Zone Cooling Design Supply Air
    Temperature Difference
    SupplyAirTemperature,                      !- Zone Heating Design Supply Air
    Temperature Input Method
    50,                                         !- Zone Heating Design Supply Air
    Temperature
    ,                                            !- Zone Heating Design Supply Air
    Temperature Difference
    0.008,                                       !- Zone Cooling Design Supply Air
    Humidity Ratio
    0.008,                                       !- Zone Heating Design Supply Air
    Humidity Ratio
    SZ_DSOA_living_unit1,                      !- Design Specification Outdoor Air
    Object Name
    ,                                             !- Zone Heating Sizing Factor
    ,                                             !- Zone Cooling Sizing Factor
    DesignDay,                                    !- Cooling Design Air Flow Method
    ,                                             !- Cooling Design Air Flow Rate
    0.000762,                                     !- Cooling Minimum Air Flow per Zone
    Floor Area
    ,                                             !- Cooling Minimum Air Flow
    ,                                             !- Cooling Minimum Air Flow Fraction
    DesignDay,                                    !- Heating Design Air Flow Method
    ,                                             !- Heating Design Air Flow Rate
    0.002032,                                     !- Heating Maximum Air Flow per Zone
    Floor Area
    0.1415762,                                    !- Heating Maximum Air Flow
    0.3,                                         !- Heating Maximum Air Flow Fraction
    ,                                             !- Design Specification Zone Air

```

```

Distribution Object Name
,
                               !- Account for Dedicated Outdoor Air
System
,
                               !- Dedicated Outdoor Air System
Control Strategy
,
                               !- Dedicated Outdoor Air Low Setpoint
Temperature for Design
;
                               !- Dedicated Outdoor Air High Setpoint
Temperature for Design

Sizing:System,
Central System_unit1,           !- AirLoop Name
Sensible,                      !- Type of Load to Size On
autosize,                       !- Design Outdoor Air Flow Rate
1,                                !- Central Heating Maximum System Air
Flow Ratio
7,                                !- Preheat Design Temperature
0.008,                            !- Preheat Design Humidity Ratio
11,                               !- Precool Design Temperature
0.008,                            !- Precool Design Humidity Ratio
12,                               !- Central Cooling Design Supply Air
Temperature
50,                               !- Central Heating Design Supply Air
Temperature
NonCoincident,                  !- Type of Zone Sum to Use
No,                                !- 100 Outdoor Air in Cooling
No,                                !- 100 Outdoor Air in Heating
0.008,                            !- Central Cooling Design Supply Air
Humidity Ratio
0.008,                            !- Central Heating Design Supply Air
Humidity Ratio
DesignDay,                        !- Cooling Supply Air Flow Rate Method
,
                               !- Cooling Supply Air Flow Rate
,
                               !- Cooling Supply Air Flow Rate Per
Floor Area
,
                               !- Cooling Fraction of Autosized

```

```

Cooling Supply Air Flow Rate
,
                               !- Cooling Supply Air Flow Rate Per
Unit Cooling Capacity
DesignDay ,                  !- Heating Supply Air Flow Rate Method
,
                               !- Heating Supply Air Flow Rate
,
                               !- Heating Supply Air Flow Rate Per
Floor Area
,
                               !- Heating Fraction of Autosized
Heating Supply Air Flow Rate
,
                               !- Heating Fraction of Autosized
Cooling Supply Air Flow Rate
,
                               !- Heating Supply Air Flow Rate Per
Unit Heating Capacity
,
                               !- System Outdoor Air Method
1 ,                         !- Zone Maximum Outdoor Air Fraction
CoolingDesignCapacity ,      !- Cooling Design Capacity Method
autosize ,                   !- Cooling Design Capacity
,
                               !- Cooling Design Capacity Per Floor
Area
,
                               !- Fraction of Autosized Cooling
Design Capacity
HeatingDesignCapacity ,     !- Heating Design Capacity Method
autosize ,                   !- Heating Design Capacity
,
                               !- Heating Design Capacity Per Floor
Area
,
                               !- Fraction of Autosized Heating
Design Capacity
OnOff;                      !- Central Cooling Capacity Control
Method

Sizing:Plant ,
DHW Loop_unit1 ,           !- Plant or Condenser Loop Name
Heating ,                   !- Loop Type
48.888888888889 ,        !- Design Loop Exit Temperature
5.55555555555556 ;       !- Loop Design Temperature Difference

```

```

ZoneControl:Thermostat ,
    Zone Thermostat_unit1 ,      !- Name
    living_unit1 ,              !- Zone or ZoneList Name
    zone_control_type ,        !- Control Type Schedule Name
    ThermostatSetpoint:DualSetpoint ,   !- Control 1 Object Type
    thermostat_living Dual SP Control;   !- Control 1 Name

ThermostatSetpoint:DualSetpoint ,
    thermostat_living Dual SP Control ,      !- Name
    heating_sch ,                  !- Heating Setpoint Temperature
    Schedule Name
    cooling_sch ;                !- Cooling Setpoint Temperature
    Schedule Name

ZoneHVAC:EnergyRecoveryVentilator ,
    ERV_unit1 ,                  !- Name
    always_avail ,               !- Availability Schedule Name
    OA_Heat_Recovery_Unit1 ,     !- Heat Exchanger Name
    0.0283168464628752 ,       !- Supply Air Flow Rate
    0.0283168464628752 ,       !- Exhaust Air Flow Rate
    OASupplyFan_unit1 ,         !- Supply Air Fan Name
    OAExhaustFan_unit1;        !- Exhaust Air Fan Name

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
    ZoneDirectAir_unit1 ,        !- Name
    always_avail ,               !- Availability Schedule Name
    Zone Inlet Node_unit1 ATInlet ,   !- Air Inlet Node Name
    Zone Inlet Node_unit1 ,       !- Air Outlet Node Name
    autosize;                   !- Maximum Air Flow Rate

ZoneHVAC:AirDistributionUnit ,
    ZoneDirectAir_unit1 ADU ,    !- Name
    Zone Inlet Node_unit1 ,     !- Air Distribution Unit Outlet Node
    Name
    AirTerminal:SingleDuct:ConstantVolume>NoReheat ,      !- Air
    Terminal Object Type

```

```

ZoneDirectAir_unit1;           !- Air Terminal Name

ZoneHVAC:EquipmentList,
    ZoneEquipment_unit1,      !- Name
    SequentialLoad,          !- Load Distribution Scheme
    ZoneHVAC:AirDistributionUnit,   !- Zone Equipment 1 Object Type
    ZoneDirectAir_unit1 ADU,     !- Zone Equipment 1 Name
    3,                         !- Zone Equipment 1 Cooling Sequence
    3,                         !- Zone Equipment 1 Heating or NoLoad
    Sequence
    ,
    !- Zone Equipment 1 Sequential Cooling
    Fraction Schedule Name
    ,
    !- Zone Equipment 1 Sequential Heating
    Fraction Schedule Name
    WaterHeater:HeatPump:WrappedCondenser,    !- Zone Equipment 2
    Object Type
    Water Heater_unit1,        !- Zone Equipment 2 Name
    1,                         !- Zone Equipment 2 Cooling Sequence
    1,                         !- Zone Equipment 2 Heating or NoLoad
    Sequence
    ,
    !- Zone Equipment 2 Sequential Cooling
    Fraction Schedule Name
    ,
    !- Zone Equipment 2 Sequential Heating
    Fraction Schedule Name
    ZoneHVAC:EnergyRecoveryVentilator,    !- Zone Equipment 3 Object
    Type
    ERV_unit1,                !- Zone Equipment 3 Name
    2,                         !- Zone Equipment 3 Cooling Sequence
    2;                         !- Zone Equipment 3 Heating or NoLoad
    Sequence

ZoneHVAC:EquipmentConnections,
    living_unit1,            !- Zone Name
    ZoneEquipment_unit1,     !- Zone Conditioning Equipment List
    Name
    zone inlet nodes_unit1,   !- Zone Air Inlet Node or NodeList

```

```

Name

Zone Exhaust Node_list_unit1,      !- Zone Air Exhaust Node or
NodeList Name

Zone Node_unit1,                  !- Zone Air Node Name

Zone Outlet Node_unit1;          !- Zone Return Air Node or NodeList
Name

Fan:OnOff ,

Supply Fan_unit1,                !- Name
always_avail,                    !- Availability Schedule Name
0.50054,                         !- Fan Total Efficiency
400,                             !- Pressure Rise
autosize,                        !- Maximum Flow Rate
0.863,                           !- Motor Efficiency
1,                               !- Motor In Airstream Fraction
air loop inlet node_unit1,       !- Air Inlet Node Name
cooling coil air inlet node_unit1, !- Air Outlet Node Name
,
!- Fan Power Ratio Function of Speed
Ratio Curve Name

,
!- Fan Efficiency Ratio Function of
Speed Ratio Curve Name

General;                         !- EndUse Subcategory

Fan:OnOff ,

OA SupplyFan_unit1,              !- Name
always_avail,                    !- Availability Schedule Name
0.6,                            !- Fan Total Efficiency
227.022858530508,              !- Pressure Rise
0.0283168464628752,            !- Maximum Flow Rate
1,                               !- Motor Efficiency
0,                               !- Motor In Airstream Fraction
OA fan inlet node_unit1,        !- Air Inlet Node Name
OA inlet node_unit1,             !- Air Outlet Node Name
,
!- Fan Power Ratio Function of Speed
Ratio Curve Name

,
!- Fan Efficiency Ratio Function of

```

```

Speed Ratio Curve Name
Ventilation;           !- EndUse Subcategory

Fan:OnOff,
    OAExhaustFan_unit1,      !- Name
    always_avail,            !- Availability Schedule Name
    0.6,                     !- Fan Total Efficiency
    227.022858530508,       !- Pressure Rise
    0.0283168464628752,     !- Maximum Flow Rate
    1,                       !- Motor Efficiency
    0,                       !- Motor In Airstream Fraction
    ERVexhaustnode_unit1,    !- Air Inlet Node Name
    exhaust outlet node_unit1, !- Air Outlet Node Name
    ,                         !- Fan Power Ratio Function of Speed
Ratio Curve Name
    ,                         !- Fan Efficiency Ratio Function of
Speed Ratio Curve Name
Ventilation;           !- EndUse Subcategory

Fan:OnOff,
    Heat Pump Water Heater Fan_unit1,    !- Name
    always_avail,            !- Availability Schedule Name
    0.7,                     !- Fan Total Efficiency
    100,                     !- Pressure Rise
    autosize,                !- Maximum Flow Rate
    0.9,                     !- Motor Efficiency
    1,                       !- Motor In Airstream Fraction
    Heat Pump Water Heater Fan Inlet Node_unit1,   !- Air Inlet
Node Name
    HPWH zone inlet node_unit1,   !- Air Outlet Node Name
    ,                         !- Fan Power Ratio Function of Speed
Ratio Curve Name
    ,                         !- Fan Efficiency Ratio Function of
Speed Ratio Curve Name
General;             !- EndUse Subcategory

```

```

Coil:Cooling:DX:SingleSpeed ,
  DX Cooling Coil_unit1,      !- Name
  always_avail,              !- Availability Schedule Name
  autosize,                  !- Gross Rated Total Cooling Capacity
  autosize,                  !- Gross Rated Sensible Heat Ratio
  4.06853019625951,         !- Gross Rated Cooling COP
  autosize,                  !- Rated Air Flow Rate
  ,                         !- Rated Evaporator Fan Power Per
  Volume Flow Rate
  Cooling Coil Air Inlet Node_unit1,    !- Air Inlet Node Name
  Heating Coil Air Inlet Node_unit1,    !- Air Outlet Node Name
  HPACCoolCapFT,                !- Total Cooling Capacity Function of
  Temperature Curve Name
  HPACCoolCapFFF,               !- Total Cooling Capacity Function of
  Flow Fraction Curve Name
  HPACCOOLEIRFT,                !- Energy Input Ratio Function of
  Temperature Curve Name
  HPACCOOLEIRFFF,               !- Energy Input Ratio Function of Flow
  Fraction Curve Name
  HPACCOOLPLFFPLR;             !- Part Load Fraction Correlation
  Curve Name

Coil:Heating:Electric ,
  Supp Heating Coil_unit1,     !- Name
  always_avail,               !- Availability Schedule Name
  1,                          !- Efficiency
  autosize,                  !- Nominal Capacity
  Supp Heating Coil Air Inlet Node_unit1,   !- Air Inlet Node
  Name
  Air Loop Outlet Node_unit1;   !- Air Outlet Node Name

Coil:Heating:DX:SingleSpeed ,
  Main DX Heating Coil_unit1,   !- Name
  always_avail,               !- Availability Schedule Name
  autosize,                  !- Gross Rated Heating Capacity
  3.69308080013886,          !- Gross Rated Heating COP

```

```

autosize,                                !- Rated Air Flow Rate
,
!- Rated Supply Fan Power Per Volume
Flow Rate
Heating Coil Air Inlet Node_unit1,      !- Air Inlet Node Name
Supp Heating Coil Air Inlet Node_unit1, !- Air Outlet Node
Name
HPACHeatCapFT,                         !- Heating Capacity Function of
Temperature Curve Name
HPACHeatCapFFF,                        !- Heating Capacity Function of Flow
Fraction Curve Name
HPACHeatEIRFT,                         !- Energy Input Ratio Function of
Temperature Curve Name
HPACHeatEIRFFF,                        !- Energy Input Ratio Function of Flow
Fraction Curve Name
HPACCOOLPLFFPLR,                      !- Part Load Fraction Correlation
Curve Name
Defrost_EIR_FT,                        !- Defrost Energy Input Ratio Function
of Temperature Curve Name
-17.78,                                 !- Minimum Outdoor DryBulb Temperature
for Compressor Operation
,
!- Outdoor DryBulb Temperature to Turn
On Compressor
5,                                      !- Maximum Outdoor DryBulb Temperature
for Defrost Operation
200,                                     !- Crankcase Heater Capacity
10,                                      !- Maximum Outdoor DryBulb Temperature
for Crankcase Heater Operation
ReverseCycle,                            !- Defrost Strategy
OnDemand;                                !- Defrost Control

Coil:WaterHeating:AirToWaterHeatPump:Wrapped,
Heat Pump Water Heater Evaporator_unit1, !- Name
1500,                                     !- Rated Heating Capacity
3,                                         !- Rated COP
0.981,                                    !- Rated Sensible Heat Ratio
19.7,                                     !- Rated Evaporator Inlet Air DryBulb

```

```

Temperature
13.5,                               !- Rated Evaporator Inlet Air WetBulb

Temperature
48.89,                               !- Rated Condenser Water Temperature
0.189,                               !- Rated Evaporator Air Flow Rate
yes,                                  !- Evaporator Fan Power Included in
Rated COP
Zone Exhaust Node1_unit1,      !- Evaporator Air Inlet Node Name
Heat Pump Water Heater Fan Inlet Node_unit1,    !- Evaporator
Air Outlet Node Name
,                                     !- Crankcase Heater Capacity
10,                                   !- Maximum Ambient Temperature for
Crankcase Heater Operation
WetBulbTemperature,           !- Evaporator Air Temperature Type for
Curve Objects
HPWH-Htg-Cap-fT,                !- Heating Capacity Function of
Temperature Curve Name
,                                     !- Heating Capacity Function of Air
Flow Fraction Curve Name
HPWH-Htg-COP-fT,                !- Heating COP Function of Temperature
Curve Name
,                                     !- Heating COP Function of Air Flow
Fraction Curve Name
HPWH-COP-fPLR;                  !- Part Load Fraction Correlation
Curve Name

HeatExchanger:AirToAir:SensibleAndLatent,
OA_Heat_Recovery_Unit1,      !- Name
always_off,                   !- Availability Schedule Name
0.0283168464628752,        !- Nominal Supply Air Flow Rate
0.65,                         !- Sensible Effectiveness at 100
Heating Air Flow
0,                             !- Latent Effectiveness at 100 Heating
Air Flow
0.65,                         !- Sensible Effectiveness at 75
Heating Air Flow

```

```

0,                                     !- Latent Effectiveness at 75 Heating
Air Flow

0.65,                                    !- Sensible Effectiveness at 100
Cooling Air Flow

0,                                     !- Latent Effectiveness at 100 Cooling
Air Flow

0.65,                                    !- Sensible Effectiveness at 75
Cooling Air Flow

0,                                     !- Latent Effectiveness at 75 Cooling
Air Flow

outdoor air node_unit1,      !- Supply Air Inlet Node Name
OA fan inlet node_unit1,      !- Supply Air Outlet Node Name
Zone Exhaust Node_unit1,      !- Exhaust Air Inlet Node Name
ERVExhaustnode_unit1,         !- Exhaust Air Outlet Node Name
0,                                     !- Nominal Electric Power
No,                                     !- Supply Air Outlet Temperature

Control

Plate,                                    !- Heat Exchanger Type
None,                                     !- Frost Control Type
-16.8333337792644,                    !- Threshold Temperature
0.083,                                    !- Initial Defrost Time Fraction
0.0215999989700318,                    !- Rate of Defrost Time Fraction

Increase

No;                                      !- Economizer Lockout

AirLoopHVAC:UnitaryHeatPump:AirToAir,
Heat Pump_unit1,           !- Name
always_avail,                !- Availability Schedule Name
Air Loop Inlet node_unit1,    !- Air Inlet Node Name
Air Loop Outlet Node_unit1,   !- Air Outlet Node Name
autosize,                     !- Cooling Supply Air Flow Rate
autosize,                     !- Heating Supply Air Flow Rate
0,                           !- No Load Supply Air Flow Rate
living_unit1,                 !- Controlling Zone or Thermostat

Location

Fan:OnOff,                      !- Supply Air Fan Object Type

```

```

Supply Fan_unit1,           !- Supply Air Fan Name
Coil:Heating:DX:SingleSpeed,   !- Heating Coil Object Type
Main DX Heating Coil_unit1,    !- Heating Coil Name
Coil:Cooling:DX:SingleSpeed,   !- Cooling Coil Object Type
DX Cooling Coil_unit1,       !- Cooling Coil Name
Coil:Heating:Electric,        !- Supplemental Heating Coil Object
Type
Supp Heating Coil_unit1,     !- Supplemental Heating Coil Name
50,                           !- Maximum Supply Air Temperature from
Supplemental Heater
10,                            !- Maximum Outdoor DryBulb Temperature
for Supplemental Heater Operation
BlowThrough,                  !- Fan Placement
fan_cycle;                   !- Supply Air Fan Operating Mode
Schedule Name

AirLoopHVAC,
Central System_unit1,         !- Name
,                               !- Controller List Name
availability list,            !- Availability Manager List Name
autosize,                     !- Design Supply Air Flow Rate
Air Loop Branches_unit1,      !- Branch List Name
,                               !- Connector List Name
Air Loop Inlet Node_unit1,     !- Supply Side Inlet Node Name
Return Air Mixer Outlet_unit1, !- Demand Side Outlet Node
Name
Zone Equipment Inlet Node_unit1, !- Demand Side Inlet Node
Names
Air Loop Outlet Node_unit1;    !- Supply Side Outlet Node Names

AirLoopHVAC:ZoneSplitter,
Zone Supply Air Splitter_unit1, !- Name
Zone Equipment Inlet Node_unit1, !- Inlet Node Name
Zone Inlet Node_unit1 ATInlet;  !- Outlet 1 Node Name

AirLoopHVAC:SupplyPath,

```

```

SupplyPath_unit1,           !- Name
Zone Equipment Inlet Node_unit1,      !- Supply Air Path Inlet
Node Name
AirLoopHVAC:ZoneSplitter,     !- Component 1 Object Type
Zone Supply Air Splitter_unit1;    !- Component 1 Name

AirLoopHVAC:ZoneMixer,
Zone Return Air Mixer_unit1,      !- Name
Return Air Mixer Outlet_unit1,    !- Outlet Node Name
Zone Outlet Node_unit1;         !- Inlet 1 Node Name

AirLoopHVAC:ReturnPath,
ReturnPath_unit1,             !- Name
Return Air Mixer Outlet_unit1,   !- Return Air Path Outlet Node
Name
AirLoopHVAC:ZoneMixer,        !- Component 1 Object Type
Zone Return Air Mixer_unit1;   !- Component 1 Name

Branch,
Air Loop Main Branch_unit1,     !- Name
,                               !- Pressure Drop Curve Name
AirLoopHVAC:UnitaryHeatPump:AirtoAir,   !- Component 1 Object
Type
Heat Pump_unit1,              !- Component 1 Name
Air Loop Inlet Node_unit1,     !- Component 1 Inlet Node Name
Air Loop Outlet Node_unit1;   !- Component 1 Outlet Node Name

Branch,
Mains Inlet Branch_unit1,     !- Name
,                               !- Pressure Drop Curve Name
Pump:VariableSpeed,          !- Component 1 Object Type
Mains Pressure_unit1,         !- Component 1 Name
Mains Inlet Node_unit1,       !- Component 1 Inlet Node Name
Mains Pressure Outlet Node_unit1; !- Component 1 Outlet Node
Name

```

```
Branch,  
    DHW Supply Outlet Branch_unit1,      !- Name  
        ,  
            !- Pressure Drop Curve Name  
    Pipe:Adiabatic,          !- Component 1 Object Type  
    DHW Supply Outlet Pipe_unit1,      !- Component 1 Name  
    DHW Supply Outlet Pipe Inlet Node_unit1,      !- Component 1 Inlet  
    Node Name  
    DHW Supply Outlet Node_unit1;      !- Component 1 Outlet Node Name
```

```
Branch,  
    DHW Demand Inlet Branch_unit1,      !- Name  
        ,  
            !- Pressure Drop Curve Name  
    Pipe:Adiabatic,          !- Component 1 Object Type  
    DHW Demand Inlet Pipe_unit1,      !- Component 1 Name  
    DHW Demand Inlet Node_unit1,      !- Component 1 Inlet Node Name  
    DHW Demand Inlet Pipe Outlet Node_unit1;      !- Component 1  
    Outlet Node Name
```

```
Branch,  
    Water Sink Branch_unit1,      !- Name  
        ,  
            !- Pressure Drop Curve Name  
    WaterUse:Connections,      !- Component 1 Object Type  
    DHW Sinks_unit1,          !- Component 1 Name  
    Water Sink Inlet Node_unit1,      !- Component 1 Inlet Node Name  
    Water Sink outlet Node_unit1;      !- Component 1 Outlet Node Name
```

```
Branch,  
    Water Shower Branch_unit1,      !- Name  
        ,  
            !- Pressure Drop Curve Name  
    WaterUse:Connections,      !- Component 1 Object Type  
    DHW Showers_unit1,          !- Component 1 Name  
    Water Shower Inlet Node_unit1,      !- Component 1 Inlet Node Name  
    Water Shower Outlet Node_unit1;      !- Component 1 Outlet Node  
    Name
```

```
Branch,
```

```

Water ClothesWasher Branch_unit1,      !- Name
,
                           !- Pressure Drop Curve Name
WaterUse:Connections,      !- Component 1 Object Type
DHW ClothesWasher_unit1,    !- Component 1 Name
Water ClothesWasher Inlet Node_unit1,    !- Component 1 Inlet
Node Name
Water ClothesWasher Outlet Node_unit1;   !- Component 1 Outlet
Node Name

Branch,
Water Dishwasher Branch_unit1,      !- Name
,
                           !- Pressure Drop Curve Name
WaterUse:Connections,      !- Component 1 Object Type
DHW DishWasher_unit1,    !- Component 1 Name
Water DishWasher Inlet Node_unit1,    !- Component 1 Inlet Node
Name
Water DishWasher outlet Node_unit1;   !- Component 1 Outlet
Node Name

Branch,
Water Bath Branch_unit1,      !- Name
,
                           !- Pressure Drop Curve Name
WaterUse:Connections,      !- Component 1 Object Type
DHW Baths_unit1,    !- Component 1 Name
Water Bath Inlet Node_unit1,    !- Component 1 Inlet Node Name
Water bath Outlet Node_unit1;   !- Component 1 Outlet Node Name

Branch,
Mains Makeup Branch_unit1,      !- Name
,
                           !- Pressure Drop Curve Name
Pipe:Adiabatic,      !- Component 1 Object Type
Mains Makeup Pipe_unit1,    !- Component 1 Name
Mains Makeup Pipe Inlet Node_unit1,    !- Component 1 Inlet Node
Name
Mains Makeup Node_unit1;   !- Component 1 Outlet Node Name

```

```

Branch,
    Water Heater Branch_unit1,      !- Name
        ,
            !- Pressure Drop Curve Name
    WaterHeater:HeatPump:WrappedCondenser,      !- Component 1 Object
Type
    Water Heater_unit1,      !- Component 1 Name
    Water Heater Use Inlet Node_unit1,      !- Component 1 Inlet Node
Name
    Water Heater Use Outlet Node_unit1;      !- Component 1 Outlet
Node Name


BranchList,
    Air Loop Branches_unit1,      !- Name
    Air Loop Main Branch_unit1;      !- Branch 1 Name


BranchList,
    DHW Supply Branches_unit1,      !- Name
    Mains Inlet Branch_unit1,      !- Branch 1 Name
    Water Heater Branch_unit1,      !- Branch 2 Name
    DHW Supply Outlet Branch_unit1;      !- Branch 3 Name


BranchList,
    DHW Demand Branches_unit1,      !- Name
    DHW Demand Inlet Branch_unit1,      !- Branch 1 Name
    Water Sink Branch_unit1,      !- Branch 2 Name
    Water Shower Branch_unit1,      !- Branch 3 Name
    Water ClothesWasher Branch_unit1,      !- Branch 4 Name
    Water Dishwasher Branch_unit1,      !- Branch 5 Name
    Water Bath Branch_unit1,      !- Branch 6 Name
    Mains Makeup Branch_unit1;      !- Branch 7 Name


Connector:Splitter,
    DHW Demand Splitter_unit1,      !- Name
    DHW Demand Inlet Branch_unit1,      !- Inlet Branch Name
    Water Sink Branch_unit1,      !- Outlet Branch 1 Name
    Water Shower Branch_unit1,      !- Outlet Branch 2 Name

```

```

Water ClothesWasher Branch_unit1,      !- Outlet Branch 3 Name
Water Dishwasher Branch_unit1,      !- Outlet Branch 4 Name
Water Bath Branch_unit1;      !- Outlet Branch 5 Name

Connector:Splitter,
    DHW Supply Splitter_unit1,      !- Name
    Mains Inlet Branch_unit1,      !- Inlet Branch Name
    Water Heater Branch_unit1;      !- Outlet Branch 1 Name

Connector:Mixer,
    DHW Demand Mixer_unit1,      !- Name
    Mains Makeup Branch_unit1,      !- Outlet Branch Name
    Water Sink Branch_unit1,      !- Inlet Branch 1 Name
    Water Shower Branch_unit1,      !- Inlet Branch 2 Name
    Water ClothesWasher Branch_unit1,      !- Inlet Branch 3 Name
    Water Dishwasher Branch_unit1,      !- Inlet Branch 4 Name
    Water Bath Branch_unit1;      !- Inlet Branch 5 Name

Connector:Mixer,
    DHW Supply Mixer_unit1,      !- Name
    DHW Supply Outlet Branch_unit1,      !- Outlet Branch Name
    Water Heater Branch_unit1;      !- Inlet Branch 1 Name

ConnectorList,
    DHW Demand Connectors_unit1,      !- Name
    Connector:Splitter,      !- Connector 1 Object Type
    DHW Demand Splitter_unit1,      !- Connector 1 Name
    Connector:Mixer,      !- Connector 2 Object Type
    DHW Demand Mixer_unit1;      !- Connector 2 Name

ConnectorList,
    DHW Supply Connectors_unit1,      !- Name
    Connector:Splitter,      !- Connector 1 Object Type
    DHW Supply Splitter_unit1,      !- Connector 1 Name
    Connector:Mixer,      !- Connector 2 Object Type
    DHW Supply Mixer_unit1;      !- Connector 2 Name

```

```

NodeList ,
    Zone Inlet Nodes_unit1,      !- Name
    Zone Inlet Node_unit1,      !- Node 1 Name
    HPWH Zone Inlet Node_unit1,      !- Node 2 Name
    OA Inlet Node_unit1;      !- Node 3 Name

NodeList ,
    Zone Exhaust Node_list_unit1,      !- Name
    Zone Exhaust Node_unit1,      !- Node 1 Name
    Zone Exhaust Node1_unit1;      !- Node 2 Name

OutdoorAir:Node ,
    outside air inlet node_unit1,      !- Name
    0.914355407629293;      !- Height Above Ground

OutdoorAir:NodeList ,
    outdoor air node_unit1;      !- Node or NodeList Name 1

Pipe:Adiabatic ,
    DHW Supply Outlet Pipe_unit1,      !- Name
    DHW Supply Outlet Pipe Inlet Node_unit1,      !- Inlet Node Name
    DHW Supply Outlet Node_unit1;      !- Outlet Node Name

Pipe:Adiabatic ,
    Mains Makeup Pipe_unit1,      !- Name
    Mains Makeup Pipe Inlet Node_unit1,      !- Inlet Node Name
    Mains Makeup Node_unit1;      !- Outlet Node Name

Pipe:Adiabatic ,
    DHW Demand Inlet Pipe_unit1,      !- Name
    DHW Demand Inlet Node_unit1,      !- Inlet Node Name
    DHW Demand Inlet Pipe Outlet Node_unit1;      !- Outlet Node Name

Pump:VariableSpeed ,
    Mains Pressure_unit1,      !- Name

```

```

Mains Inlet Node_unit1,      !- Inlet Node Name
Mains Pressure Outlet Node_unit1,      !- Outlet Node Name
autosize,                      !- Design Maximum Flow Rate
1,                            !- Design Pump Head
0,                            !- Design Power Consumption
1,                            !- Motor Efficiency
0,                            !- Fraction of Motor Inefficiencies to
Fluid Stream
0,                            !- Coefficient 1 of the Part Load
Performance Curve
1,                            !- Coefficient 2 of the Part Load
Performance Curve
0,                            !- Coefficient 3 of the Part Load
Performance Curve
0,                            !- Coefficient 4 of the Part Load
Performance Curve
0,                            !- Design Minimum Flow Rate
Intermittent;                !- Pump Control Type

WaterHeater:Stratified,
Water Heater_Tank_unit1,      !- Name
Water Heater,                  !- EndUse Subcategory
0.196841372,                 !- Tank Volume
1.594,                        !- Tank Height
VerticalCylinder,            !- Tank Shape
,                            !- Tank Perimeter
51,                           !- Maximum Temperature Limit
MasterSlave,                  !- Heater Priority Control
dhw_setpt_hpwh,              !- Heater 1 Setpoint Temperature
Schedule Name
2,                            !- Heater 1 Deadband Temperature
Difference
autosize,                      !- Heater 1 Capacity
1.129,                        !- Heater 1 Height
dhw_setpt_hpwh,              !- Heater 2 Setpoint Temperature
Schedule Name

```

```

2,                                     !- Heater 2 Deadband Temperature
Difference

0,                                     !- Heater 2 Capacity
0.266,                                  !- Heater 2 Height
electricity,                            !- Heater Fuel Type
1,                                      !- Heater Thermal Efficiency
8.3,                                     !- Off Cycle Parasitic Fuel

Consumption Rate

Electricity,                            !- Off Cycle Parasitic Fuel Type
0,                                      !- Off Cycle Parasitic Heat Fraction
to Tank

1,                                      !- Off Cycle Parasitic Height
8.3,                                     !- On Cycle Parasitic Fuel Consumption
Rate

Electricity,                            !- On Cycle Parasitic Fuel Type
0,                                      !- On Cycle Parasitic Heat Fraction to
Tank

1,                                      !- On Cycle Parasitic Height
Zone,                                    !- Ambient Temperature Indicator
,                                         !- Ambient Temperature Schedule Name
living_unit1,                           !- Ambient Temperature Zone Name
,                                         !- Ambient Temperature Outdoor Air

Node Name

0.730336050939686,          !- Uniform Skin Loss Coefficient per
Unit Area to Ambient Temperature

1,                                      !- Skin Loss Fraction to Zone
,                                         !- Off Cycle Flue Loss Coefficient to
Ambient Temperature

1,                                      !- Off Cycle Flue Loss Fraction to
Zone

,                                         !- Peak Use Flow Rate
,                                         !- Use Flow Rate Fraction Schedule
Name

,                                         !- Cold Water Supply Temperature
Schedule Name

Water Heater use inlet node_unit1,      !- Use Side Inlet Node

```

```

Name
Water Heater use outlet node_unit1,      !- Use Side Outlet Node

Name
1,                                !- Use Side Effectiveness
0,                                !- Use Side Inlet Height
autocalculate,                    !- Use Side Outlet Height
,                                  !- Source Side Inlet Node Name
,                                  !- Source Side Outlet Node Name
1,                                !- Source Side Effectiveness
0.7,                               !- Source Side Inlet Height
0,                                !- Source Side Outlet Height
Fixed,                            !- Inlet Mode
autosize,                          !- Use Side Design Flow Rate
autosize,                          !- Source Side Design Flow Rate
1.5,                               !- Indirect Water Heating Recovery

Time
1;                                !- Number of Nodes

WaterHeater:Sizing,
Water Heater_Tank_unit1,      !- WaterHeater Name
ResidentialHUD-FHAMinimum,    !- Design Mode
,                                !- Time Storage Can Meet Peak Draw
,                                !- Time for Tank Recovery
,                                !- Nominal Tank Volume for Autosizing

Plant Connections
3,                                !- Number of Bedrooms
3;                                !- Number of Bathrooms

WaterHeater:HeatPump:WrappedCondenser,
Water Heater_unit1,            !- Name
always_avail,                   !- Availability Schedule Name
Compressor Setpoint,           !- Compressor Setpoint Temperature
Schedule Name
5,                                !- Dead Band Temperature Difference
0.0664166667,                 !- Condenser Bottom Location
0.8634166667,                 !- Condenser Top Location

```

```

autocalculate,           !- Evaporator Air Flow Rate
ZoneAirOnly,            !- Inlet Air Configuration
Zone Exhaust Node1_unit1,      !- Air Inlet Node Name
HPWH Zone Inlet Node_unit1,      !- Air Outlet Node Name
,
          !- Outdoor Air Node Name
,
          !- Exhaust Air Node Name
,
          !- Inlet Air Temperature Schedule Name
,
          !- Inlet Air Humidity Schedule Name
living_unit1,           !- Inlet Air Zone Name
WaterHeater:Stratified,    !- Tank Object Type
Water Heater_Tank_unit1,    !- Tank Name
Water Heater use inlet node_unit1,      !- Tank Use Side Inlet
Node Name
Water Heater use outlet node_unit1,      !- Tank Use Side Outlet
Node Name
Coil:WaterHeating:AirToWaterHeatPump:Wrapped,    !- DX Coil
Object Type
Heat Pump Water Heater Evaporator_unit1,      !- DX Coil Name
10,           !- Minimum Inlet Air Temperature for
Compressor Operation
48.89,         !- Maximum Inlet Air Temperature for
Compressor Operation
Zone,           !- Compressor Location
,
          !- Compressor Ambient Temperature
Schedule Name
Fan:OnOff,        !- Fan Object Type
Heat Pump Water Heater Fan_unit1,    !- Fan Name
DrawThrough,       !- Fan Placement
0,           !- On Cycle Parasitic Electric Load
0,           !- Off Cycle Parasitic Electric Load
,
          !- Parasitic Heat Rejection Location
,
          !- Inlet Air Mixer Node Name
,
          !- Outlet Air Splitter Node Name
,
          !- Inlet Air Mixer Schedule Name
MutuallyExclusive,   !- Tank Element Control Logic
1.262,          !- Control Sensor 1 Height In

```

```

Stratified Tank
0.75,           !- Control Sensor 1 Weight
0.464;          !- Control Sensor 2 Height In

Stratified Tank

PlantLoop,
    DHW Loop_unit1,           !- Name
    Water,                     !- Fluid Type
    ,                         !- User Defined Fluid Type
    DHW Loop Operation_unit1,   !- Plant Equipment Operation Scheme
    Name
    DHW Supply Outlet Node_unit1,   !- Loop Temperature Setpoint
    Node Name
    100,                      !- Maximum Loop Temperature
    0,                         !- Minimum Loop Temperature
    autosize,                  !- Maximum Loop Flow Rate
    0,                         !- Minimum Loop Flow Rate
    autocalculate,             !- Plant Loop Volume
    Mains Inlet Node_unit1,     !- Plant Side Inlet Node Name
    DHW Supply Outlet Node_unit1,   !- Plant Side Outlet Node Name
    DHW Supply Branches_unit1,    !- Plant Side Branch List Name
    DHW Supply Connectors_unit1,   !- Plant Side Connector List
    Name
    DHW Demand Inlet Node_unit1,   !- Demand Side Inlet Node Name
    Mains Makeup Node_unit1,      !- Demand Side Outlet Node Name
    DHW Demand Branches_unit1,    !- Demand Side Branch List Name
    DHW Demand Connectors_unit1,   !- Demand Side Connector List
    Name
    Optimal;                   !- Load Distribution Scheme

PlantEquipmentList,
    DHW Plant Equipment_unit1,   !- Name
    WaterHeater:HeatPump:WrappedCondenser,   !- Equipment 1 Object
    Type
    Water Heater_unit1;         !- Equipment 1 Name

```

```

PlantEquipmentOperation:HeatingLoad ,
    DHW Control Scheme_unit1 ,      !- Name
    0 ,                           !- Load Range 1 Lower Limit
    1000000000000000 ,           !- Load Range 1 Upper Limit
    DHW Plant Equipment_unit1;    !- Range 1 Equipment List Name

PlantEquipmentOperationSchemes ,
    DHW Loop Operation_unit1 ,      !- Name
    PlantEquipmentOperation:HeatingLoad ,      !- Control Scheme 1
Object Type
    DHW Control Scheme_unit1 ,      !- Control Scheme 1 Name
    always_avail;                 !- Control Scheme 1 Schedule Name

AvailabilityManager:Scheduled ,
    System availability ,        !- Name
    always_avail;                 !- Schedule Name

AvailabilityManagerAssignmentList ,
    availability list ,          !- Name
    AvailabilityManager:Scheduled ,      !- Availability Manager 1
Object Type
    System availability;        !- Availability Manager 1 Name

SetpointManager:Scheduled ,
    DHW Loop Setpoint Manager_unit1 ,      !- Name
    Temperature ,                  !- Control Variable
    DHWSupplySetpoint ,           !- Schedule Name
    DHW Supply Outlet Node_unit1;    !- Setpoint Node or NodeList
Name

Generator:Photovoltaic ,
    PV_roof_front ,              !- Name
    Roof_front_unit1 ,           !- Surface Name
    PhotovoltaicPerformance:Simple ,      !- Photovoltaic Performance
Object Type
    20percentEffPVhalfArea ,     !- Module Performance Name

```

```

Decoupled,                                !- Heat Transfer Integration Mode
1,                                         !- Number of Series Strings in
Parallel
1;                                         !- Number of Modules in Series

Generator:Photovoltaic,
PV_roof_back,                            !- Name
Roof_back_unit1,                         !- Surface Name
PhotovoltaicPerformance:Simple,          !- Photovoltaic Performance
Object Type
20percentEffPVhalfArea,                  !- Module Performance Name
Decoupled,                                !- Heat Transfer Integration Mode
1,                                         !- Number of Series Strings in
Parallel
1;                                         !- Number of Modules in Series

PhotovoltaicPerformance:Simple,
20percentEffPVhalfArea,                  !- Name
0.9,                                      !- Fraction of Surface Area with
Active Solar Cells
Fixed,                                     !- Conversion Efficiency Input Mode
0.2,                                      !- Value for Cell Efficiency if Fixed
;                                         !- Efficiency Schedule Name

ElectricLoadCenter:Generators,
Generator List,                           !- Name
PV_roof_front,                            !- Generator 1 Name
Generator:Photovoltaic,                  !- Generator 1 Object Type
9000,                                     !- Generator 1 Rated Electric Power
Output
,                                         !- Generator 1 Availability Schedule
Name
,                                         !- Generator 1 Rated Thermal to
Electrical Power Ratio
PV_roof_back,                            !- Generator 2 Name
Generator:Photovoltaic,                  !- Generator 2 Object Type

```

```

9000,                                     !- Generator 2 Rated Electric Power
Output
,
                                     !- Generator 2 Availability Schedule
Name
;
                                     !- Generator 2 Rated Thermal to
Electrical Power Ratio

ElectricLoadCenter:Inverter:LookUpTable ,
PV Inverter,                               !- Name
ALWAYS_ON,                                  !- Availability Schedule Name
,
                                     !- Zone Name
0.25,                                      !- Radiative Fraction
14000,                                     !- Rated Maximum Continuous Output
Power
200,                                       !- Night Tare Loss Power
368,                                       !- Nominal Voltage Input
0.839,                                     !- Efficiency at 10 Power and Nominal
Voltage
0.897,                                     !- Efficiency at 20 Power and Nominal
Voltage
0.916,                                     !- Efficiency at 30 Power and Nominal
Voltage
0.931,                                     !- Efficiency at 50 Power and Nominal
Voltage
0.934,                                     !- Efficiency at 75 Power and Nominal
Voltage
0.93;                                      !- Efficiency at 100 Power and Nominal
Voltage

ElectricLoadCenter:Storage:LiIonNMCBattery ,
LiIonBattery,                                !- Name
ALWAYS_ON,                                   !- Availability Schedule Name
,
                                     !- Zone Name
0,                                         !- Radiative Fraction
KandlerSmith,                                !- Lifetime Model
139,                                        !- Number of Cells in Series

```

```

5,                                     !- Number of Strings in Parallel
0.7,                                    !- Initial Fractional State of Charge
,                                         !- DC to DC Charging Efficiency
342,                                     !- Battery Mass
4.26,                                    !- Battery Surface Area
,                                         !- Battery Specific Heat Capacity
;                                         !- Heat Transfer Coefficient Between
                                         Battery and Ambient

ElectricLoadCenter:Distribution,
PV Array Load Center,          !- Name
Generator List,                !- Generator List Name
TrackElectrical,              !- Generator Operation Scheme Type
0,                           !- Generator Demand Limit Scheme
Purchased Electric Demand Limit
,                               !- Generator Track Schedule Name
Scheme Schedule Name
,                               !- Generator Track Meter Scheme Meter
Name
DirectCurrentWithInverterDCStorage,   !- Electrical Buss Type
PV Inverter,                   !- Inverter Name
LiIonBattery,                  !- Electrical Storage Object Name
,                               !- Transformer Object Name
TrackChargeDischargeSchedules,    !- Storage Operation Scheme
,                               !- Storage Control Track Meter Name
Storage Converter,             !- Storage Converter Object Name
0.95,                         !- Maximum Storage State of Charge
Fraction
0.2,                           !- Minimum Storage State of Charge
Fraction
3706,                         !- Design Storage Control Charge Power
charge_sch,                    !- Storage Charge Power Fraction
Schedule Name
2780,                         !- Design Storage Control Discharge
Power
discharge_sch,                 !- Storage Discharge Power Fraction

```

```

Schedule Name
,
                    !- Storage Control Utility Demand

Target
;
                    !- Storage Control Utility Demand

Target Fraction Schedule Name

ElectricLoadCenter:Storage:Converter,
    Storage Converter,           !- Name
    ALWAYS_ON,                  !- Availability Schedule Name
    SimpleFixed,                !- Power Conversion Efficiency Method
    0.95,                       !- Simple Fixed Efficiency
    ,
                    !- Design Maximum Continuous Input

Power
,
                    !- Efficiency Function of Power Curve

Name
,
                    !- Ancillary Power Consumed In Standby
,
                    !- Zone Name
;
                    !- Radiative Fraction

WaterUse:Equipment,
    Clothes Washer_unit1,      !- Name
    Domestic Hot Water,        !- EndUse Subcategory
    1.6219189818e-06,          !- Peak Flow Rate
    ClothesWasher,              !- Flow Rate Fraction Schedule Name
    CWWaterTempSchedule;        !- Target Temperature Schedule Name

WaterUse:Equipment,
    Dishwasher_unit1,          !- Name
    Domestic Hot Water,        !- EndUse Subcategory
    6.36685353e-07,            !- Peak Flow Rate
    Dishwasher,                 !- Flow Rate Fraction Schedule Name
    DWWaterTempSchedule;        !- Target Temperature Schedule Name

WaterUse:Equipment,
    Sinks_unit1,                !- Name
    Domestic Hot Water,         !- EndUse Subcategory

```

```

    7.1934e-05,                               !- Peak Flow Rate
    BA_sink_sch,                            !- Flow Rate Fraction Schedule Name
    SSBWaterTempSchedule;                  !- Target Temperature Schedule Name

WaterUse:Equipment,
    Showers_unit1,                         !- Name
    Domestic Hot Water,                   !- EndUse Subcategory
    0.000141975,                          !- Peak Flow Rate
    BA_shower_sch,                        !- Flow Rate Fraction Schedule Name
    SSBWaterTempSchedule;                  !- Target Temperature Schedule Name

WaterUse:Equipment,
    Baths_unit1,                           !- Name
    Domestic Hot Water,                   !- EndUse Subcategory
    0.00027764,                           !- Peak Flow Rate
    BA_bath_sch,                          !- Flow Rate Fraction Schedule Name
    SSBWaterTempSchedule;                  !- Target Temperature Schedule Name

WaterUse:Connections,
    DHW_Sinks_unit1,                      !- Name
    Water Sink Inlet Node_unit1,          !- Inlet Node Name
    Water Sink Outlet Node_unit1,         !- Outlet Node Name
    ,                                     !- Supply Water Storage Tank Name
    ,                                     !- Reclamation Water Storage Tank Name
    ,                                     !- Hot Water Supply Temperature
    Schedule Name
    ,                                     !- Cold Water Supply Temperature
    Schedule Name
    None,                                 !- Drain Water Heat Exchanger Type
    ,                                     !- Drain Water Heat Exchanger
    Destination
    ,                                     !- Drain Water Heat Exchanger UFactor
    Times Area
    Sinks_unit1;                          !- Water Use Equipment 1 Name

WaterUse:Connections ,

```

```

DHW Showers_unit1,           !- Name
Water Shower Inlet Node_unit1,    !- Inlet Node Name
Water Shower Outlet Node_unit1,   !- Outlet Node Name
,
          !- Supply Water Storage Tank Name
,
          !- Reclamation Water Storage Tank Name
,
          !- Hot Water Supply Temperature
Schedule Name
,
          !- Cold Water Supply Temperature
Schedule Name
None,           !- Drain Water Heat Exchanger Type
,
          !- Drain Water Heat Exchanger
Destination
,
          !- Drain Water Heat Exchanger UFactor
Times Area
Showers_unit1;      !- Water Use Equipment 1 Name

WaterUse:Connections ,
DHW ClothesWasher_unit1,     !- Name
Water ClothesWasher Inlet Node_unit1,    !- Inlet Node Name
Water ClothesWasher Outlet Node_unit1,   !- Outlet Node Name
,
          !- Supply Water Storage Tank Name
,
          !- Reclamation Water Storage Tank Name
,
          !- Hot Water Supply Temperature
Schedule Name
,
          !- Cold Water Supply Temperature
Schedule Name
None,           !- Drain Water Heat Exchanger Type
,
          !- Drain Water Heat Exchanger
Destination
,
          !- Drain Water Heat Exchanger UFactor
Times Area
Clothes Washer_unit1;      !- Water Use Equipment 1 Name

WaterUse:Connections ,
DHW DishWasher_unit1,       !- Name
Water DishWasher Inlet Node_unit1,    !- Inlet Node Name

```

```

Water DishWasher Outlet Node_unit1,      !- Outlet Node Name
,
          !- Supply Water Storage Tank Name
,
          !- Reclamation Water Storage Tank Name
,
          !- Hot Water Supply Temperature

Schedule Name
,
          !- Cold Water Supply Temperature

Schedule Name
None,           !- Drain Water Heat Exchanger Type
,
          !- Drain Water Heat Exchanger

Destination
,
          !- Drain Water Heat Exchanger UFactor

Times Area
Dishwasher_unit1;        !- Water Use Equipment 1 Name

WaterUse:Connections ,
DHW Baths_unit1,           !- Name
Water Bath Inlet Node_unit1,    !- Inlet Node Name
Water Bath Outlet Node_unit1,   !- Outlet Node Name
,
          !- Supply Water Storage Tank Name
,
          !- Reclamation Water Storage Tank Name
,
          !- Hot Water Supply Temperature

Schedule Name
,
          !- Cold Water Supply Temperature

Schedule Name
None,           !- Drain Water Heat Exchanger Type
,
          !- Drain Water Heat Exchanger

Destination
,
          !- Drain Water Heat Exchanger UFactor

Times Area
Baths_unit1;        !- Water Use Equipment 1 Name

Curve:Quadratic ,
HPWH-COP-fPLR ,           !- Name
1,                         !- Coefficient1 Constant
0,                         !- Coefficient2 x
0,                         !- Coefficient3 x2

```

```

0,                                     ! - Minimum Value of x
1;                                     ! - Maximum Value of x

Curve:Quadratic,
    HPACCoolCapFFF,                  ! - Name
    0.8,                                ! - Coefficient1 Constant
    0.2,                                ! - Coefficient2 x
    0,                                   ! - Coefficient3 x2
    0.5,                                ! - Minimum Value of x
    1.5;                                ! - Maximum Value of x

Curve:Quadratic,
    HPACCOOLEIRFFF,                  ! - Name
    1.156,                               ! - Coefficient1 Constant
    -0.1816,                             ! - Coefficient2 x
    0.0256,                             ! - Coefficient3 x2
    0.5,                                 ! - Minimum Value of x
    1.5;                                ! - Maximum Value of x

Curve:Quadratic,
    HPACCOOLPLFFPLR,                  ! - Name
    0.85,                               ! - Coefficient1 Constant
    0.15,                               ! - Coefficient2 x
    0,                                   ! - Coefficient3 x2
    0,                                   ! - Minimum Value of x
    1;                                   ! - Maximum Value of x

Curve:Quadratic,
    HPACHeatEIRFFF,                  ! - Name
    1.3824,                             ! - Coefficient1 Constant
    -0.4336,                            ! - Coefficient2 x
    0.0512,                            ! - Coefficient3 x2
    0,                                   ! - Minimum Value of x
    1;                                   ! - Maximum Value of x

Curve:Quadratic,

```

```

ACCoolingCAPFFF ,           !- Name
0.718605468 ,              !- Coefficient1 Constant
0.410099989 ,              !- Coefficient2 x
-0.128705457 ,             !- Coefficient3 x2
0 ,                         !- Minimum Value of x
1.5 ,                        !- Maximum Value of x
0 ,                           !- Minimum Curve Output
2 ,                           !- Maximum Curve Output
Dimensionless ,              !- Input Unit Type for X
Dimensionless;               !- Output Unit Type

Curve:Quadratic ,
ACCoolingEIRFFF ,           !- Name
1.32299905 ,                !- Coefficient1 Constant
-0.477711207 ,              !- Coefficient2 x
0.154712157 ,              !- Coefficient3 x2
0 ,                           !- Minimum Value of x
1.5 ,                        !- Maximum Value of x
0 ,                           !- Minimum Curve Output
2 ,                           !- Maximum Curve Output
Dimensionless ,              !- Input Unit Type for X
Dimensionless;               !- Output Unit Type

Curve:Quadratic ,
ACCoolingPLFFPLR ,           !- Name
0.9 ,                         !- Coefficient1 Constant
0.1 ,                          !- Coefficient2 x
0 ,                            !- Coefficient3 x2
0 ,                           !- Minimum Value of x
1;                            !- Maximum Value of x

Curve:Quadratic ,
HPCoolingCAPFFF ,            !- Name
0.718664047 ,                !- Coefficient1 Constant
0.41797409 ,                 !- Coefficient2 x
-0.136638137 ,               !- Coefficient3 x2

```

```

0,                                     !- Minimum Value of x
1.5,                                    !- Maximum Value of x
0,                                     !- Minimum Curve Output
2,                                      !- Maximum Curve Output
Dimensionless,                         !- Input Unit Type for X
Dimensionless;                         !- Output Unit Type

Curve:Quadratic,
HPCoolingEIRFFF,                      !- Name
1.143487507,                           !- Coefficient1 Constant
-0.13943972,                           !- Coefficient2 x
-0.004047787,                          !- Coefficient3 x2
0,                                      !- Minimum Value of x
1.5,                                     !- Maximum Value of x
0,                                      !- Minimum Curve Output
2,                                       !- Maximum Curve Output
Dimensionless,                          !- Input Unit Type for X
Dimensionless;                         !- Output Unit Type

Curve:Quadratic,
HPCOOLPLFFPLR,                        !- Name
0.9,                                     !- Coefficient1 Constant
0.1,                                     !- Coefficient2 x
0,                                       !- Coefficient3 x2
0,                                      !- Minimum Value of x
1;                                       !- Maximum Value of x

Curve:Quadratic,
HPHeatingCAPFFF,                       !- Name
0.694045465,                           !- Coefficient1 Constant
0.474207981,                           !- Coefficient2 x
-0.168253446,                          !- Coefficient3 x2
0,                                      !- Minimum Value of x
1.5,                                     !- Maximum Value of x
0,                                      !- Minimum Curve Output
2,                                       !- Maximum Curve Output

```

```

Dimensionless ,           !- Input Unit Type for X
Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
    HPHeatingEIRFFF ,      !- Name
    2.185418751 ,          !- Coefficient1 Constant
    -1.942827919 ,         !- Coefficient2 x
    0.757409168 ,          !- Coefficient3 x2
    0 ,                     !- Minimum Value of x
    1.5 ,                   !- Maximum Value of x
    0 ,                     !- Minimum Curve Output
    2 ,                     !- Maximum Curve Output
    Dimensionless ,          !- Input Unit Type for X
    Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
    HPHeatPLFFPLR ,        !- Name
    0.9 ,                   !- Coefficient1 Constant
    0.1 ,                   !- Coefficient2 x
    0 ,                     !- Coefficient3 x2
    0 ,                     !- Minimum Value of x
    1;                      !- Maximum Value of x

Curve:Quadratic ,
    HPLowStageHeatingCAPFFF ,   !- Name
    0.741466907 ,            !- Coefficient1 Constant
    0.378645444 ,            !- Coefficient2 x
    -0.119754733 ,           !- Coefficient3 x2
    0 ,                      !- Minimum Value of x
    1.5 ,                    !- Maximum Value of x
    0 ,                      !- Minimum Curve Output
    2 ,                      !- Maximum Curve Output
    Dimensionless ,           !- Input Unit Type for X
    Dimensionless;             !- Output Unit Type

Curve:Quadratic ,

```

```

HPLowStageHeatingEIRFFF ,      !- Name
2.153618211 ,                !- Coefficient1 Constant
-1.737190609 ,               !- Coefficient2 x
0.584269478 ,                !- Coefficient3 x2
0,                            !- Minimum Value of x
1.5,                           !- Maximum Value of x
0,                            !- Minimum Curve Output
2,                            !- Maximum Curve Output
Dimensionless ,               !- Input Unit Type for X
Dimensionless;                !- Output Unit Type

Curve:Quadratic ,
HPHighStageHeatingCAPFFF ,    !- Name
0.76634609 ,                  !- Coefficient1 Constant
0.32840943 ,                  !- Coefficient2 x
-0.094701495 ,                !- Coefficient3 x2
0,                            !- Minimum Value of x
1.5,                           !- Maximum Value of x
0,                            !- Minimum Curve Output
2,                            !- Maximum Curve Output
Dimensionless ,               !- Input Unit Type for X
Dimensionless;                !- Output Unit Type

Curve:Quadratic ,
HPHighStageHeatingEIRFFF ,    !- Name
2.001041353 ,                 !- Coefficient1 Constant
-1.58869128 ,                !- Coefficient2 x
0.587593517 ,                !- Coefficient3 x2
0,                            !- Minimum Value of x
1.5,                           !- Maximum Value of x
0,                            !- Minimum Curve Output
2,                            !- Maximum Curve Output
Dimensionless ,               !- Input Unit Type for X
Dimensionless;                !- Output Unit Type

Curve:Quadratic ,

```

```

HP2StageHeatingPLFFPLR ,      ! - Name
0.93,                         ! - Coefficient1 Constant
0.07,                          ! - Coefficient2 x
0,                             ! - Coefficient3 x2
0,                             ! - Minimum Value of x
1;                            ! - Maximum Value of x

Curve:Quadratic ,
HPLowStageCoolingCAPFFF ,    ! - Name
0.655239515,                 ! - Coefficient1 Constant
0.511655216,                 ! - Coefficient2 x
-0.166894731,                ! - Coefficient3 x2
0,                            ! - Minimum Value of x
1.5,                           ! - Maximum Value of x
0,                            ! - Minimum Curve Output
2,                            ! - Maximum Curve Output
Dimensionless,                ! - Input Unit Type for X
Dimensionless;                ! - Output Unit Type

Curve:Quadratic ,
HPLowStageCoolingEIRFFF ,    ! - Name
1.639108268,                 ! - Coefficient1 Constant
-0.998953996,                ! - Coefficient2 x
0.359845728,                 ! - Coefficient3 x2
0,                            ! - Minimum Value of x
1.5,                           ! - Maximum Value of x
0,                            ! - Minimum Curve Output
2,                            ! - Maximum Curve Output
Dimensionless,                ! - Input Unit Type for X
Dimensionless;                ! - Output Unit Type

Curve:Quadratic ,
HPHighStageCoolingCAPFFF ,   ! - Name
0.618281092,                 ! - Coefficient1 Constant
0.569060264,                 ! - Coefficient2 x
-0.187341356,                ! - Coefficient3 x2

```

```

0,                               !- Minimum Value of x
1.5,                             !- Maximum Value of x
0,                               !- Minimum Curve Output
2,                               !- Maximum Curve Output
Dimensionless,                  !- Input Unit Type for X
Dimensionless;                  !- Output Unit Type

Curve:Quadratic,
HPHighStageCoolingEIRFFF,      !- Name
1.570774717,                   !- Coefficient1 Constant
-0.914152018,                 !- Coefficient2 x
0.343377302,                  !- Coefficient3 x2
0,                               !- Minimum Value of x
1.5,                             !- Maximum Value of x
0,                               !- Minimum Curve Output
2,                               !- Maximum Curve Output
Dimensionless,                  !- Input Unit Type for X
Dimensionless;                  !- Output Unit Type

Curve:Quadratic,
HP2StageCoolingPLFFPLR,        !- Name
0.93,                            !- Coefficient1 Constant
0.07,                            !- Coefficient2 x
0,                               !- Coefficient3 x2
0,                               !- Minimum Value of x
1;                               !- Maximum Value of x

Curve:Quadratic,
ACLowStageCoolingCAPFFF,       !- Name
0.65673024,                    !- Coefficient1 Constant
0.516470835,                  !- Coefficient2 x
-0.172887149,                 !- Coefficient3 x2
0,                               !- Minimum Value of x
1.5,                             !- Maximum Value of x
0,                               !- Minimum Curve Output
2,                               !- Maximum Curve Output

```

```

Dimensionless ,           !- Input Unit Type for X
Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
ACLowStageCoolingEIRFFF ,      !- Name
1.562945114 ,                !- Coefficient1 Constant
-0.791859997 ,              !- Coefficient2 x
0.230030877 ,                !- Coefficient3 x2
0 ,                           !- Minimum Value of x
1.5 ,                          !- Maximum Value of x
0 ,                           !- Minimum Curve Output
2 ,                           !- Maximum Curve Output
Dimensionless ,               !- Input Unit Type for X
Dimensionless;               !- Output Unit Type

Curve:Quadratic ,
ACHighStageCoolingCAPFFF ,    !- Name
0.690334551 ,                !- Coefficient1 Constant
0.464383753 ,              !- Coefficient2 x
-0.154507638 ,              !- Coefficient3 x2
0 ,                           !- Minimum Value of x
1.5 ,                          !- Maximum Value of x
0 ,                           !- Minimum Curve Output
2 ,                           !- Maximum Curve Output
Dimensionless ,               !- Input Unit Type for X
Dimensionless;               !- Output Unit Type

Curve:Quadratic ,
ACHighStageCoolingEIRFFF ,    !- Name
1.31565404 ,                !- Coefficient1 Constant
-0.482467162 ,              !- Coefficient2 x
0.166239001 ,                !- Coefficient3 x2
0 ,                           !- Minimum Value of x
1.5 ,                          !- Maximum Value of x
0 ,                           !- Minimum Curve Output
2 ,                           !- Maximum Curve Output

```

```

Dimensionless ,           !- Input Unit Type for X
Dimensionless;           !- Output Unit Type

Curve:Quadratic ,
AC2StageCoolingPLFFPLR ,      !- Name
0.93 ,                      !- Coefficient1 Constant
0.07 ,                      !- Coefficient2 x
0 ,                          !- Coefficient3 x2
0 ,                          !- Minimum Value of x
1;                           !- Maximum Value of x

Curve:Quadratic ,
Cool-PLF-fPLR ,            !- Name
0.80141423 ,               !- Coefficient1 Constant
0.23744685 ,               !- Coefficient2 x
-0.0393773 ,              !- Coefficient3 x2
0 ,                          !- Minimum Value of x
1 ,                          !- Maximum Value of x
0.7 ,                        !- Minimum Curve Output
1;                           !- Maximum Curve Output

Curve:Cubic ,
HPACHeatCapFT ,            !- Name
0.758746 ,                  !- Coefficient1 Constant
0.027626 ,                  !- Coefficient2 x
0.000148716 ,              !- Coefficient3 x2
3.4992e-06 ,                !- Coefficient4 x3
-20 ,                        !- Minimum Value of x
20;                          !- Maximum Value of x

Curve:Cubic ,
HPACHeatCapFFF ,           !- Name
0.84 ,                      !- Coefficient1 Constant
0.16 ,                      !- Coefficient2 x
0 ,                          !- Coefficient3 x2
0 ,                          !- Coefficient4 x3

```

```

0.5,                                ! - Minimum Value of x
1.5;                                 ! - Maximum Value of x

Curve:Cubic,
    HPACHeatEIRFT,                  ! - Name
    1.19248,                         ! - Coefficient1 Constant
    -0.0300438,                      ! - Coefficient2 x
    0.00103745,                      ! - Coefficient3 x2
    -2.3328e-05,                     ! - Coefficient4 x3
    -20,                               ! - Minimum Value of x
    20;                               ! - Maximum Value of x

Curve:Cubic,
    Fan-EIR-fPLR,                  ! - Name
    0,                                ! - Coefficient1 Constant
    1,                                ! - Coefficient2 x
    0,                                ! - Coefficient3 x2
    0,                                ! - Coefficient4 x3
    0,                                ! - Minimum Value of x
    1,                                ! - Maximum Value of x
    0,                                ! - Minimum Curve Output
    1;                                ! - Maximum Curve Output

Curve:Cubic,
    ConstantCubic,                  ! - Name
    1,                                ! - Coefficient1 Constant
    0,                                ! - Coefficient2 x
    0,                                ! - Coefficient3 x2
    0,                                ! - Coefficient4 x3
    -100,                             ! - Minimum Value of x
    100;                             ! - Maximum Value of x

Curve:Biquadratic,
    HPWH-Htg-Cap-fT,                ! - Name
    0.563,                           ! - Coefficient1 Constant
    0.0437,                          ! - Coefficient2 x

```

```

3.9e-05,                               !- Coefficient3 x2
0.0055,                                !- Coefficient4 y
-0.000148,                             !- Coefficient5 y2
-0.000145,                             !- Coefficient6 xy
0,                                     !- Minimum Value of x
100,                                    !- Maximum Value of x
0,                                     !- Minimum Value of y
100,                                    !- Maximum Value of y
0;                                     !- Minimum Curve Output

Curve:Biquadratic,
HPWH-Htg-COP-fT,                      !- Name
1.1332,                                 !- Coefficient1 Constant
0.063,                                  !- Coefficient2 x
-9.79e-05,                             !- Coefficient3 x2
-0.00972,                               !- Coefficient4 y
-2.14e-05,                             !- Coefficient5 y2
-0.000686,                            !- Coefficient6 xy
0,                                      !- Minimum Value of x
100,                                     !- Maximum Value of x
0,                                      !- Minimum Value of y
100;                                    !- Maximum Value of y

Curve:Biquadratic,
HPWHHeatingCapFTemp,                   !- Name
0.369827,                               !- Coefficient1 Constant
0.043341,                               !- Coefficient2 x
-0.00023,                               !- Coefficient3 x2
0.000466,                               !- Coefficient4 y
2.6e-05,                                !- Coefficient5 y2
-0.00027,                               !- Coefficient6 xy
0,                                      !- Minimum Value of x
40,                                     !- Maximum Value of x
20,                                     !- Minimum Value of y
90,                                     !- Maximum Value of y
,                                       !- Minimum Curve Output

```

```

        ,                                     !- Maximum Curve Output
Temperature ,                               !- Input Unit Type for X
Temperature ,                               !- Input Unit Type for Y
Dimensionless;                            !- Output Unit Type

Curve:Biquadratic ,
    HPWHHeatingCOPFTemp ,                !- Name
    1.19713 ,                             !- Coefficient1 Constant
    0.077849 ,                            !- Coefficient2 x
    -1.6e-06 ,                            !- Coefficient3 x2
    -0.02675 ,                            !- Coefficient4 y
    0.000296 ,                            !- Coefficient5 y2
    -0.00112 ,                            !- Coefficient6 xy
    0 ,                                    !- Minimum Value of x
    40 ,                                   !- Maximum Value of x
    20 ,                                   !- Minimum Value of y
    90 ,                                   !- Maximum Value of y
    ,                                     !- Minimum Curve Output
    ,                                     !- Maximum Curve Output
Temperature ,                            !- Input Unit Type for X
Temperature ,                            !- Input Unit Type for Y
Dimensionless;                          !- Output Unit Type

Curve:Biquadratic ,
    HPACCoolCapFT ,                     !- Name
    0.766956 ,                           !- Coefficient1 Constant
    0.0107756 ,                          !- Coefficient2 x
    -4.14703e-05 ,                      !- Coefficient3 x2
    0.00134961 ,                         !- Coefficient4 y
    -0.000261144 ,                       !- Coefficient5 y2
    0.000457488 ,                        !- Coefficient6 xy
    12.77778 ,                           !- Minimum Value of x
    23.88889 ,                           !- Maximum Value of x
    21.11111 ,                           !- Minimum Value of y
    46.11111 ;                           !- Maximum Value of y

```

```

Curve:Biquadratic ,
    HPACCOOLEIRFT ,           !- Name
    0.297145 ,                !- Coefficient1 Constant
    0.0430933 ,               !- Coefficient2 x
    -0.000748766 ,            !- Coefficient3 x2
    0.00597727 ,              !- Coefficient4 y
    0.000482112 ,             !- Coefficient5 y2
    -0.000956448 ,            !- Coefficient6 xy
    12.77778 ,                 !- Minimum Value of x
    23.88889 ,                 !- Maximum Value of x
    21.11111 ,                 !- Minimum Value of y
    46.11111;                  !- Maximum Value of y

Curve:Biquadratic ,
    Defrost_EIR_FT ,           !- Name
    1 ,                         !- Coefficient1 Constant
    0 ,                         !- Coefficient2 x
    0 ,                         !- Coefficient3 x2
    0 ,                         !- Coefficient4 y
    0 ,                         !- Coefficient5 y2
    0 ,                         !- Coefficient6 xy
    0 ,                         !- Minimum Value of x
    100 ,                        !- Maximum Value of x
    0 ,                         !- Minimum Value of y
    100;                        !- Maximum Value of y

Curve:Biquadratic ,
    dummy-waste-heat-curve ,   !- Name
    1 ,                         !- Coefficient1 Constant
    0 ,                         !- Coefficient2 x
    0 ,                         !- Coefficient3 x2
    0 ,                         !- Coefficient4 y
    0 ,                         !- Coefficient5 y2
    0 ,                         !- Coefficient6 xy
    0 ,                         !- Minimum Value of x
    50 ,                        !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
1,                                      !- Minimum Curve Output
1,                                      !- Maximum Curve Output
Dimensionless,                         !- Input Unit Type for X
Dimensionless,                         !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
ACCoolingCAPFTemp,                    !- Name
1.5509,                                !- Coefficient1 Constant
-0.07505,                               !- Coefficient2 x
0.0031,                                 !- Coefficient3 x2
0.0024,                                 !- Coefficient4 y
-5e-05,                                 !- Coefficient5 y2
-0.00043,                               !- Coefficient6 xy
0,                                       !- Minimum Value of x
50,                                      !- Maximum Value of x
0,                                       !- Minimum Value of y
50,                                      !- Maximum Value of y
0,                                      !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
ACCoolingEIRFTemp,                    !- Name
-0.30428,                               !- Coefficient1 Constant
0.11805,                                !- Coefficient2 x
-0.00342,                               !- Coefficient3 x2
-0.00626,                               !- Coefficient4 y
0.0007,                                 !- Coefficient5 y2
-0.00047,                               !- Coefficient6 xy
0,                                       !- Minimum Value of x
50,                                      !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                     !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPCoolingCAPFTemp,                    !- Name
1.55736,                                !- Coefficient1 Constant
-0.074448,                               !- Coefficient2 x
0.003099,                                !- Coefficient3 x2
0.00146,                                 !- Coefficient4 y
-4.1e-05,                                !- Coefficient5 y2
-0.000427,                               !- Coefficient6 xy
0,                                       !- Minimum Value of x
50,                                      !- Maximum Value of x
0,                                       !- Minimum Value of y
50,                                      !- Maximum Value of y
0,                                       !- Minimum Curve Output
5,                                       !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPCoolingEIRFTemp,                    !- Name
-0.350448,                               !- Coefficient1 Constant
0.11681,                                 !- Coefficient2 x
-0.0034,                                 !- Coefficient3 x2
-0.001226,                               !- Coefficient4 y
0.000601,                                !- Coefficient5 y2
-0.000467,                               !- Coefficient6 xy
0,                                       !- Minimum Value of x
50,                                      !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                     !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPHeatingCAPFTemp,                    !- Name
0.876825,                             !- Coefficient1 Constant
-0.002955,                            !- Coefficient2 x
-5.8e-05,                             !- Coefficient3 x2
0.025335,                            !- Coefficient4 y
0.000196,                            !- Coefficient5 y2
-4.3e-05,                            !- Coefficient6 xy
0,                                     !- Minimum Value of x
50,                                    !- Maximum Value of x
0,                                     !- Minimum Value of y
50,                                    !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                     !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
HPHeatingEIRFTemp,                    !- Name
0.704658,                            !- Coefficient1 Constant
0.008767,                            !- Coefficient2 x
0.000625,                            !- Coefficient3 x2
-0.009037,                            !- Coefficient4 y
0.000738,                            !- Coefficient5 y2
-0.001025,                            !- Coefficient6 xy
0,                                     !- Minimum Value of x
50,                                    !- Maximum Value of x

```

```

0,                               !- Minimum Value of y
50,                             !- Maximum Value of y
0,                               !- Minimum Curve Output
5,                               !- Maximum Curve Output
Temperature,                   !- Input Unit Type for X
Temperature,                   !- Input Unit Type for Y
Dimensionless;                 !- Output Unit Type

```

```

Curve:Biquadratic,
HPLowStageHeatingCAPFTemp,      !- Name
0.84613,                        !- Coefficient1 Constant
-0.002279,                      !- Coefficient2 x
-4.7e-05,                        !- Coefficient3 x2
0.026703,                        !- Coefficient4 y
0.000201,                        !- Coefficient5 y2
-7.9e-05,                        !- Coefficient6 xy
0,                               !- Minimum Value of x
50,                             !- Maximum Value of x
0,                               !- Minimum Value of y
50,                             !- Maximum Value of y
0,                               !- Minimum Curve Output
5,                               !- Maximum Curve Output
Temperature,                   !- Input Unit Type for X
Temperature,                   !- Input Unit Type for Y
Dimensionless;                 !- Output Unit Type

```

```

Curve:Biquadratic,
HPLowStageHeatingEIRFTemp,      !- Name
0.551837,                        !- Coefficient1 Constant
0.02038,                         !- Coefficient2 x
0.000546,                         !- Coefficient3 x2
-0.009638,                        !- Coefficient4 y
0.000785,                         !- Coefficient5 y2
-0.00125,                          !- Coefficient6 xy
0,                                !- Minimum Value of x
50,                              !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                     !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
    HPHighStageHeatingCAPFTemp,      !- Name
    0.818223,                      !- Coefficient1 Constant
    0.001981,                      !- Coefficient2 x
    -0.000203,                     !- Coefficient3 x2
    0.028703,                      !- Coefficient4 y
    0.000207,                      !- Coefficient5 y2
    -7.1e-05,                       !- Coefficient6 xy
    0,                               !- Minimum Value of x
    50,                             !- Maximum Value of x
    0,                               !- Minimum Value of y
    50,                             !- Maximum Value of y
    0,                               !- Minimum Curve Output
    5,                               !- Maximum Curve Output
    Temperature,                   !- Input Unit Type for X
    Temperature,                   !- Input Unit Type for Y
    Dimensionless;                !- Output Unit Type

Curve:Biquadratic,
    HPHighStageHeatingEIRFTemp,    !- Name
    0.81584,                      !- Coefficient1 Constant
    -0.00615,                      !- Coefficient2 x
    0.001021,                      !- Coefficient3 x2
    -0.001301,                     !- Coefficient4 y
    0.001083,                      !- Coefficient5 y2
    -0.001487,                     !- Coefficient6 xy
    0,                               !- Minimum Value of x
    50,                             !- Maximum Value of x

```

```

0,                               !- Minimum Value of y
50,                             !- Maximum Value of y
0,                               !- Minimum Curve Output
5,                               !- Maximum Curve Output
Temperature,                   !- Input Unit Type for X
Temperature,                   !- Input Unit Type for Y
Dimensionless;                 !- Output Unit Type

```

```

Curve:Biquadratic,
HPLowStageCoolingCAPFTemp,      !- Name
1.658788,                        !- Coefficient1 Constant
-0.083453,                       !- Coefficient2 x
0.003424,                         !- Coefficient3 x2
0.002433,                         !- Coefficient4 y
-4.5e-05,                          !- Coefficient5 y2
-0.000534,                        !- Coefficient6 xy
0,                                !- Minimum Value of x
50,                               !- Maximum Value of x
0,                                !- Minimum Value of y
50,                               !- Maximum Value of y
0,                                !- Minimum Curve Output
5,                                !- Maximum Curve Output
Temperature,                     !- Input Unit Type for X
Temperature,                     !- Input Unit Type for Y
Dimensionless;                  !- Output Unit Type

```

```

Curve:Biquadratic,
HPLowStageCoolingEIRFTemp,      !- Name
-0.582916,                        !- Coefficient1 Constant
0.158101,                          !- Coefficient2 x
-0.004398,                         !- Coefficient3 x2
-0.020335,                         !- Coefficient4 y
0.00108,                           !- Coefficient5 y2
-0.00064,                           !- Coefficient6 xy
0,                                !- Minimum Value of x
50,                               !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                      !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
    HPHighStageCoolingCAPFTemp,      !- Name
    1.472738,                        !- Coefficient1 Constant
    -0.067222,                       !- Coefficient2 x
    0.00292,                          !- Coefficient3 x2
    5.2e-05,                           !- Coefficient4 y
    -3e-05,                            !- Coefficient5 y2
    -0.000359,                         !- Coefficient6 xy
    0,                                   !- Minimum Value of x
    50,                                 !- Maximum Value of x
    0,                                   !- Minimum Value of y
    50,                                 !- Maximum Value of y
    0,                                   !- Minimum Curve Output
    5,                                   !- Maximum Curve Output
    Temperature,                      !- Input Unit Type for X
    Temperature,                      !- Input Unit Type for Y
    Dimensionless;                   !- Output Unit Type

Curve:Biquadratic,
    HPHighStageCoolingEIRFTemp,     !- Name
    -0.488196,                        !- Coefficient1 Constant
    0.099162,                          !- Coefficient2 x
    -0.00237,                           !- Coefficient3 x2
    0.019503,                           !- Coefficient4 y
    0.00043,                            !- Coefficient5 y2
    -0.001097,                           !- Coefficient6 xy
    0,                                   !- Minimum Value of x
    50,                                 !- Maximum Value of x

```

```

0,                               !- Minimum Value of y
50,                             !- Maximum Value of y
0,                               !- Minimum Curve Output
5,                               !- Maximum Curve Output
Temperature,                   !- Input Unit Type for X
Temperature,                   !- Input Unit Type for Y
Dimensionless;                 !- Output Unit Type

```

```

Curve:Biquadratic,
ACLowStageCoolingCAPFTemp,      !- Name
1.66458,                        !- Coefficient1 Constant
-0.08039,                       !- Coefficient2 x
0.0033,                          !- Coefficient3 x2
0.00124,                         !- Coefficient4 y
-3e-05,                          !- Coefficient5 y2
-0.00052,                        !- Coefficient6 xy
0,                               !- Minimum Value of x
50,                             !- Maximum Value of x
0,                               !- Minimum Value of y
50,                             !- Maximum Value of y
0,                               !- Minimum Curve Output
5,                               !- Maximum Curve Output
Temperature,                   !- Input Unit Type for X
Temperature,                   !- Input Unit Type for Y
Dimensionless;                 !- Output Unit Type

```

```

Curve:Biquadratic,
ACLowStageCoolingEIRFTemp,      !- Name
-0.42738,                        !- Coefficient1 Constant
0.14191,                         !- Coefficient2 x
-0.00412,                        !- Coefficient3 x2
-0.01406,                         !- Coefficient4 y
0.00083,                          !- Coefficient5 y2
-0.00043,                         !- Coefficient6 xy
0,                               !- Minimum Value of x
50,                             !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                     !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
    ACHighStageCoolingCAPFTemp,      !- Name
    1.36788,                         !- Coefficient1 Constant
    -0.06257,                        !- Coefficient2 x
    0.0028,                           !- Coefficient3 x2
    0.00504,                          !- Coefficient4 y
    -7e-05,                           !- Coefficient5 y2
    -0.00045,                         !- Coefficient6 xy
    0,                                 !- Minimum Value of x
    50,                               !- Maximum Value of x
    0,                                 !- Minimum Value of y
    50,                               !- Maximum Value of y
    0,                                 !- Minimum Curve Output
    5,                                 !- Maximum Curve Output
    Temperature,                      !- Input Unit Type for X
    Temperature,                      !- Input Unit Type for Y
    Dimensionless;                   !- Output Unit Type

Curve:Biquadratic,
    ACHighStageCoolingEIRFTemp,     !- Name
    0.04232,                         !- Coefficient1 Constant
    0.07892,                          !- Coefficient2 x
    -0.00238,                         !- Coefficient3 x2
    -0.00304,                          !- Coefficient4 y
    0.00053,                          !- Coefficient5 y2
    -0.00032,                         !- Coefficient6 xy
    0,                                 !- Minimum Value of x
    50,                               !- Maximum Value of x

```

```

0,                                     !- Minimum Value of y
50,                                     !- Maximum Value of y
0,                                     !- Minimum Curve Output
5,                                      !- Maximum Curve Output
Temperature,                            !- Input Unit Type for X
Temperature,                            !- Input Unit Type for Y
Dimensionless;                         !- Output Unit Type

Curve:Biquadratic,
Cool-Cap-fT,                           !- Name
1.26489391,                            !- Coefficient1 Constant
-0.035054982,                          !- Coefficient2 x
0.00211086,                            !- Coefficient3 x2
-0.001526886,                          !- Coefficient4 y
-7.0308e-06,                           !- Coefficient5 y2
-0.0004691844,                         !- Coefficient6 xy
-100,                                    !- Minimum Value of x
100,                                     !- Maximum Value of x
-100,                                    !- Minimum Value of y
100;                                     !- Maximum Value of y

Curve:Biquadratic,
Cool-EIR-fT,                           !- Name
0.38402403,                            !- Coefficient1 Constant
0.029696724,                           !- Coefficient2 x
-0.0011329308,                         !- Coefficient3 x2
0.006490674,                           !- Coefficient4 y
0.0002626992,                           !- Coefficient5 y2
-0.0001207224,                         !- Coefficient6 xy
-100,                                    !- Minimum Value of x
100,                                     !- Maximum Value of x
-100,                                    !- Minimum Value of y
100;                                     !- Maximum Value of y

Curve:DoubleExponentialDecay,
Doubleexponential,                      !- Name

```

```

1380,                               !- Coefficient1 C1
6834,                               !- Coefficient2 C2
-8.75,                               !- Coefficient3 C3
6747,                               !- Coefficient4 C4
-6.22,                               !- Coefficient5 C5
0,                                    !- Minimum Value of x
1,                                    !- Maximum Value of x
,                                     !- Minimum Curve Output
,                                     !- Maximum Curve Output
Dimensionless,                      !- Input Unit Type for x
Dimensionless;                      !- Output Unit Type

ComponentCost:LineItem,
PV_roof_front,                      !- Name
,
!- Type
Generator:Photovoltaic,             !- Line Item Type
PV_roof_front,                      !- Item Name
,
!- Object EndUse Key
,
!- Cost per Each
,
!- Cost per Area
9000,                                !- Cost per Unit of Output Capacity
,
!- Cost per Unit of Output Capacity
per COP
,
!- Cost per Volume
,
!- Cost per Volume Rate
,
!- Cost per Energy per Temperature
Difference
;
!- Quantity

ComponentCost:LineItem,
PV_roof_back,                        !- Name
,
!- Type
Generator:Photovoltaic,              !- Line Item Type
PV_roof_back,                        !- Item Name
,
!- Object EndUse Key
,
!- Cost per Each

```

```

        ,           !- Cost per Area
9000,           !- Cost per Unit of Output Capacity
        ,           !- Cost per Unit of Output Capacity
per COP

        ,           !- Cost per Volume
        ,           !- Cost per Volume Rate
        ,           !- Cost per Energy per Temperature

Difference

;

        !- Quantity

Output:Variable,
*,           !- Key Value
Electric Load Center Produced Electricity Rate,      !- Variable
Name
hourly;           !- Reporting Frequency

Output:Variable,
*,           !- Key Value
Electric Storage Charge Power,      !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,           !- Key Value
Electric Storage Discharge Power,      !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,           !- Key Value
Facility Total Purchased Electricity Rate,      !- Variable Name
hourly;           !- Reporting Frequency

Output:Variable,
*,           !- Key Value
Facility Total Surplus Electricity Rate,      !- Variable Name
hourly;           !- Reporting Frequency

```

```

Output:Variable,
*,                               !- Key Value
Facility Net Purchased Electricity Rate,      !- Variable Name
hourly;                           !- Reporting Frequency

Output:Variable,
*,                               !- Key Value
Facility Total Electricity Demand Rate,      !- Variable Name
hourly;                           !- Reporting Frequency

Output:Variable,
*,                               !- Key Value
Site Outdoor Air Drybulb Temperature,      !- Variable Name
hourly;                           !- Reporting Frequency

Output:Variable,
*,                               !- Key Value
Zone Thermostat Cooling Setpoint Temperature,      !- Variable
Name
hourly;                           !- Reporting Frequency

Output:Variable,
*,                               !- Key Value
Zone Thermal Comfort Pierce Model Standard Effective Temperature
,      !- Variable Name
hourly;                           !- Reporting Frequency

```

### D.3 Kuwait Residential idf

Multi-family residential model in Kuwait, developed by the research team members, Jonathon Brearley and David Birge.

```

Version ,
9.5;                                !- Version Identifier

Timestep ,
6;                                    !- Number of Timesteps per
Hour

LifeCycleCost:Parameters ,
Life Cycle Cost Parameters ,           !- Name
EndOfYear ,                           !- Discounting Convention
ConstantDollar ,                     !- Inflation Approach
0.03 ,                                !- Real Discount Rate
,                                     !- Nominal Discount Rate
,                                     !- Inflation
,                                     !- Base Date Month
2011 ,                                 !- Base Date Year
,                                     !- Service Date Month
2011 ,                                 !- Service Date Year
25 ,                                   !- Length of Study Period
in Years
,
None;                                  !- Depreciation Method

LifeCycleCost:UsePriceEscalation ,
U.S. Avg Commercial-Electricity ,     !- Name
Electricity ,                         !- Resource
2011 ,                                !- Escalation Start Year
January ,                             !- Escalation Start Month
0.9838 ,                             !- Year Escalation 1
0.9730 ,                             !- Year Escalation 2
0.9632 ,                             !- Year Escalation 3
0.9611 ,                             !- Year Escalation 4
0.9571 ,                             !- Year Escalation 5
0.9553 ,                             !- Year Escalation 6
0.9539 ,                             !- Year Escalation 7

```

```

0.9521,                               !- Year Escalation 8
0.9546,                               !- Year Escalation 9
0.9550,                               !- Year Escalation 10
0.9553,                               !- Year Escalation 11
0.9564,                               !- Year Escalation 12
0.9575,                               !- Year Escalation 13
0.9596,                               !- Year Escalation 14
0.9618,                               !- Year Escalation 15
0.9614,                               !- Year Escalation 16
0.9618,                               !- Year Escalation 17
0.9618,                               !- Year Escalation 18
0.9593,                               !- Year Escalation 19
0.9589,                               !- Year Escalation 20
0.9607,                               !- Year Escalation 21
0.9625,                               !- Year Escalation 22
0.9650,                               !- Year Escalation 23
0.9708,                               !- Year Escalation 24
0.9751,                               !- Year Escalation 25
0.9762,                               !- Year Escalation 26
0.9766,                               !- Year Escalation 27
0.9766,                               !- Year Escalation 28
0.9769,                               !- Year Escalation 29
0.9773;                              !- Year Escalation 30

LifeCycleCost:UsePriceEscalation,
U.S. Avg Commercial-Distillate Oil,      !- Name
FuelOilNo1,                            !- Resource
2011,                                  !- Escalation Start Year
January,                                !- Escalation Start Month
0.9714,                                !- Year Escalation 1
0.9730,                                !- Year Escalation 2
0.9942,                                !- Year Escalation 3
1.0164,                                !- Year Escalation 4
1.0541,                                !- Year Escalation 5
1.0928,                                !- Year Escalation 6
1.1267,                                !- Year Escalation 7

```

1.1580,	! - Year Escalation 8
1.1792,	! - Year Escalation 9
1.1967,	! - Year Escalation 10
1.2200,	! - Year Escalation 11
1.2333,	! - Year Escalation 12
1.2566,	! - Year Escalation 13
1.2709,	! - Year Escalation 14
1.2826,	! - Year Escalation 15
1.2985,	! - Year Escalation 16
1.3102,	! - Year Escalation 17
1.3250,	! - Year Escalation 18
1.3261,	! - Year Escalation 19
1.3282,	! - Year Escalation 20
1.3324,	! - Year Escalation 21
1.3356,	! - Year Escalation 22
1.3431,	! - Year Escalation 23
1.3510,	! - Year Escalation 24
1.3568,	! - Year Escalation 25
1.3606,	! - Year Escalation 26
1.3637,	! - Year Escalation 27
1.3674,	! - Year Escalation 28
1.3706,	! - Year Escalation 29
1.3743;	! - Year Escalation 30

LifeCycleCost:UsePriceEscalation,	
U.S. Avg Commercial-Residual Oil,	! - Name
FuelOilNo2,	! - Resource
2011,	! - Escalation Start Year
January,	! - Escalation Start Month
0.8469,	! - Year Escalation 1
0.8257,	! - Year Escalation 2
0.8681,	! - Year Escalation 3
0.8988,	! - Year Escalation 4
0.9289,	! - Year Escalation 5
0.9604,	! - Year Escalation 6
0.9897,	! - Year Escalation 7

1.0075,	! - Year Escalation 8
1.0314,	! - Year Escalation 9
1.0554,	! - Year Escalation 10
1.0861,	! - Year Escalation 11
1.1278,	! - Year Escalation 12
1.1497,	! - Year Escalation 13
1.1620,	! - Year Escalation 14
1.1743,	! - Year Escalation 15
1.1852,	! - Year Escalation 16
1.1948,	! - Year Escalation 17
1.2037,	! - Year Escalation 18
1.2071,	! - Year Escalation 19
1.2119,	! - Year Escalation 20
1.2139,	! - Year Escalation 21
1.2194,	! - Year Escalation 22
1.2276,	! - Year Escalation 23
1.2365,	! - Year Escalation 24
1.2420,	! - Year Escalation 25
1.2461,	! - Year Escalation 26
1.2509,	! - Year Escalation 27
1.2550,	! - Year Escalation 28
1.2591,	! - Year Escalation 29
1.2638;	! - Year Escalation 30

LifeCycleCost:UsePriceEscalation,	
U.S. Avg Commercial-Natural gas,	! - Name
NaturalGas,	! - Resource
2011,	! - Escalation Start Year
January,	! - Escalation Start Month
0.9823,	! - Year Escalation 1
0.9557,	! - Year Escalation 2
0.9279,	! - Year Escalation 3
0.9257,	! - Year Escalation 4
0.9346,	! - Year Escalation 5
0.9412,	! - Year Escalation 6
0.9512,	! - Year Escalation 7

0.9645,	! - Year Escalation 8
0.9856,	! - Year Escalation 9
1.0067,	! - Year Escalation 10
1.0222,	! - Year Escalation 11
1.0410,	! - Year Escalation 12
1.0610,	! - Year Escalation 13
1.0787,	! - Year Escalation 14
1.0942,	! - Year Escalation 15
1.1098,	! - Year Escalation 16
1.1220,	! - Year Escalation 17
1.1308,	! - Year Escalation 18
1.1386,	! - Year Escalation 19
1.1486,	! - Year Escalation 20
1.1619,	! - Year Escalation 21
1.1763,	! - Year Escalation 22
1.1918,	! - Year Escalation 23
1.2118,	! - Year Escalation 24
1.2284,	! - Year Escalation 25
1.2439,	! - Year Escalation 26
1.2605,	! - Year Escalation 27
1.2772,	! - Year Escalation 28
1.2938,	! - Year Escalation 29
1.3115;	! - Year Escalation 30

LifeCycleCost:UsePriceEscalation,	
U.S. Avg Commercial-Coal,	! - Name
Coal,	! - Resource
2011,	! - Escalation Start Year
January,	! - Escalation Start Month
0.9970,	! - Year Escalation 1
1.0089,	! - Year Escalation 2
1.0089,	! - Year Escalation 3
0.9941,	! - Year Escalation 4
0.9941,	! - Year Escalation 5
1.0000,	! - Year Escalation 6
1.0030,	! - Year Escalation 7

```

1.0059,                                     !- Year Escalation 8
1.0089,                                     !- Year Escalation 9
1.0119,                                     !- Year Escalation 10
1.0148,                                     !- Year Escalation 11
1.0178,                                     !- Year Escalation 12
1.0208,                                     !- Year Escalation 13
1.0267,                                     !- Year Escalation 14
1.0297,                                     !- Year Escalation 15
1.0356,                                     !- Year Escalation 16
1.0415,                                     !- Year Escalation 17
1.0534,                                     !- Year Escalation 18
1.0564,                                     !- Year Escalation 19
1.0593,                                     !- Year Escalation 20
1.0653,                                     !- Year Escalation 21
1.0712,                                     !- Year Escalation 22
1.0742,                                     !- Year Escalation 23
1.0801,                                     !- Year Escalation 24
1.0831,                                     !- Year Escalation 25
1.0831,                                     !- Year Escalation 26
1.0861,                                     !- Year Escalation 27
1.0890,                                     !- Year Escalation 28
1.0920,                                     !- Year Escalation 29
1.0950;                                     !- Year Escalation 30

Building,
  Building 1,                                !- Name
  0,                                         !- North Axis {deg}
  Urban,                                      !- Terrain
  ,                                           !- Loads Convergence
  Tolerance Value {W}                         !- Temperature Convergence
  ,                                           !- Temperature Convergence
  Tolerance Value {deltaC}
FullExteriorWithReflections,                 !- Solar Distribution
  ,                                           !- Maximum Number of
  Warmup Days

```

```

;

; Minimum Number of
Warmup Days

Zone ,
Room_16_3d8c5364 , ! - Name
0 , ! - Direction of Relative
North {deg}
0 , ! - X Origin {m}
0 , ! - Y Origin {m}
0 , ! - Z Origin {m}
, ! - Type
1 , ! - Multiplier
, ! - Ceiling Height {m}
, ! - Volume {m3}
, ! - Floor Area {m2}
, ! - Zone Inside Convection
Algorithm
,
! - Zone Outside Convection
Algorithm
Yes ; ! - Part of Total Floor
Area

BuildingSurface:Detailed ,
Room_16_3d8c5364..Face0 , ! - Name
Wall , ! - Surface Type
project_wall , ! - Construction Name
Room_16_3d8c5364 , ! - Zone Name
Outdoors , ! - Outside Boundary
Condition
,
! - Outside Boundary
Condition Object
SunExposed , ! - Sun Exposure
WindExposed , ! - Wind Exposure
, ! - View Factor to Ground
, ! - Number of Vertices

```

```

23.1619451669316, 55.2819899121844, 3.24999999997549, !- X,Y,Z
    Vertex 1 {m}
13.1619451669316, 55.2819899121844, 3.24999999995968, !- X,Y,Z
    Vertex 2 {m}
13.161945166923, 55.2819899122047, -4.03238477771582e-11, !- X,Y,Z
    Vertex 3 {m}
23.161945166923, 55.2819899122047, -2.45078148573979e-11; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_16_3d8c5364..Face0_Glz0,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_16_3d8c5364..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
15.2348618335962, 55.2819899121872, 2.79999999996295, !- X,Y,Z
    Vertex 1 {m}
14.4223618335973, 55.2819899121872, 2.79999999996167, !- X,Y,Z
    Vertex 2 {m}
14.4223618336004, 55.2819899121997, 0.79999999996167, !- X,Y,Z
    Vertex 3 {m}
15.2348618335993, 55.2819899121997, 0.799999999962955; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_16_3d8c5364..Face0_Glz1,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_16_3d8c5364..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Frame and Divider Name
        ,                                     !- Multiplier
        ,                                     !- Number of Vertices
18.5681951669249, 55.2819899121872, 2.79999999996823, !- X,Y,Z
    Vertex 1 {m}
17.755695166926, 55.2819899121872, 2.79999999996694, !- X,Y,Z
    Vertex 2 {m}
17.7556951669292, 55.2819899121997, 0.799999999966942, !- X,Y,Z
    Vertex 3 {m}
18.5681951669281, 55.2819899121997, 0.799999999968227; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_16_3d8c5364..Face0_Glz2,           !- Name
Window,                                    !- Surface Type
project_window,                          !- Construction Name
Room_16_3d8c5364..Face0,                 !- Building Surface Name
,                                         !- Outside Boundary
    Condition Object
        ,                                     !- View Factor to Ground
        ,                                     !- Frame and Divider Name
        ,                                     !- Multiplier
        ,                                     !- Number of Vertices
21.9015285002536, 55.2819899121872, 2.7999999999735, !- X,Y,Z
    Vertex 1 {m}
21.0890285002548, 55.2819899121872, 2.79999999997221, !- X,Y,Z
    Vertex 2 {m}
21.0890285002579, 55.2819899121997, 0.799999999972214, !- X,Y,Z
    Vertex 3 {m}
21.9015285002568, 55.2819899121997, 0.799999999973499; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_16_3d8c5364..Face1,                 !- Name
Wall,                                     !- Surface Type

```

```

project_wall_int,                                !- Construction Name
Room_16_3d8c5364,                               !- Zone Name
Surface,                                         !- Outside Boundary
Condition
Room_27_0080b418..Face3,                         !- Outside Boundary
Condition Object
NoSun,                                            !- Sun Exposure
NoWind,                                           !- Wind Exposure
,                                                 !- View Factor to Ground
,                                                 !- Number of Vertices
23.1619451669316, 55.2819899121844, 3.2499999997549, !- X,Y,Z
Vertex 1 {m}
23.161945166923, 55.2819899122047, -2.45078148573979e-11, !- X,Y,Z
Vertex 2 {m}
19.8286118335897, 60.2819899122047, -6.55526866515655e-11, !- X,Y,
Z Vertex 3 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_16_3d8c5364..Face2,                        !- Name
Wall,                                              !- Surface Type
project_wall_int,                                !- Construction Name
Room_16_3d8c5364,                               !- Zone Name
Surface,                                         !- Outside Boundary
Condition
Room_21_4c523269..Face0,                         !- Outside Boundary
Condition Object
NoSun,                                            !- Sun Exposure
NoWind,                                           !- Wind Exposure
,                                                 !- View Factor to Ground
,                                                 !- Number of Vertices
19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
Vertex 1 {m}
19.8286118335897, 60.2819899122047, -6.55526866515655e-11, !- X,Y,
Z Vertex 2 {m}

```

```

16.4952785002563, 60.2819899122047, -7.08246976248188e-11, !- X,Y,
Z Vertex 3 {m}

16.495278500265, 60.2819899121844, 3.24999999992918; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_16_3d8c5364..Face3, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_16_3d8c5364, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_24_159d21b7..Face0, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
13.1619451669316, 55.2819899121844, 3.2499999995968, !- X,Y,Z
Vertex 1 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
Vertex 2 {m}
16.4952785002563, 60.2819899122047, -7.08246976248188e-11, !- X,Y,
Z Vertex 3 {m}
13.161945166923, 55.2819899122047, -4.03238477771582e-11; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_16_3d8c5364..Face4, !- Name
Floor, !- Surface Type
project_slab, !- Construction Name
Room_16_3d8c5364, !- Zone Name
Ground, !- Outside Boundary
Condition
, !- Outside Boundary
Condition Object

```

```

NoSun ,                                     ! - Sun Exposure
NoWind ,                                     ! - Wind Exposure
,                                         ! - View Factor to Ground
,                                         ! - Number of Vertices
19.8286118335897 , 60.2819899122047 , -6.55526866515655e-11 , !- X,Y,
Z Vertex 1 {m}
23.161945166923 , 55.2819899122047 , -2.45078148573979e-11 , !- X,Y,Z
Vertex 2 {m}
13.161945166923 , 55.2819899122047 , -4.03238477771582e-11 , !- X,Y,Z
Vertex 3 {m}
16.4952785002563 , 60.2819899122047 , -7.08246976248188e-11 ; !- X,Y,
Z Vertex 4 {m}

BuildingSurface:Detailed ,
Room_16_3d8c5364..Face5 ,                   ! - Name
Ceiling ,                                    ! - Surface Type
project_ceiling_int ,                       ! - Construction Name
Room_16_3d8c5364 ,                         ! - Zone Name
Surface ,                                    ! - Outside Boundary
Condition
Room_17_fb615533..Face4 ,                   ! - Outside Boundary
Condition Object
NoSun ,                                     ! - Sun Exposure
NoWind ,                                     ! - Wind Exposure
,                                         ! - View Factor to Ground
,                                         ! - Number of Vertices
23.1619451669316 , 55.2819899121844 , 3.24999999997549 , !- X,Y,Z
Vertex 1 {m}
19.8286118335983 , 60.2819899121844 , 3.24999999993445 , !- X,Y,Z
Vertex 2 {m}
16.495278500265 , 60.2819899121844 , 3.24999999992918 , !- X,Y,Z
Vertex 3 {m}
13.1619451669316 , 55.2819899121844 , 3.24999999995968 ; !- X,Y,Z
Vertex 4 {m}

ZoneControl:Thermostat ,

```

```

Room_16_3d8c5364 Thermostat ,           !- Name
Room_16_3d8c5364 ,                      !- Zone or ZoneList Name
Room_16_3d8c5364 Thermostat Schedule ,   !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint ,          !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 1 ,      !- Control 1 Name
,                                         !- Control 2 Object Type
,                                         !- Control 2 Name
,                                         !- Control 3 Object Type
,                                         !- Control 3 Name
,                                         !- Control 4 Object Type
,                                         !- Control 4 Name
0;                                         !- Temperature Difference

Between Cutout And Setpoint {deltaC}

ScheduleTypeLimits ,
any number;                                !- Name

Schedule:Compact ,
ALWAYS_ON ,                                    !- Name
On/Off ,                                       !- Schedule Type Limits Name
Through: 12/31 ,                               !- Field 1
For: AllDays ,                                 !- Field 2
Until: 24:00 ,1;                               !- Field 3

Schedule:Compact ,
charge_sch ,                                  !- Name
Any Number ,                                   !- Schedule Type Limits Name
Through: 12/31 ,                               !- Field 1
For: AllDays ,                                 !- Field 2
Until: 1:00 ,                                   !- Field 3
0 ,                                         !- Field 4
Until: 2:00 ,                                   !- Field 5
0 ,                                         !- Field 6
Until: 3:00 ,                                   !- Field 7
0 ,                                         !- Field 8
Until: 4:00 ,                                   !- Field 9

```

0,	!- Field 10
Until: 5:00,	!- Field 11
0,	!- Field 12
Until: 6:00,	!- Field 13
0,	!- Field 14
Until: 7:00,	!- Field 15
0,	!- Field 16
Until: 8:00,	!- Field 17
0,	!- Field 18
Until: 9:00,	!- Field 19
0.20993163977729543,	!- Field 20
Until: 10:00,	!- Field 21
0.6063652250396501,	!- Field 22
Until: 11:00,	!- Field 23
0.82298326696258,	!- Field 24
Until: 12:00,	!- Field 25
0.811209619326249,	!- Field 26
Until: 13:00,	!- Field 27
1,	!- Field 28
Until: 14:00,	!- Field 29
0.9365412179871627,	!- Field 30
Until: 15:00,	!- Field 31
0.7474753945294974,	!- Field 32
Until: 16:00,	!- Field 33
0.31017915474001695,	!- Field 34
Until: 17:00,	!- Field 35
0.0006572039008697994,	!- Field 36
Until: 18:00,	!- Field 37
0,	!- Field 38
Until: 19:00,	!- Field 39
0,	!- Field 40
Until: 20:00,	!- Field 41
0,	!- Field 42
Until: 21:00,	!- Field 43
0,	!- Field 44
Until: 22:00,	!- Field 45

```

0,                                !- Field 46
Until: 23:00,                      !- Field 47
0,                                !- Field 48
Until: 24:00,                      !- Field 49
0;                                !- Field 50

Schedule:Compact,
  discharge_sch,                  !- Name
  Any Number,                     !- Schedule Type Limits Name
  Through: 12/31,                !- Field 1
  For: AllDays,                 !- Field 2
  Until: 1:00,                   !- Field 3
  1.4859886047370414e-16,       !- Field 4
  Until: 2:00,                   !- Field 5
  2.4412669934965675e-16,       !- Field 6
  Until: 3:00,                   !- Field 7
  2.4412669934965675e-16,       !- Field 8
  Until: 4:00,                   !- Field 9
  1.4859886047370407e-16,       !- Field 10
  Until: 5:00,                   !- Field 11
  1.8044147343235496e-16,       !- Field 12
  Until: 6:00,                   !- Field 13
  1.4859886047370407e-16,       !- Field 14
  Until: 7:00,                   !- Field 15
  4.3518237710156196e-16,       !- Field 16
  Until: 8:00,                   !- Field 17
  5.12135358418302e-16,        !- Field 18
  Until: 9:00,                   !- Field 19
  0,                                !- Field 20
  Until: 10:00,                  !- Field 21
  0,                                !- Field 22
  Until: 11:00,                  !- Field 23
  0,                                !- Field 24
  Until: 12:00,                  !- Field 25
  0,                                !- Field 26
  Until: 13:00,                  !- Field 27

```

```
0,                                !- Field 28
Until: 14:00,                      !- Field 29
0,                                !- Field 30
Until: 15:00,                      !- Field 31
0,                                !- Field 32
Until: 16:00,                      !- Field 33
0,                                !- Field 34
Until: 17:00,                      !- Field 35
0.17680191083590457,             !- Field 36
Until: 18:00,                      !- Field 37
0.7298301024347349,              !- Field 38
Until: 19:00,                      !- Field 39
0.9288259054679598,              !- Field 40
Until: 20:00,                      !- Field 41
1,                                !- Field 42
Until: 21:00,                      !- Field 43
0.9042389568206112,              !- Field 44
Until: 22:00,                      !- Field 45
0.6622444643283896,              !- Field 46
Until: 23:00,                      !- Field 47
2.1228408639100586e-17,          !- Field 48
Until: 24:00,                      !- Field 49
1.4859886047370407e-16;         !- Field 50
```

```
Schedule:Compact,
Clg-SetP-Sch,                      !- Name
Temperature, !- Schedule Type Limits Name
Through: 12/31,                      !- Field 1
For: AllDays,                        !- Field 2
Until: 24:00,                        !- Field 3
28;                                 !- Field 4
```

```
Schedule:Compact,
Room_16_3d8c5364 Thermostat Schedule,    !- Name
Room_16_3d8c5364 Thermostat Schedule Type Limits, !- Schedule Type
Limits Name
```

```

Through: 12/31,                               !- Field 1
For: AllDays,                                !- Field 2
Until: 24:00,                                 !- Field 3
4;                                              !- Field 4

ScheduleTypeLimits,
Room_16_3d8c5364 Thermostat Schedule Type Limits, !- Name
0,                                         !- Lower Limit Value {
BasedOnField A3}
4,                                         !- Upper Limit Value {
BasedOnField A3}
DISCRETE;                                    !- Numeric Type

ThermostatSetpoint:DualSetpoint,
Thermostat Setpoint Dual Setpoint 1,      !- Name
project_heat,                            !- Heating Setpoint
Temperature Schedule Name
Clg-SetP-Sch;                           !- Cooling Setpoint
Temperature Schedule Name

ScheduleTypeLimits,
Temperature,                                !- Name
-273.15,                                   !- Lower Limit Value {
BasedOnField A3}
,                                         !- Upper Limit Value {
BasedOnField A3}
Continuous,                                !- Numeric Type
temperature;                                !- Unit Type

Schedule:File,
project_heat,                                !- Name
Temperature,                                 !- Schedule Type Limits
Name
/content/drive/My Drive/Kuwait/reference_schedules/project_heat.
csv, !- File Name
1,                                         !- Column Number

```

```

1,                                     ! - Rows to Skip at Top
,
Comma,                                 ! - Number of Hours of Data
No,                                    ! - Column Separator
60;                                    ! - Interpolate to Timestep
                                         ! - Minutes per Item

Schedule:Day:Interval,
Standard_Cooling_Sunday,                ! - Name
Temperature,                            ! - Schedule Type Limits
Name
No,                                     ! - Interpolate to Timestep
24:00,                                  ! - Time 1 {hh:mm}
23;                                     ! - Value Until Time 1

Schedule:Week:Daily,
Standard_Cooling_Week Rule - Jan1-Dec31, ! - Name
Standard_Cooling_Sunday,                  ! - Sunday Schedule:Day
Name
Standard_Cooling_Sunday,                  ! - Monday Schedule:Day
Name
Standard_Cooling_Sunday,                  ! - Tuesday Schedule:Day
Name
Standard_Cooling_Sunday,                  ! - Wednesday Schedule:Day
Name
Standard_Cooling_Sunday,                  ! - Thursday Schedule:Day
Name
Standard_Cooling_Sunday,                  ! - Friday Schedule:Day
Name
Standard_Cooling_Sunday,                  ! - Saturday Schedule:Day
Name
Standard_Cooling_Hol_1,                  ! - Holiday Schedule:Day
Name
Standard_Cooling_SmrDsn_1,               ! - SummerDesignDay
Schedule:Day Name

```

```

Standard_Cooling_WntrDsn 1,           ! - WinterDesignDay
  Schedule:Day Name
Standard_Cooling_Sunday,             ! - CustomDay1 Schedule:Day
  Name
Standard_Cooling_Sunday;            ! - CustomDay2 Schedule:Day
  Name

Schedule:Year,
  Standard_Cooling,                 ! - Name
  Temperature,                      ! - Schedule Type Limits
  Name
  Standard_Cooling Week Rule - Jan1-Dec31, ! - Schedule:Week Name 1
  1,                                ! - Start Month 1
  1,                                ! - Start Day 1
  12,                               ! - End Month 1
  31;                               ! - End Day 1

Schedule:Day:Interval,
  Standard_Cooling_SmrDsn 1,         ! - Name
  Temperature,                      ! - Schedule Type Limits
  Name
  No,                               ! - Interpolate to Timestep
  24:00,                            ! - Time 1 {hh:mm}
  23;                               ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Cooling_WntrDsn 1,       ! - Name
  Temperature,                      ! - Schedule Type Limits
  Name
  No,                               ! - Interpolate to Timestep
  24:00,                            ! - Time 1 {hh:mm}
  23;                               ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Cooling_Hol 1,           ! - Name

```

```

Temperature ,                                     !- Schedule Type Limits
  Name
No ,                                              !- Interpolate to Timestep
24:00 ,                                           !- Time 1 {hh:mm}
23;                                              !- Value Until Time 1

ZoneHVAC:EquipmentConnections ,
  Room_16_3d8c5364 ,                           !- Zone Name
  Room_16_3d8c5364 Equipment List ,           !- Zone Conditioning
    Equipment List Name
  Room_16_3d8c5364 Inlet Node List ,          !- Zone Air Inlet Node or
    NodeList Name
  Room_16_3d8c5364 Exhaust Node List ,         !- Zone Air Exhaust Node
    or NodeList Name
  Room_16_3d8c5364 Zone Air Node ,            !- Zone Air Node Name
  Room_16_3d8c5364 Return Node List;          !- Zone Return Air Node or
    NodeList Name

NodeList ,
  Room_16_3d8c5364 Inlet Node List ,          !- Name
  Room_16_3d8c5364 Air Terminal Outlet Air Node , !- Node Name 1
  Room_16_3d8c5364 VRF Terminal Unit Outlet Air Node; !- Node Name 2

NodeList ,
  Room_16_3d8c5364 Exhaust Node List ,         !- Name
  Room_16_3d8c5364 VRF Terminal Unit Inlet Air Node; !- Node Name 1

NodeList ,
  Room_16_3d8c5364 Return Node List ,          !- Name
  Room_16_3d8c5364 Return Air Node;            !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
  Room_16_3d8c5364 Air Terminal ,              !- Name
  Always On Discrete ,                         !- Availability Schedule
  Name

```

```

Room_16_3d8c5364 Air Terminal Inlet Air Node, !- Air Inlet Node
Name

Room_16_3d8c5364 Air Terminal Outlet Air Node, !- Air Outlet Node
Name

AutoSize;                                     !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit,
ADU Room_16_3d8c5364 Air Terminal,          !- Name
Room_16_3d8c5364 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
Object Type
Room_16_3d8c5364 Air Terminal;             !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow,
Room_16_3d8c5364 VRF Terminal Unit,         !- Zone Terminal Unit Name
Always On Discrete,                         !- Terminal Unit
Availability Schedule
Room_16_3d8c5364 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_16_3d8c5364 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                                    !- Cooling Supply Air Flow
Rate {m3/s}
Autosize,                                    !- No Cooling Supply Air
Flow Rate {m3/s}
Autosize,                                    !- Heating Supply Air Flow
Rate {m3/s}
Autosize,                                    !- No Heating Supply Air
Flow Rate {m3/s}
Autosize,                                    !- Cooling Outdoor Air
Flow Rate {m3/s}
Autosize,                                    !- Heating Outdoor Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- No Load Outdoor Air
Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
Placement

Fan:OnOff,                                    !- Supply Air Fan Object
Type

Room_16_3d8c5364 VRF Unit Cycling Fan,      !- Supply Air Fan Object
Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
Object Type

Room_16_3d8c5364 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,    !- Cooling Coil Object
Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil,
!- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,     !- Heating Coil Object
Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil,
!- Heating Coil Object Name

30,                                           !- Zone Terminal Unit On
Parasitic Electric Energy Use {W}

20,                                           !- Zone Terminal Unit Off
Parasitic Electric Energy Use {W}

1,                                            !- Rated Heating Capacity
Sizing Ratio {W/W}

,                                              !- Availability Manager

List Name

,                                              !- Design Specification

ZoneHVAC Sizing Object Name

,                                              !- Supplemental Heating
Coil Object Type

,                                              !- Supplemental Heating
Coil Name

```

```

Autosize,                                     ! - Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                         ! - Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

Schedule:Constant,
Always On Discrete,                         ! - Name
OnOff,                                       ! - Schedule Type Limits
Name
1;                                           ! - Hourly Value

Schedule:Constant,
Always Off Discrete,                        ! - Name
OnOff 1,                                      ! - Schedule Type Limits
Name
0;                                           ! - Hourly Value

OutdoorAir:Mixer,
Room_16_3d8c5364 VRF Terminal Unit OA Mixer, !- Name
Room_16_3d8c5364 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_16_3d8c5364 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_16_3d8c5364 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_16_3d8c5364 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_16_3d8c5364 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil,
! - Name

```

```

Always On Discrete , ! - Availability Schedule
Name

Autosize , ! - Gross Rated Total
Cooling Capacity {W}

Autosize , ! - Gross Rated Sensible
Heat Ratio

Autosize , ! - Rated Air Flow Rate {m3
/s}

VRFTUCoolCapFT , ! - Cooling Capacity Ratio
Modifier Function of Temperature Curve Name

VRFACCoolCapFFF , ! - Cooling Capacity
Modifier Curve Function of Flow Fraction Name

Room_16_3d8c5364 VRF Terminal Unit Mixer Outlet Node , ! - Coil Air
Inlet Node

Room_16_3d8c5364 VRF Terminal Unit Cooling Coil Outlet Node ; ! -
Coil Air Outlet Node

Curve:Biquadratic ,
VRFTUCoolCapFT , ! - Name
0.0585884077803259 , ! - Coefficient1 Constant
0.0587396532718384 , ! - Coefficient2 x
-0.000210274979759697 , ! - Coefficient3 x**2
0.0109370473889647 , ! - Coefficient4 y
-0.0001219549 , ! - Coefficient5 y**2
-0.0005246615 , ! - Coefficient6 x*y
15 , ! - Minimum Value of x {
BasedOnField A2}
23.89 , ! - Maximum Value of x {
BasedOnField A2}
20 , ! - Minimum Value of y {
BasedOnField A3}
43.33 , ! - Maximum Value of y {
BasedOnField A3}
0.8083 , ! - Minimum Curve Output {
BasedOnField A4}

```

```

1.2583;                                     !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
VRFACCCoolCapFFF,                           !- Name
0.8,                                         !- Coefficient1 Constant
0.2,                                         !- Coefficient2 x
0,                                            !- Coefficient3 x**2
0.5,                                         !- Minimum Value of x {
BasedOnField A2}
1.5;                                         !- Maximum Value of x {
BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil,
!- Name
Always On Discrete,                         !- Availability Schedule
Autosize,                                     !- Gross Rated Heating
Capacity {W}
Autosize,                                     !- Rated Air Flow Rate {m3
/s}
Room_16_3d8c5364 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_16_3d8c5364 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT, !-
Name
0.375443994956127,                          !- Coefficient1 Constant
0.0668190645147821,                        !- Coefficient2 x

```

```

-0.00194171026482001 , !- Coefficient3 x**2
0.0442618420640187 , !- Coefficient4 y
-0.0004009578 , !- Coefficient5 y**2
-0.0014819801 , !- Coefficient6 x*y
21.11 , !- Minimum Value of x {
    BasedOnField A2}
27.22 , !- Maximum Value of x {
    BasedOnField A2}
-15 , !- Minimum Value of y {
    BasedOnField A3}
18.33 , !- Maximum Value of y {
    BasedOnField A3}
0.6074 , !- Minimum Curve Output {
    BasedOnField A4}
1; !- Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF , !-
    Name
0.8 , !- Coefficient1 Constant
0.2 , !- Coefficient2 x
0 , !- Coefficient3 x**2
0.5 , !- Minimum Value of x {
    BasedOnField A2}
1.5 ; !- Maximum Value of x {
    BasedOnField A2}

Fan:OnOff ,
Room_16_3d8c5364 VRF Unit Cycling Fan , !- Name
Always On Discrete , !- Availability Schedule
    Name
0.6 , !- Fan Total Efficiency
300 , !- Pressure Rise {Pa}
Autosize , !- Maximum Flow Rate {m3/s}
    }

```

```

0.8,                                     !- Motor Efficiency
1,                                         !- Motor In Airstream
    Fraction

Room_16_3d8c5364 VRF Terminal Unit Heating Coil Outlet Node, !-
    Air Inlet Node Name

Room_16_3d8c5364 VRF Terminal Unit Outlet Air Node, !- Air Outlet
    Node Name

Fan On Off Power Curve,                   !- Fan Power Ratio
    Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve,            !- Fan Efficiency Ratio
    Function of Speed Ratio Curve Name

General;                                !- End-Use Subcategory

Curve:Exponent,
    Fan On Off Power Curve,             !- Name
    1,                                  !- Coefficient1 Constant
    0,                                  !- Coefficient2 Constant
    0,                                  !- Coefficient3 Constant
    0,                                  !- Minimum Value of x {
        BasedOnField A2}
    1;                                 !- Maximum Value of x {
        BasedOnField A2}

Curve:Cubic,
    Fan On Off Efficiency Curve,       !- Name
    1,                                  !- Coefficient1 Constant
    0,                                  !- Coefficient2 x
    0,                                  !- Coefficient3 x**2
    0,                                  !- Coefficient4 x**3
    0,                                  !- Minimum Value of x {
        BasedOnField A2}
    1;                                 !- Maximum Value of x {
        BasedOnField A2}

ZoneHVAC:EquipmentList,
    Room_16_3d8c5364 Equipment List,      !- Name

```

```

SequentialLoad ,                               ! - Load Distribution
  Scheme
ZoneHVAC:AirDistributionUnit ,               ! - Zone Equipment Object
  Type 1
    ADU Room_16_3d8c5364 Air Terminal ,      ! - Zone Equipment Name 1
    1 ,                                         ! - Zone Equipment Cooling
      Sequence 1                                ! - Zone Equipment Heating
    1 ,                                         ! - Zone Equipment Heating
      or No-Load Sequence 1
    Schedule Constant 1 ,                      ! - Zone Equipment
      Sequential Cooling Fraction Schedule Name 1
    Schedule Constant 2 ,                      ! - Zone Equipment
      Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow , ! - Zone Equipment
  Object Type 2
    Room_16_3d8c5364 VRF Terminal Unit ,     ! - Zone Equipment Name 2
    2 ,                                         ! - Zone Equipment Cooling
      Sequence 2                                ! - Zone Equipment Heating
    2 ,                                         ! - Zone Equipment Heating
      or No-Load Sequence 2
    ,
      Sequential Cooling Fraction Schedule Name 2 ! - Zone Equipment
    ;
      Sequential Heating Fraction Schedule Name 2 ! - Zone Equipment

Sizing:Zone ,
  Room_16_3d8c5364 ,                         ! - Zone or ZoneList Name
  SupplyAirTemperature ,                       ! - Zone Cooling Design
    Supply Air Temperature Input Method
    12.77777777777778 ,                     ! - Zone Cooling Design
      Supply Air Temperature {C}
    11.11 ,                                     ! - Zone Cooling Design
      Supply Air Temperature Difference {deltaC}
    SupplyAirTemperature ,                      ! - Zone Heating Design
      Supply Air Temperature Input Method

```

```

40.00000000000001,                                !- Zone Heating Design
Supply Air Temperature {C}
11.11,                                         !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                         !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                         !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                     !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor
,
!- Zone Cooling Sizing
Factor
DesignDay,                                     !- Cooling Design Air Flow
Method
0,                                              !- Cooling Design Air Flow
Rate {m3/s}
0.000762,                                       !- Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                              !- Cooling Minimum Air
Flow {m3/s}
0,                                              !- Cooling Minimum Air
Flow Fraction
DesignDay,                                     !- Heating Design Air Flow
Method
0,                                              !- Heating Design Air Flow
Rate {m3/s}
0.002032,                                       !- Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                      !- Heating Maximum Air
Flow {m3/s}
0.3,                                            !- Heating Maximum Air
Flow Fraction
,
!- Design Specification
Zone Air Distribution Object Name

```

```

Yes,                                     !- Account for Dedicated
                                         Outdoor Air System
NeutralSupplyAir,                         !- Dedicated Outdoor Air
                                         System Control Strategy
15.55555555555556,                      !- Dedicated Outdoor Air
                                         Low Setpoint Temperature for Design {C}
21.111111111111;                        !- Dedicated Outdoor Air
                                         High Setpoint Temperature for Design {C}

ScheduleTypeLimits,
On-Off,                                    !- Name
0,                                         !- Lower Limit Value {
                                         BasedOnField A3}
1,                                         !- Upper Limit Value {
                                         BasedOnField A3}
Discrete,                                   !- Numeric Type
dimensionless;                            !- Unit Type

Schedule:Day:Interval,
Standard_Ventilation_Sunday,              !- Name
On-Off,                                    !- Schedule Type Limits
                                         Name
No,                                         !- Interpolate to Timestep
24:00,                                     !- Time 1 {hh:mm}
1;                                         !- Value Until Time 1

Schedule:Week:Daily,
Standard_Ventilation Week Rule - Jan1-Dec31, !- Name
Standard_Ventilation_Sunday,                !- Sunday Schedule:Day
                                         Name
Standard_Ventilation_Sunday,                !- Monday Schedule:Day
                                         Name
Standard_Ventilation_Sunday,                !- Tuesday Schedule:Day
                                         Name
Standard_Ventilation_Sunday,                !- Wednesday Schedule:Day
                                         Name

```

```

Standard_Ventilation_Sunday , ! - Thursday Schedule:Day
    Name

Standard_Ventilation_Sunday , ! - Friday Schedule:Day
    Name

Standard_Ventilation_Sunday , ! - Saturday Schedule:Day
    Name

Standard_Ventilation_Hol 1 , ! - Holiday Schedule:Day
    Name

Standard_Ventilation_SmrDsn 1 , ! - SummerDesignDay
    Schedule:Day Name

Standard_Ventilation_WntrDsn 1 , ! - WinterDesignDay
    Schedule:Day Name

Standard_Ventilation_Sunday , ! - CustomDay1 Schedule:Day
    Name

Standard_Ventilation_Sunday ; ! - CustomDay2 Schedule:Day
    Name

Schedule:Year ,
    Standard_Ventilation , ! - Name
    On-Off , ! - Schedule Type Limits
    Name

    Standard_Ventilation Week Rule - Jan1-Dec31 , ! - Schedule:Week Name
        1
        1 , ! - Start Month 1
        1 , ! - Start Day 1
        12 , ! - End Month 1
        31 ; ! - End Day 1

Schedule:Day:Interval ,
    Standard_Ventilation_SmrDsn 1 , ! - Name
    On-Off , ! - Schedule Type Limits
    Name

    No , ! - Interpolate to Timestep
    24:00 , ! - Time 1 {hh:mm}
    1 ; ! - Value Until Time 1

```

```

Schedule:Day:Interval ,
  Standard_Ventilation_WntrDsn 1,           !- Name
  On-Off,                                     !- Schedule Type Limits
    Name
    No,                                         !- Interpolate to Timestep
    24:00,                                       !- Time 1 {hh:mm}
    1;                                           !- Value Until Time 1

Schedule:Day:Interval ,
  Standard_Ventilation_Hol 1,                 !- Name
  On-Off,                                     !- Schedule Type Limits
    Name
    No,                                         !- Interpolate to Timestep
    24:00,                                       !- Time 1 {hh:mm}
    1;                                           !- Value Until Time 1

Controller:MechanicalVentilation ,
  15 Zone DOAS Mechanical Ventilation Controller, !- Name
  Standard_Ventilation,                      !- Availability Schedule
    Name
    No,                                         !- Demand Controlled
    Ventilation
    ZoneSum,                                    !- System Outdoor Air
      Method
      ,
      !- Zone Maximum Outdoor
      Air Fraction {dimensionless}
    Room_16_3d8c5364,                         !- Zone or ZoneList Name 1
    ventilation,                                !- Design Specification
      Outdoor Air Object Name 1
      ,
      !- Design Specification
      Zone Air Distribution Object Name 1
    Room_17_fb615533,                         !- Zone or ZoneList Name 2
    ventilation,                                !- Design Specification
      Outdoor Air Object Name 2
      ,
      !- Design Specification
      Zone Air Distribution Object Name 2

```

```

Room_18_6cc35095 , !- Zone or ZoneList Name 3
ventilation , !- Design Specification
    Outdoor Air Object Name 3
,
    !- Design Specification
Zone Air Distribution Object Name 3

Room_19_6ae0f9a9 , !- Zone or ZoneList Name 4
ventilation , !- Design Specification
    Outdoor Air Object Name 4
,
    !- Design Specification
Zone Air Distribution Object Name 4

Room_20_4d060559 , !- Zone or ZoneList Name 5
ventilation , !- Design Specification
    Outdoor Air Object Name 5
,
    !- Design Specification
Zone Air Distribution Object Name 5

Room_21_4c523269 , !- Zone or ZoneList Name 6
ventilation , !- Design Specification
    Outdoor Air Object Name 6
,
    !- Design Specification
Zone Air Distribution Object Name 6

Room_22_f3ee5a53 , !- Zone or ZoneList Name 7
ventilation , !- Design Specification
    Outdoor Air Object Name 7
,
    !- Design Specification
Zone Air Distribution Object Name 7

Room_23_e751e71f , !- Zone or ZoneList Name 8
ventilation , !- Design Specification
    Outdoor Air Object Name 8
,
    !- Design Specification
Zone Air Distribution Object Name 8

Room_24_159d21b7 , !- Zone or ZoneList Name 9
ventilation , !- Design Specification
    Outdoor Air Object Name 9
,
    !- Design Specification
Zone Air Distribution Object Name 9

```

```

Room_25_d27e0933 , ! - Zone or ZoneList Name
10
ventilation , ! - Design Specification
    Outdoor Air Object Name 10
,
! - Design Specification
    Zone Air Distribution Object Name 10
Room_26_f4ea3797 , ! - Zone or ZoneList Name
11
ventilation , ! - Design Specification
    Outdoor Air Object Name 11
,
! - Design Specification
    Zone Air Distribution Object Name 11
Room_27_0080b418 , ! - Zone or ZoneList Name
12
ventilation , ! - Design Specification
    Outdoor Air Object Name 12
,
! - Design Specification
    Zone Air Distribution Object Name 12
Room_28_d6ed2799 , ! - Zone or ZoneList Name
13
ventilation , ! - Design Specification
    Outdoor Air Object Name 13
,
! - Design Specification
    Zone Air Distribution Object Name 13
Room_29_2a634042 , ! - Zone or ZoneList Name
14
ventilation , ! - Design Specification
    Outdoor Air Object Name 14
,
! - Design Specification
    Zone Air Distribution Object Name 14
Room_30_98f1d6c8 , ! - Zone or ZoneList Name
15
ventilation , ! - Design Specification
    Outdoor Air Object Name 15
;
! - Design Specification
    Zone Air Distribution Object Name 15

```

```

DesignSpecification:OutdoorAir ,
  ventilation ,                                     !- Name
  Sum ,                                            !- Outdoor Air Method
  0.01 ,                                           !- Outdoor Air Flow per
  Person {m3/s-person}                            !- Outdoor Air Flow per
  0 ,                                              !- Outdoor Air Flow per
  Zone Floor Area {m3/s-m2}                      !- Outdoor Air Flow per
  0 ,                                              !- Outdoor Air Flow per
  Zone {m3/s}                                     !- Outdoor Air Flow Air
  0 ,                                              !- Outdoor Air Flow Air
  Changes per Hour {1/hr}                         !- Outdoor Air Schedule
  Standard_Ventilation;                          !- Outdoor Air Schedule
  Name

Zone ,
  Room_17_fb615533 ,                           !- Name
  0 ,                                            !- Direction of Relative
  North {deg}                                    !- Type
  0 ,                                            !- X Origin {m}
  0 ,                                            !- Y Origin {m}
  0 ,                                            !- Z Origin {m}
  ,                                              !- Type
  1 ,                                            !- Multiplier
  ,                                              !- Ceiling Height {m}
  ,                                              !- Volume {m3}
  ,                                              !- Floor Area {m2}
  ,                                              !- Zone Inside Convection
  Algorithm ,                                    !- Zone Outside Convection
  ,
  Algorithm ,                                    !- Part of Total Floor
  Yes ;                                         !- Part of Total Floor
  Area

BuildingSurface:Detailed ,
  Room_17_fb615533..Face0 ,                     !- Name

```

```

Wall,                                     !- Surface Type
project_wall,                            !- Construction Name
Room_17_fb615533,                      !- Zone Name
Outdoors,                                 !- Outside Boundary
Condition
,
Condition Object
SunExposed,                                !- Sun Exposure
WindExposed,                                !- Wind Exposure
,
,                                         !- View Factor to Ground
,
,                                         !- Number of Vertices
23.1619451669403, 55.2819899121641, 6.49999999997549, !- X,Y,Z
Vertex 1 {m}
13.1619451669403, 55.2819899121641, 6.49999999995968, !- X,Y,Z
Vertex 2 {m}
13.1619451669316, 55.2819899121844, 3.24999999995968, !- X,Y,Z
Vertex 3 {m}
23.1619451669316, 55.2819899121844, 3.24999999997549; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_17_fb615533..Face0_Glz0,           !- Name
Window,                                   !- Surface Type
project_window,                           !- Construction Name
Room_17_fb615533..Face0,                 !- Building Surface Name
,
,                                         !- Outside Boundary
Condition Object
,
,                                         !- View Factor to Ground
,
,                                         !- Frame and Divider Name
,
,                                         !- Multiplier
,
,                                         !- Number of Vertices
15.2348618336048, 55.281989912167, 6.04999999996296, !- X,Y,Z
Vertex 1 {m}
14.4223618336059, 55.281989912167, 6.04999999996167, !- X,Y,Z
Vertex 2 {m}

```

```

14.4223618336091, 55.2819899121794, 4.04999999996167, !- X,Y,Z
    Vertex 3 {m}

15.234861833608, 55.2819899121794, 4.04999999996296; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_17_fb615533..Face0_Glz1,           !- Name
Window,                                     !- Surface Type
project_window,                            !- Construction Name
Room_17_fb615533..Face0,                  !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
18.5681951669335, 55.281989912167, 6.04999999996823, !- X,Y,Z
    Vertex 1 {m}

17.7556951669347, 55.281989912167, 6.04999999996694, !- X,Y,Z
    Vertex 2 {m}

17.7556951669378, 55.2819899121794, 4.04999999996694, !- X,Y,Z
    Vertex 3 {m}

18.5681951669367, 55.2819899121794, 4.04999999996823; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_17_fb615533..Face0_Glz2,           !- Name
Window,                                     !- Surface Type
project_window,                            !- Construction Name
Room_17_fb615533..Face0,                  !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices

```

```

21.9015285002623, 55.281989912167, 6.0499999999735, !- X,Y,Z
    Vertex 1 {m}
21.0890285002634, 55.281989912167, 6.04999999997221, !- X,Y,Z
    Vertex 2 {m}
21.0890285002666, 55.2819899121794, 4.04999999997221, !- X,Y,Z
    Vertex 3 {m}
21.9015285002654, 55.2819899121794, 4.0499999999735; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_17_fb615533..Face1,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_17_fb615533,                                         !- Zone Name
Surface,                                              !- Outside Boundary
    Condition
Room_26_f4ea3797..Face3,                               !- Outside Boundary
    Condition Object
NoSun,                                               !- Sun Exposure
NoWind,                                              !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
23.1619451669403, 55.2819899121641, 6.49999999997549, !- X,Y,Z
    Vertex 1 {m}
23.1619451669316, 55.2819899121844, 3.24999999997549, !- X,Y,Z
    Vertex 2 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
    Vertex 3 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_17_fb615533..Face2,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_17_fb615533,                                         !- Zone Name

```

```

Surface,                                     !- Outside Boundary
  Condition
Room_20_4d060559..Face0,                     !- Outside Boundary
  Condition Object
NoSun,                                         !- Sun Exposure
NoWind,                                         !- Wind Exposure
,
,                                               !- View Factor to Ground
,
,                                               !- Number of Vertices
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
  Vertex 1 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
  Vertex 2 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
  Vertex 3 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917; !- X,Y,Z
  Vertex 4 {m}

BuildingSurface:Detailed,
  Room_17_fb615533..Face3,                   !- Name
  Wall,                                         !- Surface Type
  project_wall_int,                           !- Construction Name
  Room_17_fb615533,                           !- Zone Name
  Surface,                                     !- Outside Boundary
  Condition
  Room_23_e751e71f..Face0,                   !- Outside Boundary
  Condition Object
  NoSun,                                       !- Sun Exposure
  NoWind,                                      !- Wind Exposure
,
,                                               !- View Factor to Ground
,
,                                               !- Number of Vertices
13.1619451669403, 55.2819899121641, 6.49999999995968, !- X,Y,Z
  Vertex 1 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
  Vertex 2 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
  Vertex 3 {m}

```

```

13.1619451669316, 55.2819899121844, 3.24999999995968; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_17_fb615533..Face4, !- Name
Floor, !- Surface Type
project_floor, !- Construction Name
Room_17_fb615533, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_16_3d8c5364..Face5, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118335983, 60.2819899121844, 3.2499999993445, !- X,Y,Z
Vertex 1 {m}
23.1619451669316, 55.2819899121844, 3.2499999997549, !- X,Y,Z
Vertex 2 {m}
13.1619451669316, 55.2819899121844, 3.2499999995968, !- X,Y,Z
Vertex 3 {m}
16.495278500265, 60.2819899121844, 3.2499999992918; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_17_fb615533..Face5, !- Name
Ceiling, !- Surface Type
project_ceiling_int, !- Construction Name
Room_17_fb615533, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_18_6cc35095..Face4, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Number of Vertices
23.1619451669403, 55.2819899121641, 6.4999999997549, !- X,Y,Z
    Vertex 1 {m}
19.8286118336069, 60.2819899121641, 6.4999999993444, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 60.2819899121641, 6.4999999992917, !- X,Y,Z
    Vertex 3 {m}
13.1619451669403, 55.2819899121641, 6.4999999995968; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat,
    Room_17_fb615533 Thermostat,           !- Name
    Room_17_fb615533,                      !- Zone or ZoneList Name
    Room_17_fb615533 Thermostat Schedule, !- Control Type Schedule
        Name
    ThermostatSetpoint:DualSetpoint,         !- Control 1 Object Type
    Thermostat Setpoint Dual Setpoint 2,     !- Control 1 Name
    ,                                       !- Control 2 Object Type
    ,                                       !- Control 2 Name
    ,                                       !- Control 3 Object Type
    ,                                       !- Control 3 Name
    ,                                       !- Control 4 Object Type
    ,                                       !- Control 4 Name
    0;                                      !- Temperature Difference
        Between Cutout And Setpoint {deltaC}

Schedule:Compact,
    Room_17_fb615533 Thermostat Schedule,   !- Name
    Room_17_fb615533 Thermostat Schedule Type Limits, !- Schedule Type
        Limits Name
    Through: 12/31,                          !- Field 1
    For: AllDays,                            !- Field 2
    Until: 24:00,                            !- Field 3
    4;                                      !- Field 4

```

```

ScheduleTypeLimits ,
  Room_17_fb615533 Thermostat Schedule Type Limits, !- Name
    0,                                     !- Lower Limit Value {
      BasedOnField A3}
    4,                                     !- Upper Limit Value {
      BasedOnField A3}
  DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint ,
  Thermostat Setpoint Dual Setpoint 2,      !- Name
  project_heat,                            !- Heating Setpoint
  Temperature Schedule Name
  Clg-SetP-Sch;                           !- Cooling Setpoint
  Temperature Schedule Name

ZoneHVAC:EquipmentConnections ,
  Room_17_fb615533,                      !- Zone Name
  Room_17_fb615533 Equipment List,        !- Zone Conditioning
  Equipment List Name
  Room_17_fb615533 Inlet Node List,       !- Zone Air Inlet Node or
  NodeList Name
  Room_17_fb615533 Exhaust Node List,     !- Zone Air Exhaust Node
  or NodeList Name
  Room_17_fb615533 Zone Air Node,         !- Zone Air Node Name
  Room_17_fb615533 Return Node List;      !- Zone Return Air Node or
  NodeList Name

  NodeList,
    Room_17_fb615533 Inlet Node List,      !- Name
    Room_17_fb615533 Air Terminal Outlet Air Node, !- Node Name 1
    Room_17_fb615533 VRF Terminal Unit Outlet Air Node; !- Node Name 2

  NodeList,
    Room_17_fb615533 Exhaust Node List,    !- Name
    Room_17_fb615533 VRF Terminal Unit Inlet Air Node; !- Node Name 1

```

```

NodeList ,
Room_17_fb615533 Return Node List ,      !- Name
Room_17_fb615533 Return Air Node;        !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
Room_17_fb615533 Air Terminal ,          !- Name
Always On Discrete ,                     !- Availability Schedule
Name
Room_17_fb615533 Air Terminal Inlet Air Node , !- Air Inlet Node
Name
Room_17_fb615533 Air Terminal Outlet Air Node , !- Air Outlet Node
Name
AutoSize;                                !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit ,
ADU Room_17_fb615533 Air Terminal ,      !- Name
Room_17_fb615533 Air Terminal Outlet Air Node , !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat , !- Air Terminal
Object Type
Room_17_fb615533 Air Terminal;           !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
Room_17_fb615533 VRF Terminal Unit ,     !- Zone Terminal Unit Name
Always On Discrete ,                     !- Terminal Unit
Availability Schedule
Room_17_fb615533 VRF Terminal Unit Inlet Air Node , !- Terminal
Unit Air Inlet Node Name
Room_17_fb615533 VRF Terminal Unit Outlet Air Node , !- Terminal
Unit Air Outlet Node Name
Autosize ,                               !- Cooling Supply Air Flow
Rate {m3/s}
Autosize ,                               !- No Cooling Supply Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- Heating Supply Air Flow
    Rate {m3/s}

Autosize,                                     !- No Heating Supply Air
    Flow Rate {m3/s}

Autosize,                                     !- Cooling Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
    Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
    Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
    Placement

Fan:OnOff,                                    !- Supply Air Fan Object
    Type

Room_17_fb615533 VRF Unit Cycling Fan,     !- Supply Air Fan Object
    Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
    Object Type

Room_17_fb615533 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
    Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
1, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
1, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
    Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
    Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
    Sizing Ratio {W/W}

```

```

        ,                                     !- Availability Manager
List Name

        ,                                     !- Design Specification
ZoneHVAC Sizing Object Name

        ,                                     !- Supplemental Heating
Coil Object Type

        ,                                     !- Supplemental Heating
Coil Name

Autosize,                                !- Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                      !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_17_fb615533 VRF Terminal Unit OA Mixer, !- Name
Room_17_fb615533 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_17_fb615533 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_17_fb615533 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_17_fb615533 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_17_fb615533 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
1, !- Name
Always On Discrete,                      !- Availability Schedule
Name
Autosize,                                !- Gross Rated Total
Cooling Capacity {W}

```

```

Autosize,                                     ! - Gross Rated Sensible
Heat Ratio

Autosize,                                     ! - Rated Air Flow Rate {m3
/s}

VRFTUCoolCapFT 1,                           ! - Cooling Capacity Ratio
Modifier Function of Temperature Curve Name

VRFACCoolCapFFF 1,                          ! - Cooling Capacity
Modifier Curve Function of Flow Fraction Name

Room_17_fb615533 VRF Terminal Unit Mixer Outlet Node, ! - Coil Air
Inlet Node

Room_17_fb615533 VRF Terminal Unit Cooling Coil Outlet Node; ! -
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 1,                         ! - Name
0.0585884077803259,                      ! - Coefficient1 Constant
0.0587396532718384,                      ! - Coefficient2 x
-0.000210274979759697,                   ! - Coefficient3 x**2
0.0109370473889647,                      ! - Coefficient4 y
-0.0001219549,                           ! - Coefficient5 y**2
-0.0005246615,                           ! - Coefficient6 x*y
15,                                       ! - Minimum Value of x {
    BasedOnField A2}
23.89,                                     ! - Maximum Value of x {
    BasedOnField A2}
20,                                         ! - Minimum Value of y {
    BasedOnField A3}
43.33,                                      ! - Maximum Value of y {
    BasedOnField A3}
0.8083,                                     ! - Minimum Curve Output {
    BasedOnField A4}
1.2583;                                    ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
VRFACCoolCapFFF 1,                         ! - Name

```

```

0.8,                                     !- Coefficient1 Constant
0.2,                                     !- Coefficient2 x
0,                                         !- Coefficient3 x**2
0.5,                                     !- Minimum Value of x {
    BasedOnField A2}
1.5;                                      !- Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
1, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                 !- Rated Air Flow Rate {m3
/s}
Room_17_fb615533 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_17_fb615533 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 1, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 1; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 1, !-
Name
0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                    !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                           !- Coefficient5 y**2
-0.0014819801,                           !- Coefficient6 x*y

```

```

21.11 ,                                     ! - Minimum Value of x {
    BasedOnField A2}

27.22 ,                                     ! - Maximum Value of x {
    BasedOnField A2}

-15 ,                                       ! - Minimum Value of y {
    BasedOnField A3}

18.33 ,                                      ! - Maximum Value of y {
    BasedOnField A3}

0.6074 ,                                     ! - Minimum Curve Output {
    BasedOnField A4}

1;                                           ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 1, !-
Name
0.8,                                         ! - Coefficient1 Constant
0.2,                                         ! - Coefficient2 x
0,                                            ! - Coefficient3 x**2
0.5,                                         ! - Minimum Value of x {
    BasedOnField A2}

1.5;                                         ! - Maximum Value of x {
    BasedOnField A2}

Fan:OnOff ,
Room_17_fb615533 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                         ! - Availability Schedule
Name
0.6,                                         ! - Fan Total Efficiency
300,                                         ! - Pressure Rise {Pa}
Autosize,                                     ! - Maximum Flow Rate {m3/s
}
0.8,                                         ! - Motor Efficiency
1,                                           ! - Motor In Airstream
Fraction

```

```

Room_17_fb615533 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name

Room_17_fb615533 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name

Fan On Off Power Curve 1,           !- Fan Power Ratio
Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve 1,      !- Fan Efficiency Ratio
Function of Speed Ratio Curve Name

General;                          !- End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 1,          !- Name
1,                                  !- Coefficient1 Constant
0,                                  !- Coefficient2 Constant
0,                                  !- Coefficient3 Constant
0,                                  !- Minimum Value of x {
BasedOnField A2}
1;                                 !- Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 1,     !- Name
1,                                  !- Coefficient1 Constant
0,                                  !- Coefficient2 x
0,                                  !- Coefficient3 x**2
0,                                  !- Coefficient4 x**3
0,                                  !- Minimum Value of x {
BasedOnField A2}
1;                                 !- Maximum Value of x {
BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_17_fb615533 Equipment List,    !- Name
SequentialLoad,                     !- Load Distribution
Scheme

```

```

ZoneHVAC:AirDistributionUnit,           !- Zone Equipment Object
  Type 1
ADU Room_17_fb615533 Air Terminal,    !- Zone Equipment Name 1
  1,                                     !- Zone Equipment Cooling
    Sequence 1
  1,                                     !- Zone Equipment Heating
    or No-Load Sequence 1
Schedule Constant 3,                   !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1
Schedule Constant 4,                   !- Zone Equipment
  Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
  Object Type 2
Room_17_fb615533 VRF Terminal Unit,    !- Zone Equipment Name 2
  2,                                     !- Zone Equipment Cooling
    Sequence 2
  2,                                     !- Zone Equipment Heating
    or No-Load Sequence 2
  ,
    !- Zone Equipment
    Sequential Cooling Fraction Schedule Name 2
  ;
    !- Zone Equipment
    Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
  Room_17_fb615533,                     !- Zone or ZoneList Name
  SupplyAirTemperature,                  !- Zone Cooling Design
    Supply Air Temperature Input Method
  12.77777777777778,                  !- Zone Cooling Design
    Supply Air Temperature {C}
  11.11,                                 !- Zone Cooling Design
    Supply Air Temperature Difference {deltaC}
  SupplyAirTemperature,                  !- Zone Heating Design
    Supply Air Temperature Input Method
  40.0000000000001,                    !- Zone Heating Design
    Supply Air Temperature {C}

```

```

11.11,                                     !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                      !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                       !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor
,
!- Zone Cooling Sizing
Factor
DesignDay,                                    !- Cooling Design Air Flow
Method
0,                                           !- Cooling Design Air Flow
Rate {m3/s}
0.000762,                                     !- Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                           !- Cooling Minimum Air
Flow {m3/s}
0,                                           !- Cooling Minimum Air
Flow Fraction
DesignDay,                                    !- Heating Design Air Flow
Method
0,                                           !- Heating Design Air Flow
Rate {m3/s}
0.002032,                                     !- Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                    !- Heating Maximum Air
Flow {m3/s}
0.3,                                         !- Heating Maximum Air
Flow Fraction
,
!- Design Specification
Zone Air Distribution Object Name
Yes,                                         !- Account for Dedicated
Outdoor Air System

```

```

NeutralSupplyAir,                               !- Dedicated Outdoor Air
System Control Strategy
15.55555555555556,                         !- Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}
21.1111111111111;                          !- Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_18_6cc35095,                           !- Name
0,                                         !- Direction of Relative
North {deg}
0,                                         !- X Origin {m}
0,                                         !- Y Origin {m}
0,                                         !- Z Origin {m}
,                                           !- Type
1,                                         !- Multiplier
,                                           !- Ceiling Height {m}
,                                           !- Volume {m3}
,                                           !- Floor Area {m2}
,                                           !- Zone Inside Convection
Algorithm
,                                         !- Zone Outside Convection
Algorithm
Yes;                                       !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_18_6cc35095..Face0,                   !- Name
Wall,                                       !- Surface Type
project_wall,                                !- Construction Name
Room_18_6cc35095,                           !- Zone Name
Outdoors,                                    !- Outside Boundary
Condition
,                                         !- Outside Boundary
Condition Object
SunExposed,                                  !- Sun Exposure

```

```

WindExposed ,                                     ! - Wind Exposure
,
,                                         ! - View Factor to Ground
,
23.1619451669489 , 55.2819899121439 , 9.7499999999755 , ! - X,Y,Z
    Vertex 1 {m}
13.1619451669489 , 55.2819899121439 , 9.74999999995968 , ! - X,Y,Z
    Vertex 2 {m}
13.1619451669403 , 55.2819899121641 , 6.49999999995968 , ! - X,Y,Z
    Vertex 3 {m}
23.1619451669403 , 55.2819899121641 , 6.49999999997549 ; ! - X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed ,
Room_18_6cc35095..Face0_Glz0 ,                  ! - Name
Window ,                                         ! - Surface Type
project_window ,                                ! - Construction Name
Room_18_6cc35095..Face0 ,                      ! - Building Surface Name
,
                                         ! - Outside Boundary
    Condition Object
,
                                         ! - View Factor to Ground
,
                                         ! - Frame and Divider Name
,
                                         ! - Multiplier
,
                                         ! - Number of Vertices
15.2348618336134 , 55.2819899121467 , 9.2999999996296 , ! - X,Y,Z
    Vertex 1 {m}
14.4223618336146 , 55.2819899121467 , 9.2999999996167 , ! - X,Y,Z
    Vertex 2 {m}
14.4223618336177 , 55.2819899121592 , 7.2999999996167 , ! - X,Y,Z
    Vertex 3 {m}
15.2348618336166 , 55.2819899121592 , 7.2999999996296 ; ! - X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed ,
Room_18_6cc35095..Face0_Glz1 ,                  ! - Name
Window ,                                         ! - Surface Type
project_window ,                                ! - Construction Name

```

```

Room_18_6cc35095..Face0,
                           !- Building Surface Name
,
                           !- Outside Boundary

Condition Object

,
                           !- View Factor to Ground
,
                           !- Frame and Divider Name
,
                           !- Multiplier
,
                           !- Number of Vertices

18.5681951669422, 55.2819899121467, 9.29999999996823, !- X,Y,Z
Vertex 1 {m}
17.7556951669433, 55.2819899121467, 9.29999999996694, !- X,Y,Z
Vertex 2 {m}
17.7556951669465, 55.2819899121592, 7.29999999996694, !- X,Y,Z
Vertex 3 {m}
18.5681951669453, 55.2819899121592, 7.29999999996823; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_18_6cc35095..Face0_Glz2,                               !- Name
Window,                                                 !- Surface Type
project_window,                                         !- Construction Name
Room_18_6cc35095..Face0,                               !- Building Surface Name
,
                           !- Outside Boundary

Condition Object

,
                           !- View Factor to Ground
,
                           !- Frame and Divider Name
,
                           !- Multiplier
,
                           !- Number of Vertices

21.9015285002709, 55.2819899121467, 9.2999999999735, !- X,Y,Z
Vertex 1 {m}
21.089028500272, 55.2819899121467, 9.29999999997221, !- X,Y,Z
Vertex 2 {m}
21.0890285002752, 55.2819899121592, 7.29999999997222, !- X,Y,Z
Vertex 3 {m}
21.9015285002741, 55.2819899121592, 7.2999999999735; !- X,Y,Z
Vertex 4 {m}

```

```

BuildingSurface:Detailed,
Room_18_6cc35095..Face1,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_18_6cc35095,                                         !- Zone Name
Surface,                                              !- Outside Boundary
Condition
Room_25_d27e0933..Face3,                               !- Outside Boundary
Condition Object
NoSun,                                               !- Sun Exposure
NoWind,                                              !- Wind Exposure
,                                                    !- View Factor to Ground
,                                                    !- Number of Vertices
23.1619451669489, 55.2819899121439, 9.7499999999755, !- X,Y,Z
Vertex 1 {m}
23.1619451669403, 55.2819899121641, 6.4999999997549, !- X,Y,Z
Vertex 2 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
Vertex 3 {m}
19.8286118336156, 60.2819899121439, 9.74999999993446; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_18_6cc35095..Face2,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_18_6cc35095,                                         !- Zone Name
Surface,                                              !- Outside Boundary
Condition
Room_19_6ae0f9a9..Face0,                               !- Outside Boundary
Condition Object
NoSun,                                               !- Sun Exposure
NoWind,                                              !- Wind Exposure
,                                                    !- View Factor to Ground
,                                                    !- Number of Vertices

```

```

19.8286118336156, 60.2819899121439, 9.74999999993446, !- X,Y,Z
    Vertex 1 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
    Vertex 3 {m}
16.4952785002823, 60.2819899121439, 9.74999999992918; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_18_6cc35095..Face3,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                     !- Construction Name
Room_18_6cc35095,                                     !- Zone Name
Surface,                                              !- Outside Boundary
    Condition
Room_22_f3ee5a53..Face0,                               !- Outside Boundary
    Condition Object
NoSun,                                                !- Sun Exposure
NoWind,                                               !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
13.1619451669489, 55.2819899121439, 9.7499999995968, !- X,Y,Z
    Vertex 1 {m}
16.4952785002823, 60.2819899121439, 9.74999999992918, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
    Vertex 3 {m}
13.1619451669403, 55.2819899121641, 6.49999999995968; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_18_6cc35095..Face4,                               !- Name
Floor,                                                 !- Surface Type
project_floor,                                         !- Construction Name
Room_18_6cc35095,                                     !- Zone Name

```

```

Surface,                                     !- Outside Boundary
  Condition
  Room_17_fb615533..Face5,                  !- Outside Boundary
    Condition Object
    NoSun,                                      !- Sun Exposure
    NoWind,                                     !- Wind Exposure
    ,                                           !- View Factor to Ground
    ,                                           !- Number of Vertices
    19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
      Vertex 1 {m}
      23.1619451669403, 55.2819899121641, 6.49999999997549, !- X,Y,Z
      Vertex 2 {m}
      13.1619451669403, 55.2819899121641, 6.49999999995968, !- X,Y,Z
      Vertex 3 {m}
      16.4952785002736, 60.2819899121641, 6.49999999992917; !- X,Y,Z
      Vertex 4 {m}

BuildingSurface:Detailed,
  Room_18_6cc35095..Face5,                  !- Name
  Roof,                                       !- Surface Type
  project_roof,                                !- Construction Name
  Room_18_6cc35095,                            !- Zone Name
  Outdoors,                                    !- Outside Boundary
    Condition
    ,                                           !- Outside Boundary
    Condition Object
    SunExposed,                                 !- Sun Exposure
    WindExposed,                                !- Wind Exposure
    ,                                           !- View Factor to Ground
    ,                                           !- Number of Vertices
    23.1619451669489, 55.2819899121439, 9.7499999999755, !- X,Y,Z
      Vertex 1 {m}
      19.8286118336156, 60.2819899121439, 9.74999999993446, !- X,Y,Z
      Vertex 2 {m}
      16.4952785002823, 60.2819899121439, 9.74999999992918, !- X,Y,Z
      Vertex 3 {m}

```

```

13.1619451669489, 55.2819899121439, 9.74999999995968; !- X,Y,Z
Vertex 4 {m}

ZoneControl:Thermostat ,
Room_18_6cc35095 Thermostat , !- Name
Room_18_6cc35095 , !- Zone or ZoneList Name
Room_18_6cc35095 Thermostat Schedule , !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint , !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 3 , !- Control 1 Name
,
!- Control 2 Object Type
,
!- Control 2 Name
,
!- Control 3 Object Type
,
!- Control 3 Name
,
!- Control 4 Object Type
,
!- Control 4 Name
0; !- Temperature Difference
Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
Room_18_6cc35095 Thermostat Schedule , !- Name
Room_18_6cc35095 Thermostat Schedule Type Limits , !- Schedule Type
Limits Name
Through: 12/31 , !- Field 1
For: AllDays , !- Field 2
Until: 24:00 , !- Field 3
4; !- Field 4

ScheduleTypeLimits ,
Room_18_6cc35095 Thermostat Schedule Type Limits , !- Name
0, !- Lower Limit Value {
BasedOnField A3}
4, !- Upper Limit Value {
BasedOnField A3}
DISCRETE; !- Numeric Type

```

```

ThermostatSetpoint:DualSetpoint ,
    Thermostat Setpoint Dual Setpoint 3,      !- Name
    project_heat,                          !- Heating Setpoint
        Temperature Schedule Name
    Clg-SetP-Sch;                      !- Cooling Setpoint
        Temperature Schedule Name

ZoneHVAC:EquipmentConnections ,
    Room_18_6cc35095,                  !- Zone Name
    Room_18_6cc35095 Equipment List,   !- Zone Conditioning
        Equipment List Name
    Room_18_6cc35095 Inlet Node List,   !- Zone Air Inlet Node or
        NodeList Name
    Room_18_6cc35095 Exhaust Node List, !- Zone Air Exhaust Node
        or NodeList Name
    Room_18_6cc35095 Zone Air Node,     !- Zone Air Node Name
    Room_18_6cc35095 Return Node List;  !- Zone Return Air Node or
        NodeList Name

    NodeList,
        Room_18_6cc35095 Inlet Node List,      !- Name
        Room_18_6cc35095 Air Terminal Outlet Air Node, !- Node Name 1
        Room_18_6cc35095 VRF Terminal Unit Outlet Air Node; !- Node Name 2

    NodeList,
        Room_18_6cc35095 Exhaust Node List,      !- Name
        Room_18_6cc35095 VRF Terminal Unit Inlet Air Node; !- Node Name 1

    NodeList,
        Room_18_6cc35095 Return Node List,      !- Name
        Room_18_6cc35095 Return Air Node;       !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
    Room_18_6cc35095 Air Terminal,          !- Name
    Always On Discrete,                   !- Availability Schedule
        Name

```

```

Room_18_6cc35095 Air Terminal Inlet Air Node, !- Air Inlet Node
Name

Room_18_6cc35095 Air Terminal Outlet Air Node, !- Air Outlet Node
Name

AutoSize;                                     !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit,
ADU Room_18_6cc35095 Air Terminal,          !- Name
Room_18_6cc35095 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
Object Type
Room_18_6cc35095 Air Terminal;             !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow,
Room_18_6cc35095 VRF Terminal Unit,         !- Zone Terminal Unit Name
Always On Discrete,                         !- Terminal Unit
Availability Schedule
Room_18_6cc35095 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_18_6cc35095 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                                    !- Cooling Supply Air Flow
Rate {m3/s}
Autosize,                                    !- No Cooling Supply Air
Flow Rate {m3/s}
Autosize,                                    !- Heating Supply Air Flow
Rate {m3/s}
Autosize,                                    !- No Heating Supply Air
Flow Rate {m3/s}
Autosize,                                    !- Cooling Outdoor Air
Flow Rate {m3/s}
Autosize,                                    !- Heating Outdoor Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- No Load Outdoor Air
Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
Placement

Fan:OnOff,                                    !- Supply Air Fan Object
Type

Room_18_6cc35095 VRF Unit Cycling Fan,      !- Supply Air Fan Object
Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
Object Type

Room_18_6cc35095 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
2, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,    !- Heating Coil Object
Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
2, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
Sizing Ratio {W/W}

,                                             !- Availability Manager

List Name

,                                             !- Design Specification

ZoneHVAC Sizing Object Name

,                                             !- Supplemental Heating
Coil Object Type

,                                             !- Supplemental Heating
Coil Name

```

```

Autosize,                                     !- Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                         !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_18_6cc35095 VRF Terminal Unit OA Mixer, !- Name
Room_18_6cc35095 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_18_6cc35095 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_18_6cc35095 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_18_6cc35095 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_18_6cc35095 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
2, !- Name
Always On Discrete,                         !- Availability Schedule
Name
Autosize,                                     !- Gross Rated Total
Cooling Capacity {W}
Autosize,                                     !- Gross Rated Sensible
Heat Ratio
Autosize,                                     !- Rated Air Flow Rate {m3
/s}
VRFTUCoolCapFT 2,                           !- Cooling Capacity Ratio
Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 2,                           !- Cooling Capacity
Modifier Curve Function of Flow Fraction Name

```

```

Room_18_6cc35095 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
Inlet Node

Room_18_6cc35095 VRF Terminal Unit Cooling Coil Outlet Node; !-
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 2,                                     !- Name
0.0585884077803259,                                !- Coefficient1 Constant
0.0587396532718384,                                !- Coefficient2 x
-0.000210274979759697,                            !- Coefficient3 x**2
0.0109370473889647,                                !- Coefficient4 y
-0.0001219549,                                    !- Coefficient5 y**2
-0.0005246615,                                    !- Coefficient6 x*y
15,                                                 !- Minimum Value of x {
BasedOnField A2}

23.89,                                              !- Maximum Value of x {
BasedOnField A2}

20,                                                 !- Minimum Value of y {
BasedOnField A3}

43.33,                                              !- Maximum Value of y {
BasedOnField A3}

0.8083,                                             !- Minimum Curve Output {
BasedOnField A4}

1.2583;                                            !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
VRFACCoolCapFFF 2,                                     !- Name
0.8,                                                !- Coefficient1 Constant
0.2,                                                !- Coefficient2 x
0,                                                 !- Coefficient3 x**2
0.5,                                               !- Minimum Value of x {
BasedOnField A2}

1.5;                                               !- Maximum Value of x {
BasedOnField A2}

```

```

Coil:Heating:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
2, !- Name
Always On Discrete, !- Availability Schedule
Autosize, !- Gross Rated Heating
Capacity {W}
Autosize, !- Rated Air Flow Rate {m3
/s}

Room_18_6cc35095 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node

Room_18_6cc35095 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 2, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 2; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 2, !-
Name
0.375443994956127, !- Coefficient1 Constant
0.0668190645147821, !- Coefficient2 x
-0.00194171026482001, !- Coefficient3 x**2
0.0442618420640187, !- Coefficient4 y
-0.0004009578, !- Coefficient5 y**2
-0.0014819801, !- Coefficient6 x*y
21.11, !- Minimum Value of x {
BasedOnField A2}
27.22, !- Maximum Value of x {
BasedOnField A2}
-15, !- Minimum Value of y {
BasedOnField A3}
18.33, !- Maximum Value of y {
BasedOnField A3}

```

```

0.6074,                                     !- Minimum Curve Output {
BasedOnField A4}

1;                                         !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 2, !-
Name
0.8,                                         !- Coefficient1 Constant
0.2,                                         !- Coefficient2 x
0,                                            !- Coefficient3 x**2
0.5,                                         !- Minimum Value of x {
BasedOnField A2}
1.5;                                         !- Maximum Value of x {
BasedOnField A2}

Fan:OnOff,
Room_18_6cc35095 VRF Unit Cycling Fan,   !- Name
Always On Discrete,                      !- Availability Schedule
Name
0.6,                                         !- Fan Total Efficiency
300,                                         !- Pressure Rise {Pa}
Autosize,                                    !- Maximum Flow Rate {m3/s
}
0.8,                                         !- Motor Efficiency
1,                                           !- Motor In Airstream
Fraction
Room_18_6cc35095 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name
Room_18_6cc35095 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name
Fan On Off Power Curve 2,                  !- Fan Power Ratio
Function of Speed Ratio Curve Name
Fan On Off Efficiency Curve 2,           !- Fan Efficiency Ratio
Function of Speed Ratio Curve Name
General;                                    !- End-Use Subcategory

```

```

Curve:Exponent ,
  Fan On Off Power Curve 2,           ! - Name
  1,                                ! - Coefficient1 Constant
  0,                                ! - Coefficient2 Constant
  0,                                ! - Coefficient3 Constant
  0,                                ! - Minimum Value of x {
    BasedOnField A2}
  1;                                ! - Maximum Value of x {
    BasedOnField A2}

Curve:Cubic ,
  Fan On Off Efficiency Curve 2,      ! - Name
  1,                                ! - Coefficient1 Constant
  0,                                ! - Coefficient2 x
  0,                                ! - Coefficient3 x**2
  0,                                ! - Coefficient4 x**3
  0,                                ! - Minimum Value of x {
    BasedOnField A2}
  1;                                ! - Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList ,
  Room_18_6cc35095 Equipment List,    ! - Name
  SequentialLoad,                    ! - Load Distribution
  Scheme
  ZoneHVAC:AirDistributionUnit,      ! - Zone Equipment Object
  Type 1
  ADU Room_18_6cc35095 Air Terminal, ! - Zone Equipment Name 1
  1,                                ! - Zone Equipment Cooling
  Sequence 1
  1,                                ! - Zone Equipment Heating
  or No-Load Sequence 1
  Schedule Constant 5,              ! - Zone Equipment
  Sequential Cooling Fraction Schedule Name 1

```

```

Schedule Constant 6,                               !- Zone Equipment
Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2
Room_18_6cc35095 VRF Terminal Unit,           !- Zone Equipment Name 2
2,                                              !- Zone Equipment Cooling
Sequence 2
2,                                              !- Zone Equipment Heating
or No-Load Sequence 2
,
!- Zone Equipment
Sequential Cooling Fraction Schedule Name 2
;
!- Zone Equipment
Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
Room_18_6cc35095,                            !- Zone or ZoneList Name
SupplyAirTemperature,                          !- Zone Cooling Design
Supply Air Temperature Input Method
12.77777777777778,                         !- Zone Cooling Design
Supply Air Temperature {C}
11.11,                                         !- Zone Cooling Design
Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,                         !- Zone Heating Design
Supply Air Temperature Input Method
40.0000000000001,                           !- Zone Heating Design
Supply Air Temperature {C}
11.11,                                         !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                         !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                          !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                    !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor

```

```

        ,                                     !- Zone Cooling Sizing
    Factor
DesignDay ,                               !- Cooling Design Air Flow
    Method
0,                                         !- Cooling Design Air Flow
    Rate {m3/s}
0.000762,                                    !- Cooling Minimum Air
    Flow per Zone Floor Area {m3/s-m2}
0,                                         !- Cooling Minimum Air
    Flow {m3/s}
0,                                         !- Cooling Minimum Air
    Flow Fraction
DesignDay ,                               !- Heating Design Air Flow
    Method
0,                                         !- Heating Design Air Flow
    Rate {m3/s}
0.002032,                                    !- Heating Maximum Air
    Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                   !- Heating Maximum Air
    Flow {m3/s}
0.3,                                         !- Heating Maximum Air
    Flow Fraction
,                                           !- Design Specification
Zone Air Distribution Object Name
Yes,                                         !- Account for Dedicated
    Outdoor Air System
NeutralSupplyAir ,                           !- Dedicated Outdoor Air
    System Control Strategy
15.5555555555556,                         !- Dedicated Outdoor Air
    Low Setpoint Temperature for Design {C}
21.111111111111;                          !- Dedicated Outdoor Air
    High Setpoint Temperature for Design {C}

Zone ,
Room_19_6ae0f9a9 ,                         !- Name

```

```

0,                                     !- Direction of Relative
North {deg}

0,                                     !- X Origin {m}
0,                                     !- Y Origin {m}
0,                                     !- Z Origin {m}
,                                     !- Type
1,                                     !- Multiplier
,                                     !- Ceiling Height {m}
,                                     !- Volume {m3}
,                                     !- Floor Area {m2}
,                                     !- Zone Inside Convection
Algorithm

,                                     !- Zone Outside Convection
Algorithm

Yes;                                    !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_19_6ae0f9a9..Face0,                !- Name
Wall,                                     !- Surface Type
project_wall_int,                        !- Construction Name
Room_19_6ae0f9a9,                        !- Zone Name
Surface,                                  !- Outside Boundary
Condition

Room_18_6cc35095..Face2,                !- Outside Boundary
Condition Object

NoSun,                                    !- Sun Exposure
NoWind,                                   !- Wind Exposure
,                                         !- View Factor to Ground
,                                         !- Number of Vertices
19.8286118336156, 60.2819899121439, 9.74999999993446, !- X,Y,Z
Vertex 1 {m}

16.4952785002823, 60.2819899121439, 9.74999999992918, !- X,Y,Z
Vertex 2 {m}

16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
Vertex 3 {m}

```

```

19.8286118336069, 60.2819899121641, 6.49999999993444; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_19_6ae0f9a9..Face1, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_19_6ae0f9a9, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_25_d27e0933..Face2, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118336156, 60.2819899121439, 9.74999999993446, !- X,Y,Z
Vertex 1 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
Vertex 2 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
Vertex 3 {m}
19.8286118336156, 65.2819899121439, 9.74999999989868; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_19_6ae0f9a9..Face2, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_19_6ae0f9a9, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_28_d6ed2799..Face1, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure

```

```

,
          !- View Factor to Ground
,
          !- Number of Vertices
19.8286118336156, 65.2819899121439, 9.74999999989868, !- X,Y,Z
  Vertex 1 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
  Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
  Vertex 3 {m}
16.4952785002823, 65.2819899121439, 9.74999999989341; !- X,Y,Z
  Vertex 4 {m}

BuildingSurface:Detailed,
Room_19_6ae0f9a9..Face3,           !- Name
Wall,                               !- Surface Type
project_wall_int,                  !- Construction Name
Room_19_6ae0f9a9,                  !- Zone Name
Surface,                            !- Outside Boundary
Condition
Room_22_f3ee5a53..Face1,           !- Outside Boundary
  Condition Object
NoSun,                             !- Sun Exposure
NoWind,                            !- Wind Exposure
,
          !- View Factor to Ground
,
          !- Number of Vertices
16.4952785002823, 60.2819899121439, 9.7499999992918, !- X,Y,Z
  Vertex 1 {m}
16.4952785002823, 65.2819899121439, 9.74999999989341, !- X,Y,Z
  Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
  Vertex 3 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917; !- X,Y,Z
  Vertex 4 {m}

BuildingSurface:Detailed,
Room_19_6ae0f9a9..Face4,           !- Name
Floor,                             !- Surface Type

```

```

project_floor ,                                     !- Construction Name
Room_19_6ae0f9a9 ,                               !- Zone Name
Surface ,                                         !- Outside Boundary
    Condition
Room_20_4d060559..Face5 ,                       !- Outside Boundary
        Condition Object
NoSun ,                                           !- Sun Exposure
NoWind ,                                          !- Wind Exposure
,
,
19.8286118336069 , 65.2819899121641 , 6.49999999989867 , !- X,Y,Z
    Vertex 1 {m}
19.8286118336069 , 60.2819899121641 , 6.49999999993444 , !- X,Y,Z
    Vertex 2 {m}
16.4952785002736 , 60.2819899121641 , 6.49999999992917 , !- X,Y,Z
    Vertex 3 {m}
16.4952785002736 , 65.2819899121641 , 6.4999999998934; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_19_6ae0f9a9..Face5 ,                         !- Name
Roof ,                                            !- Surface Type
project_roof ,                                     !- Construction Name
Room_19_6ae0f9a9 ,                               !- Zone Name
Outdoors ,                                         !- Outside Boundary
    Condition
,
,
Condition Object
SunExposed ,                                       !- Sun Exposure
WindExposed ,                                      !- Wind Exposure
,
,
19.8286118336156 , 60.2819899121439 , 9.7499999993446 , !- X,Y,Z
    Vertex 1 {m}
19.8286118336156 , 65.2819899121439 , 9.74999999989868 , !- X,Y,Z
    Vertex 2 {m}

```

```

16.4952785002823, 65.2819899121439, 9.74999999989341, !- X,Y,Z
    Vertex 3 {m}

16.4952785002823, 60.2819899121439, 9.74999999992918; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat ,
    Room_19_6ae0f9a9 Thermostat ,           !- Name
    Room_19_6ae0f9a9 ,                     !- Zone or ZoneList Name
    Room_19_6ae0f9a9 Thermostat Schedule , !- Control Type Schedule
        Name
    ThermostatSetpoint:DualSetpoint ,       !- Control 1 Object Type
    Thermostat Setpoint Dual Setpoint 4 ,   !- Control 1 Name
    ,                                     !- Control 2 Object Type
    ,                                     !- Control 2 Name
    ,                                     !- Control 3 Object Type
    ,                                     !- Control 3 Name
    ,                                     !- Control 4 Object Type
    ,                                     !- Control 4 Name
    0;                                    !- Temperature Difference
        Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
    Room_19_6ae0f9a9 Thermostat Schedule , !- Name
    Room_19_6ae0f9a9 Thermostat Schedule Type Limits , !- Schedule Type
        Limits Name
    Through: 12/31 ,                      !- Field 1
    For: AllDays ,                        !- Field 2
    Until: 24:00 ,                         !- Field 3
    4;                                    !- Field 4

ScheduleTypeLimits ,
    Room_19_6ae0f9a9 Thermostat Schedule Type Limits , !- Name
    0,                                     !- Lower Limit Value {
        BasedOnField A3}
    4,                                     !- Upper Limit Value {
        BasedOnField A3}

```

```

DISCRETE;                                     !- Numeric Type

ThermostatSetpoint:DualSetpoint ,
    Thermostat Setpoint Dual Setpoint 4,      !- Name
    project_heat,                           !- Heating Setpoint
        Temperature Schedule Name
    Clg-SetP-Sch;                         !- Cooling Setpoint
        Temperature Schedule Name

ZoneHVAC:EquipmentConnections ,
    Room_19_6ae0f9a9 ,                      !- Zone Name
    Room_19_6ae0f9a9 Equipment List,        !- Zone Conditioning
        Equipment List Name
    Room_19_6ae0f9a9 Inlet Node List,       !- Zone Air Inlet Node or
        NodeList Name
    Room_19_6ae0f9a9 Exhaust Node List,     !- Zone Air Exhaust Node
        or NodeList Name
    Room_19_6ae0f9a9 Zone Air Node,         !- Zone Air Node Name
    Room_19_6ae0f9a9 Return Node List;      !- Zone Return Air Node or
        NodeList Name

    NodeList,
        Room_19_6ae0f9a9 Inlet Node List,     !- Name
        Room_19_6ae0f9a9 Air Terminal Outlet Air Node, !- Node Name 1
        Room_19_6ae0f9a9 VRF Terminal Unit Outlet Air Node; !- Node Name 2

    NodeList,
        Room_19_6ae0f9a9 Exhaust Node List,   !- Name
        Room_19_6ae0f9a9 VRF Terminal Unit Inlet Air Node; !- Node Name 1

    NodeList,
        Room_19_6ae0f9a9 Return Node List,    !- Name
        Room_19_6ae0f9a9 Return Air Node;     !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
    Room_19_6ae0f9a9 Air Terminal,          !- Name

```

```

Always On Discrete , ! - Availability Schedule
Name

Room_19_6ae0f9a9 Air Terminal Inlet Air Node , ! - Air Inlet Node
Name

Room_19_6ae0f9a9 Air Terminal Outlet Air Node , ! - Air Outlet Node
Name

AutoSize; ! - Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit ,
ADU Room_19_6ae0f9a9 Air Terminal , ! - Name
Room_19_6ae0f9a9 Air Terminal Outlet Air Node , ! - Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat , ! - Air Terminal
Object Type
Room_19_6ae0f9a9 Air Terminal; ! - Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
Room_19_6ae0f9a9 VRF Terminal Unit , ! - Zone Terminal Unit Name
Always On Discrete , ! - Terminal Unit
Availability Schedule
Room_19_6ae0f9a9 VRF Terminal Unit Inlet Air Node , ! - Terminal
Unit Air Inlet Node Name
Room_19_6ae0f9a9 VRF Terminal Unit Outlet Air Node , ! - Terminal
Unit Air Outlet Node Name
Autosize , ! - Cooling Supply Air Flow
Rate {m3/s}
Autosize , ! - No Cooling Supply Air
Flow Rate {m3/s}
Autosize , ! - Heating Supply Air Flow
Rate {m3/s}
Autosize , ! - No Heating Supply Air
Flow Rate {m3/s}
Autosize , ! - Cooling Outdoor Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- Heating Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
  Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
  Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
  Placement

Fan:OnOff,                                    !- Supply Air Fan Object
  Type

Room_19_6ae0f9a9 VRF Unit Cycling Fan,      !- Supply Air Fan Object
  Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
  Object Type

Room_19_6ae0f9a9 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
  Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,    !- Cooling Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
  3, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,     !- Heating Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
  3, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
  Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
  Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
  Sizing Ratio {W/W}

,                                             !- Availability Manager

List Name

,                                             !- Design Specification

ZoneHVAC Sizing Object Name

,                                             !- Supplemental Heating
  Coil Object Type

```

```

        ,                                     !- Supplemental Heating
    Coil Name
Autosize,                                     !- Maximum Supply Air
    Temperature from Supplemental Heater {C}
21;                                         !- Maximum Outdoor Dry-
    Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_19_6ae0f9a9 VRF Terminal Unit OA Mixer, !- Name
Room_19_6ae0f9a9 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
    Node Name
Room_19_6ae0f9a9 VRF Terminal Unit Outdoor Air Node, !- Outdoor
    Air Stream Node Name
Room_19_6ae0f9a9 VRF Terminal Unit Relief Node Name, !- Relief Air
    Stream Node Name
Room_19_6ae0f9a9 VRF Terminal Unit Inlet Air Node; !- Return Air
    Stream Node Name

OutdoorAir:NodeList,
Room_19_6ae0f9a9 VRF Terminal Unit Outdoor Air Node; !- Node or
    NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
3, !- Name
Always On Discrete,                           !- Availability Schedule
    Name
Autosize,                                     !- Gross Rated Total
    Cooling Capacity {W}
Autosize,                                     !- Gross Rated Sensible
    Heat Ratio
Autosize,                                     !- Rated Air Flow Rate {m3
    /s}
VRFTUCoolCapFT 3,                            !- Cooling Capacity Ratio
    Modifier Function of Temperature Curve Name

```

```

VRFACCoolCapFFF 3,                               !- Cooling Capacity
    Modifier Curve Function of Flow Fraction Name
Room_19_6ae0f9a9 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
    Inlet Node
Room_19_6ae0f9a9 VRF Terminal Unit Cooling Coil Outlet Node; !-
    Coil Air Outlet Node

Curve:Biquadratic,
    VRFTUCoolCapFT 3,                           !- Name
    0.0585884077803259,                         !- Coefficient1 Constant
    0.0587396532718384,                         !- Coefficient2 x
    -0.000210274979759697,                      !- Coefficient3 x**2
    0.0109370473889647,                         !- Coefficient4 y
    -0.0001219549,                             !- Coefficient5 y**2
    -0.0005246615,                             !- Coefficient6 x*y
    15,                                         !- Minimum Value of x {
        BasedOnField A2}
    23.89,                                       !- Maximum Value of x {
        BasedOnField A2}
    20,                                         !- Minimum Value of y {
        BasedOnField A3}
    43.33,                                       !- Maximum Value of y {
        BasedOnField A3}
    0.8083,                                      !- Minimum Curve Output {
        BasedOnField A4}
    1.2583;                                     !- Maximum Curve Output {
        BasedOnField A4}

Curve:Quadratic,
    VRFACCoolCapFFF 3,                           !- Name
    0.8,                                         !- Coefficient1 Constant
    0.2,                                         !- Coefficient2 x
    0,                                           !- Coefficient3 x**2
    0.5,                                         !- Minimum Value of x {
        BasedOnField A2}

```

```

1.5;                                     !- Maximum Value of x {
BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
3, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                 !- Rated Air Flow Rate {m3
/s}
Room_19_6ae0f9a9 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_19_6ae0f9a9 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 3, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 3; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 3, !-
Name
0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                    !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                          !- Coefficient5 y**2
-0.0014819801,                          !- Coefficient6 x*y
21.11,                                    !- Minimum Value of x {
BasedOnField A2}
27.22,                                    !- Maximum Value of x {
BasedOnField A2}
-15,                                      !- Minimum Value of y {
BasedOnField A3}

```

```

18.33,                                     !- Maximum Value of y {
    BasedOnField A3}

0.6074,                                     !- Minimum Curve Output {
    BasedOnField A4}

1;                                         !- Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 3, !-
Name
0.8,                                         !- Coefficient1 Constant
0.2,                                         !- Coefficient2 x
0,                                            !- Coefficient3 x**2
0.5,                                         !- Minimum Value of x {
    BasedOnField A2}
1.5;                                         !- Maximum Value of x {
    BasedOnField A2}

Fan:OnOff,
Room_19_6ae0f9a9 VRF Unit Cycling Fan,   !- Name
Always On Discrete,                         !- Availability Schedule
Name
0.6,                                         !- Fan Total Efficiency
300,                                         !- Pressure Rise {Pa}
Autosize,                                    !- Maximum Flow Rate {m3/s
}
0.8,                                         !- Motor Efficiency
1,                                            !- Motor In Airstream
Fraction
Room_19_6ae0f9a9 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name
Room_19_6ae0f9a9 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name
Fan On Off Power Curve 3,                   !- Fan Power Ratio
Function of Speed Ratio Curve Name

```

```

Fan On Off Efficiency Curve 3,           ! - Fan Efficiency Ratio
Function of Speed Ratio Curve Name
General;                                ! - End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 3,              ! - Name
1,                                      ! - Coefficient1 Constant
0,                                      ! - Coefficient2 Constant
0,                                      ! - Coefficient3 Constant
0,                                      ! - Minimum Value of x {
BasedOnField A2}
1;                                      ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 3,          ! - Name
1,                                      ! - Coefficient1 Constant
0,                                      ! - Coefficient2 x
0,                                      ! - Coefficient3 x**2
0,                                      ! - Coefficient4 x**3
0,                                      ! - Minimum Value of x {
BasedOnField A2}
1;                                      ! - Maximum Value of x {
BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_19_6ae0f9a9 Equipment List,        ! - Name
SequentialLoad,                         ! - Load Distribution
Scheme
ZoneHVAC:AirDistributionUnit,           ! - Zone Equipment Object
Type 1
ADU Room_19_6ae0f9a9 Air Terminal,     ! - Zone Equipment Name 1
1,                                      ! - Zone Equipment Cooling
Sequence 1
1,                                      ! - Zone Equipment Heating
or No-Load Sequence 1

```

```

Schedule Constant 7,           !- Zone Equipment
Sequential Cooling Fraction Schedule Name 1
Schedule Constant 8,           !- Zone Equipment
Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2
Room_19_6ae0f9a9 VRF Terminal Unit,      !- Zone Equipment Name 2
2,                                     !- Zone Equipment Cooling
Sequence 2
2,                                     !- Zone Equipment Heating
or No-Load Sequence 2
,
           !- Zone Equipment
Sequential Cooling Fraction Schedule Name 2
;
           !- Zone Equipment
Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
Room_19_6ae0f9a9,           !- Zone or ZoneList Name
SupplyAirTemperature,         !- Zone Cooling Design
Supply Air Temperature Input Method
12.77777777777778,          !- Zone Cooling Design
Supply Air Temperature {C}
11.11,                      !- Zone Cooling Design
Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,         !- Zone Heating Design
Supply Air Temperature Input Method
40.0000000000001,            !- Zone Heating Design
Supply Air Temperature {C}
11.11,                      !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                      !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                       !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                 !- Design Specification
Outdoor Air Object Name

```

```

,
! - Zone Heating Sizing

Factor
,
! - Zone Cooling Sizing

Factor
DesignDay,
! - Cooling Design Air Flow

Method
0,
! - Cooling Design Air Flow

Rate {m3/s}
0.000762,
! - Cooling Minimum Air

Flow per Zone Floor Area {m3/s-m2}
0,
! - Cooling Minimum Air

Flow {m3/s}
0,
! - Cooling Minimum Air

Flow Fraction
DesignDay,
! - Heating Design Air Flow

Method
0,
! - Heating Design Air Flow

Rate {m3/s}
0.002032,
! - Heating Maximum Air

Flow per Zone Floor Area {m3/s-m2}
0.1415762,
! - Heating Maximum Air

Flow {m3/s}
0.3,
! - Heating Maximum Air

Flow Fraction
,
! - Design Specification

Zone Air Distribution Object Name
Yes,
! - Account for Dedicated

Outdoor Air System
NeutralSupplyAir,
! - Dedicated Outdoor Air

System Control Strategy
15.5555555555556,
! - Dedicated Outdoor Air

Low Setpoint Temperature for Design {C}
21.111111111111;
! - Dedicated Outdoor Air

High Setpoint Temperature for Design {C}

Zone ,

```

```

Room_20_4d060559 , ! - Name
0, ! - Direction of Relative
    North {deg}
0, ! - X Origin {m}
0, ! - Y Origin {m}
0, ! - Z Origin {m}
,
! - Type
1, ! - Multiplier
,
! - Ceiling Height {m}
,
! - Volume {m3}
,
! - Floor Area {m2}
,
! - Zone Inside Convection
Algorithm
,
! - Zone Outside Convection
Algorithm
Yes; ! - Part of Total Floor
Area

BuildingSurface:Detailed ,
Room_20_4d060559..Face0, ! - Name
Wall, ! - Surface Type
project_wall_int, ! - Construction Name
Room_20_4d060559, ! - Zone Name
Surface, ! - Outside Boundary
Condition
Room_17_fb615533..Face2, ! - Outside Boundary
    Condition Object
NoSun, ! - Sun Exposure
NoWind, ! - Wind Exposure
,
! - View Factor to Ground
,
! - Number of Vertices
19.8286118336069, 60.2819899121641, 6.49999999993444, ! - X,Y,Z
    Vertex 1 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, ! - X,Y,Z
    Vertex 2 {m}

```

```

16.495278500265 , 60.2819899121844 , 3.24999999992918 , !- X,Y,Z
    Vertex 3 {m}

19.8286118335983 , 60.2819899121844 , 3.24999999993445 ; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_20_4d060559..Face1 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_20_4d060559 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_26_f4ea3797..Face2 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118336069 , 60.2819899121641 , 6.49999999993444 , !- X,Y,Z
    Vertex 1 {m}
19.8286118335983 , 60.2819899121844 , 3.24999999993445 , !- X,Y,Z
    Vertex 2 {m}
19.8286118335983 , 65.2819899121844 , 3.24999999989868 , !- X,Y,Z
    Vertex 3 {m}
19.8286118336069 , 65.2819899121641 , 6.49999999989867 ; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_20_4d060559..Face2 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_20_4d060559 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_29_2a634042..Face1 , !- Outside Boundary
Condition Object

```

```

NoSun ,                                     ! - Sun Exposure
NoWind ,                                     ! - Wind Exposure
,                                         ! - View Factor to Ground
,                                         ! - Number of Vertices
19.8286118336069 , 65.2819899121641 , 6.49999999989867 , !- X,Y,Z
    Vertex 1 {m}
19.8286118335983 , 65.2819899121844 , 3.24999999989868 , !- X,Y,Z
    Vertex 2 {m}
16.495278500265 , 65.2819899121844 , 3.2499999998934 , !- X,Y,Z
    Vertex 3 {m}
16.4952785002736 , 65.2819899121641 , 6.4999999998934 ; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_20_4d060559..Face3 ,                   ! - Name
Wall ,                                       ! - Surface Type
project_wall_int ,                          ! - Construction Name
Room_20_4d060559 ,                         ! - Zone Name
Surface ,                                    ! - Outside Boundary
    Condition
Room_23_e751e71f..Face1 ,                   ! - Outside Boundary
    Condition Object
NoSun ,                                     ! - Sun Exposure
NoWind ,                                     ! - Wind Exposure
,                                         ! - View Factor to Ground
,                                         ! - Number of Vertices
16.4952785002736 , 60.2819899121641 , 6.4999999992917 , !- X,Y,Z
    Vertex 1 {m}
16.4952785002736 , 65.2819899121641 , 6.4999999998934 , !- X,Y,Z
    Vertex 2 {m}
16.495278500265 , 65.2819899121844 , 3.2499999998934 , !- X,Y,Z
    Vertex 3 {m}
16.495278500265 , 60.2819899121844 , 3.2499999992918 ; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,

```

```

Room_20_4d060559..Face4,                               !- Name
Floor,                                                 !- Surface Type
project_floor,                                         !- Construction Name
Room_20_4d060559,                                     !- Zone Name
Surface,                                               !- Outside Boundary
    Condition
Room_21_4c523269..Face5,                               !- Outside Boundary
    Condition Object
NoSun,                                                 !- Sun Exposure
NoWind,                                                !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
    Vertex 1 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
    Vertex 2 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
    Vertex 3 {m}
16.495278500265, 65.2819899121844, 3.2499999998934; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_20_4d060559..Face5,                               !- Name
Ceiling,                                                !- Surface Type
project_ceiling_int,                                    !- Construction Name
Room_20_4d060559,                                     !- Zone Name
Surface,                                               !- Outside Boundary
    Condition
Room_19_6ae0f9a9..Face4,                               !- Outside Boundary
    Condition Object
NoSun,                                                 !- Sun Exposure
NoWind,                                                !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
    Vertex 1 {m}

```

```

19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
    Vertex 3 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat ,
Room_20_4d060559 Thermostat ,           !- Name
Room_20_4d060559 ,                      !- Zone or ZoneList Name
Room_20_4d060559 Thermostat Schedule , !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint ,        !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 5 ,    !- Control 1 Name
,
!- Control 2 Object Type
,
!- Control 2 Name
,
!- Control 3 Object Type
,
!- Control 3 Name
,
!- Control 4 Object Type
,
!- Control 4 Name
0;                                     !- Temperature Difference
Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
Room_20_4d060559 Thermostat Schedule , !- Name
Room_20_4d060559 Thermostat Schedule Type Limits , !- Schedule Type
Limits Name
Through: 12/31 ,                         !- Field 1
For: AllDays ,                           !- Field 2
Until: 24:00 ,                           !- Field 3
4;                                      !- Field 4

ScheduleTypeLimits ,
Room_20_4d060559 Thermostat Schedule Type Limits , !- Name
0,                                         !- Lower Limit Value {
BasedOnField A3}

```

```

4,                                     !- Upper Limit Value {
BasedOnField A3}

DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint,
    Thermostat Setpoint Dual Setpoint 5,      !- Name
    project_heat,                            !- Heating Setpoint
        Temperature Schedule Name
    Clg-SetP-Sch;                          !- Cooling Setpoint
        Temperature Schedule Name

ZoneHVAC:EquipmentConnections,
    Room_20_4d060559,                      !- Zone Name
    Room_20_4d060559 Equipment List,       !- Zone Conditioning
        Equipment List Name
    Room_20_4d060559 Inlet Node List,      !- Zone Air Inlet Node or
        NodeList Name
    Room_20_4d060559 Exhaust Node List,     !- Zone Air Exhaust Node
        or NodeList Name
    Room_20_4d060559 Zone Air Node,         !- Zone Air Node Name
    Room_20_4d060559 Return Node List;     !- Zone Return Air Node or
        NodeList Name

    NodeList,
        Room_20_4d060559 Inlet Node List,    !- Name
        Room_20_4d060559 Air Terminal Outlet Air Node, !- Node Name 1
        Room_20_4d060559 VRF Terminal Unit Outlet Air Node; !- Node Name 2

    NodeList,
        Room_20_4d060559 Exhaust Node List,   !- Name
        Room_20_4d060559 VRF Terminal Unit Inlet Air Node; !- Node Name 1

    NodeList,
        Room_20_4d060559 Return Node List,    !- Name
        Room_20_4d060559 Return Air Node;      !- Node Name 1

```

```

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
Room_20_4d060559 Air Terminal,           !- Name
Always On Discrete,                      !- Availability Schedule
Name
Room_20_4d060559 Air Terminal Inlet Air Node, !- Air Inlet Node
Name
Room_20_4d060559 Air Terminal Outlet Air Node, !- Air Outlet Node
Name
AutoSize;                                !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit ,
ADU Room_20_4d060559 Air Terminal,       !- Name
Room_20_4d060559 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat , !- Air Terminal
Object Type
Room_20_4d060559 Air Terminal;          !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
Room_20_4d060559 VRF Terminal Unit,      !- Zone Terminal Unit Name
Always On Discrete,                      !- Terminal Unit
Availability Schedule
Room_20_4d060559 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_20_4d060559 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                                 !- Cooling Supply Air Flow
Rate {m3/s}
Autosize,                                 !- No Cooling Supply Air
Flow Rate {m3/s}
Autosize,                                 !- Heating Supply Air Flow
Rate {m3/s}
Autosize,                                 !- No Heating Supply Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- Cooling Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
  Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
  Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
  Placement

Fan:OnOff,                                    !- Supply Air Fan Object
  Type

Room_20_4d060559 VRF Unit Cycling Fan,    !- Supply Air Fan Object
  Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
  Object Type

Room_20_4d060559 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
  Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
  4, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
  4, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
  Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
  Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
  Sizing Ratio {W/W}

,                                             !- Availability Manager
  List Name

,                                             !- Design Specification
  ZoneHVAC Sizing Object Name

```

```

        ,                                     !- Supplemental Heating
    Coil Object Type
    ,
                                     !- Supplemental Heating
    Coil Name
    Autosize,                      !- Maximum Supply Air
        Temperature from Supplemental Heater {C}
    21;                           !- Maximum Outdoor Dry-
        Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
    Room_20_4d060559 VRF Terminal Unit OA Mixer, !- Name
    Room_20_4d060559 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
        Node Name
    Room_20_4d060559 VRF Terminal Unit Outdoor Air Node, !- Outdoor
        Air Stream Node Name
    Room_20_4d060559 VRF Terminal Unit Relief Node Name, !- Relief Air
        Stream Node Name
    Room_20_4d060559 VRF Terminal Unit Inlet Air Node; !- Return Air
        Stream Node Name

OutdoorAir:NodeList,
    Room_20_4d060559 VRF Terminal Unit Outdoor Air Node; !- Node or
        NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
    Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
    4, !- Name
    Always On Discrete,           !- Availability Schedule
        Name
    Autosize,                     !- Gross Rated Total
        Cooling Capacity {W}
    Autosize,                     !- Gross Rated Sensible
        Heat Ratio
    Autosize,                     !- Rated Air Flow Rate {m3
        /s}

```

```

VRFTUCoolCapFT 4,                               ! - Cooling Capacity Ratio
    Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 4,                            ! - Cooling Capacity
    Modifier Curve Function of Flow Fraction Name
Room_20_4d060559 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
    Inlet Node
Room_20_4d060559 VRF Terminal Unit Cooling Coil Outlet Node; !-
    Coil Air Outlet Node

Curve:Biquadratic,
    VRFTUCoolCapFT 4,                           ! - Name
    0.0585884077803259,                         ! - Coefficient1 Constant
    0.0587396532718384,                         ! - Coefficient2 x
    -0.000210274979759697,                      ! - Coefficient3 x**2
    0.0109370473889647,                         ! - Coefficient4 y
    -0.0001219549,                             ! - Coefficient5 y**2
    -0.0005246615,                             ! - Coefficient6 x*y
    15,                                         ! - Minimum Value of x {
        BasedOnField A2}
    23.89,                                       ! - Maximum Value of x {
        BasedOnField A2}
    20,                                         ! - Minimum Value of y {
        BasedOnField A3}
    43.33,                                       ! - Maximum Value of y {
        BasedOnField A3}
    0.8083,                                      ! - Minimum Curve Output {
        BasedOnField A4}
    1.2583;                                     ! - Maximum Curve Output {
        BasedOnField A4}

Curve:Quadratic,
    VRFACCoolCapFFF 4,                           ! - Name
    0.8,                                         ! - Coefficient1 Constant
    0.2,                                         ! - Coefficient2 x
    0,                                           ! - Coefficient3 x**2

```

```

0.5,                                     !- Minimum Value of x {
BasedOnField A2}

1.5;                                     !- Maximum Value of x {
BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
4, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                 !- Rated Air Flow Rate {m3
/s}

Room_20_4d060559 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node

Room_20_4d060559 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 4, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 4; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 4, !-
Name
0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                    !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                           !- Coefficient5 y**2
-0.0014819801,                           !- Coefficient6 x*y
21.11,                                    !- Minimum Value of x {
BasedOnField A2}

27.22,                                    !- Maximum Value of x {
BasedOnField A2}

```

```

-15,                                     ! - Minimum Value of y {
    BasedOnField A3}

18.33,                                    ! - Maximum Value of y {
    BasedOnField A3}

0.6074,                                   ! - Minimum Curve Output {
    BasedOnField A4}

1;                                         ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 4, !-
Name

0.8,                                       ! - Coefficient1 Constant
0.2,                                       ! - Coefficient2 x
0,                                           ! - Coefficient3 x**2
0.5,                                       ! - Minimum Value of x {
    BasedOnField A2}

1.5;                                       ! - Maximum Value of x {
    BasedOnField A2}

Fan:OnOff,
Room_20_4d060559 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                      ! - Availability Schedule
Name

0.6,                                       ! - Fan Total Efficiency
300,                                       ! - Pressure Rise {Pa}
Autosize,                                  ! - Maximum Flow Rate {m3/s
}

0.8,                                       ! - Motor Efficiency
1,                                           ! - Motor In Airstream
Fraction

Room_20_4d060559 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name

Room_20_4d060559 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name

```

```

Fan On Off Power Curve 4,           ! - Fan Power Ratio
Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve 4,      ! - Fan Efficiency Ratio
Function of Speed Ratio Curve Name

General;                           ! - End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 4,          ! - Name
1,                                  ! - Coefficient1 Constant
0,                                  ! - Coefficient2 Constant
0,                                  ! - Coefficient3 Constant
0,                                  ! - Minimum Value of x {
    BasedOnField A2}
1;                                 ! - Maximum Value of x {
    BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 4,     ! - Name
1,                                  ! - Coefficient1 Constant
0,                                  ! - Coefficient2 x
0,                                  ! - Coefficient3 x**2
0,                                  ! - Coefficient4 x**3
0,                                  ! - Minimum Value of x {
    BasedOnField A2}
1;                                 ! - Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_20_4d060559 Equipment List,   ! - Name
SequentialLoad,                     ! - Load Distribution
Scheme

ZoneHVAC:AirDistributionUnit,       ! - Zone Equipment Object
Type 1

ADU Room_20_4d060559 Air Terminal, ! - Zone Equipment Name 1
1,                                  ! - Zone Equipment Cooling
Sequence 1

```

```

1,                                     !- Zone Equipment Heating
  or No-Load Sequence 1
Schedule Constant 9,                   !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1
Schedule Constant 10,                  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
  Object Type 2
Room_20_4d060559 VRF Terminal Unit,      !- Zone Equipment Name 2
2,                                     !- Zone Equipment Cooling
  Sequence 2
2,                                     !- Zone Equipment Heating
  or No-Load Sequence 2
,
  !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
;
  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
  Room_20_4d060559,                      !- Zone or ZoneList Name
  SupplyAirTemperature,                    !- Zone Cooling Design
    Supply Air Temperature Input Method
  12.77777777777778,                   !- Zone Cooling Design
    Supply Air Temperature {C}
  11.11,                                  !- Zone Cooling Design
    Supply Air Temperature Difference {deltaC}
  SupplyAirTemperature,                    !- Zone Heating Design
    Supply Air Temperature Input Method
  40.0000000000001,                     !- Zone Heating Design
    Supply Air Temperature {C}
  11.11,                                  !- Zone Heating Design
    Supply Air Temperature Difference {deltaC}
  0.0085,                                 !- Zone Cooling Design
    Supply Air Humidity Ratio {kgWater/kgDryAir}
  0.008,                                   !- Zone Heating Design
    Supply Air Humidity Ratio {kgWater/kgDryAir}

```

```

ventilation,                                     ! - Design Specification
    Outdoor Air Object Name
,
    Factor                                         ! - Zone Heating Sizing
,
    Factor                                         ! - Zone Cooling Sizing
DesignDay,                                       ! - Cooling Design Air Flow
    Method
0,                                              ! - Cooling Design Air Flow
    Rate {m3/s}
0.000762,                                         ! - Cooling Minimum Air
    Flow per Zone Floor Area {m3/s-m2}
0,                                              ! - Cooling Minimum Air
    Flow {m3/s}
0,                                              ! - Cooling Minimum Air
    Flow Fraction
DesignDay,                                       ! - Heating Design Air Flow
    Method
0,                                              ! - Heating Design Air Flow
    Rate {m3/s}
0.002032,                                         ! - Heating Maximum Air
    Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                         ! - Heating Maximum Air
    Flow {m3/s}
0.3,                                              ! - Heating Maximum Air
    Flow Fraction
,
    Zone Air Distribution Object Name           ! - Design Specification
Yes,                                             ! - Account for Dedicated
    Outdoor Air System
NeutralSupplyAir,                                ! - Dedicated Outdoor Air
    System Control Strategy
15.55555555555556,                            ! - Dedicated Outdoor Air
    Low Setpoint Temperature for Design {C}
21.111111111111;                             ! - Dedicated Outdoor Air
    High Setpoint Temperature for Design {C}

```

```

Zone ,
    Room_21_4c523269 ,           !- Name
    0,                           !- Direction of Relative
        North {deg}
    0,                           !- X Origin {m}
    0,                           !- Y Origin {m}
    0,                           !- Z Origin {m}
    ,                           !- Type
    1,                           !- Multiplier
    ,                           !- Ceiling Height {m}
    ,                           !- Volume {m3}
    ,                           !- Floor Area {m2}
    ,                           !- Zone Inside Convection
Algorithm
,
    Algorithm
Yes;                         !- Part of Total Floor
Area

BuildingSurface:Detailed ,
    Room_21_4c523269..Face0 ,      !- Name
    Wall ,                        !- Surface Type
    project_wall_int ,           !- Construction Name
    Room_21_4c523269 ,           !- Zone Name
    Surface ,                     !- Outside Boundary
        Condition
    Room_16_3d8c5364..Face2 ,      !- Outside Boundary
        Condition Object
    NoSun ,                       !- Sun Exposure
    NoWind ,                      !- Wind Exposure
    ,                           !- View Factor to Ground
    ,                           !- Number of Vertices
    19.8286118335983 , 60.2819899121844 , 3.24999999993445 , !- X,Y,Z
    Vertex 1 {m}

```

```

16.495278500265 , 60.2819899121844 , 3.24999999992918 , !- X,Y,Z
    Vertex 2 {m}
16.4952785002563 , 60.2819899122047 , -7.08246976248188e-11 , !- X,Y,
    Z Vertex 3 {m}
19.8286118335897 , 60.2819899122047 , -6.55526866515655e-11; !- X,Y,
    Z Vertex 4 {m}

BuildingSurface:Detailed ,
Room_21_4c523269..Face1 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_21_4c523269 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_27_0080b418..Face2 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118335983 , 60.2819899121844 , 3.2499999993445 , !- X,Y,Z
    Vertex 1 {m}
19.8286118335897 , 60.2819899122047 , -6.55526866515655e-11 , !- X,Y,
    Z Vertex 2 {m}
19.8286118335897 , 65.2819899122047 , -1.0132554747248e-10 , !- X,Y,Z
    Vertex 3 {m}
19.8286118335983 , 65.2819899121844 , 3.24999999989868; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_21_4c523269..Face2 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_21_4c523269 , !- Zone Name
Surface , !- Outside Boundary
Condition

```

```

Room_30_98f1d6c8..Face1 , ! - Outside Boundary
  Condition Object
  NoSun , ! - Sun Exposure
  NoWind , ! - Wind Exposure
  , ! - View Factor to Ground
  , ! - Number of Vertices
  19.8286118335983 , 65.2819899121844 , 3.24999999989868 , ! - X,Y,Z
    Vertex 1 {m}
  19.8286118335897 , 65.2819899122047 , -1.0132554747248e-10 , ! - X,Y,Z
    Vertex 2 {m}
  16.4952785002563 , 65.2819899122047 , -1.06597558445733e-10 , ! - X,Y,
  Z Vertex 3 {m}
  16.495278500265 , 65.2819899121844 , 3.2499999998934; ! - X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
  Room_21_4c523269..Face3 , ! - Name
  Wall , ! - Surface Type
  project_wall_int , ! - Construction Name
  Room_21_4c523269 , ! - Zone Name
  Surface , ! - Outside Boundary
  Condition
  Room_24_159d21b7..Face1 , ! - Outside Boundary
  Condition Object
  NoSun , ! - Sun Exposure
  NoWind , ! - Wind Exposure
  , ! - View Factor to Ground
  , ! - Number of Vertices
  16.495278500265 , 60.2819899121844 , 3.24999999992918 , ! - X,Y,Z
    Vertex 1 {m}
  16.495278500265 , 65.2819899121844 , 3.2499999998934 , ! - X,Y,Z
    Vertex 2 {m}
  16.4952785002563 , 65.2819899122047 , -1.06597558445733e-10 , ! - X,Y,
  Z Vertex 3 {m}
  16.4952785002563 , 60.2819899122047 , -7.08246976248188e-11; ! - X,Y,
  Z Vertex 4 {m}

```

```

BuildingSurface:Detailed,
  Room_21_4c523269..Face4,           !- Name
  Floor,                            !- Surface Type
  project_slab,                    !- Construction Name
  Room_21_4c523269,                !- Zone Name
  Ground,                           !- Outside Boundary
  Condition
  ,
  !- Outside Boundary
  Condition Object
  NoSun,                            !- Sun Exposure
  NoWind,                           !- Wind Exposure
  ,
  !- View Factor to Ground
  ,
  !- Number of Vertices
  19.8286118335897, 65.2819899122047, -1.0132554747248e-10, !- X,Y,Z
    Vertex 1 {m}
  19.8286118335897, 60.2819899122047, -6.55526866515655e-11, !- X,Y,
    Z Vertex 2 {m}
  16.4952785002563, 60.2819899122047, -7.08246976248188e-11, !- X,Y,
    Z Vertex 3 {m}
  16.4952785002563, 65.2819899122047, -1.06597558445733e-10; !- X,Y,
    Z Vertex 4 {m}

BuildingSurface:Detailed,
  Room_21_4c523269..Face5,           !- Name
  Ceiling,                           !- Surface Type
  project_ceiling_int,              !- Construction Name
  Room_21_4c523269,                !- Zone Name
  Surface,                           !- Outside Boundary
  Condition
  Room_20_4d060559..Face4,          !- Outside Boundary
  Condition Object
  NoSun,                            !- Sun Exposure
  NoWind,                           !- Wind Exposure
  ,
  !- View Factor to Ground
  ,
  !- Number of Vertices

```

```

19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
    Vertex 1 {m}
19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
    Vertex 2 {m}
16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z
    Vertex 3 {m}
16.495278500265, 60.2819899121844, 3.24999999992918; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat ,
Room_21_4c523269 Thermostat,           !- Name
Room_21_4c523269,                      !- Zone or ZoneList Name
Room_21_4c523269 Thermostat Schedule, !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint,        !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 6,   !- Control 1 Name
,                                     !- Control 2 Object Type
,                                     !- Control 2 Name
,                                     !- Control 3 Object Type
,                                     !- Control 3 Name
,                                     !- Control 4 Object Type
,                                     !- Control 4 Name
0;                                    !- Temperature Difference
Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
Room_21_4c523269 Thermostat Schedule, !- Name
Room_21_4c523269 Thermostat Schedule Type Limits, !- Schedule Type
Limits Name
Through: 12/31,                         !- Field 1
For: AllDays,                            !- Field 2
Until: 24:00,                            !- Field 3
4;                                      !- Field 4

ScheduleTypeLimits ,
Room_21_4c523269 Thermostat Schedule Type Limits, !- Name

```

```

0,                                     !- Lower Limit Value {
    BasedOnField A3}

4,                                     !- Upper Limit Value {
    BasedOnField A3}

DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint,
    Thermostat Setpoint Dual Setpoint 6,      !- Name
    project_heat,                            !- Heating Setpoint
        Temperature Schedule Name
    Clg-SetP-Sch;                          !- Cooling Setpoint
        Temperature Schedule Name

ZoneHVAC:EquipmentConnections,
    Room_21_4c523269,                      !- Zone Name
    Room_21_4c523269 Equipment List,       !- Zone Conditioning
        Equipment List Name
    Room_21_4c523269 Inlet Node List,     !- Zone Air Inlet Node or
        NodeList Name
    Room_21_4c523269 Exhaust Node List,   !- Zone Air Exhaust Node
        or NodeList Name
    Room_21_4c523269 Zone Air Node,       !- Zone Air Node Name
    Room_21_4c523269 Return Node List;    !- Zone Return Air Node or
        NodeList Name

NodeList,
    Room_21_4c523269 Inlet Node List,      !- Name
    Room_21_4c523269 Air Terminal Outlet Air Node, !- Node Name 1
    Room_21_4c523269 VRF Terminal Unit Outlet Air Node; !- Node Name 2

NodeList,
    Room_21_4c523269 Exhaust Node List,    !- Name
    Room_21_4c523269 VRF Terminal Unit Inlet Air Node; !- Node Name 1

NodeList,
    Room_21_4c523269 Return Node List,     !- Name

```

```

Room_21_4c523269 Return Air Node;           !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat,
Room_21_4c523269 Air Terminal,             !- Name
Always On Discrete,                      !- Availability Schedule
Name
Room_21_4c523269 Air Terminal Inlet Air Node, !- Air Inlet Node
Name
Room_21_4c523269 Air Terminal Outlet Air Node, !- Air Outlet Node
Name
AutoSize;                                !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit,
ADU Room_21_4c523269 Air Terminal,        !- Name
Room_21_4c523269 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
Object Type
Room_21_4c523269 Air Terminal;           !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow,
Room_21_4c523269 VRF Terminal Unit,       !- Zone Terminal Unit Name
Always On Discrete,                      !- Terminal Unit
Availability Schedule
Room_21_4c523269 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_21_4c523269 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                                !- Cooling Supply Air Flow
Rate {m3/s}
Autosize,                                !- No Cooling Supply Air
Flow Rate {m3/s}
Autosize,                                !- Heating Supply Air Flow
Rate {m3/s}

```

```

Autosize,                                     !- No Heating Supply Air
  Flow Rate {m3/s}

Autosize,                                     !- Cooling Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
  Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
  Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
  Placement

Fan:OnOff,                                    !- Supply Air Fan Object
  Type

Room_21_4c523269 VRF Unit Cycling Fan,    !- Supply Air Fan Object
  Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
  Object Type

Room_21_4c523269 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
  Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
  5, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
  5, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
  Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
  Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
  Sizing Ratio {W/W}

,                                            !- Availability Manager

List Name

```

```

        ,                                     !- Design Specification
ZoneHVAC Sizing Object Name

        ,                                     !- Supplemental Heating
Coil Object Type

        ,                                     !- Supplemental Heating
Coil Name

Autosize,                               !- Maximum Supply Air
Temperature from Supplemental Heater {C}

21;                                    !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_21_4c523269 VRF Terminal Unit OA Mixer, !- Name
Room_21_4c523269 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_21_4c523269 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_21_4c523269 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_21_4c523269 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_21_4c523269 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
5, !- Name
Always On Discrete,                      !- Availability Schedule
Name
Autosize,                                !- Gross Rated Total
Cooling Capacity {W}
Autosize,                                !- Gross Rated Sensible
Heat Ratio

```

```

Autosize,                                     ! - Rated Air Flow Rate {m3
/s}

VRFTUCoolCapFT 5,                           ! - Cooling Capacity Ratio
    Modifier Function of Temperature Curve Name

VRFACCoolCapFFF 5,                          ! - Cooling Capacity
    Modifier Curve Function of Flow Fraction Name

Room_21_4c523269 VRF Terminal Unit Mixer Outlet Node, ! - Coil Air
    Inlet Node

Room_21_4c523269 VRF Terminal Unit Cooling Coil Outlet Node; ! -
    Coil Air Outlet Node

Curve:Biquadratic,
    VRFTUCoolCapFT 5,                         ! - Name
    0.0585884077803259,                      ! - Coefficient1 Constant
    0.0587396532718384,                      ! - Coefficient2 x
    -0.000210274979759697,                   ! - Coefficient3 x**2
    0.0109370473889647,                      ! - Coefficient4 y
    -0.0001219549,                           ! - Coefficient5 y**2
    -0.0005246615,                           ! - Coefficient6 x*y
    15,                                      ! - Minimum Value of x {
        BasedOnField A2}
    23.89,                                     ! - Maximum Value of x {
        BasedOnField A2}
    20,                                         ! - Minimum Value of y {
        BasedOnField A3}
    43.33,                                      ! - Maximum Value of y {
        BasedOnField A3}
    0.8083,                                     ! - Minimum Curve Output {
        BasedOnField A4}
    1.2583;                                     ! - Maximum Curve Output {
        BasedOnField A4}

Curve:Quadratic,
    VRFACCoolCapFFF 5,                         ! - Name
    0.8,                                       ! - Coefficient1 Constant
    0.2,                                       ! - Coefficient2 x

```

```

0,                                     !- Coefficient3 x**2
0.5,                                    !- Minimum Value of x {
BasedOnField A2}
1.5;                                    !- Maximum Value of x {
BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
5, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                !- Rated Air Flow Rate {m3
/s}

Room_21_4c523269 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_21_4c523269 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 5, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 5; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 5, !-
Name
0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                    !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                           !- Coefficient5 y**2
-0.0014819801,                           !- Coefficient6 x*y
21.11,                                    !- Minimum Value of x {
BasedOnField A2}

```

```

27.22,                                     ! - Maximum Value of x {
    BasedOnField A2}

-15,                                         ! - Minimum Value of y {
    BasedOnField A3}

18.33,                                         ! - Maximum Value of y {
    BasedOnField A3}

0.6074,                                       ! - Minimum Curve Output {
    BasedOnField A4}

1;                                            ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 5, !-
Name

0.8,                                           ! - Coefficient1 Constant
0.2,                                           ! - Coefficient2 x
0,                                              ! - Coefficient3 x**2
0.5,                                           ! - Minimum Value of x {
    BasedOnField A2}

1.5;                                          ! - Maximum Value of x {
    BasedOnField A2}

Fan:OnOff,
Room_21_4c523269 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                         ! - Availability Schedule
Name

0.6,                                           ! - Fan Total Efficiency
300,                                           ! - Pressure Rise {Pa}
Autosize,                                      ! - Maximum Flow Rate {m3/s
    }

0.8,                                           ! - Motor Efficiency
1,                                              ! - Motor In Airstream
Fraction

Room_21_4c523269 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name

```

```

Room_21_4c523269 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name

Fan On Off Power Curve 5,           !- Fan Power Ratio
Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve 5,      !- Fan Efficiency Ratio
Function of Speed Ratio Curve Name

General;                          !- End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 5,          !- Name
1,                                !- Coefficient1 Constant
0,                                !- Coefficient2 Constant
0,                                !- Coefficient3 Constant
0,                                !- Minimum Value of x {
BasedOnField A2}
1;                                !- Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 5,     !- Name
1,                                 !- Coefficient1 Constant
0,                                 !- Coefficient2 x
0,                                 !- Coefficient3 x**2
0,                                 !- Coefficient4 x**3
0,                                !- Minimum Value of x {
BasedOnField A2}
1;                                !- Maximum Value of x {
BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_21_4c523269 Equipment List,   !- Name
SequentialLoad,                    !- Load Distribution
Scheme

ZoneHVAC:AirDistributionUnit,       !- Zone Equipment Object
Type 1

ADU Room_21_4c523269 Air Terminal, !- Zone Equipment Name 1

```

```

1,                                     !- Zone Equipment Cooling
Sequence 1

1,                                     !- Zone Equipment Heating
or No-Load Sequence 1

Schedule Constant 11,                   !- Zone Equipment
Sequential Cooling Fraction Schedule Name 1

Schedule Constant 12,                   !- Zone Equipment
Sequential Heating Fraction Schedule Name 1

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2

Room_21_4c523269 VRF Terminal Unit,      !- Zone Equipment Name 2
2,                                     !- Zone Equipment Cooling
Sequence 2

2,                                     !- Zone Equipment Heating
or No-Load Sequence 2

,                                         !- Zone Equipment
Sequential Cooling Fraction Schedule Name 2
;                                         !- Zone Equipment
Sequential Heating Fraction Schedule Name 2


Sizing:Zone,
Room_21_4c523269,                      !- Zone or ZoneList Name
SupplyAirTemperature,                     !- Zone Cooling Design
Supply Air Temperature Input Method
12.77777777777778,                    !- Zone Cooling Design
Supply Air Temperature {C}
11.11,                                    !- Zone Cooling Design
Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,                     !- Zone Heating Design
Supply Air Temperature Input Method
40.0000000000001,                      !- Zone Heating Design
Supply Air Temperature {C}
11.11,                                    !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                   !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}

```

```

0.008,                                     !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor
,
!- Zone Cooling Sizing
Factor
DesignDay,                                   !- Cooling Design Air Flow
Method
0,                                         !- Cooling Design Air Flow
Rate {m3/s}
0.000762,                                    !- Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                         !- Cooling Minimum Air
Flow {m3/s}
0,                                         !- Cooling Minimum Air
Flow Fraction
DesignDay,                                   !- Heating Design Air Flow
Method
0,                                         !- Heating Design Air Flow
Rate {m3/s}
0.002032,                                    !- Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                   !- Heating Maximum Air
Flow {m3/s}
0.3,                                         !- Heating Maximum Air
Flow Fraction
,
!- Design Specification
Zone Air Distribution Object Name
Yes,                                         !- Account for Dedicated
Outdoor Air System
NeutralSupplyAir,                            !- Dedicated Outdoor Air
System Control Strategy
15.55555555555556,                         !- Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}

```

```

21.11111111111111;                               !- Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_22_f3ee5a53,                                !- Name
0,                                                 !- Direction of Relative
North {deg}
0,                                                 !- X Origin {m}
0,                                                 !- Y Origin {m}
0,                                                 !- Z Origin {m}
,                                                 !- Type
1,                                                 !- Multiplier
,                                                 !- Ceiling Height {m}
,                                                 !- Volume {m3}
,                                                 !- Floor Area {m2}
,                                                 !- Zone Inside Convection
Algorithm
,
!- Zone Outside Convection
Algorithm
Yes;                                              !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_22_f3ee5a53..Face0,                          !- Name
Wall,                                              !- Surface Type
project_wall_int,                                 !- Construction Name
Room_22_f3ee5a53,                                !- Zone Name
Surface,                                            !- Outside Boundary
Condition
Room_18_6cc35095..Face3,                          !- Outside Boundary
Condition Object
NoSun,                                             !- Sun Exposure
NoWind,                                            !- Wind Exposure
,                                                 !- View Factor to Ground
,                                                 !- Number of Vertices

```

```

13.1619451669489, 55.2819899121439, 9.74999999995968, !- X,Y,Z
    Vertex 1 {m}
13.1619451669403, 55.2819899121641, 6.49999999995968, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
    Vertex 3 {m}
16.4952785002823, 60.2819899121439, 9.74999999992918; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_22_f3ee5a53..Face1,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_22_f3ee5a53,                                         !- Zone Name
Surface,                                              !- Outside Boundary
    Condition
Room_19_6ae0f9a9..Face3,                               !- Outside Boundary
    Condition Object
NoSun,                                               !- Sun Exposure
NoWind,                                              !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
16.4952785002823, 60.2819899121439, 9.74999999992918, !- X,Y,Z
    Vertex 1 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
    Vertex 3 {m}
16.4952785002823, 65.2819899121439, 9.74999999989341; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_22_f3ee5a53..Face2,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_22_f3ee5a53,                                         !- Zone Name

```

```

Surface,                                     !- Outside Boundary
  Condition
Room_28_d6ed2799..Face0,                     !- Outside Boundary
  Condition Object
NoSun,                                         !- Sun Exposure
NoWind,                                         !- Wind Exposure
,
,                                              !- View Factor to Ground
,
,                                              !- Number of Vertices
16.4952785002823, 65.2819899121439, 9.74999999989341, !- X,Y,Z
  Vertex 1 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
  Vertex 2 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236, !- X,Y,Z
  Vertex 3 {m}
13.1619451669489, 70.2819899121439, 9.74999999985237; !- X,Y,Z
  Vertex 4 {m}

BuildingSurface:Detailed,
  Room_22_f3ee5a53..Face3,                   !- Name
  Wall,                                         !- Surface Type
  project_wall,                                !- Construction Name
  Room_22_f3ee5a53,                            !- Zone Name
  Outdoors,                                    !- Outside Boundary
  Condition
  ,
  !- Outside Boundary
  Condition Object
  SunExposed,                                  !- Sun Exposure
  WindExposed,                                 !- Wind Exposure
  ,
  ,                                              !- View Factor to Ground
  ,
  ,                                              !- Number of Vertices
13.1619451669489, 55.2819899121439, 9.7499999995968, !- X,Y,Z
  Vertex 1 {m}
13.1619451669489, 70.2819899121439, 9.74999999985237, !- X,Y,Z
  Vertex 2 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236, !- X,Y,Z
  Vertex 3 {m}

```

```

13.1619451669403, 55.2819899121641, 6.49999999995968; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_22_f3ee5a53..Face3_Glz0,                               !- Name
Window,                                                 !- Surface Type
project_window,                                         !- Construction Name
Room_22_f3ee5a53..Face3,                                 !- Building Surface Name
,                                                       !- Outside Boundary
Condition Object
,                                               !- View Factor to Ground
,                                               !- Frame and Divider Name
,                                               !- Multiplier
,                                               !- Number of Vertices
13.1619451669477, 68.4163649121461, 9.29999999986571, !- X,Y,Z
Vertex 1 {m}
13.1619451669477, 69.147614912144, 9.29999999986048, !- X,Y,Z
Vertex 2 {m}
13.1619451669424, 69.1476149121297, 7.29999999986048, !- X,Y,Z
Vertex 3 {m}
13.1619451669424, 68.4163649121318, 7.29999999986571; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_22_f3ee5a53..Face3_Glz1,                               !- Name
Window,                                                 !- Surface Type
project_window,                                         !- Construction Name
Room_22_f3ee5a53..Face3,                                 !- Building Surface Name
,                                                       !- Outside Boundary
Condition Object
,                                               !- View Factor to Ground
,                                               !- Frame and Divider Name
,                                               !- Multiplier
,                                               !- Number of Vertices
13.1619451669477, 65.4163649121548, 9.29999999988717, !- X,Y,Z
Vertex 1 {m}

```

```

13.1619451669477, 66.1476149121527, 9.2999999998194, !- X,Y,Z
    Vertex 2 {m}
13.1619451669424, 66.1476149121384, 7.2999999998194, !- X,Y,Z
    Vertex 3 {m}
13.1619451669424, 65.4163649121405, 7.29999999988717; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_22_f3ee5a53..Face3_Glz2,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_22_f3ee5a53..Face3,                !- Building Surface Name
,                                       !- Outside Boundary
Condition Object
,                                       !- View Factor to Ground
,                                       !- Frame and Divider Name
,                                       !- Multiplier
,                                       !- Number of Vertices
13.1619451669477, 62.4163649121635, 9.2999999990864, !- X,Y,Z
    Vertex 1 {m}
13.1619451669477, 63.1476149121614, 9.299999999034, !- X,Y,Z
    Vertex 2 {m}
13.1619451669424, 63.1476149121471, 7.299999999034, !- X,Y,Z
    Vertex 3 {m}
13.1619451669424, 62.4163649121492, 7.2999999990864; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_22_f3ee5a53..Face3_Glz3,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_22_f3ee5a53..Face3,                !- Building Surface Name
,                                       !- Outside Boundary
Condition Object
,                                       !- View Factor to Ground
,                                       !- Frame and Divider Name

```

```

        ,                                     !- Multiplier
        ,                                     !- Number of Vertices
13.1619451669477, 59.4163649121722, 9.2999999999301, !- X,Y,Z
    Vertex 1 {m}
13.1619451669477, 60.1476149121701, 9.29999999992487, !- X,Y,Z
    Vertex 2 {m}
13.1619451669424, 60.1476149121558, 7.29999999992487, !- X,Y,Z
    Vertex 3 {m}
13.1619451669424, 59.4163649121579, 7.2999999999301; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_22_f3ee5a53..Face3_Glz4,                               !- Name
Window,                                                 !- Surface Type
project_window,                                         !- Construction Name
Room_22_f3ee5a53..Face3,                               !- Building Surface Name
,                                                       !- Outside Boundary
    Condition Object
,                                                       !- View Factor to Ground
,                                                       !- Frame and Divider Name
,                                                       !- Multiplier
,                                                       !- Number of Vertices
13.1619451669477, 56.4163649121809, 9.2999999995156, !- X,Y,Z
    Vertex 1 {m}
13.1619451669477, 57.1476149121788, 9.2999999994633, !- X,Y,Z
    Vertex 2 {m}
13.1619451669424, 57.1476149121645, 7.2999999994633, !- X,Y,Z
    Vertex 3 {m}
13.1619451669424, 56.4163649121666, 7.2999999995156; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_22_f3ee5a53..Face4,                               !- Name
Floor,                                                 !- Surface Type
project_floor,                                         !- Construction Name
Room_22_f3ee5a53,                                     !- Zone Name

```

```

Surface,                                     !- Outside Boundary
  Condition
Room_23_e751e71f..Face5,                     !- Outside Boundary
  Condition Object
NoSun,                                         !- Sun Exposure
NoWind,                                         !- Wind Exposure
,
,                                              !- View Factor to Ground
,
,                                              !- Number of Vertices
13.1619451669403, 70.2819899121641, 6.49999999985236, !- X,Y,Z
  Vertex 1 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
  Vertex 2 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
  Vertex 3 {m}
13.1619451669403, 55.2819899121641, 6.49999999995968; !- X,Y,Z
  Vertex 4 {m}

BuildingSurface:Detailed,
  Room_22_f3ee5a53..Face5,                   !- Name
  Roof,                                         !- Surface Type
  project_roof,                                !- Construction Name
  Room_22_f3ee5a53,                            !- Zone Name
  Outdoors,                                    !- Outside Boundary
  Condition
,
,                                              !- Outside Boundary
  Condition Object
SunExposed,                                    !- Sun Exposure
WindExposed,                                   !- Wind Exposure
,
,                                              !- View Factor to Ground
,
,                                              !- Number of Vertices
13.1619451669489, 55.2819899121439, 9.74999999995968, !- X,Y,Z
  Vertex 1 {m}
16.4952785002823, 60.2819899121439, 9.74999999992918, !- X,Y,Z
  Vertex 2 {m}
16.4952785002823, 65.2819899121439, 9.74999999989341, !- X,Y,Z
  Vertex 3 {m}

```

```

13.1619451669489, 70.2819899121439, 9.74999999985237; !- X,Y,Z
Vertex 4 {m}

ZoneControl:Thermostat ,
Room_22_f3ee5a53 Thermostat , !- Name
Room_22_f3ee5a53 , !- Zone or ZoneList Name
Room_22_f3ee5a53 Thermostat Schedule , !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint , !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 7 , !- Control 1 Name
,
!- Control 2 Object Type
,
!- Control 2 Name
,
!- Control 3 Object Type
,
!- Control 3 Name
,
!- Control 4 Object Type
,
!- Control 4 Name
0; !- Temperature Difference
Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
Room_22_f3ee5a53 Thermostat Schedule , !- Name
Room_22_f3ee5a53 Thermostat Schedule Type Limits , !- Schedule Type
Limits Name
Through: 12/31 , !- Field 1
For: AllDays , !- Field 2
Until: 24:00 , !- Field 3
4; !- Field 4

ScheduleTypeLimits ,
Room_22_f3ee5a53 Thermostat Schedule Type Limits , !- Name
0, !- Lower Limit Value {
BasedOnField A3}
4, !- Upper Limit Value {
BasedOnField A3}
DISCRETE; !- Numeric Type

```

```

ThermostatSetpoint:DualSetpoint ,
  Thermostat Setpoint Dual Setpoint 7,      !- Name
  project_heat,                           !- Heating Setpoint
    Temperature Schedule Name
  Clg-SetP-Sch;                         !- Cooling Setpoint
    Temperature Schedule Name

ZoneHVAC:EquipmentConnections ,
  Room_22_f3ee5a53,                      !- Zone Name
  Room_22_f3ee5a53 Equipment List,       !- Zone Conditioning
    Equipment List Name
  Room_22_f3ee5a53 Inlet Node List,     !- Zone Air Inlet Node or
    NodeList Name
  Room_22_f3ee5a53 Exhaust Node List,   !- Zone Air Exhaust Node
    or NodeList Name
  Room_22_f3ee5a53 Zone Air Node,       !- Zone Air Node Name
  Room_22_f3ee5a53 Return Node List;    !- Zone Return Air Node or
    NodeList Name

  NodeList,
    Room_22_f3ee5a53 Inlet Node List,     !- Name
    Room_22_f3ee5a53 Air Terminal Outlet Air Node, !- Node Name 1
    Room_22_f3ee5a53 VRF Terminal Unit Outlet Air Node; !- Node Name 2

  NodeList,
    Room_22_f3ee5a53 Exhaust Node List,   !- Name
    Room_22_f3ee5a53 VRF Terminal Unit Inlet Air Node; !- Node Name 1

  NodeList,
    Room_22_f3ee5a53 Return Node List,     !- Name
    Room_22_f3ee5a53 Return Air Node;      !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
  Room_22_f3ee5a53 Air Terminal,          !- Name
  Always On Discrete,                    !- Availability Schedule
    Name

```

```

Room_22_f3ee5a53 Air Terminal Inlet Air Node, !- Air Inlet Node
Name

Room_22_f3ee5a53 Air Terminal Outlet Air Node, !- Air Outlet Node
Name

AutoSize;                                     !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit,
ADU Room_22_f3ee5a53 Air Terminal,          !- Name
Room_22_f3ee5a53 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
Object Type
Room_22_f3ee5a53 Air Terminal;             !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow,
Room_22_f3ee5a53 VRF Terminal Unit,         !- Zone Terminal Unit Name
Always On Discrete,                         !- Terminal Unit
Availability Schedule
Room_22_f3ee5a53 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_22_f3ee5a53 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                                    !- Cooling Supply Air Flow
Rate {m3/s}
Autosize,                                    !- No Cooling Supply Air
Flow Rate {m3/s}
Autosize,                                    !- Heating Supply Air Flow
Rate {m3/s}
Autosize,                                    !- No Heating Supply Air
Flow Rate {m3/s}
Autosize,                                    !- Cooling Outdoor Air
Flow Rate {m3/s}
Autosize,                                    !- Heating Outdoor Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- No Load Outdoor Air
Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
Placement

Fan:OnOff,                                    !- Supply Air Fan Object
Type

Room_22_f3ee5a53 VRF Unit Cycling Fan,      !- Supply Air Fan Object
Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
Object Type

Room_22_f3ee5a53 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
6, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
6, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
Sizing Ratio {W/W}

,                                             !- Availability Manager

List Name

,                                             !- Design Specification

ZoneHVAC Sizing Object Name

,                                             !- Supplemental Heating
Coil Object Type

,                                             !- Supplemental Heating
Coil Name

```

```

Autosize,                                     !- Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                         !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_22_f3ee5a53 VRF Terminal Unit OA Mixer, !- Name
Room_22_f3ee5a53 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_22_f3ee5a53 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_22_f3ee5a53 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_22_f3ee5a53 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_22_f3ee5a53 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
6, !- Name
Always On Discrete,                         !- Availability Schedule
Name
Autosize,                                     !- Gross Rated Total
Cooling Capacity {W}
Autosize,                                     !- Gross Rated Sensible
Heat Ratio
Autosize,                                     !- Rated Air Flow Rate {m3
/s}
VRFTUCoolCapFT 6,                           !- Cooling Capacity Ratio
Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 6,                          !- Cooling Capacity
Modifier Curve Function of Flow Fraction Name

```

```

Room_22_f3ee5a53 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
Inlet Node

Room_22_f3ee5a53 VRF Terminal Unit Cooling Coil Outlet Node; !-
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 6,                                     !- Name
0.0585884077803259,                                !- Coefficient1 Constant
0.0587396532718384,                                !- Coefficient2 x
-0.000210274979759697,                            !- Coefficient3 x**2
0.0109370473889647,                                !- Coefficient4 y
-0.0001219549,                                    !- Coefficient5 y**2
-0.0005246615,                                    !- Coefficient6 x*y
15,                                                 !- Minimum Value of x {
BasedOnField A2}

23.89,                                              !- Maximum Value of x {
BasedOnField A2}

20,                                                 !- Minimum Value of y {
BasedOnField A3}

43.33,                                              !- Maximum Value of y {
BasedOnField A3}

0.8083,                                             !- Minimum Curve Output {
BasedOnField A4}

1.2583;                                            !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
VRFACCoolCapFFF 6,                                     !- Name
0.8,                                                !- Coefficient1 Constant
0.2,                                                !- Coefficient2 x
0,                                                 !- Coefficient3 x**2
0.5,                                               !- Minimum Value of x {
BasedOnField A2}

1.5;                                               !- Maximum Value of x {
BasedOnField A2}

```

```

Coil:Heating:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
6, !- Name
Always On Discrete, !- Availability Schedule
Autosize, !- Gross Rated Heating
Capacity {W}
Autosize, !- Rated Air Flow Rate {m3
/s}

Room_22_f3ee5a53 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node

Room_22_f3ee5a53 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 6, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 6; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 6, !-
Name
0.375443994956127, !- Coefficient1 Constant
0.0668190645147821, !- Coefficient2 x
-0.00194171026482001, !- Coefficient3 x**2
0.0442618420640187, !- Coefficient4 y
-0.0004009578, !- Coefficient5 y**2
-0.0014819801, !- Coefficient6 x*y
21.11, !- Minimum Value of x {
BasedOnField A2}
27.22, !- Maximum Value of x {
BasedOnField A2}
-15, !- Minimum Value of y {
BasedOnField A3}
18.33, !- Maximum Value of y {
BasedOnField A3}

```

```

0.6074,                                     !- Minimum Curve Output {
BasedOnField A4}

1;                                         !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 6, !-
Name
0.8,                                         !- Coefficient1 Constant
0.2,                                         !- Coefficient2 x
0,                                            !- Coefficient3 x**2
0.5,                                         !- Minimum Value of x {
BasedOnField A2}
1.5;                                         !- Maximum Value of x {
BasedOnField A2}

Fan:OnOff,
Room_22_f3ee5a53 VRF Unit Cycling Fan,   !- Name
Always On Discrete,                         !- Availability Schedule
Name
0.6,                                         !- Fan Total Efficiency
300,                                         !- Pressure Rise {Pa}
Autosize,                                    !- Maximum Flow Rate {m3/s
}
0.8,                                         !- Motor Efficiency
1,                                           !- Motor In Airstream
Fraction
Room_22_f3ee5a53 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name
Room_22_f3ee5a53 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name
Fan On Off Power Curve 6,                    !- Fan Power Ratio
Function of Speed Ratio Curve Name
Fan On Off Efficiency Curve 6,             !- Fan Efficiency Ratio
Function of Speed Ratio Curve Name
General;                                    !- End-Use Subcategory

```

```

Curve:Exponent ,
  Fan On Off Power Curve 6,           !- Name
  1,                                !- Coefficient1 Constant
  0,                                !- Coefficient2 Constant
  0,                                !- Coefficient3 Constant
  0,                                !- Minimum Value of x {
    BasedOnField A2}
  1;                                !- Maximum Value of x {
    BasedOnField A2}

Curve:Cubic ,
  Fan On Off Efficiency Curve 6,      !- Name
  1,                                !- Coefficient1 Constant
  0,                                !- Coefficient2 x
  0,                                !- Coefficient3 x**2
  0,                                !- Coefficient4 x**3
  0,                                !- Minimum Value of x {
    BasedOnField A2}
  1;                                !- Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList ,
  Room_22_f3ee5a53 Equipment List,    !- Name
  SequentialLoad,                    !- Load Distribution
  Scheme
  ZoneHVAC:AirDistributionUnit,      !- Zone Equipment Object
  Type 1
  ADU Room_22_f3ee5a53 Air Terminal, !- Zone Equipment Name 1
  1,                                !- Zone Equipment Cooling
  Sequence 1
  1,                                !- Zone Equipment Heating
  or No-Load Sequence 1
  Schedule Constant 13,              !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1

```

```

Schedule Constant 14,                               !- Zone Equipment
Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2
Room_22_f3ee5a53 VRF Terminal Unit,           !- Zone Equipment Name 2
2,                                              !- Zone Equipment Cooling
Sequence 2
2,                                              !- Zone Equipment Heating
or No-Load Sequence 2
,
!- Zone Equipment
Sequential Cooling Fraction Schedule Name 2
;
!- Zone Equipment
Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
Room_22_f3ee5a53,                           !- Zone or ZoneList Name
SupplyAirTemperature,                         !- Zone Cooling Design
Supply Air Temperature Input Method
12.77777777777778,                         !- Zone Cooling Design
Supply Air Temperature {C}
11.11,                                         !- Zone Cooling Design
Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,                         !- Zone Heating Design
Supply Air Temperature Input Method
40.0000000000001,                           !- Zone Heating Design
Supply Air Temperature {C}
11.11,                                         !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                         !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                          !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                    !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor

```

```

,
! - Zone Cooling Sizing

Factor

DesignDay , ! - Cooling Design Air Flow

Method

0, ! - Cooling Design Air Flow

Rate {m3/s}

0.000762, ! - Cooling Minimum Air

Flow per Zone Floor Area {m3/s-m2}

0, ! - Cooling Minimum Air

Flow {m3/s}

0, ! - Cooling Minimum Air

Flow Fraction

DesignDay , ! - Heating Design Air Flow

Method

0, ! - Heating Design Air Flow

Rate {m3/s}

0.002032, ! - Heating Maximum Air

Flow per Zone Floor Area {m3/s-m2}

0.1415762, ! - Heating Maximum Air

Flow {m3/s}

0.3, ! - Heating Maximum Air

Flow Fraction

,
! - Design Specification

Zone Air Distribution Object Name

Yes, ! - Account for Dedicated

Outdoor Air System

NeutralSupplyAir , ! - Dedicated Outdoor Air

System Control Strategy

15.5555555555556, ! - Dedicated Outdoor Air

Low Setpoint Temperature for Design {C}

21.111111111111; ! - Dedicated Outdoor Air

High Setpoint Temperature for Design {C}

Zone ,
Room_23_e751e71f , ! - Name

```

```

0,                                     !- Direction of Relative
North {deg}

0,                                     !- X Origin {m}
0,                                     !- Y Origin {m}
0,                                     !- Z Origin {m}
,                                     !- Type
1,                                     !- Multiplier
,                                     !- Ceiling Height {m}
,                                     !- Volume {m3}
,                                     !- Floor Area {m2}
,                                     !- Zone Inside Convection
Algorithm

,                                     !- Zone Outside Convection
Algorithm

Yes;                                    !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_23_e751e71f..Face0,                !- Name
Wall,                                     !- Surface Type
project_wall_int,                        !- Construction Name
Room_23_e751e71f,                        !- Zone Name
Surface,                                  !- Outside Boundary
Condition

Room_17_fb615533..Face3,                !- Outside Boundary
Condition Object

NoSun,                                    !- Sun Exposure
NoWind,                                   !- Wind Exposure
,                                         !- View Factor to Ground
,                                         !- Number of Vertices
13.1619451669403, 55.2819899121641, 6.49999999995968, !- X,Y,Z
Vertex 1 {m}

13.1619451669316, 55.2819899121844, 3.24999999995968, !- X,Y,Z
Vertex 2 {m}

16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
Vertex 3 {m}

```

```

16.4952785002736, 60.2819899121641, 6.49999999992917; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_23_e751e71f..Face1, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_23_e751e71f, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_20_4d060559..Face3, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
Vertex 1 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
Vertex 2 {m}
16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z
Vertex 3 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_23_e751e71f..Face2, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_23_e751e71f, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_29_2a634042..Face0, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Number of Vertices
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
    Vertex 1 {m}
16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z
    Vertex 2 {m}
13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
    Vertex 3 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_23_e751e71f..Face3,                               !- Name
Wall,                                                 !- Surface Type
project_wall,                                         !- Construction Name
Room_23_e751e71f,                                     !- Zone Name
Outdoors,                                              !- Outside Boundary
Condition
,
                                         !- Outside Boundary
Condition Object
SunExposed,                                            !- Sun Exposure
WindExposed,                                           !- Wind Exposure
,
                                         !- View Factor to Ground
,
                                         !- Number of Vertices
13.1619451669403, 55.2819899121641, 6.4999999995968, !- X,Y,Z
    Vertex 1 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236, !- X,Y,Z
    Vertex 2 {m}
13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
    Vertex 3 {m}
13.1619451669316, 55.2819899121844, 3.2499999995968; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_23_e751e71f..Face3_Glz0,                         !- Name
Window,                                                !- Surface Type

```

```

project_window,                                     !- Construction Name
Room_23_e751e71f..Face3,                         !- Building Surface Name
,
!- Outside Boundary

Condition Object

,
!- View Factor to Ground
,
!- Frame and Divider Name
,
!- Multiplier
,
!- Number of Vertices
13.1619451669391, 68.4163649121664, 6.04999999986571, !- X,Y,Z
Vertex 1 {m}
13.1619451669391, 69.1476149121642, 6.04999999986048, !- X,Y,Z
Vertex 2 {m}
13.1619451669338, 69.1476149121499, 4.04999999986048, !- X,Y,Z
Vertex 3 {m}
13.1619451669338, 68.416364912152, 4.04999999986571; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_23_e751e71f..Face3_Glz1,                   !- Name
Window,                                         !- Surface Type
project_window,                                   !- Construction Name
Room_23_e751e71f..Face3,                         !- Building Surface Name
,
!- Outside Boundary

Condition Object

,
!- View Factor to Ground
,
!- Frame and Divider Name
,
!- Multiplier
,
!- Number of Vertices
13.1619451669391, 65.4163649121751, 6.0499999998717, !- X,Y,Z
Vertex 1 {m}
13.1619451669391, 66.147614912173, 6.04999999988194, !- X,Y,Z
Vertex 2 {m}
13.1619451669338, 66.1476149121586, 4.04999999988194, !- X,Y,Z
Vertex 3 {m}
13.1619451669338, 65.4163649121608, 4.04999999988717; !- X,Y,Z
Vertex 4 {m}

```

```

FenestrationSurface:Detailed,
  Room_23_e751e71f..Face3_Glz2,           !- Name
  Window,                                !- Surface Type
  project_window,                         !- Construction Name
  Room_23_e751e71f..Face3,                !- Building Surface Name
  ,                                       !- Outside Boundary

  Condition Object

  ,                                       !- View Factor to Ground
  ,                                       !- Frame and Divider Name
  ,                                       !- Multiplier
  ,                                       !- Number of Vertices
  13.1619451669391, 62.4163649121838, 6.04999999990863, !- X,Y,Z

  Vertex 1 {m}
  13.1619451669391, 63.1476149121817, 6.0499999999034, !- X,Y,Z

  Vertex 2 {m}
  13.1619451669338, 63.1476149121673, 4.0499999999034, !- X,Y,Z

  Vertex 3 {m}
  13.1619451669338, 62.4163649121695, 4.04999999990863; !- X,Y,Z

  Vertex 4 {m}

FenestrationSurface:Detailed,
  Room_23_e751e71f..Face3_Glz3,           !- Name
  Window,                                !- Surface Type
  project_window,                         !- Construction Name
  Room_23_e751e71f..Face3,                !- Building Surface Name
  ,                                       !- Outside Boundary

  Condition Object

  ,                                       !- View Factor to Ground
  ,                                       !- Frame and Divider Name
  ,                                       !- Multiplier
  ,                                       !- Number of Vertices
  13.1619451669391, 59.4163649121925, 6.0499999999301, !- X,Y,Z

  Vertex 1 {m}
  13.1619451669391, 60.1476149121903, 6.04999999992487, !- X,Y,Z

  Vertex 2 {m}

```

```

13.1619451669338, 60.147614912176, 4.04999999992487, !- X,Y,Z
    Vertex 3 {m}

13.1619451669338, 59.4163649121782, 4.0499999999301; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_23_e751e71f..Face3_Glz4,           !- Name
    Window,                                !- Surface Type
    project_window,                         !- Construction Name
    Room_23_e751e71f..Face3,                !- Building Surface Name
    ,
    !- Outside Boundary

    Condition Object

    ,                                     !- View Factor to Ground
    ,                                     !- Frame and Divider Name
    ,                                     !- Multiplier
    ,                                     !- Number of Vertices

13.1619451669391, 56.4163649122012, 6.0499999995156, !- X,Y,Z
    Vertex 1 {m}

13.1619451669391, 57.1476149121991, 6.0499999994633, !- X,Y,Z
    Vertex 2 {m}

13.1619451669338, 57.1476149121847, 4.0499999994633, !- X,Y,Z
    Vertex 3 {m}

13.1619451669338, 56.4163649121869, 4.0499999995156; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_23_e751e71f..Face4,               !- Name
    Floor,                                 !- Surface Type
    project_floor,                         !- Construction Name
    Room_23_e751e71f,                      !- Zone Name
    Surface,                               !- Outside Boundary

    Condition

    Room_24_159d21b7..Face5,              !- Outside Boundary

    Condition Object

    NoSun,                                !- Sun Exposure
    NoWind,                               !- Wind Exposure

```

```

,
           !- View Factor to Ground
,
           !- Number of Vertices
13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
    Vertex 1 {m}
16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z
    Vertex 2 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
    Vertex 3 {m}
13.1619451669316, 55.2819899121844, 3.24999999995968; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_23_e751e71f..Face5,                      !- Name
Ceiling,                                         !- Surface Type
project_ceiling_int,                           !- Construction Name
Room_23_e751e71f,                             !- Zone Name
Surface,                                         !- Outside Boundary
    Condition
Room_22_f3ee5a53..Face4,                      !- Outside Boundary
        Condition Object
NoSun,                                           !- Sun Exposure
NoWind,                                          !- Wind Exposure
,
           !- View Factor to Ground
,
           !- Number of Vertices
13.1619451669403, 55.2819899121641, 6.49999999995968, !- X,Y,Z
    Vertex 1 {m}
16.4952785002736, 60.2819899121641, 6.49999999992917, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
    Vertex 3 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat,
Room_23_e751e71f Thermostat,                  !- Name
Room_23_e751e71f,                            !- Zone or ZoneList Name

```

```

Room_23_e751e71f Thermostat Schedule,      !- Control Type Schedule
    Name

ThermostatSetpoint:DualSetpoint,           !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 8,       !- Control 1 Name
,
                                         !- Control 2 Object Type
,
                                         !- Control 2 Name
,
                                         !- Control 3 Object Type
,
                                         !- Control 3 Name
,
                                         !- Control 4 Object Type
,
                                         !- Control 4 Name
0;                                     !- Temperature Difference

    Between Cutout And Setpoint {deltaC}

Schedule:Compact,
Room_23_e751e71f Thermostat Schedule,      !- Name
Room_23_e751e71f Thermostat Schedule Type Limits, !- Schedule Type
    Limits Name
Through: 12/31,                            !- Field 1
For: AllDays,                             !- Field 2
Until: 24:00,                             !- Field 3
4;                                       !- Field 4

ScheduleTypeLimits,
Room_23_e751e71f Thermostat Schedule Type Limits, !- Name
0,                                         !- Lower Limit Value {
    BasedOnField A3}
4,                                         !- Upper Limit Value {
    BasedOnField A3}
DISCRETE;                                  !- Numeric Type

ThermostatSetpoint:DualSetpoint,
Thermostat Setpoint Dual Setpoint 8,       !- Name
project_heat,                            !- Heating Setpoint
    Temperature Schedule Name
Clg-SetP-Sch;                           !- Cooling Setpoint
    Temperature Schedule Name

```

```

ZoneHVAC:EquipmentConnections ,
  Room_23_e751e71f ,           !- Zone Name
  Room_23_e751e71f Equipment List ,      !- Zone Conditioning
    Equipment List Name
  Room_23_e751e71f Inlet Node List ,     !- Zone Air Inlet Node or
    NodeList Name
  Room_23_e751e71f Exhaust Node List ,   !- Zone Air Exhaust Node
    or NodeList Name
  Room_23_e751e71f Zone Air Node ,       !- Zone Air Node Name
  Room_23_e751e71f Return Node List;    !- Zone Return Air Node or
    NodeList Name

  NodeList ,
    Room_23_e751e71f Inlet Node List ,      !- Name
    Room_23_e751e71f Air Terminal Outlet Air Node , !- Node Name 1
    Room_23_e751e71f VRF Terminal Unit Outlet Air Node; !- Node Name 2

  NodeList ,
    Room_23_e751e71f Exhaust Node List ,     !- Name
    Room_23_e751e71f VRF Terminal Unit Inlet Air Node; !- Node Name 1

  NodeList ,
    Room_23_e751e71f Return Node List ,       !- Name
    Room_23_e751e71f Return Air Node;         !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
  Room_23_e751e71f Air Terminal ,          !- Name
  Always On Discrete ,                    !- Availability Schedule
    Name
  Room_23_e751e71f Air Terminal Inlet Air Node , !- Air Inlet Node
    Name
  Room_23_e751e71f Air Terminal Outlet Air Node , !- Air Outlet Node
    Name
  AutoSize;                                !- Maximum Air Flow Rate {
    m3/s}

```

```

ZoneHVAC:AirDistributionUnit ,
    ADU Room_23_e751e71f Air Terminal ,      !- Name
    Room_23_e751e71f Air Terminal Outlet Air Node , !- Air Distribution
        Unit Outlet Node Name
    AirTerminal:SingleDuct:ConstantVolume>NoReheat , !- Air Terminal
        Object Type
    Room_23_e751e71f Air Terminal;           !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
    Room_23_e751e71f VRF Terminal Unit ,      !- Zone Terminal Unit Name
    Always On Discrete ,                      !- Terminal Unit
        Availability Schedule
    Room_23_e751e71f VRF Terminal Unit Inlet Air Node , !- Terminal
        Unit Air Inlet Node Name
    Room_23_e751e71f VRF Terminal Unit Outlet Air Node , !- Terminal
        Unit Air Outlet Node Name
    Autosize ,                                !- Cooling Supply Air Flow
        Rate {m3/s}
    Autosize ,                                !- No Cooling Supply Air
        Flow Rate {m3/s}
    Autosize ,                                !- Heating Supply Air Flow
        Rate {m3/s}
    Autosize ,                                !- No Heating Supply Air
        Flow Rate {m3/s}
    Autosize ,                                !- Cooling Outdoor Air
        Flow Rate {m3/s}
    Autosize ,                                !- Heating Outdoor Air
        Flow Rate {m3/s}
    Autosize ,                                !- No Load Outdoor Air
        Flow Rate {m3/s}
    Always Off Discrete ,                     !- Supply Air Fan
        Operating Mode Schedule Name
    DrawThrough ,                            !- Supply Air Fan
        Placement

```

```

Fan:OnOff ,                                     !- Supply Air Fan Object
  Type
Room_23_e751e71f VRF Unit Cycling Fan ,      !- Supply Air Fan Object
  Name
OutdoorAir:Mixer ,                           !- Outside Air Mixer
  Object Type
Room_23_e751e71f VRF Terminal Unit OA Mixer , !- Outside Air Mixer
  Object Name
Coil:Cooling:DX:VariableRefrigerantFlow ,   !- Cooling Coil Object
  Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
  7 , !- Cooling Coil Object Name
Coil:Heating:DX:VariableRefrigerantFlow ,   !- Heating Coil Object
  Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
  7 , !- Heating Coil Object Name
30 ,                                         !- Zone Terminal Unit On
  Parasitic Electric Energy Use {W}
20 ,                                         !- Zone Terminal Unit Off
  Parasitic Electric Energy Use {W}
1 ,                                           !- Rated Heating Capacity
  Sizing Ratio {W/W}
,                                              !- Availability Manager
  List Name
,                                              !- Design Specification
  ZoneHVAC Sizing Object Name
,                                              !- Supplemental Heating
  Coil Object Type
,                                              !- Supplemental Heating
  Coil Name
Autosize ,                                    !- Maximum Supply Air
  Temperature from Supplemental Heater {C}
21;                                         !- Maximum Outdoor Dry-
  Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer ,

```

```

Room_23_e751e71f VRF Terminal Unit OA Mixer, !- Name
Room_23_e751e71f VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
    Node Name
Room_23_e751e71f VRF Terminal Unit Outdoor Air Node, !- Outdoor
    Air Stream Node Name
Room_23_e751e71f VRF Terminal Unit Relief Node Name, !- Relief Air
    Stream Node Name
Room_23_e751e71f VRF Terminal Unit Inlet Air Node; !- Return Air
    Stream Node Name

OutdoorAir:NodeList,
    Room_23_e751e71f VRF Terminal Unit Outdoor Air Node; !- Node or
        NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow ,
    Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
    7, !- Name
    Always On Discrete, !- Availability Schedule
    Name
    Autosize, !- Gross Rated Total
    Cooling Capacity {W}
    Autosize, !- Gross Rated Sensible
    Heat Ratio
    Autosize, !- Rated Air Flow Rate {m3
    /s}
    VRFTUCoolCapFT 7, !- Cooling Capacity Ratio
    Modifier Function of Temperature Curve Name
    VRFACCoolCapFFF 7, !- Cooling Capacity
    Modifier Curve Function of Flow Fraction Name
    Room_23_e751e71f VRF Terminal Unit Mixer Outlet Node, !- Coil Air
    Inlet Node
    Room_23_e751e71f VRF Terminal Unit Cooling Coil Outlet Node; !-
    Coil Air Outlet Node

Curve:Biquadratic ,
    VRFTUCoolCapFT 7, !- Name

```

```

0.0585884077803259 ,                               ! - Coefficient1 Constant
0.0587396532718384 ,                               ! - Coefficient2 x
-0.000210274979759697 ,                           ! - Coefficient3 x**2
0.0109370473889647 ,                               ! - Coefficient4 y
-0.0001219549 ,                                   ! - Coefficient5 y**2
-0.0005246615 ,                                   ! - Coefficient6 x*y
15 ,                                              ! - Minimum Value of x {
    BasedOnField A2}
23.89 ,                                         ! - Maximum Value of x {
    BasedOnField A2}
20 ,                                              ! - Minimum Value of y {
    BasedOnField A3}
43.33 ,                                         ! - Maximum Value of y {
    BasedOnField A3}
0.8083 ,                                         ! - Minimum Curve Output {
    BasedOnField A4}
1.2583;                                         ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
VRFACCCoolCapFFF 7 ,                            ! - Name
0.8 ,                                            ! - Coefficient1 Constant
0.2 ,                                            ! - Coefficient2 x
0 ,                                              ! - Coefficient3 x**2
0.5 ,                                            ! - Minimum Value of x {
    BasedOnField A2}
1.5;                                             ! - Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
7 , !- Name
Always On Discrete ,                            ! - Availability Schedule
Autosize ,                                       ! - Gross Rated Heating
Capacity {W}

```

```

Autosize,                                     !- Rated Air Flow Rate {m3
/s}

Room_23_e751e71f VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node

Room_23_e751e71f VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 7, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 7; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 7, !-
Name
0.375443994956127,                         !- Coefficient1 Constant
0.0668190645147821,                         !- Coefficient2 x
-0.00194171026482001,                        !- Coefficient3 x**2
0.0442618420640187,                         !- Coefficient4 y
-0.0004009578,                             !- Coefficient5 y**2
-0.0014819801,                             !- Coefficient6 x*y
21.11,                                       !- Minimum Value of x {
BasedOnField A2}
27.22,                                       !- Maximum Value of x {
BasedOnField A2}
-15,                                         !- Minimum Value of y {
BasedOnField A3}
18.33,                                       !- Maximum Value of y {
BasedOnField A3}
0.6074,                                      !- Minimum Curve Output {
BasedOnField A4}
1;                                            !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,

```

```

Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 7, !-
  Name
  0.8,                                     !- Coefficient1 Constant
  0.2,                                     !- Coefficient2 x
  0,                                         !- Coefficient3 x**2
  0.5,                                     !- Minimum Value of x {
    BasedOnField A2}
  1.5;                                      !- Maximum Value of x {
    BasedOnField A2}

Fan:OnOff,
  Room_23_e751e71f VRF Unit Cycling Fan,   !- Name
  Always On Discrete,                      !- Availability Schedule
    Name
    0.6,                                     !- Fan Total Efficiency
    300,                                     !- Pressure Rise {Pa}
    Autosize,                                !- Maximum Flow Rate {m3/s
    }
    0.8,                                     !- Motor Efficiency
    1,                                         !- Motor In Airstream
      Fraction
  Room_23_e751e71f VRF Terminal Unit Heating Coil Outlet Node, !-
    Air Inlet Node Name
  Room_23_e751e71f VRF Terminal Unit Outlet Air Node, !- Air Outlet
    Node Name
  Fan On Off Power Curve 7,                  !- Fan Power Ratio
    Function of Speed Ratio Curve Name
  Fan On Off Efficiency Curve 7,           !- Fan Efficiency Ratio
    Function of Speed Ratio Curve Name
  General;                                 !- End-Use Subcategory

Curve:Exponent,
  Fan On Off Power Curve 7,                !- Name
  1,                                       !- Coefficient1 Constant
  0,                                         !- Coefficient2 Constant
  0,                                         !- Coefficient3 Constant

```

```

0,                                     !- Minimum Value of x {
BasedOnField A2}

1;                                     !- Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 7,          !- Name
1,                                       !- Coefficient1 Constant
0,                                       !- Coefficient2 x
0,                                       !- Coefficient3 x**2
0,                                       !- Coefficient4 x**3
0,                                     !- Minimum Value of x {
BasedOnField A2}

1;                                     !- Maximum Value of x {
BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_23_e751e71f Equipment List,        !- Name
SequentialLoad,                         !- Load Distribution
Scheme
ZoneHVAC:AirDistributionUnit,           !- Zone Equipment Object
Type 1
ADU Room_23_e751e71f Air Terminal,     !- Zone Equipment Name 1
1,                                       !- Zone Equipment Cooling
Sequence 1
1,                                       !- Zone Equipment Heating
or No-Load Sequence 1
Schedule Constant 15,                   !- Zone Equipment
Sequential Cooling Fraction Schedule Name 1
Schedule Constant 16,                   !- Zone Equipment
Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2
Room_23_e751e71f VRF Terminal Unit,    !- Zone Equipment Name 2
2,                                       !- Zone Equipment Cooling
Sequence 2

```

```

2,                                     !- Zone Equipment Heating
  or No-Load Sequence 2
,
                                     !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
;
                                     !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
Room_23_e751e71f,                  !- Zone or ZoneList Name
SupplyAirTemperature,                !- Zone Cooling Design
  Supply Air Temperature Input Method
12.77777777777778,                 !- Zone Cooling Design
  Supply Air Temperature {C}
11.11,                                !- Zone Cooling Design
  Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,                !- Zone Heating Design
  Supply Air Temperature Input Method
40.0000000000001,                   !- Zone Heating Design
  Supply Air Temperature {C}
11.11,                                !- Zone Heating Design
  Supply Air Temperature Difference {deltaC}
0.0085,                               !- Zone Cooling Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                !- Zone Heating Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                          !- Design Specification
  Outdoor Air Object Name
,
                                     !- Zone Heating Sizing
  Factor
,
                                     !- Zone Cooling Sizing
  Factor
DesignDay,                            !- Cooling Design Air Flow
  Method
0,                                    !- Cooling Design Air Flow
  Rate {m3/s}

```

```

0.000762,                                     ! - Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                              ! - Cooling Minimum Air
Flow {m3/s}
0,                                              ! - Cooling Minimum Air
Flow Fraction
DesignDay,                                     ! - Heating Design Air Flow
Method
0,                                              ! - Heating Design Air Flow
Rate {m3/s}
0.002032,                                     ! - Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                    ! - Heating Maximum Air
Flow {m3/s}
0.3,                                            ! - Heating Maximum Air
Flow Fraction
,
! - Design Specification
Zone Air Distribution Object Name
Yes,                                           ! - Account for Dedicated
Outdoor Air System
NeutralSupplyAir,                                ! - Dedicated Outdoor Air
System Control Strategy
15.55555555555556,                            ! - Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}
21.1111111111111;                            ! - Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_24_159d21b7,                            ! - Name
0,                                              ! - Direction of Relative
North {deg}
0,                                              ! - X Origin {m}
0,                                              ! - Y Origin {m}
0,                                              ! - Z Origin {m}
,
! - Type
1,                                              ! - Multiplier

```

```

        ,                                     !- Ceiling Height {m}
        ,                                     !- Volume {m3}
        ,                                     !- Floor Area {m2}
        ,                                     !- Zone Inside Convection

    Algorithm
        ,                                     !- Zone Outside Convection

    Algorithm
Yes;                                         !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_24_159d21b7..Face0,                      !- Name
Wall,                                            !- Surface Type
project_wall_int,                                !- Construction Name
Room_24_159d21b7,                                !- Zone Name
Surface,                                         !- Outside Boundary
Condition
Room_16_3d8c5364..Face3,                        !- Outside Boundary
Condition Object
NoSun,                                           !- Sun Exposure
NoWind,                                          !- Wind Exposure
,                                                 !- View Factor to Ground
,                                                 !- Number of Vertices
13.1619451669316, 55.2819899121844, 3.2499999995968, !- X,Y,Z
Vertex 1 {m}
13.161945166923, 55.2819899122047, -4.03238477771582e-11, !- X,Y,Z
Vertex 2 {m}
16.4952785002563, 60.2819899122047, -7.08246976248188e-11, !- X,Y,
Z Vertex 3 {m}
16.495278500265, 60.2819899121844, 3.24999999992918; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_24_159d21b7..Face1,                      !- Name
Wall,                                            !- Surface Type
project_wall_int,                                !- Construction Name

```

```

Room_24_159d21b7 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_21_4c523269..Face3 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
16.495278500265 , 60.2819899121844 , 3.24999999992918 , !- X,Y,Z
Vertex 1 {m}
16.4952785002563 , 60.2819899122047 , -7.08246976248188e-11 , !- X,Y,
Z Vertex 2 {m}
16.4952785002563 , 65.2819899122047 , -1.06597558445733e-10 , !- X,Y,
Z Vertex 3 {m}
16.495278500265 , 65.2819899121844 , 3.2499999998934 ; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed ,
Room_24_159d21b7..Face2 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_24_159d21b7 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_30_98f1d6c8..Face0 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
16.495278500265 , 65.2819899121844 , 3.2499999998934 , !- X,Y,Z
Vertex 1 {m}
16.4952785002563 , 65.2819899122047 , -1.06597558445733e-10 , !- X,Y,
Z Vertex 2 {m}

```

```

13.161945166923, 70.2819899122047, -1.47642430239901e-10, !- X,Y,Z
    Vertex 3 {m}

13.1619451669316, 70.2819899121844, 3.24999999985236; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_24_159d21b7..Face3,           !- Name
    Wall,                            !- Surface Type
    project_wall,                   !- Construction Name
    Room_24_159d21b7,                !- Zone Name
    Outdoors,                        !- Outside Boundary
    Condition,
    ,                                !- Outside Boundary
    Condition Object
    SunExposed,                      !- Sun Exposure
    WindExposed,                     !- Wind Exposure
    ,                                !- View Factor to Ground
    ,                                !- Number of Vertices
13.1619451669316, 55.2819899121844, 3.2499999995968, !- X,Y,Z
    Vertex 1 {m}

13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
    Vertex 2 {m}

13.161945166923, 70.2819899122047, -1.47642430239901e-10, !- X,Y,Z
    Vertex 3 {m}

13.161945166923, 55.2819899122047, -4.03238477771582e-11; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_24_159d21b7..Face3_Glz0,      !- Name
    Window,                           !- Surface Type
    project_window,                  !- Construction Name
    Room_24_159d21b7..Face3,          !- Building Surface Name
    ,                                !- Outside Boundary
    Condition Object
    ,                                !- View Factor to Ground
    ,                                !- Frame and Divider Name

```

```

        ,                                     !- Multiplier
        ,                                     !- Number of Vertices
13.1619451669304, 68.4163649121866, 2.79999999986571, !- X,Y,Z
    Vertex 1 {m}
13.1619451669304, 69.1476149121845, 2.79999999986047, !- X,Y,Z
    Vertex 2 {m}
13.1619451669251, 69.1476149121702, 0.799999999860474, !- X,Y,Z
    Vertex 3 {m}
13.1619451669251, 68.4163649121723, 0.799999999865705; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_24_159d21b7..Face3_Glz1,           !- Name
    Window,                                !- Surface Type
    project_window,                         !- Construction Name
    Room_24_159d21b7..Face3,                !- Building Surface Name
    ,                                      !- Outside Boundary
    Condition Object
    ,                                      !- View Factor to Ground
    ,                                      !- Frame and Divider Name
    ,                                      !- Multiplier
    ,                                      !- Number of Vertices
13.1619451669304, 65.4163649121953, 2.79999999988717, !- X,Y,Z
    Vertex 1 {m}
13.1619451669304, 66.1476149121932, 2.79999999988194, !- X,Y,Z
    Vertex 2 {m}
13.1619451669251, 66.1476149121789, 0.799999999881937, !- X,Y,Z
    Vertex 3 {m}
13.1619451669251, 65.416364912181, 0.799999999887169; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_24_159d21b7..Face3_Glz2,           !- Name
    Window,                                !- Surface Type
    project_window,                         !- Construction Name
    Room_24_159d21b7..Face3,                !- Building Surface Name

```

```

        ,                                         !- Outside Boundary
Condition Object

        ,                                         !- View Factor to Ground
        ,                                         !- Frame and Divider Name
        ,                                         !- Multiplier
        ,                                         !- Number of Vertices
13.1619451669304, 62.4163649122041, 2.79999999990863, !- X,Y,Z

Vertex 1 {m}
13.1619451669304, 63.1476149122019, 2.7999999999034, !- X,Y,Z

Vertex 2 {m}
13.1619451669251, 63.1476149121876, 0.799999999903401, !- X,Y,Z

Vertex 3 {m}
13.1619451669251, 62.4163649121897, 0.799999999908633; !- X,Y,Z

Vertex 4 {m}

FenestrationSurface:Detailed,
Room_24_159d21b7..Face3_Glz3,           !- Name
Window,                                    !- Surface Type
project_window,                          !- Construction Name
Room_24_159d21b7..Face3,                 !- Building Surface Name
        ,                                         !- Outside Boundary

Condition Object

        ,                                         !- View Factor to Ground
        ,                                         !- Frame and Divider Name
        ,                                         !- Multiplier
        ,                                         !- Number of Vertices
13.1619451669304, 59.4163649122128, 2.7999999999301, !- X,Y,Z

Vertex 1 {m}
13.1619451669304, 60.1476149122106, 2.79999999992486, !- X,Y,Z

Vertex 2 {m}
13.1619451669251, 60.1476149121963, 0.799999999924865, !- X,Y,Z

Vertex 3 {m}
13.1619451669251, 59.4163649121985, 0.799999999930097; !- X,Y,Z

Vertex 4 {m}

FenestrationSurface:Detailed,

```

```

Room_24_159d21b7..Face3_Glz4 , ! - Name
Window , ! - Surface Type
project_window , ! - Construction Name
Room_24_159d21b7..Face3 , ! - Building Surface Name
,
! - Outside Boundary

Condition Object

, ! - View Factor to Ground
, ! - Frame and Divider Name
, ! - Multiplier
, ! - Number of Vertices
13.1619451669304, 56.4163649122215, 2.79999999995156, !- X,Y,Z
Vertex 1 {m}
13.1619451669304, 57.1476149122194, 2.79999999994633, !- X,Y,Z
Vertex 2 {m}
13.1619451669251, 57.147614912205, 0.799999999946328, !- X,Y,Z
Vertex 3 {m}
13.1619451669251, 56.4163649122072, 0.79999999995156; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed ,
Room_24_159d21b7..Face4 , ! - Name
Floor , ! - Surface Type
project_slab , ! - Construction Name
Room_24_159d21b7 , ! - Zone Name
Ground , ! - Outside Boundary
Condition
,
! - Outside Boundary

Condition Object

NoSun , ! - Sun Exposure
NoWind , ! - Wind Exposure
,
! - View Factor to Ground
,
! - Number of Vertices
13.161945166923, 70.2819899122047, -1.47642430239901e-10, !- X,Y,Z
Vertex 1 {m}
16.4952785002563, 65.2819899122047, -1.06597558445733e-10, !- X,Y,
Z Vertex 2 {m}

```

```

16.4952785002563, 60.2819899122047, -7.08246976248188e-11, !- X,Y,
Z Vertex 3 {m}

13.161945166923, 55.2819899122047, -4.03238477771582e-11; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_24_159d21b7..Face5, !- Name
Ceiling, !- Surface Type
project_ceiling_int, !- Construction Name
Room_24_159d21b7, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_23_e751e71f..Face4, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
13.1619451669316, 55.2819899121844, 3.24999999995968, !- X,Y,Z
Vertex 1 {m}
16.495278500265, 60.2819899121844, 3.24999999992918, !- X,Y,Z
Vertex 2 {m}
16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z
Vertex 3 {m}
13.1619451669316, 70.2819899121844, 3.24999999985236; !- X,Y,Z
Vertex 4 {m}

ZoneControl:Thermostat,
Room_24_159d21b7 Thermostat, !- Name
Room_24_159d21b7, !- Zone or ZoneList Name
Room_24_159d21b7 Thermostat Schedule, !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint, !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 9, !- Control 1 Name
, !- Control 2 Object Type
, !- Control 2 Name

```

```

,
          !- Control 3 Object Type
,
          !- Control 3 Name
,
          !- Control 4 Object Type
,
          !- Control 4 Name
0;                      !- Temperature Difference

      Between Cutout And Setpoint {deltaC}

Schedule:Compact,
Room_24_159d21b7 Thermostat Schedule,      !- Name
Room_24_159d21b7 Thermostat Schedule Type Limits, !- Schedule Type
Limits Name
Through: 12/31,                      !- Field 1
For: AllDays,                         !- Field 2
Until: 24:00,                          !- Field 3
4;                                     !- Field 4

ScheduleTypeLimits,
Room_24_159d21b7 Thermostat Schedule Type Limits, !- Name
0,                                         !- Lower Limit Value {
BasedOnField A3}
4,                                         !- Upper Limit Value {
BasedOnField A3}
DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint,
Thermostat Setpoint Dual Setpoint 9,      !- Name
project_heat,                            !- Heating Setpoint
Temperature Schedule Name
Clg-SetP-Sch;                           !- Cooling Setpoint
Temperature Schedule Name

ZoneHVAC:EquipmentConnections,
Room_24_159d21b7,                      !- Zone Name
Room_24_159d21b7 Equipment List,        !- Zone Conditioning
Equipment List Name

```

```

Room_24_159d21b7 Inlet Node List,           !- Zone Air Inlet Node or
 NodeList Name

Room_24_159d21b7 Exhaust Node List,         !- Zone Air Exhaust Node
 or NodeList Name

Room_24_159d21b7 Zone Air Node,             !- Zone Air Node Name

Room_24_159d21b7 Return Node List;          !- Zone Return Air Node or
 NodeList Name

 NodeList,
 Room_24_159d21b7 Inlet Node List,          !- Name
 Room_24_159d21b7 Air Terminal Outlet Air Node, !- Node Name 1
 Room_24_159d21b7 VRF Terminal Unit Outlet Air Node; !- Node Name 2

 NodeList,
 Room_24_159d21b7 Exhaust Node List,         !- Name
 Room_24_159d21b7 VRF Terminal Unit Inlet Air Node; !- Node Name 1

 NodeList,
 Room_24_159d21b7 Return Node List,          !- Name
 Room_24_159d21b7 Return Air Node;           !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat,
Room_24_159d21b7 Air Terminal,               !- Name
Always On Discrete,                         !- Availability Schedule
Name

Room_24_159d21b7 Air Terminal Inlet Air Node, !- Air Inlet Node
Name

Room_24_159d21b7 Air Terminal Outlet Air Node, !- Air Outlet Node
Name

AutoSize;                                    !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit,
ADU Room_24_159d21b7 Air Terminal,          !- Name
Room_24_159d21b7 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name

```

```

AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
Object Type
Room_24_159d21b7 Air Terminal;           !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow,
Room_24_159d21b7 VRF Terminal Unit,      !- Zone Terminal Unit Name
Always On Discrete,                      !- Terminal Unit

Availability Schedule
Room_24_159d21b7 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_24_159d21b7 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                                !- Cooling Supply Air Flow
Rate {m3/s}
Autosize,                                !- No Cooling Supply Air
Flow Rate {m3/s}
Autosize,                                !- Heating Supply Air Flow
Rate {m3/s}
Autosize,                                !- No Heating Supply Air
Flow Rate {m3/s}
Autosize,                                !- Cooling Outdoor Air
Flow Rate {m3/s}
Autosize,                                !- Heating Outdoor Air
Flow Rate {m3/s}
Autosize,                                !- No Load Outdoor Air
Flow Rate {m3/s}
Always Off Discrete,                     !- Supply Air Fan
Operating Mode Schedule Name
DrawThrough,                             !- Supply Air Fan
Placement
Fan:OnOff,                               !- Supply Air Fan Object
Type
Room_24_159d21b7 VRF Unit Cycling Fan, !- Supply Air Fan Object
Name
OutdoorAir:Mixer,                        !- Outside Air Mixer
Object Type

```

```

Room_24_159d21b7 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
Object Name
Coil:Cooling:DX:VariableRefrigerantFlow, !- Cooling Coil Object
Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
8, !- Cooling Coil Object Name
Coil:Heating:DX:VariableRefrigerantFlow, !- Heating Coil Object
Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
8, !- Heating Coil Object Name
30,                                     !- Zone Terminal Unit On
Parasitic Electric Energy Use {W}
20,                                     !- Zone Terminal Unit Off
Parasitic Electric Energy Use {W}
1,                                       !- Rated Heating Capacity
Sizing Ratio {W/W}
,                                         !- Availability Manager
List Name
,                                         !- Design Specification
ZoneHVAC Sizing Object Name
,                                         !- Supplemental Heating
Coil Object Type
,                                         !- Supplemental Heating
Coil Name
Autosize,                                !- Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                      !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_24_159d21b7 VRF Terminal Unit OA Mixer, !- Name
Room_24_159d21b7 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_24_159d21b7 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name

```

```

Room_24_159d21b7 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name

Room_24_159d21b7 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_24_159d21b7 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
8, !- Name
Always On Discrete, !- Availability Schedule
Name
Autosize, !- Gross Rated Total
Cooling Capacity {W}
Autosize, !- Gross Rated Sensible
Heat Ratio
Autosize, !- Rated Air Flow Rate {m3
/s}
VRFTUCoolCapFT 8, !- Cooling Capacity Ratio
Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 8, !- Cooling Capacity
Modifier Curve Function of Flow Fraction Name
Room_24_159d21b7 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
Inlet Node
Room_24_159d21b7 VRF Terminal Unit Cooling Coil Outlet Node; !-
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 8, !- Name
0.0585884077803259, !- Coefficient1 Constant
0.0587396532718384, !- Coefficient2 x
-0.000210274979759697, !- Coefficient3 x**2
0.0109370473889647, !- Coefficient4 y
-0.0001219549, !- Coefficient5 y**2

```

```

-0.0005246615 ,                               ! - Coefficient6 x*y
15 ,                                         ! - Minimum Value of x {
    BasedOnField A2}
23.89 ,                                     ! - Maximum Value of x {
    BasedOnField A2}
20 ,                                         ! - Minimum Value of y {
    BasedOnField A3}
43.33 ,                                     ! - Maximum Value of y {
    BasedOnField A3}
0.8083 ,                                    ! - Minimum Curve Output {
    BasedOnField A4}
1.2583;                                     ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
VRFACCCoolCapFFF 8 ,                         ! - Name
0.8 ,                                         ! - Coefficient1 Constant
0.2 ,                                         ! - Coefficient2 x
0 ,                                           ! - Coefficient3 x**2
0.5 ,                                         ! - Minimum Value of x {
    BasedOnField A2}
1.5;                                         ! - Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
8, !- Name
Always On Discrete ,                           ! - Availability Schedule
Autosize ,                                     ! - Gross Rated Heating
Capacity {W}
Autosize ,                                     ! - Rated Air Flow Rate {m3
/s}
Room_24_159d21b7 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_24_159d21b7 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

```

```

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 8, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 8; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 8, !-
Name
0.375443994956127,                               !- Coefficient1 Constant
0.0668190645147821,                            !- Coefficient2 x
-0.00194171026482001,                          !- Coefficient3 x**2
0.0442618420640187,                            !- Coefficient4 y
-0.0004009578,                                !- Coefficient5 y**2
-0.0014819801,                                !- Coefficient6 x*y
21.11,                                         !- Minimum Value of x {
BasedOnField A2}
27.22,                                         !- Maximum Value of x {
BasedOnField A2}
-15,                                            !- Minimum Value of y {
BasedOnField A3}
18.33,                                         !- Maximum Value of y {
BasedOnField A3}
0.6074,                                         !- Minimum Curve Output {
BasedOnField A4}
1;                                              !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 8, !-
Name
0.8,                                            !- Coefficient1 Constant
0.2,                                            !- Coefficient2 x
0,                                              !- Coefficient3 x**2
0.5,                                            !- Minimum Value of x {
BasedOnField A2}

```

```

1.5;                                     ! - Maximum Value of x {
BasedOnField A2}

Fan:OnOff,
Room_24_159d21b7 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                      ! - Availability Schedule
Name
0.6,                                      ! - Fan Total Efficiency
300,                                       ! - Pressure Rise {Pa}
Autosize,                                   ! - Maximum Flow Rate {m3/s
}
0.8,                                      ! - Motor Efficiency
1,                                         ! - Motor In Airstream
Fraction
Room_24_159d21b7 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name
Room_24_159d21b7 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name
Fan On Off Power Curve 8,                  ! - Fan Power Ratio
Function of Speed Ratio Curve Name
Fan On Off Efficiency Curve 8,            ! - Fan Efficiency Ratio
Function of Speed Ratio Curve Name
General;                                  ! - End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 8,                ! - Name
1,                                         ! - Coefficient1 Constant
0,                                         ! - Coefficient2 Constant
0,                                         ! - Coefficient3 Constant
0,                                         ! - Minimum Value of x {
BasedOnField A2}
1;                                         ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 8,          ! - Name

```

```

1,                                     !- Coefficient1 Constant
0,                                     !- Coefficient2 x
0,                                     !- Coefficient3 x**2
0,                                     !- Coefficient4 x**3
0,                                     !- Minimum Value of x {
    BasedOnField A2}
1;                                     !- Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList ,
Room_24_159d21b7 Equipment List,           !- Name
SequentialLoad,                           !- Load Distribution
Scheme
ZoneHVAC:AirDistributionUnit,             !- Zone Equipment Object
Type 1
ADU Room_24_159d21b7 Air Terminal,       !- Zone Equipment Name 1
1,                                         !- Zone Equipment Cooling
Sequence 1                               !- Zone Equipment Heating
1,                                         !- Zone Equipment Heating
or No-Load Sequence 1
Schedule Constant 17,                     !- Zone Equipment
Sequential Cooling Fraction Schedule Name 1
Schedule Constant 18,                     !- Zone Equipment
Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2
Room_24_159d21b7 VRF Terminal Unit,      !- Zone Equipment Name 2
2,                                         !- Zone Equipment Cooling
Sequence 2                               !- Zone Equipment Heating
2,                                         !- Zone Equipment Heating
or No-Load Sequence 2
,                                           !- Zone Equipment
Sequential Cooling Fraction Schedule Name 2
;                                           !- Zone Equipment
Sequential Heating Fraction Schedule Name 2

```

```

Sizing:Zone ,
Room_24_159d21b7 , !- Zone or ZoneList Name
SupplyAirTemperature , !- Zone Cooling Design
  Supply Air Temperature Input Method
12.77777777777778 , !- Zone Cooling Design
  Supply Air Temperature {C}
11.11 , !- Zone Cooling Design
  Supply Air Temperature Difference {deltaC}
SupplyAirTemperature , !- Zone Heating Design
  Supply Air Temperature Input Method
40.0000000000001 , !- Zone Heating Design
  Supply Air Temperature {C}
11.11 , !- Zone Heating Design
  Supply Air Temperature Difference {deltaC}
0.0085 , !- Zone Cooling Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008 , !- Zone Heating Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation , !- Design Specification
  Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor
,
!- Zone Cooling Sizing
Factor
DesignDay , !- Cooling Design Air Flow
  Method
0 , !- Cooling Design Air Flow
  Rate {m3/s}
0.000762 , !- Cooling Minimum Air
  Flow per Zone Floor Area {m3/s-m2}
0 , !- Cooling Minimum Air
  Flow {m3/s}
0 , !- Cooling Minimum Air
  Flow Fraction
DesignDay , !- Heating Design Air Flow
  Method

```

```

0,                                     ! - Heating Design Air Flow
    Rate {m3/s}
0.002032,                                ! - Heating Maximum Air
    Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                ! - Heating Maximum Air
    Flow {m3/s}
0.3,                                     ! - Heating Maximum Air
    Flow Fraction
,
                                         ! - Design Specification
Zone Air Distribution Object Name
Yes,                                      ! - Account for Dedicated
    Outdoor Air System
NeutralSupplyAir,                           ! - Dedicated Outdoor Air
    System Control Strategy
15.55555555555556,                      ! - Dedicated Outdoor Air
    Low Setpoint Temperature for Design {C}
21.111111111111;                         ! - Dedicated Outdoor Air
    High Setpoint Temperature for Design {C}

Zone,
Room_25_d27e0933,                        ! - Name
0,                                         ! - Direction of Relative
    North {deg}
0,                                         ! - X Origin {m}
0,                                         ! - Y Origin {m}
0,                                         ! - Z Origin {m}
,
                                         ! - Type
1,                                         ! - Multiplier
,
                                         ! - Ceiling Height {m}
,
                                         ! - Volume {m3}
,
                                         ! - Floor Area {m2}
,
                                         ! - Zone Inside Convection
Algorithm
,
                                         ! - Zone Outside Convection
Algorithm

```

```

Yes;                                         !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_25_d27e0933..Face0,                      !- Name
Wall,                                           !- Surface Type
project_wall,                                    !- Construction Name
Room_25_d27e0933,                                !- Zone Name
Outdoors,                                         !- Outside Boundary
Condition
,
Condition Object
SunExposed,                                     !- Sun Exposure
WindExposed,                                    !- Wind Exposure
,
,                                              !- View Factor to Ground
,
,                                              !- Number of Vertices
23.1619451669489, 55.2819899121439, 9.7499999999755, !- X,Y,Z
Vertex 1 {m}
23.1619451669403, 55.2819899121641, 6.4999999997549, !- X,Y,Z
Vertex 2 {m}
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
Vertex 3 {m}
23.1619451669489, 70.2819899121439, 9.74999999986818; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_25_d27e0933..Face0_Glz0,                  !- Name
Window,                                         !- Surface Type
project_window,                                   !- Construction Name
Room_25_d27e0933..Face0,                        !- Building Surface Name
,
!- Outside Boundary
Condition Object
,
,                                              !- View Factor to Ground
,
,                                              !- Frame and Divider Name
,
!- Multiplier
,
!- Number of Vertices

```

```

23.1619451669477, 56.4163649121809, 9.29999999996738, !- X,Y,Z
    Vertex 1 {m}
23.1619451669424, 56.4163649121666, 7.29999999996738, !- X,Y,Z
    Vertex 2 {m}
23.1619451669424, 57.1476149121645, 7.29999999996215, !- X,Y,Z
    Vertex 3 {m}
23.1619451669477, 57.1476149121788, 9.29999999996215; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_25_d27e0933..Face0_Glz1,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_25_d27e0933..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
23.1619451669477, 59.4163649121722, 9.29999999994591, !- X,Y,Z
    Vertex 1 {m}
23.1619451669424, 59.4163649121579, 7.29999999994591, !- X,Y,Z
    Vertex 2 {m}
23.1619451669424, 60.1476149121558, 7.29999999994068, !- X,Y,Z
    Vertex 3 {m}
23.1619451669477, 60.1476149121701, 9.29999999994068; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_25_d27e0933..Face0_Glz2,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_25_d27e0933..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Frame and Divider Name
        ,                                     !- Multiplier
        ,                                     !- Number of Vertices
23.1619451669477, 62.4163649121635, 9.29999999992445, !- X,Y,Z
    Vertex 1 {m}
23.1619451669424, 62.4163649121492, 7.29999999992445, !- X,Y,Z
    Vertex 2 {m}
23.1619451669424, 63.1476149121471, 7.29999999991922, !- X,Y,Z
    Vertex 3 {m}
23.1619451669477, 63.1476149121614, 9.29999999991922; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_25_d27e0933..Face0_Glz3,           !- Name
Window,                                  !- Surface Type
project_window,                         !- Construction Name
Room_25_d27e0933..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                     !- View Factor to Ground
,                                     !- Frame and Divider Name
,                                     !- Multiplier
,                                     !- Number of Vertices
23.1619451669477, 65.4163649121548, 9.29999999990299, !- X,Y,Z
    Vertex 1 {m}
23.1619451669424, 65.4163649121405, 7.29999999990299, !- X,Y,Z
    Vertex 2 {m}
23.1619451669424, 66.1476149121384, 7.29999999989776, !- X,Y,Z
    Vertex 3 {m}
23.1619451669477, 66.1476149121527, 9.29999999989776; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_25_d27e0933..Face0_Glz4,           !- Name
Window,                                  !- Surface Type

```

```

project_window,
Room_25_d27e0933..Face0,
,
Condition Object
,
,
,
,
23.1619451669477, 68.4163649121461, 9.2999999998152, !- X,Y,Z
Vertex 1 {m}
23.1619451669424, 68.4163649121318, 7.2999999998152, !- X,Y,Z
Vertex 2 {m}
23.1619451669424, 69.1476149121296, 7.29999999987629, !- X,Y,Z
Vertex 3 {m}
23.1619451669477, 69.147614912144, 9.29999999987629; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_25_d27e0933..Face1, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_25_d27e0933, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_28_d6ed2799..Face2, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
,
,
19.8286118336156, 65.2819899121439, 9.74999999989868, !- X,Y,Z
Vertex 1 {m}
23.1619451669489, 70.2819899121439, 9.74999999986818, !- X,Y,Z
Vertex 2 {m}
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
Vertex 3 {m}

```

```

19.8286118336069, 65.2819899121641, 6.49999999989867; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_25_d27e0933..Face2, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_25_d27e0933, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_19_6ae0f9a9..Face1, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118336156, 60.2819899121439, 9.7499999993446, !- X,Y,Z
Vertex 1 {m}
19.8286118336156, 65.2819899121439, 9.74999999989868, !- X,Y,Z
Vertex 2 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
Vertex 3 {m}
19.8286118336069, 60.2819899121641, 6.4999999993444; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_25_d27e0933..Face3, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_25_d27e0933, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_18_6cc35095..Face1, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Number of Vertices
23.1619451669489, 55.2819899121439, 9.7499999999755, !- X,Y,Z
    Vertex 1 {m}
19.8286118336156, 60.2819899121439, 9.74999999993446, !- X,Y,Z
    Vertex 2 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
    Vertex 3 {m}
23.1619451669403, 55.2819899121641, 6.49999999997549; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_25_d27e0933..Face4,           !- Name
    Floor,                            !- Surface Type
    project_floor,                   !- Construction Name
    Room_25_d27e0933,                !- Zone Name
    Surface,                          !- Outside Boundary
    Condition
    Room_26_f4ea3797..Face5,          !- Outside Boundary
    Condition Object
    NoSun,                           !- Sun Exposure
    NoWind,                          !- Wind Exposure
    ,                                 !- View Factor to Ground
    ,                                 !- Number of Vertices
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
    Vertex 1 {m}
23.1619451669403, 55.2819899121641, 6.49999999997549, !- X,Y,Z
    Vertex 2 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
    Vertex 3 {m}
19.8286118336069, 65.2819899121641, 6.499999999989867; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_25_d27e0933..Face5,           !- Name
    Roof,                            !- Surface Type

```

```

project_roof ,
!- Construction Name

Room_25_d27e0933 ,
!- Zone Name

Outdoors ,
!- Outside Boundary

Condition
,
!- Outside Boundary

Condition Object

SunExposed , !- Sun Exposure
WindExposed , !- Wind Exposure
,
!- View Factor to Ground
,
!- Number of Vertices
23.1619451669489 , 55.2819899121439 , 9.7499999999755 , !- X,Y,Z

Vertex 1 {m}
23.1619451669489 , 70.2819899121439 , 9.74999999986818 , !- X,Y,Z

Vertex 2 {m}
19.8286118336156 , 65.2819899121439 , 9.74999999989868 , !- X,Y,Z

Vertex 3 {m}
19.8286118336156 , 60.2819899121439 , 9.74999999993446 ; !- X,Y,Z

Vertex 4 {m}

ZoneControl:Thermostat ,
Room_25_d27e0933 Thermostat , !- Name
Room_25_d27e0933 , !- Zone or ZoneList Name
Room_25_d27e0933 Thermostat Schedule , !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint , !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 10 , !- Control 1 Name
,
!- Control 2 Object Type
,
!- Control 2 Name
,
!- Control 3 Object Type
,
!- Control 3 Name
,
!- Control 4 Object Type
,
!- Control 4 Name
0; !- Temperature Difference

Between Cutout And Setpoint {deltaC}

Schedule:Compact ,

```

```

Room_25_d27e0933 Thermostat Schedule,      !- Name
Room_25_d27e0933 Thermostat Schedule Type Limits, !- Schedule Type
    Limits Name
Through: 12/31,                      !- Field 1
For: AllDays,                         !- Field 2
Until: 24:00,                          !- Field 3
4;                                    !- Field 4

ScheduleTypeLimits,
Room_25_d27e0933 Thermostat Schedule Type Limits, !- Name
0,                                     !- Lower Limit Value {
    BasedOnField A3}
4,                                     !- Upper Limit Value {
    BasedOnField A3}
DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint,
Thermostat Setpoint Dual Setpoint 10,      !- Name
project_heat,                            !- Heating Setpoint
    Temperature Schedule Name
Clg-SetP-Sch;                           !- Cooling Setpoint
    Temperature Schedule Name

ZoneHVAC:EquipmentConnections,
Room_25_d27e0933,                       !- Zone Name
Room_25_d27e0933 Equipment List,        !- Zone Conditioning
    Equipment List Name
Room_25_d27e0933 Inlet Node List,       !- Zone Air Inlet Node or
    NodeList Name
Room_25_d27e0933 Exhaust Node List,     !- Zone Air Exhaust Node
    or NodeList Name
Room_25_d27e0933 Zone Air Node,         !- Zone Air Node Name
Room_25_d27e0933 Return Node List;      !- Zone Return Air Node or
    NodeList Name

NodeList,

```

```

Room_25_d27e0933 Inlet Node List,           !- Name
Room_25_d27e0933 Air Terminal Outlet Air Node, !- Node Name 1
Room_25_d27e0933 VRF Terminal Unit Outlet Air Node; !- Node Name 2

NodeList,
  Room_25_d27e0933 Exhaust Node List,      !- Name
  Room_25_d27e0933 VRF Terminal Unit Inlet Air Node; !- Node Name 1

NodeList,
  Room_25_d27e0933 Return Node List,       !- Name
  Room_25_d27e0933 Return Air Node;        !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
  Room_25_d27e0933 Air Terminal,           !- Name
  Always On Discrete,                     !- Availability Schedule
  Name
  Room_25_d27e0933 Air Terminal Inlet Air Node, !- Air Inlet Node
  Name
  Room_25_d27e0933 Air Terminal Outlet Air Node, !- Air Outlet Node
  Name
  AutoSize;                                !- Maximum Air Flow Rate {
  m3/s}

ZoneHVAC:AirDistributionUnit ,
  ADU Room_25_d27e0933 Air Terminal,       !- Name
  Room_25_d27e0933 Air Terminal Outlet Air Node, !- Air Distribution
  Unit Outlet Node Name
  AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
  Object Type
  Room_25_d27e0933 Air Terminal;          !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
  Room_25_d27e0933 VRF Terminal Unit,      !- Zone Terminal Unit Name
  Always On Discrete,                      !- Terminal Unit
  Availability Schedule

```

```

Room_25_d27e0933 VRF Terminal Unit Inlet Air Node, !- Terminal
    Unit Air Inlet Node Name

Room_25_d27e0933 VRF Terminal Unit Outlet Air Node, !- Terminal
    Unit Air Outlet Node Name

Autosize,                                     !- Cooling Supply Air Flow
    Rate {m3/s}

Autosize,                                     !- No Cooling Supply Air
    Flow Rate {m3/s}

Autosize,                                     !- Heating Supply Air Flow
    Rate {m3/s}

Autosize,                                     !- No Heating Supply Air
    Flow Rate {m3/s}

Autosize,                                     !- Cooling Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
    Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
    Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
    Placement

Fan:OnOff,                                    !- Supply Air Fan Object
    Type

Room_25_d27e0933 VRF Unit Cycling Fan,      !- Supply Air Fan Object
    Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
    Object Type

Room_25_d27e0933 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
    Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
9, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
    Type

```

```

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
9, !- Heating Coil Object Name
30,                                     !- Zone Terminal Unit On
    Parasitic Electric Energy Use {W}
20,                                     !- Zone Terminal Unit Off
    Parasitic Electric Energy Use {W}
1,                                         !- Rated Heating Capacity
    Sizing Ratio {W/W}
,
                                         !- Availability Manager
List Name
,
                                         !- Design Specification
ZoneHVAC Sizing Object Name
,
                                         !- Supplemental Heating
Coil Object Type
,
                                         !- Supplemental Heating
Coil Name
Autosize,                               !- Maximum Supply Air
    Temperature from Supplemental Heater {C}
21;                                     !- Maximum Outdoor Dry-
    Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_25_d27e0933 VRF Terminal Unit OA Mixer, !- Name
Room_25_d27e0933 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
    Node Name
Room_25_d27e0933 VRF Terminal Unit Outdoor Air Node, !- Outdoor
    Air Stream Node Name
Room_25_d27e0933 VRF Terminal Unit Relief Node Name, !- Relief Air
    Stream Node Name
Room_25_d27e0933 VRF Terminal Unit Inlet Air Node; !- Return Air
    Stream Node Name

OutdoorAir:NodeList,
Room_25_d27e0933 VRF Terminal Unit Outdoor Air Node; !- Node or
    NodeList Name 1

```

```

Coil:Cooling:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
9, !- Name
Always On Discrete, !- Availability Schedule
Name
Autosize, !- Gross Rated Total
Cooling Capacity {W}
Autosize, !- Gross Rated Sensible
Heat Ratio
Autosize, !- Rated Air Flow Rate {m3
/s}
VRFTUCoolCapFT 9, !- Cooling Capacity Ratio
Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 9, !- Cooling Capacity
Modifier Curve Function of Flow Fraction Name
Room_25_d27e0933 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
Inlet Node
Room_25_d27e0933 VRF Terminal Unit Cooling Coil Outlet Node; !-
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 9, !- Name
0.0585884077803259, !- Coefficient1 Constant
0.0587396532718384, !- Coefficient2 x
-0.000210274979759697, !- Coefficient3 x**2
0.0109370473889647, !- Coefficient4 y
-0.0001219549, !- Coefficient5 y**2
-0.0005246615, !- Coefficient6 x*y
15, !- Minimum Value of x {
BasedOnField A2}
23.89, !- Maximum Value of x {
BasedOnField A2}
20, !- Minimum Value of y {
BasedOnField A3}
43.33, !- Maximum Value of y {
BasedOnField A3}

```

```

0.8083,                                     !- Minimum Curve Output {
BasedOnField A4}

1.2583;                                     !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,
VRFACCoolCapFFF 9,                         !- Name
0.8,                                         !- Coefficient1 Constant
0.2,                                         !- Coefficient2 x
0,                                            !- Coefficient3 x**2
0.5,                                         !- Minimum Value of x {
BasedOnField A2}                            !- Maximum Value of x {
1.5;                                         BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
9, !- Name
Always On Discrete,                         !- Availability Schedule
Autosize,                                    !- Gross Rated Heating
Capacity {W}
Autosize,                                    !- Rated Air Flow Rate {m3
/s}

Room_25_d27e0933 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_25_d27e0933 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 9, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 9; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 9, !-
Name

```

```

0.375443994956127 ,                               ! - Coefficient1 Constant
0.0668190645147821 ,                            ! - Coefficient2 x
-0.00194171026482001 ,                           ! - Coefficient3 x**2
0.0442618420640187 ,                            ! - Coefficient4 y
-0.0004009578 ,                                 ! - Coefficient5 y**2
-0.0014819801 ,                                 ! - Coefficient6 x*y
21.11 ,                                         ! - Minimum Value of x {
BasedOnField A2}

27.22 ,                                         ! - Maximum Value of x {
BasedOnField A2}

-15 ,                                           ! - Minimum Value of y {
BasedOnField A3}

18.33 ,                                         ! - Maximum Value of y {
BasedOnField A3}

0.6074 ,                                         ! - Minimum Curve Output {
BasedOnField A4}

1;                                              ! - Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 9, !-
Name
0.8 ,                                            ! - Coefficient1 Constant
0.2 ,                                            ! - Coefficient2 x
0 ,                                              ! - Coefficient3 x**2
0.5 ,                                            ! - Minimum Value of x {
BasedOnField A2}

1.5;                                             ! - Maximum Value of x {
BasedOnField A2}

Fan:OnOff ,
Room_25_d27e0933 VRF Unit Cycling Fan ,      ! - Name
Always On Discrete ,                           ! - Availability Schedule
Name
0.6 ,                                            ! - Fan Total Efficiency
300 ,                                           ! - Pressure Rise {Pa}

```

```

    Autosize,                               ! - Maximum Flow Rate {m3/s
    }
    0.8,                                    ! - Motor Efficiency
    1,                                       ! - Motor In Airstream
    Fraction

Room_25_d27e0933 VRF Terminal Unit Heating Coil Outlet Node, !-
    Air Inlet Node Name

Room_25_d27e0933 VRF Terminal Unit Outlet Air Node, !- Air Outlet
    Node Name

Fan On Off Power Curve 9,                  ! - Fan Power Ratio
    Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve 9,             ! - Fan Efficiency Ratio
    Function of Speed Ratio Curve Name

General;                                  ! - End-Use Subcategory

Curve:Exponent,
    Fan On Off Power Curve 9,              ! - Name
    1,                                     ! - Coefficient1 Constant
    0,                                     ! - Coefficient2 Constant
    0,                                     ! - Coefficient3 Constant
    0,                                     ! - Minimum Value of x {
        BasedOnField A2}
    1;                                     ! - Maximum Value of x {
        BasedOnField A2}

Curve:Cubic,
    Fan On Off Efficiency Curve 9,        ! - Name
    1,                                     ! - Coefficient1 Constant
    0,                                     ! - Coefficient2 x
    0,                                     ! - Coefficient3 x**2
    0,                                     ! - Coefficient4 x**3
    0,                                     ! - Minimum Value of x {
        BasedOnField A2}
    1;                                     ! - Maximum Value of x {
        BasedOnField A2}

```

```

ZoneHVAC:EquipmentList ,
  Room_25_d27e0933 Equipment List ,           !- Name
  SequentialLoad ,                           !- Load Distribution
  Scheme
ZoneHVAC:AirDistributionUnit ,             !- Zone Equipment Object
  Type 1
ADU Room_25_d27e0933 Air Terminal ,       !- Zone Equipment Name 1
1 ,                                         !- Zone Equipment Cooling
  Sequence 1
1 ,                                         !- Zone Equipment Heating
  or No-Load Sequence 1
Schedule Constant 19 ,                      !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1
Schedule Constant 20 ,                      !- Zone Equipment
  Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow , !- Zone Equipment
  Object Type 2
Room_25_d27e0933 VRF Terminal Unit ,       !- Zone Equipment Name 2
2 ,                                         !- Zone Equipment Cooling
  Sequence 2
2 ,                                         !- Zone Equipment Heating
  or No-Load Sequence 2
,                                           !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
;                                           !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone ,
  Room_25_d27e0933 ,                       !- Zone or ZoneList Name
  SupplyAirTemperature ,                     !- Zone Cooling Design
  Supply Air Temperature Input Method
  12.7777777777778 ,                     !- Zone Cooling Design
  Supply Air Temperature {C}
  11.11 ,                                    !- Zone Cooling Design
  Supply Air Temperature Difference {deltaC}

```

```

SupplyAirTemperature ,                               !- Zone Heating Design
  Supply Air Temperature Input Method
40.0000000000001 ,                             !- Zone Heating Design
  Supply Air Temperature {C}
11.11 ,                                         !- Zone Heating Design
  Supply Air Temperature Difference {deltaC}
0.0085 ,                                         !- Zone Cooling Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008 ,                                         !- Zone Heating Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation ,                                    !- Design Specification
  Outdoor Air Object Name
,
  !- Zone Heating Sizing
Factor
,
  !- Zone Cooling Sizing
Factor
DesignDay ,                                     !- Cooling Design Air Flow
  Method
0 ,                                              !- Cooling Design Air Flow
  Rate {m3/s}
0.000762 ,                                       !- Cooling Minimum Air
  Flow per Zone Floor Area {m3/s-m2}
0 ,                                              !- Cooling Minimum Air
  Flow {m3/s}
0 ,                                              !- Cooling Minimum Air
  Flow Fraction
DesignDay ,                                     !- Heating Design Air Flow
  Method
0 ,                                              !- Heating Design Air Flow
  Rate {m3/s}
0.002032 ,                                       !- Heating Maximum Air
  Flow per Zone Floor Area {m3/s-m2}
0.1415762 ,                                      !- Heating Maximum Air
  Flow {m3/s}
0.3 ,                                            !- Heating Maximum Air
  Flow Fraction

```

```

,
!- Design Specification

Zone Air Distribution Object Name
Yes, !- Account for Dedicated
Outdoor Air System
NeutralSupplyAir, !- Dedicated Outdoor Air
System Control Strategy
15.5555555555556, !- Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}
21.111111111111; !- Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_26_f4ea3797, !- Name
0, !- Direction of Relative
North {deg}
0, !- X Origin {m}
0, !- Y Origin {m}
0, !- Z Origin {m}
, !- Type
1, !- Multiplier
, !- Ceiling Height {m}
, !- Volume {m3}
, !- Floor Area {m2}
, !- Zone Inside Convection
Algorithm
, !- Zone Outside Convection
Algorithm
Yes; !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_26_f4ea3797..Face0, !- Name
Wall, !- Surface Type
project_wall, !- Construction Name
Room_26_f4ea3797, !- Zone Name

```

```

Outdoors ,                                     ! - Outside Boundary
Condition
,
                                         ! - Outside Boundary
Condition Object
SunExposed ,                                ! - Sun Exposure
WindExposed ,                                ! - Wind Exposure
,
                                         ! - View Factor to Ground
,
                                         ! - Number of Vertices
23.1619451669403 , 55.2819899121641 , 6.4999999997549 , !- X,Y,Z
Vertex 1 {m}
23.1619451669316 , 55.2819899121844 , 3.2499999997549 , !- X,Y,Z
Vertex 2 {m}
23.1619451669316 , 70.2819899121844 , 3.24999999986817 , !- X,Y,Z
Vertex 3 {m}
23.1619451669403 , 70.2819899121641 , 6.49999999986818 ; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed ,
Room_26_f4ea3797..Face0_Glz0 ,                ! - Name
Window ,                                      ! - Surface Type
project_window ,                               ! - Construction Name
Room_26_f4ea3797..Face0 ,                     ! - Building Surface Name
,
                                         ! - Outside Boundary
Condition Object
,
                                         ! - View Factor to Ground
,
                                         ! - Frame and Divider Name
,
                                         ! - Multiplier
,
                                         ! - Number of Vertices
23.1619451669391 , 56.4163649122012 , 6.0499999996738 , !- X,Y,Z
Vertex 1 {m}
23.1619451669338 , 56.4163649121869 , 4.0499999996738 , !- X,Y,Z
Vertex 2 {m}
23.1619451669338 , 57.1476149121848 , 4.0499999996214 , !- X,Y,Z
Vertex 3 {m}
23.1619451669391 , 57.1476149121991 , 6.0499999996214 ; !- X,Y,Z
Vertex 4 {m}

```

```

FenestrationSurface:Detailed,
  Room_26_f4ea3797..Face0_Glz1,           !- Name
  Window,                                !- Surface Type
  project_window,                         !- Construction Name
  Room_26_f4ea3797..Face0,                !- Building Surface Name
  ,                                       !- Outside Boundary
  Condition Object
  ,
  ,                                       !- View Factor to Ground
  ,                                       !- Frame and Divider Name
  ,                                       !- Multiplier
  ,                                       !- Number of Vertices
  23.1619451669391, 59.4163649121925, 6.04999999994591, !- X,Y,Z
  Vertex 1 {m}
  23.1619451669338, 59.4163649121782, 4.04999999994591, !- X,Y,Z
  Vertex 2 {m}
  23.1619451669338, 60.147614912176, 4.04999999994068, !- X,Y,Z
  Vertex 3 {m}
  23.1619451669391, 60.1476149121904, 6.04999999994068; !- X,Y,Z
  Vertex 4 {m}

FenestrationSurface:Detailed,
  Room_26_f4ea3797..Face0_Glz2,           !- Name
  Window,                                !- Surface Type
  project_window,                         !- Construction Name
  Room_26_f4ea3797..Face0,                !- Building Surface Name
  ,                                       !- Outside Boundary
  Condition Object
  ,
  ,                                       !- View Factor to Ground
  ,                                       !- Frame and Divider Name
  ,                                       !- Multiplier
  ,                                       !- Number of Vertices
  23.1619451669391, 62.4163649121838, 6.04999999992445, !- X,Y,Z
  Vertex 1 {m}
  23.1619451669338, 62.4163649121695, 4.04999999992445, !- X,Y,Z
  Vertex 2 {m}

```

```

23.1619451669338, 63.1476149121673, 4.04999999991922, !- X,Y,Z
    Vertex 3 {m}

23.1619451669391, 63.1476149121817, 6.04999999991922; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_26_f4ea3797..Face0_Glz3,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_26_f4ea3797..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
23.1619451669391, 65.4163649121751, 6.0499999990298, !- X,Y,Z
    Vertex 1 {m}

23.1619451669338, 65.4163649121608, 4.0499999990298, !- X,Y,Z
    Vertex 2 {m}

23.1619451669338, 66.1476149121586, 4.04999999989775, !- X,Y,Z
    Vertex 3 {m}

23.1619451669391, 66.1476149121729, 6.04999999989775; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_26_f4ea3797..Face0_Glz4,           !- Name
Window,                                !- Surface Type
project_window,                         !- Construction Name
Room_26_f4ea3797..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices

```

```

23.1619451669391, 68.4163649121663, 6.04999999988152, !- X,Y,Z
    Vertex 1 {m}
23.1619451669338, 68.416364912152, 4.04999999988152, !- X,Y,Z
    Vertex 2 {m}
23.1619451669338, 69.1476149121499, 4.04999999987629, !- X,Y,Z
    Vertex 3 {m}
23.1619451669391, 69.1476149121642, 6.04999999987629; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_26_f4ea3797..Face1,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_26_f4ea3797,                                         !- Zone Name
Surface,                                              !- Outside Boundary
    Condition
Room_29_2a634042..Face2,                               !- Outside Boundary
    Condition Object
NoSun,                                               !- Sun Exposure
NoWind,                                              !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
    Vertex 1 {m}
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
    Vertex 2 {m}
23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 3 {m}
19.8286118335983, 65.2819899121844, 3.24999999989868; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_26_f4ea3797..Face2,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                         !- Construction Name
Room_26_f4ea3797,                                         !- Zone Name

```

```

Surface,                                     !- Outside Boundary
  Condition
Room_20_4d060559..Face1,                     !- Outside Boundary
  Condition Object
NoSun,                                         !- Sun Exposure
NoWind,                                         !- Wind Exposure
,
,                                               !- View Factor to Ground
,
,                                               !- Number of Vertices
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
  Vertex 1 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
  Vertex 2 {m}
19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
  Vertex 3 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445; !- X,Y,Z
  Vertex 4 {m}

BuildingSurface:Detailed,
  Room_26_f4ea3797..Face3,                   !- Name
  Wall,                                         !- Surface Type
  project_wall_int,                          !- Construction Name
  Room_26_f4ea3797,                         !- Zone Name
  Surface,                                     !- Outside Boundary
  Condition
  Room_17_fb615533..Face1,                   !- Outside Boundary
  Condition Object
  NoSun,                                       !- Sun Exposure
  NoWind,                                      !- Wind Exposure
,
,                                               !- View Factor to Ground
,
,                                               !- Number of Vertices
23.1619451669403, 55.2819899121641, 6.49999999997549, !- X,Y,Z
  Vertex 1 {m}
19.8286118336069, 60.2819899121641, 6.49999999993444, !- X,Y,Z
  Vertex 2 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
  Vertex 3 {m}

```

```

23.1619451669316, 55.2819899121844, 3.24999999997549; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_26_f4ea3797..Face4, !- Name
Floor, !- Surface Type
project_floor, !- Construction Name
Room_26_f4ea3797, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_27_0080b418..Face5, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
Vertex 1 {m}
23.1619451669316, 55.2819899121844, 3.2499999997549, !- X,Y,Z
Vertex 2 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445, !- X,Y,Z
Vertex 3 {m}
19.8286118335983, 65.2819899121844, 3.24999999989868; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_26_f4ea3797..Face5, !- Name
Ceiling, !- Surface Type
project_ceiling_int, !- Construction Name
Room_26_f4ea3797, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_25_d27e0933..Face4, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure

```

```

,
          !- View Factor to Ground
,
          !- Number of Vertices
23.1619451669403, 55.2819899121641, 6.4999999997549, !- X,Y,Z
  Vertex 1 {m}
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
  Vertex 2 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
  Vertex 3 {m}
19.8286118336069, 60.2819899121641, 6.4999999993444; !- X,Y,Z
  Vertex 4 {m}

ZoneControl:Thermostat ,
Room_26_f4ea3797 Thermostat,           !- Name
Room_26_f4ea3797,                      !- Zone or ZoneList Name
Room_26_f4ea3797 Thermostat Schedule, !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint,        !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 11,   !- Control 1 Name
,
          !- Control 2 Object Type
,
          !- Control 2 Name
,
          !- Control 3 Object Type
,
          !- Control 3 Name
,
          !- Control 4 Object Type
,
          !- Control 4 Name
0;                                     !- Temperature Difference

  Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
Room_26_f4ea3797 Thermostat Schedule,   !- Name
Room_26_f4ea3797 Thermostat Schedule Type Limits, !- Schedule Type
Limits Name
Through: 12/31,                         !- Field 1
For: AllDays,                           !- Field 2
Until: 24:00,                            !- Field 3
4;                                     !- Field 4

```

```

ScheduleTypeLimits ,
  Room_26_f4ea3797 Thermostat Schedule Type Limits, !- Name
  0,                                     !- Lower Limit Value {
    BasedOnField A3}
  4,                                     !- Upper Limit Value {
    BasedOnField A3}
  DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint ,
  Thermostat Setpoint Dual Setpoint 11,      !- Name
  project_heat,                            !- Heating Setpoint
  Temperature Schedule Name
  Clg-SetP-Sch;                           !- Cooling Setpoint
  Temperature Schedule Name

ZoneHVAC:EquipmentConnections ,
  Room_26_f4ea3797 ,                      !- Zone Name
  Room_26_f4ea3797 Equipment List,        !- Zone Conditioning
  Equipment List Name
  Room_26_f4ea3797 Inlet Node List,       !- Zone Air Inlet Node or
  NodeList Name
  Room_26_f4ea3797 Exhaust Node List,     !- Zone Air Exhaust Node
  or NodeList Name
  Room_26_f4ea3797 Zone Air Node,         !- Zone Air Node Name
  Room_26_f4ea3797 Return Node List;      !- Zone Return Air Node or
  NodeList Name

  NodeList,
    Room_26_f4ea3797 Inlet Node List,      !- Name
    Room_26_f4ea3797 Air Terminal Outlet Air Node, !- Node Name 1
    Room_26_f4ea3797 VRF Terminal Unit Outlet Air Node; !- Node Name 2

  NodeList,
    Room_26_f4ea3797 Exhaust Node List,    !- Name
    Room_26_f4ea3797 VRF Terminal Unit Inlet Air Node; !- Node Name 1

```

```

NodeList ,
Room_26_f4ea3797 Return Node List ,      !- Name
Room_26_f4ea3797 Return Air Node;      !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
Room_26_f4ea3797 Air Terminal ,          !- Name
Always On Discrete ,                    !- Availability Schedule
Name
Room_26_f4ea3797 Air Terminal Inlet Air Node , !- Air Inlet Node
Name
Room_26_f4ea3797 Air Terminal Outlet Air Node , !- Air Outlet Node
Name
AutoSize;                                !- Maximum Air Flow Rate {
m3/s}

ZoneHVAC:AirDistributionUnit ,
ADU Room_26_f4ea3797 Air Terminal ,      !- Name
Room_26_f4ea3797 Air Terminal Outlet Air Node , !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat , !- Air Terminal
Object Type
Room_26_f4ea3797 Air Terminal;          !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
Room_26_f4ea3797 VRF Terminal Unit ,     !- Zone Terminal Unit Name
Always On Discrete ,                    !- Terminal Unit
Availability Schedule
Room_26_f4ea3797 VRF Terminal Unit Inlet Air Node , !- Terminal
Unit Air Inlet Node Name
Room_26_f4ea3797 VRF Terminal Unit Outlet Air Node , !- Terminal
Unit Air Outlet Node Name
Autosize ,                               !- Cooling Supply Air Flow
Rate {m3/s}
Autosize ,                               !- No Cooling Supply Air
Flow Rate {m3/s}

```

```

Autosize,                                     !- Heating Supply Air Flow
    Rate {m3/s}

Autosize,                                     !- No Heating Supply Air
    Flow Rate {m3/s}

Autosize,                                     !- Cooling Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
    Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
    Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
    Placement

Fan:OnOff,                                    !- Supply Air Fan Object
    Type

Room_26_f4ea3797 VRF Unit Cycling Fan,     !- Supply Air Fan Object
    Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
    Object Type

Room_26_f4ea3797 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
    Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
10, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
10, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
    Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
    Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
    Sizing Ratio {W/W}

```

```

        ,                                     !- Availability Manager
List Name

        ,                                     !- Design Specification
ZoneHVAC Sizing Object Name

        ,                                     !- Supplemental Heating
Coil Object Type

        ,                                     !- Supplemental Heating
Coil Name

Autosize,                                !- Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                      !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_26_f4ea3797 VRF Terminal Unit OA Mixer, !- Name
Room_26_f4ea3797 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_26_f4ea3797 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_26_f4ea3797 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_26_f4ea3797 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_26_f4ea3797 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
10, !- Name
Always On Discrete,                      !- Availability Schedule
Name
Autosize,                                !- Gross Rated Total
Cooling Capacity {W}

```

```

Autosize,                                     ! - Gross Rated Sensible
Heat Ratio

Autosize,                                     ! - Rated Air Flow Rate {m3
/s}

VRFTUCoolCapFT 10,                           ! - Cooling Capacity Ratio
Modifier Function of Temperature Curve Name

VRFACCoolCapFFF 10,                          ! - Cooling Capacity
Modifier Curve Function of Flow Fraction Name

Room_26_f4ea3797 VRF Terminal Unit Mixer Outlet Node, ! - Coil Air
Inlet Node

Room_26_f4ea3797 VRF Terminal Unit Cooling Coil Outlet Node; ! -
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 10,                         ! - Name
0.0585884077803259,                        ! - Coefficient1 Constant
0.0587396532718384,                        ! - Coefficient2 x
-0.000210274979759697,                     ! - Coefficient3 x**2
0.0109370473889647,                        ! - Coefficient4 y
-0.0001219549,                            ! - Coefficient5 y**2
-0.0005246615,                            ! - Coefficient6 x*y
15,                                         ! - Minimum Value of x {
BasedOnField A2}                           ! - Maximum Value of x {
23.89,                                       ! - Minimum Value of y {
BasedOnField A2}                           ! - Maximum Value of y {
20,                                         ! - Minimum Value of y {
BasedOnField A3}                           ! - Maximum Value of y {
43.33,                                       ! - Minimum Curve Output {
BasedOnField A3}                           ! - Maximum Curve Output {
0.8083,                                      ! - Minimum Curve Output {
BasedOnField A4}                           ! - Maximum Curve Output {
1.2583;                                     ! - Minimum Curve Output {
BasedOnField A4}                           ! - Maximum Curve Output {

Curve:Quadratic,
VRFACCoolCapFFF 10,                         ! - Name

```

```

0.8,                                     !- Coefficient1 Constant
0.2,                                     !- Coefficient2 x
0,                                         !- Coefficient3 x**2
0.5,                                     !- Minimum Value of x {
    BasedOnField A2}
1.5;                                      !- Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
10, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                 !- Rated Air Flow Rate {m3
/s}
Room_26_f4ea3797 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_26_f4ea3797 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 10, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 10; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 10, !-
Name
0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                     !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                           !- Coefficient5 y**2
-0.0014819801,                           !- Coefficient6 x*y

```

```

21.11 ,                                     ! - Minimum Value of x {
    BasedOnField A2}

27.22 ,                                     ! - Maximum Value of x {
    BasedOnField A2}

-15 ,                                         ! - Minimum Value of y {
    BasedOnField A3}

18.33 ,                                       ! - Maximum Value of y {
    BasedOnField A3}

0.6074 ,                                      ! - Minimum Curve Output {
    BasedOnField A4}

1;                                            ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 10, !-
    Name

0.8,                                           ! - Coefficient1 Constant
0.2,                                           ! - Coefficient2 x
0,                                              ! - Coefficient3 x**2
0.5,                                           ! - Minimum Value of x {
    BasedOnField A2}

1.5;                                           ! - Maximum Value of x {
    BasedOnField A2}

Fan:OnOff ,
Room_26_f4ea3797 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                         ! - Availability Schedule
    Name

0.6,                                           ! - Fan Total Efficiency
300,                                           ! - Pressure Rise {Pa}
Autosize,                                      ! - Maximum Flow Rate {m3/s
    }

0.8,                                           ! - Motor Efficiency
1,                                             ! - Motor In Airstream
    Fraction

```

```

Room_26_f4ea3797 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name

Room_26_f4ea3797 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name

Fan On Off Power Curve 10,           !- Fan Power Ratio
Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve 10,      !- Fan Efficiency Ratio
Function of Speed Ratio Curve Name

General;                           !- End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 10,          !- Name
1,                                    !- Coefficient1 Constant
0,                                    !- Coefficient2 Constant
0,                                    !- Coefficient3 Constant
0,                                    !- Minimum Value of x {
BasedOnField A2}                   !- Maximum Value of x {
1;                                   BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 10,     !- Name
1,                                    !- Coefficient1 Constant
0,                                    !- Coefficient2 x
0,                                    !- Coefficient3 x**2
0,                                    !- Coefficient4 x**3
0,                                    !- Minimum Value of x {
BasedOnField A2}                   !- Maximum Value of x {
1;                                   BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_26_f4ea3797 Equipment List,    !- Name
SequentialLoad,                     !- Load Distribution
Scheme

```

```

ZoneHVAC:AirDistributionUnit,           !- Zone Equipment Object
  Type 1
ADU Room_26_f4ea3797 Air Terminal,    !- Zone Equipment Name 1
1,                                     !- Zone Equipment Cooling
  Sequence 1
1,                                     !- Zone Equipment Heating
  or No-Load Sequence 1
Schedule Constant 21,                  !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1
Schedule Constant 22,                  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
  Object Type 2
Room_26_f4ea3797 VRF Terminal Unit,   !- Zone Equipment Name 2
2,                                     !- Zone Equipment Cooling
  Sequence 2
2,                                     !- Zone Equipment Heating
  or No-Load Sequence 2
  ,                                     !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
  ;                                     !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
  Room_26_f4ea3797,                   !- Zone or ZoneList Name
  SupplyAirTemperature,                !- Zone Cooling Design
    Supply Air Temperature Input Method
  12.77777777777778,                 !- Zone Cooling Design
    Supply Air Temperature {C}
  11.11,                                !- Zone Cooling Design
    Supply Air Temperature Difference {deltaC}
  SupplyAirTemperature,                 !- Zone Heating Design
    Supply Air Temperature Input Method
  40.0000000000001,                   !- Zone Heating Design
    Supply Air Temperature {C}

```

```

11.11,                                     !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                      !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                       !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor
,
!- Zone Cooling Sizing
Factor
DesignDay,                                    !- Cooling Design Air Flow
Method
0,                                            !- Cooling Design Air Flow
Rate {m3/s}
0.000762,                                     !- Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                            !- Cooling Minimum Air
Flow {m3/s}
0,                                            !- Cooling Minimum Air
Flow Fraction
DesignDay,                                    !- Heating Design Air Flow
Method
0,                                            !- Heating Design Air Flow
Rate {m3/s}
0.002032,                                     !- Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                    !- Heating Maximum Air
Flow {m3/s}
0.3,                                           !- Heating Maximum Air
Flow Fraction
,
!- Design Specification
Zone Air Distribution Object Name
Yes,                                         !- Account for Dedicated
Outdoor Air System

```

```

NeutralSupplyAir,                               !- Dedicated Outdoor Air
System Control Strategy
15.55555555555556,                         !- Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}
21.1111111111111;                          !- Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_27_0080b418,                           !- Name
0,                                         !- Direction of Relative
North {deg}
0,                                         !- X Origin {m}
0,                                         !- Y Origin {m}
0,                                         !- Z Origin {m}
,                                           !- Type
1,                                         !- Multiplier
,                                           !- Ceiling Height {m}
,                                           !- Volume {m3}
,                                           !- Floor Area {m2}
,                                           !- Zone Inside Convection
Algorithm
,                                         !- Zone Outside Convection
Algorithm
Yes;                                       !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_27_0080b418..Face0,                   !- Name
Wall,                                       !- Surface Type
project_wall,                                !- Construction Name
Room_27_0080b418,                           !- Zone Name
Outdoors,                                    !- Outside Boundary
Condition
,                                         !- Outside Boundary
Condition Object
SunExposed,                                  !- Sun Exposure

```

```

WindExposed ,                                     ! - Wind Exposure
,
,                                         ! - View Factor to Ground
,
,                                         ! - Number of Vertices
23.1619451669316 , 55.2819899121844 , 3.2499999997549 , ! - X,Y,Z
    Vertex 1 {m}
23.161945166923 , 55.2819899122047 , -2.45078148573979e-11 , ! - X,Y,Z
    Vertex 2 {m}
23.161945166923 , 70.2819899122047 , -1.3182639732014e-10 , ! - X,Y,Z
    Vertex 3 {m}
23.1619451669316 , 70.2819899121844 , 3.24999999986817 ; ! - X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed ,
Room_27_0080b418..Face0_Glz0 ,                 ! - Name
Window ,                                         ! - Surface Type
project_window ,                                ! - Construction Name
Room_27_0080b418..Face0 ,                      ! - Building Surface Name
,
,                                         ! - Outside Boundary
Condition Object
,
,                                         ! - View Factor to Ground
,
,                                         ! - Frame and Divider Name
,
,                                         ! - Multiplier
,
,                                         ! - Number of Vertices
23.1619451669304 , 56.4163649122215 , 2.7999999996738 , ! - X,Y,Z
    Vertex 1 {m}
23.1619451669251 , 56.4163649122072 , 0.79999999967376 , ! - X,Y,Z
    Vertex 2 {m}
23.1619451669251 , 57.147614912205 , 0.79999999962144 , ! - X,Y,Z
    Vertex 3 {m}
23.1619451669304 , 57.1476149122193 , 2.7999999996214 ; ! - X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed ,
Room_27_0080b418..Face0_Glz1 ,                 ! - Name
Window ,                                         ! - Surface Type
project_window ,                                ! - Construction Name

```

```

Room_27_0080b418..Face0,
                           !- Building Surface Name
,
                           !- Outside Boundary

Condition Object

,
                           !- View Factor to Ground
,
                           !- Frame and Divider Name
,
                           !- Multiplier
,
                           !- Number of Vertices

23.1619451669304, 59.4163649122128, 2.79999999994591, !- X,Y,Z
Vertex 1 {m}
23.1619451669251, 59.4163649121985, 0.799999999945913, !- X,Y,Z
Vertex 2 {m}
23.1619451669251, 60.1476149121963, 0.799999999940681, !- X,Y,Z
Vertex 3 {m}
23.1619451669304, 60.1476149122106, 2.79999999994068; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_27_0080b418..Face0_Glz2,                                !- Name
Window,                                                 !- Surface Type
project_window,                                         !- Construction Name
Room_27_0080b418..Face0,                                !- Building Surface Name
,
                           !- Outside Boundary

Condition Object

,
                           !- View Factor to Ground
,
                           !- Frame and Divider Name
,
                           !- Multiplier
,
                           !- Number of Vertices

23.1619451669304, 62.4163649122041, 2.79999999992445, !- X,Y,Z
Vertex 1 {m}
23.1619451669251, 62.4163649121897, 0.799999999924449, !- X,Y,Z
Vertex 2 {m}
23.1619451669251, 63.1476149121876, 0.799999999919217, !- X,Y,Z
Vertex 3 {m}
23.1619451669304, 63.1476149122019, 2.79999999991922; !- X,Y,Z
Vertex 4 {m}

```

```

FenestrationSurface:Detailed,
Room_27_0080b418..Face0_Glz3,           !- Name
Window,                                  !- Surface Type
project_window,                          !- Construction Name
Room_27_0080b418..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
23.1619451669304, 65.4163649121953, 2.79999999990298, !- X,Y,Z
Vertex 1 {m}
23.1619451669251, 65.416364912181, 0.799999999902985, !- X,Y,Z
Vertex 2 {m}
23.1619451669251, 66.1476149121789, 0.799999999897753, !- X,Y,Z
Vertex 3 {m}
23.1619451669304, 66.1476149121932, 2.79999999989775; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed,
Room_27_0080b418..Face0_Glz4,           !- Name
Window,                                  !- Surface Type
project_window,                          !- Construction Name
Room_27_0080b418..Face0,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
23.1619451669304, 68.4163649121866, 2.79999999988152, !- X,Y,Z
Vertex 1 {m}
23.1619451669251, 68.4163649121723, 0.799999999881521, !- X,Y,Z
Vertex 2 {m}

```

```

23.1619451669251, 69.1476149121702, 0.79999999987629, !- X,Y,Z
    Vertex 3 {m}

23.1619451669304, 69.1476149121845, 2.79999999987629; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_27_0080b418..Face1,                      !- Name
    Wall,                                            !- Surface Type
    project_wall_int,                                !- Construction Name
    Room_27_0080b418,                                !- Zone Name
    Surface,                                         !- Outside Boundary
    Condition
    Room_30_98f1d6c8..Face2,                        !- Outside Boundary
    Condition Object
    NoSun,                                           !- Sun Exposure
    NoWind,                                          !- Wind Exposure
    ,                                                 !- View Factor to Ground
    ,                                                 !- Number of Vertices
    19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
    Vertex 1 {m}
    23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 2 {m}
    23.161945166923, 70.2819899122047, -1.3182639732014e-10, !- X,Y,Z
    Vertex 3 {m}
    19.8286118335897, 65.2819899122047, -1.0132554747248e-10; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_27_0080b418..Face2,                      !- Name
    Wall,                                            !- Surface Type
    project_wall_int,                                !- Construction Name
    Room_27_0080b418,                                !- Zone Name
    Surface,                                         !- Outside Boundary
    Condition
    Room_21_4c523269..Face1,                        !- Outside Boundary
    Condition Object

```

```

NoSun ,                                     ! - Sun Exposure
NoWind ,                                     ! - Wind Exposure
,                                         ! - View Factor to Ground
,                                         ! - Number of Vertices
19.8286118335983 , 60.2819899121844 , 3.24999999993445 , !- X,Y,Z
    Vertex 1 {m}
19.8286118335983 , 65.2819899121844 , 3.24999999989868 , !- X,Y,Z
    Vertex 2 {m}
19.8286118335897 , 65.2819899122047 , -1.0132554747248e-10 , !- X,Y,Z
    Vertex 3 {m}
19.8286118335897 , 60.2819899122047 , -6.55526866515655e-11; !- X,Y,
Z Vertex 4 {m}

BuildingSurface:Detailed ,
Room_27_0080b418..Face3 ,                   ! - Name
Wall ,                                       ! - Surface Type
project_wall_int ,                          ! - Construction Name
Room_27_0080b418 ,                         ! - Zone Name
Surface ,                                    ! - Outside Boundary
    Condition
Room_16_3d8c5364..Face1 ,                   ! - Outside Boundary
    Condition Object
NoSun ,                                     ! - Sun Exposure
NoWind ,                                     ! - Wind Exposure
,                                         ! - View Factor to Ground
,                                         ! - Number of Vertices
23.1619451669316 , 55.2819899121844 , 3.24999999997549 , !- X,Y,Z
    Vertex 1 {m}
19.8286118335983 , 60.2819899121844 , 3.24999999993445 , !- X,Y,Z
    Vertex 2 {m}
19.8286118335897 , 60.2819899122047 , -6.55526866515655e-11 , !- X,Y,
Z Vertex 3 {m}
23.161945166923 , 55.2819899122047 , -2.45078148573979e-11; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,

```

```

Room_27_0080b418..Face4 , !- Name
Floor , !- Surface Type
project_slab , !- Construction Name
Room_27_0080b418 , !- Zone Name
Ground , !- Outside Boundary
Condition
,
!- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
,
!- View Factor to Ground
,
!- Number of Vertices
23.161945166923 , 70.2819899122047 , -1.3182639732014e-10 , !- X,Y,Z
Vertex 1 {m}
23.161945166923 , 55.2819899122047 , -2.45078148573979e-11 , !- X,Y,Z
Vertex 2 {m}
19.8286118335897 , 60.2819899122047 , -6.55526866515655e-11 , !- X,Y,
Z Vertex 3 {m}
19.8286118335897 , 65.2819899122047 , -1.0132554747248e-10 ; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed ,
Room_27_0080b418..Face5 , !- Name
Ceiling , !- Surface Type
project_ceiling_int , !- Construction Name
Room_27_0080b418 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_26_f4ea3797..Face4 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
,
!- View Factor to Ground
,
!- Number of Vertices
23.1619451669316 , 55.2819899121844 , 3.24999999997549 , !- X,Y,Z
Vertex 1 {m}

```

```

23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 2 {m}
19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
    Vertex 3 {m}
19.8286118335983, 60.2819899121844, 3.24999999993445; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat ,
Room_27_0080b418 Thermostat ,           !- Name
Room_27_0080b418 ,                      !- Zone or ZoneList Name
Room_27_0080b418 Thermostat Schedule , !- Control Type Schedule
Name
ThermostatSetpoint:DualSetpoint ,        !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 12,   !- Control 1 Name
,
,
,
,
,
,
,
0;                                     !- Temperature Difference

Between Cutout And Setpoint {deltaC}

Schedule:Compact ,
Room_27_0080b418 Thermostat Schedule , !- Name
Room_27_0080b418 Thermostat Schedule Type Limits , !- Schedule Type
Limits Name
Through: 12/31 ,                         !- Field 1
For: AllDays ,                           !- Field 2
Until: 24:00 ,                           !- Field 3
4;                                      !- Field 4

ScheduleTypeLimits ,
Room_27_0080b418 Thermostat Schedule Type Limits , !- Name
0,                                       !- Lower Limit Value {
BasedOnField A3}

```

```

4,                                     !- Upper Limit Value {
BasedOnField A3}

DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint,
    Thermostat Setpoint Dual Setpoint 12,      !- Name
    project_heat,                            !- Heating Setpoint
        Temperature Schedule Name
    Clg-SetP-Sch;                          !- Cooling Setpoint
        Temperature Schedule Name

ZoneHVAC:EquipmentConnections,
    Room_27_0080b418,                      !- Zone Name
    Room_27_0080b418 Equipment List,       !- Zone Conditioning
        Equipment List Name
    Room_27_0080b418 Inlet Node List,      !- Zone Air Inlet Node or
        NodeList Name
    Room_27_0080b418 Exhaust Node List,     !- Zone Air Exhaust Node
        or NodeList Name
    Room_27_0080b418 Zone Air Node,        !- Zone Air Node Name
    Room_27_0080b418 Return Node List;     !- Zone Return Air Node or
        NodeList Name

    NodeList,
        Room_27_0080b418 Inlet Node List,      !- Name
        Room_27_0080b418 Air Terminal Outlet Air Node, !- Node Name 1
        Room_27_0080b418 VRF Terminal Unit Outlet Air Node; !- Node Name 2

    NodeList,
        Room_27_0080b418 Exhaust Node List,      !- Name
        Room_27_0080b418 VRF Terminal Unit Inlet Air Node; !- Node Name 1

    NodeList,
        Room_27_0080b418 Return Node List,      !- Name
        Room_27_0080b418 Return Air Node;        !- Node Name 1

```

```

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
Room_27_0080b418 Air Terminal,           !- Name
Always On Discrete,                     !- Availability Schedule
Name
Room_27_0080b418 Air Terminal Inlet Air Node, !- Air Inlet Node
Name
Room_27_0080b418 Air Terminal Outlet Air Node, !- Air Outlet Node
Name
AutoSize;                               !- Maximum Air Flow Rate {
                                         m3/s}

ZoneHVAC:AirDistributionUnit ,
ADU Room_27_0080b418 Air Terminal,      !- Name
Room_27_0080b418 Air Terminal Outlet Air Node, !- Air Distribution
Unit Outlet Node Name
AirTerminal:SingleDuct:ConstantVolume>NoReheat , !- Air Terminal
Object Type
Room_27_0080b418 Air Terminal;        !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
Room_27_0080b418 VRF Terminal Unit,     !- Zone Terminal Unit Name
Always On Discrete,                   !- Terminal Unit
Availability Schedule
Room_27_0080b418 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name
Room_27_0080b418 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name
Autosize,                             !- Cooling Supply Air Flow
                                         Rate {m3/s}
Autosize,                             !- No Cooling Supply Air
                                         Flow Rate {m3/s}
Autosize,                             !- Heating Supply Air Flow
                                         Rate {m3/s}
Autosize,                             !- No Heating Supply Air
                                         Flow Rate {m3/s}

```

```

Autosize,                                     !- Cooling Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
  Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
  Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
  Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
  Placement

Fan:OnOff,                                    !- Supply Air Fan Object
  Type

Room_27_0080b418 VRF Unit Cycling Fan,     !- Supply Air Fan Object
  Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
  Object Type

Room_27_0080b418 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
  Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
  11, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
  Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
  11, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
  Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
  Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
  Sizing Ratio {W/W}

,                                             !- Availability Manager
  List Name

,                                             !- Design Specification
  ZoneHVAC Sizing Object Name

```

```

        ,                                     !- Supplemental Heating
    Coil Object Type
    ,                                     !- Supplemental Heating
    Coil Name
    Autosize,                                !- Maximum Supply Air
    Temperature from Supplemental Heater {C}
21;                                         !- Maximum Outdoor Dry-
    Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_27_0080b418 VRF Terminal Unit OA Mixer, !- Name
Room_27_0080b418 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
    Node Name
Room_27_0080b418 VRF Terminal Unit Outdoor Air Node, !- Outdoor
    Air Stream Node Name
Room_27_0080b418 VRF Terminal Unit Relief Node Name, !- Relief Air
    Stream Node Name
Room_27_0080b418 VRF Terminal Unit Inlet Air Node; !- Return Air
    Stream Node Name

OutdoorAir:NodeList,
Room_27_0080b418 VRF Terminal Unit Outdoor Air Node; !- Node or
    NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
11, !- Name
Always On Discrete,                         !- Availability Schedule
    Name
Autosize,                                    !- Gross Rated Total
    Cooling Capacity {W}
Autosize,                                    !- Gross Rated Sensible
    Heat Ratio
Autosize,                                    !- Rated Air Flow Rate {m3
    /s}

```

```

VRFTUCoolCapFT 11,                               ! - Cooling Capacity Ratio
  Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 11,                             ! - Cooling Capacity
  Modifier Curve Function of Flow Fraction Name
Room_27_0080b418 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
  Inlet Node
Room_27_0080b418 VRF Terminal Unit Cooling Coil Outlet Node; !-
  Coil Air Outlet Node

Curve:Biquadratic,
  VRFTUCoolCapFT 11,                           ! - Name
  0.0585884077803259,                         ! - Coefficient1 Constant
  0.0587396532718384,                         ! - Coefficient2 x
  -0.000210274979759697,                      ! - Coefficient3 x**2
  0.0109370473889647,                         ! - Coefficient4 y
  -0.0001219549,                            ! - Coefficient5 y**2
  -0.0005246615,                            ! - Coefficient6 x*y
  15,                                         ! - Minimum Value of x {
    BasedOnField A2}
  23.89,                                       ! - Maximum Value of x {
    BasedOnField A2}
  20,                                         ! - Minimum Value of y {
    BasedOnField A3}
  43.33,                                       ! - Maximum Value of y {
    BasedOnField A3}
  0.8083,                                      ! - Minimum Curve Output {
    BasedOnField A4}
  1.2583;                                     ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
  VRFACCoolCapFFF 11,                           ! - Name
  0.8,                                         ! - Coefficient1 Constant
  0.2,                                         ! - Coefficient2 x
  0,                                           ! - Coefficient3 x**2

```

```

0.5,                                     !- Minimum Value of x {
BasedOnField A2}

1.5;                                     !- Maximum Value of x {
BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
11, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                 !- Rated Air Flow Rate {m3
/s}

Room_27_0080b418 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node

Room_27_0080b418 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 11, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 11; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 11, !-
Name

0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                    !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                           !- Coefficient5 y**2
-0.0014819801,                           !- Coefficient6 x*y
21.11,                                    !- Minimum Value of x {
BasedOnField A2}

27.22,                                    !- Maximum Value of x {
BasedOnField A2}

```

```

-15,                                     ! - Minimum Value of y {
    BasedOnField A3}

18.33,                                    ! - Maximum Value of y {
    BasedOnField A3}

0.6074,                                   ! - Minimum Curve Output {
    BasedOnField A4}

1;                                         ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 11, !-
Name
0.8,                                       ! - Coefficient1 Constant
0.2,                                       ! - Coefficient2 x
0,                                           ! - Coefficient3 x**2
0.5,                                       ! - Minimum Value of x {
    BasedOnField A2}
1.5;                                       ! - Maximum Value of x {
    BasedOnField A2}

Fan:OnOff,
Room_27_0080b418 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                      ! - Availability Schedule
Name
0.6,                                       ! - Fan Total Efficiency
300,                                       ! - Pressure Rise {Pa}
Autosize,                                  ! - Maximum Flow Rate {m3/s
}
0.8,                                       ! - Motor Efficiency
1,                                           ! - Motor In Airstream
Fraction
Room_27_0080b418 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name
Room_27_0080b418 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name

```

```

Fan On Off Power Curve 11,           ! - Fan Power Ratio
Function of Speed Ratio Curve Name
Fan On Off Efficiency Curve 11,      ! - Fan Efficiency Ratio
Function of Speed Ratio Curve Name
General;                           ! - End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 11,           ! - Name
1,                                     ! - Coefficient1 Constant
0,                                     ! - Coefficient2 Constant
0,                                     ! - Coefficient3 Constant
0,                                     ! - Minimum Value of x {
    BasedOnField A2}
1;                                     ! - Maximum Value of x {
    BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 11,      ! - Name
1,                                     ! - Coefficient1 Constant
0,                                     ! - Coefficient2 x
0,                                     ! - Coefficient3 x**2
0,                                     ! - Coefficient4 x**3
0,                                     ! - Minimum Value of x {
    BasedOnField A2}
1;                                     ! - Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_27_0080b418 Equipment List,     ! - Name
SequentialLoad,                      ! - Load Distribution
Scheme
ZoneHVAC:AirDistributionUnit,        ! - Zone Equipment Object
Type 1
ADU Room_27_0080b418 Air Terminal,   ! - Zone Equipment Name 1
1,                                     ! - Zone Equipment Cooling
Sequence 1

```

```

1,                                     !- Zone Equipment Heating
  or No-Load Sequence 1
Schedule Constant 23,                  !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1
Schedule Constant 24,                  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
  Object Type 2
Room_27_0080b418 VRF Terminal Unit,      !- Zone Equipment Name 2
2,                                     !- Zone Equipment Cooling
  Sequence 2
2,                                     !- Zone Equipment Heating
  or No-Load Sequence 2
  ,
  !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
;
  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
  Room_27_0080b418,                      !- Zone or ZoneList Name
  SupplyAirTemperature,                   !- Zone Cooling Design
    Supply Air Temperature Input Method
  12.77777777777778,                   !- Zone Cooling Design
    Supply Air Temperature {C}
  11.11,                                 !- Zone Cooling Design
    Supply Air Temperature Difference {deltaC}
  SupplyAirTemperature,                   !- Zone Heating Design
    Supply Air Temperature Input Method
  40.0000000000001,                     !- Zone Heating Design
    Supply Air Temperature {C}
  11.11,                                 !- Zone Heating Design
    Supply Air Temperature Difference {deltaC}
  0.0085,                                !- Zone Cooling Design
    Supply Air Humidity Ratio {kgWater/kgDryAir}
  0.008,                                  !- Zone Heating Design
    Supply Air Humidity Ratio {kgWater/kgDryAir}

```

```

ventilation,                                     ! - Design Specification
    Outdoor Air Object Name
,
                                         ! - Zone Heating Sizing
    Factor
,
                                         ! - Zone Cooling Sizing
    Factor
DesignDay,                                     ! - Cooling Design Air Flow
    Method
0,                                            ! - Cooling Design Air Flow
    Rate {m3/s}
0.000762,                                      ! - Cooling Minimum Air
    Flow per Zone Floor Area {m3/s-m2}
0,                                            ! - Cooling Minimum Air
    Flow {m3/s}
0,                                            ! - Cooling Minimum Air
    Flow Fraction
DesignDay,                                     ! - Heating Design Air Flow
    Method
0,                                            ! - Heating Design Air Flow
    Rate {m3/s}
0.002032,                                      ! - Heating Maximum Air
    Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                     ! - Heating Maximum Air
    Flow {m3/s}
0.3,                                           ! - Heating Maximum Air
    Flow Fraction
,
                                         ! - Design Specification
Zone Air Distribution Object Name
Yes,                                          ! - Account for Dedicated
    Outdoor Air System
NeutralSupplyAir,                                ! - Dedicated Outdoor Air
    System Control Strategy
15.55555555555556,                            ! - Dedicated Outdoor Air
    Low Setpoint Temperature for Design {C}
21.111111111111;                             ! - Dedicated Outdoor Air
    High Setpoint Temperature for Design {C}

```

```

Zone ,
    Room_28_d6ed2799 ,           !- Name
    0,                            !- Direction of Relative
        North {deg}
    0,                            !- X Origin {m}
    0,                            !- Y Origin {m}
    0,                            !- Z Origin {m}
    ,                            !- Type
    1,                            !- Multiplier
    ,                            !- Ceiling Height {m}
    ,                            !- Volume {m3}
    ,                            !- Floor Area {m2}
    ,                            !- Zone Inside Convection
Algorithm
,
    Algorithm
Yes;                           !- Part of Total Floor
Area

BuildingSurface:Detailed ,
    Room_28_d6ed2799..Face0 ,      !- Name
    Wall ,                         !- Surface Type
    project_wall_int ,            !- Construction Name
    Room_28_d6ed2799 ,             !- Zone Name
    Surface ,                      !- Outside Boundary
        Condition
    Room_22_f3ee5a53..Face2 ,      !- Outside Boundary
        Condition Object
    NoSun ,                        !- Sun Exposure
    NoWind ,                       !- Wind Exposure
    ,                            !- View Factor to Ground
    ,                            !- Number of Vertices
    16.4952785002823 , 65.2819899121439 , 9.7499999989341 , !- X,Y,Z
    Vertex 1 {m}

```

```

13.1619451669489, 70.2819899121439, 9.74999999985237, !- X,Y,Z
    Vertex 2 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236, !- X,Y,Z
    Vertex 3 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_28_d6ed2799..Face1,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                     !- Construction Name
Room_28_d6ed2799,                                     !- Zone Name
Surface,                                              !- Outside Boundary
Condition
Room_19_6ae0f9a9..Face2,                               !- Outside Boundary
    Condition Object
NoSun,                                                !- Sun Exposure
NoWind,                                               !- Wind Exposure
,                                                       !- View Factor to Ground
,                                                       !- Number of Vertices
19.8286118336156, 65.2819899121439, 9.74999999989868, !- X,Y,Z
    Vertex 1 {m}
16.4952785002823, 65.2819899121439, 9.74999999989341, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
    Vertex 3 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_28_d6ed2799..Face2,                               !- Name
Wall,                                                 !- Surface Type
project_wall_int,                                     !- Construction Name
Room_28_d6ed2799,                                     !- Zone Name
Surface,                                              !- Outside Boundary
Condition

```

```

Room_25_d27e0933..Face1 , ! - Outside Boundary
  Condition Object
  NoSun , ! - Sun Exposure
  NoWind , ! - Wind Exposure
  , ! - View Factor to Ground
  , ! - Number of Vertices
  19.8286118336156 , 65.2819899121439 , 9.74999999989868 , ! - X,Y,Z
    Vertex 1 {m}
  19.8286118336069 , 65.2819899121641 , 6.49999999989867 , ! - X,Y,Z
    Vertex 2 {m}
  23.1619451669403 , 70.2819899121641 , 6.49999999986818 , ! - X,Y,Z
    Vertex 3 {m}
  23.1619451669489 , 70.2819899121439 , 9.74999999986818 ; ! - X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
  Room_28_d6ed2799..Face3 , ! - Name
  Wall , ! - Surface Type
  project_wall , ! - Construction Name
  Room_28_d6ed2799 , ! - Zone Name
  Outdoors , ! - Outside Boundary
  Condition
  , ! - Outside Boundary
  Condition Object
  SunExposed , ! - Sun Exposure
  WindExposed , ! - Wind Exposure
  , ! - View Factor to Ground
  , ! - Number of Vertices
  23.1619451669489 , 70.2819899121439 , 9.74999999986818 , ! - X,Y,Z
    Vertex 1 {m}
  23.1619451669403 , 70.2819899121641 , 6.49999999986818 , ! - X,Y,Z
    Vertex 2 {m}
  13.1619451669403 , 70.2819899121641 , 6.49999999985236 , ! - X,Y,Z
    Vertex 3 {m}
  13.1619451669489 , 70.2819899121439 , 9.74999999985237 ; ! - X,Y,Z
    Vertex 4 {m}

```

```

FenestrationSurface:Detailed,
  Room_28_d6ed2799..Face3_Glz0,           !- Name
  Window,                                !- Surface Type
  project_window,                         !- Construction Name
  Room_28_d6ed2799..Face3,                !- Building Surface Name
  ,                                       !- Outside Boundary

  Condition Object

  ,                                       !- View Factor to Ground
  ,                                       !- Frame and Divider Name
  ,                                       !- Multiplier
  ,                                       !- Number of Vertices
  21.9015285002709, 70.2819899121467, 9.29999999986618, !- X,Y,Z

  Vertex 1 {m}
  21.9015285002741, 70.2819899121592, 7.29999999986618, !- X,Y,Z

  Vertex 2 {m}
  21.0890285002752, 70.2819899121592, 7.2999999998649, !- X,Y,Z

  Vertex 3 {m}
  21.089028500272, 70.2819899121467, 9.2999999998649; !- X,Y,Z

  Vertex 4 {m}

FenestrationSurface:Detailed,
  Room_28_d6ed2799..Face3_Glz1,           !- Name
  Window,                                !- Surface Type
  project_window,                         !- Construction Name
  Room_28_d6ed2799..Face3,                !- Building Surface Name
  ,                                       !- Outside Boundary

  Condition Object

  ,                                       !- View Factor to Ground
  ,                                       !- Frame and Divider Name
  ,                                       !- Multiplier
  ,                                       !- Number of Vertices
  18.5681951669422, 70.2819899121467, 9.29999999986091, !- X,Y,Z

  Vertex 1 {m}
  18.5681951669453, 70.2819899121592, 7.29999999986091, !- X,Y,Z

  Vertex 2 {m}

```

```

17.7556951669465, 70.2819899121592, 7.29999999985962, !- X,Y,Z
    Vertex 3 {m}

17.7556951669433, 70.2819899121467, 9.29999999985963; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
Room_28_d6ed2799..Face3_Glz2,           !- Name
Window,                                  !- Surface Type
project_window,                          !- Construction Name
Room_28_d6ed2799..Face3,                !- Building Surface Name
,                                         !- Outside Boundary
Condition Object
,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
15.2348618336134, 70.2819899121467, 9.29999999985564, !- X,Y,Z
    Vertex 1 {m}

15.2348618336166, 70.2819899121592, 7.29999999985564, !- X,Y,Z
    Vertex 2 {m}

14.4223618336177, 70.2819899121592, 7.29999999985435, !- X,Y,Z
    Vertex 3 {m}

14.4223618336146, 70.2819899121467, 9.29999999985435; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_28_d6ed2799..Face4,                !- Name
Floor,                                   !- Surface Type
project_floor,                           !- Construction Name
Room_28_d6ed2799,                      !- Zone Name
Surface,                                 !- Outside Boundary
Condition
Room_29_2a634042..Face5,                !- Outside Boundary
Condition Object
NoSun,                                    !- Sun Exposure
NoWind,                                   !- Wind Exposure

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Number of Vertices
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
    Vertex 1 {m}
19.8286118336069, 65.2819899121641, 6.49999999989867, !- X,Y,Z
    Vertex 2 {m}
16.4952785002736, 65.2819899121641, 6.4999999998934, !- X,Y,Z
    Vertex 3 {m}
13.1619451669403, 70.2819899121641, 6.49999999985236; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
Room_28_d6ed2799..Face5,                               !- Name
Roof,                                                 !- Surface Type
project_roof,                                         !- Construction Name
Room_28_d6ed2799,                                     !- Zone Name
Outdoors,                                              !- Outside Boundary
Condition
,
                                         !- Outside Boundary
Condition Object
SunExposed,                                            !- Sun Exposure
WindExposed,                                           !- Wind Exposure
,
                                         !- View Factor to Ground
,
                                         !- Number of Vertices
19.8286118336156, 65.2819899121439, 9.74999999989868, !- X,Y,Z
    Vertex 1 {m}
23.1619451669489, 70.2819899121439, 9.74999999986818, !- X,Y,Z
    Vertex 2 {m}
13.1619451669489, 70.2819899121439, 9.74999999985237, !- X,Y,Z
    Vertex 3 {m}
16.4952785002823, 65.2819899121439, 9.74999999989341; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat,
Room_28_d6ed2799 Thermostat,                         !- Name
Room_28_d6ed2799,                                     !- Zone or ZoneList Name

```

```

Room_28_d6ed2799 Thermostat Schedule,      !- Control Type Schedule
Name

ThermostatSetpoint:DualSetpoint,           !- Control 1 Object Type
Thermostat Setpoint Dual Setpoint 13,      !- Control 1 Name
,
!- Control 2 Object Type
,
!- Control 2 Name
,
!- Control 3 Object Type
,
!- Control 3 Name
,
!- Control 4 Object Type
,
!- Control 4 Name
0;                                         !- Temperature Difference

Between Cutout And Setpoint {deltaC}

Schedule:Compact,
Room_28_d6ed2799 Thermostat Schedule,      !- Name
Room_28_d6ed2799 Thermostat Schedule Type Limits, !- Schedule Type
Limits Name
Through: 12/31,                            !- Field 1
For: AllDays,                             !- Field 2
Until: 24:00,                             !- Field 3
4;                                         !- Field 4

ScheduleTypeLimits,
Room_28_d6ed2799 Thermostat Schedule Type Limits, !- Name
0,                                         !- Lower Limit Value {
BasedOnField A3}
4,                                         !- Upper Limit Value {
BasedOnField A3}
DISCRETE;                                    !- Numeric Type

ThermostatSetpoint:DualSetpoint,
Thermostat Setpoint Dual Setpoint 13,      !- Name
project_heat,                           !- Heating Setpoint
Temperature Schedule Name
Clg-SetP-Sch;                           !- Cooling Setpoint
Temperature Schedule Name

```

```

ZoneHVAC:EquipmentConnections ,
  Room_28_d6ed2799 ,           !- Zone Name
  Room_28_d6ed2799 Equipment List ,      !- Zone Conditioning
    Equipment List Name
  Room_28_d6ed2799 Inlet Node List ,     !- Zone Air Inlet Node or
    NodeList Name
  Room_28_d6ed2799 Exhaust Node List ,   !- Zone Air Exhaust Node
    or NodeList Name
  Room_28_d6ed2799 Zone Air Node ,       !- Zone Air Node Name
  Room_28_d6ed2799 Return Node List;    !- Zone Return Air Node or
    NodeList Name

 NodeList ,
  Room_28_d6ed2799 Inlet Node List ,      !- Name
  Room_28_d6ed2799 Air Terminal Outlet Air Node , !- Node Name 1
  Room_28_d6ed2799 VRF Terminal Unit Outlet Air Node; !- Node Name 2

 NodeList ,
  Room_28_d6ed2799 Exhaust Node List ,     !- Name
  Room_28_d6ed2799 VRF Terminal Unit Inlet Air Node; !- Node Name 1

 NodeList ,
  Room_28_d6ed2799 Return Node List ,      !- Name
  Room_28_d6ed2799 Return Air Node;        !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
  Room_28_d6ed2799 Air Terminal ,          !- Name
  Always On Discrete ,                    !- Availability Schedule
    Name
  Room_28_d6ed2799 Air Terminal Inlet Air Node , !- Air Inlet Node
    Name
  Room_28_d6ed2799 Air Terminal Outlet Air Node , !- Air Outlet Node
    Name
  AutoSize;                            !- Maximum Air Flow Rate {
    m3/s}

```

```

ZoneHVAC:AirDistributionUnit ,
    ADU Room_28_d6ed2799 Air Terminal,           !- Name
    Room_28_d6ed2799 Air Terminal Outlet Air Node, !- Air Distribution
        Unit Outlet Node Name
    AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
        Object Type
    Room_28_d6ed2799 Air Terminal;             !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
    Room_28_d6ed2799 VRF Terminal Unit,         !- Zone Terminal Unit Name
    Always On Discrete,                         !- Terminal Unit
        Availability Schedule
    Room_28_d6ed2799 VRF Terminal Unit Inlet Air Node, !- Terminal
        Unit Air Inlet Node Name
    Room_28_d6ed2799 VRF Terminal Unit Outlet Air Node, !- Terminal
        Unit Air Outlet Node Name
    Autosize,                                !- Cooling Supply Air Flow
        Rate {m3/s}
    Autosize,                                !- No Cooling Supply Air
        Flow Rate {m3/s}
    Autosize,                                !- Heating Supply Air Flow
        Rate {m3/s}
    Autosize,                                !- No Heating Supply Air
        Flow Rate {m3/s}
    Autosize,                                !- Cooling Outdoor Air
        Flow Rate {m3/s}
    Autosize,                                !- Heating Outdoor Air
        Flow Rate {m3/s}
    Autosize,                                !- No Load Outdoor Air
        Flow Rate {m3/s}
    Always Off Discrete,                      !- Supply Air Fan
        Operating Mode Schedule Name
    DrawThrough,                             !- Supply Air Fan
        Placement

```

```

Fan:OnOff ,                                     !- Supply Air Fan Object
  Type
Room_28_d6ed2799 VRF Unit Cycling Fan ,      !- Supply Air Fan Object
  Name
OutdoorAir:Mixer ,                           !- Outside Air Mixer
  Object Type
Room_28_d6ed2799 VRF Terminal Unit OA Mixer , !- Outside Air Mixer
  Object Name
Coil:Cooling:DX:VariableRefrigerantFlow ,   !- Cooling Coil Object
  Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
  12 , !- Cooling Coil Object Name
Coil:Heating:DX:VariableRefrigerantFlow ,   !- Heating Coil Object
  Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
  12 , !- Heating Coil Object Name
30 ,                                         !- Zone Terminal Unit On
  Parasitic Electric Energy Use {W}
20 ,                                         !- Zone Terminal Unit Off
  Parasitic Electric Energy Use {W}
1 ,                                           !- Rated Heating Capacity
  Sizing Ratio {W/W}
,                                              !- Availability Manager
  List Name
,                                              !- Design Specification
  ZoneHVAC Sizing Object Name
,                                              !- Supplemental Heating
  Coil Object Type
,                                              !- Supplemental Heating
  Coil Name
Autosize ,                                    !- Maximum Supply Air
  Temperature from Supplemental Heater {C}
21;                                         !- Maximum Outdoor Dry-
  Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer ,

```

```

Room_28_d6ed2799 VRF Terminal Unit OA Mixer, !- Name
Room_28_d6ed2799 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
    Node Name
Room_28_d6ed2799 VRF Terminal Unit Outdoor Air Node, !- Outdoor
    Air Stream Node Name
Room_28_d6ed2799 VRF Terminal Unit Relief Node Name, !- Relief Air
    Stream Node Name
Room_28_d6ed2799 VRF Terminal Unit Inlet Air Node; !- Return Air
    Stream Node Name

OutdoorAir:NodeList,
Room_28_d6ed2799 VRF Terminal Unit Outdoor Air Node; !- Node or
    NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
12, !- Name
Always On Discrete, !- Availability Schedule
Name
Autosize, !- Gross Rated Total
    Cooling Capacity {W}
Autosize, !- Gross Rated Sensible
    Heat Ratio
Autosize, !- Rated Air Flow Rate {m3
    /s}
VRFTUCoolCapFT 12, !- Cooling Capacity Ratio
    Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 12, !- Cooling Capacity
    Modifier Curve Function of Flow Fraction Name
Room_28_d6ed2799 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
    Inlet Node
Room_28_d6ed2799 VRF Terminal Unit Cooling Coil Outlet Node; !-
    Coil Air Outlet Node

Curve:Biquadratic ,
VRFTUCoolCapFT 12, !- Name

```

```

0.0585884077803259 ,                               ! - Coefficient1 Constant
0.0587396532718384 ,                               ! - Coefficient2 x
-0.000210274979759697 ,                           ! - Coefficient3 x**2
0.0109370473889647 ,                               ! - Coefficient4 y
-0.0001219549 ,                                   ! - Coefficient5 y**2
-0.0005246615 ,                                   ! - Coefficient6 x*y
15 ,                                              ! - Minimum Value of x {
    BasedOnField A2}
23.89 ,                                         ! - Maximum Value of x {
    BasedOnField A2}
20 ,                                              ! - Minimum Value of y {
    BasedOnField A3}
43.33 ,                                         ! - Maximum Value of y {
    BasedOnField A3}
0.8083 ,                                         ! - Minimum Curve Output {
    BasedOnField A4}
1.2583;                                         ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
VRFACCCoolCapFFF 12 ,                            ! - Name
0.8 ,                                            ! - Coefficient1 Constant
0.2 ,                                            ! - Coefficient2 x
0 ,                                              ! - Coefficient3 x**2
0.5 ,                                            ! - Minimum Value of x {
    BasedOnField A2}
1.5;                                             ! - Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
12 , !- Name
Always On Discrete ,                             ! - Availability Schedule
Autosize ,                                       ! - Gross Rated Heating
Capacity {W}

```

```

Autosize,                                     !- Rated Air Flow Rate {m3
/s}

Room_28_d6ed2799 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node

Room_28_d6ed2799 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 12, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 12; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 12, !-
Name
0.375443994956127,                         !- Coefficient1 Constant
0.0668190645147821,                         !- Coefficient2 x
-0.00194171026482001,                       !- Coefficient3 x**2
0.0442618420640187,                         !- Coefficient4 y
-0.0004009578,                             !- Coefficient5 y**2
-0.0014819801,                             !- Coefficient6 x*y
21.11,                                      !- Minimum Value of x {
BasedOnField A2}
27.22,                                      !- Maximum Value of x {
BasedOnField A2}
-15,                                         !- Minimum Value of y {
BasedOnField A3}
18.33,                                       !- Maximum Value of y {
BasedOnField A3}
0.6074,                                      !- Minimum Curve Output {
BasedOnField A4}
1;                                            !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic,

```

```

Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 12, !-
  Name
  0.8,                               !- Coefficient1 Constant
  0.2,                               !- Coefficient2 x
  0,                                 !- Coefficient3 x**2
  0.5,                               !- Minimum Value of x {
    BasedOnField A2}
  1.5;                               !- Maximum Value of x {
    BasedOnField A2}

Fan:OnOff,
  Room_28_d6ed2799 VRF Unit Cycling Fan,      !- Name
  Always On Discrete,                      !- Availability Schedule
    Name
    0.6,                                !- Fan Total Efficiency
    300,                                !- Pressure Rise {Pa}
    Autosize,                            !- Maximum Flow Rate {m3/s
    }
    0.8,                                !- Motor Efficiency
    1,                                   !- Motor In Airstream
    Fraction
  Room_28_d6ed2799 VRF Terminal Unit Heating Coil Outlet Node, !-
    Air Inlet Node Name
  Room_28_d6ed2799 VRF Terminal Unit Outlet Air Node, !- Air Outlet
    Node Name
  Fan On Off Power Curve 12,                !- Fan Power Ratio
    Function of Speed Ratio Curve Name
  Fan On Off Efficiency Curve 12,           !- Fan Efficiency Ratio
    Function of Speed Ratio Curve Name
  General;                               !- End-Use Subcategory

Curve:Exponent,
  Fan On Off Power Curve 12,              !- Name
  1,                                     !- Coefficient1 Constant
  0,                                     !- Coefficient2 Constant
  0,                                     !- Coefficient3 Constant

```

```

0,                                     !- Minimum Value of x {
    BasedOnField A2}

1;                                     !- Maximum Value of x {
    BasedOnField A2}

Curve:Cubic,
    Fan On Off Efficiency Curve 12,      !- Name
    1,                                     !- Coefficient1 Constant
    0,                                     !- Coefficient2 x
    0,                                     !- Coefficient3 x**2
    0,                                     !- Coefficient4 x**3
    0,                                     !- Minimum Value of x {
        BasedOnField A2}
1;                                     !- Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList,
    Room_28_d6ed2799 Equipment List,      !- Name
    SequentialLoad,                      !- Load Distribution
    Scheme
    ZoneHVAC:AirDistributionUnit,         !- Zone Equipment Object
    Type 1
    ADU Room_28_d6ed2799 Air Terminal,   !- Zone Equipment Name 1
    1,                                     !- Zone Equipment Cooling
    Sequence 1                           !- Zone Equipment Heating
    1,                                     !- Zone Equipment Heating
    or No-Load Sequence 1
    Schedule Constant 25,                 !- Zone Equipment
    Sequential Cooling Fraction Schedule Name 1
    Schedule Constant 26,                 !- Zone Equipment
    Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
Object Type 2
Room_28_d6ed2799 VRF Terminal Unit,       !- Zone Equipment Name 2
2,                                         !- Zone Equipment Cooling
Sequence 2

```

```

2,                                     !- Zone Equipment Heating
  or No-Load Sequence 2
,
                                     !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
;
                                     !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
Room_28_d6ed2799,                  !- Zone or ZoneList Name
SupplyAirTemperature,                !- Zone Cooling Design
  Supply Air Temperature Input Method
12.77777777777778,                 !- Zone Cooling Design
  Supply Air Temperature {C}
11.11,                                !- Zone Cooling Design
  Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,                !- Zone Heating Design
  Supply Air Temperature Input Method
40.0000000000001,                   !- Zone Heating Design
  Supply Air Temperature {C}
11.11,                                !- Zone Heating Design
  Supply Air Temperature Difference {deltaC}
0.0085,                               !- Zone Cooling Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                !- Zone Heating Design
  Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                           !- Design Specification
  Outdoor Air Object Name
,
                                     !- Zone Heating Sizing
  Factor
,
                                     !- Zone Cooling Sizing
  Factor
DesignDay,                            !- Cooling Design Air Flow
  Method
0,                                    !- Cooling Design Air Flow
  Rate {m3/s}

```

```

0.000762,                                     ! - Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                         ! - Cooling Minimum Air
Flow {m3/s}
0,                                         ! - Cooling Minimum Air
Flow Fraction
DesignDay,                                     ! - Heating Design Air Flow
Method
0,                                         ! - Heating Design Air Flow
Rate {m3/s}
0.002032,                                     ! - Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                     ! - Heating Maximum Air
Flow {m3/s}
0.3,                                         ! - Heating Maximum Air
Flow Fraction
,
! - Design Specification
Zone Air Distribution Object Name
Yes,                                         ! - Account for Dedicated
Outdoor Air System
NeutralSupplyAir,                                ! - Dedicated Outdoor Air
System Control Strategy
15.55555555555556,                            ! - Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}
21.1111111111111;                            ! - Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_29_2a634042,                            ! - Name
0,                                         ! - Direction of Relative
North {deg}
0,                                         ! - X Origin {m}
0,                                         ! - Y Origin {m}
0,                                         ! - Z Origin {m}
,
! - Type
1,                                         ! - Multiplier

```

```

,
!- Ceiling Height {m}
,
!- Volume {m3}
,
!- Floor Area {m2}
,
!- Zone Inside Convection

Algorithm
,
!- Zone Outside Convection

Algorithm
Yes; !- Part of Total Floor
Area

BuildingSurface:Detailed,
Room_29_2a634042..Face0, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name
Room_29_2a634042, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_23_e751e71f..Face2, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
,
!- View Factor to Ground
,
!- Number of Vertices
16.4952785002736, 65.2819899121641, 6.499999998934, !- X,Y,Z
Vertex 1 {m}
13.1619451669403, 70.2819899121641, 6.4999999985236, !- X,Y,Z
Vertex 2 {m}
13.1619451669316, 70.2819899121844, 3.2499999985236, !- X,Y,Z
Vertex 3 {m}
16.495278500265, 65.2819899121844, 3.249999998934; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_29_2a634042..Face1, !- Name
Wall, !- Surface Type
project_wall_int, !- Construction Name

```

```

Room_29_2a634042 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_20_4d060559..Face2 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118336069 , 65.2819899121641 , 6.49999999989867 , !- X,Y,Z
Vertex 1 {m}
16.4952785002736 , 65.2819899121641 , 6.4999999998934 , !- X,Y,Z
Vertex 2 {m}
16.495278500265 , 65.2819899121844 , 3.2499999998934 , !- X,Y,Z
Vertex 3 {m}
19.8286118335983 , 65.2819899121844 , 3.24999999989868 ; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed ,
Room_29_2a634042..Face2 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_29_2a634042 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_26_f4ea3797..Face1 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118336069 , 65.2819899121641 , 6.49999999989867 , !- X,Y,Z
Vertex 1 {m}
19.8286118335983 , 65.2819899121844 , 3.24999999989868 , !- X,Y,Z
Vertex 2 {m}

```

```

23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 3 {m}

23.1619451669403, 70.2819899121641, 6.49999999986818; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed,
    Room_29_2a634042..Face3,                      !- Name
    Wall,                                            !- Surface Type
    project_wall,                                     !- Construction Name
    Room_29_2a634042,                                !- Zone Name
    Outdoors,                                         !- Outside Boundary
    Condition
    ,
    !- Outside Boundary
    Condition Object
    SunExposed,                                       !- Sun Exposure
    WindExposed,                                      !- Wind Exposure
    ,
    !- View Factor to Ground
    ,
    !- Number of Vertices
23.1619451669403, 70.2819899121641, 6.49999999986818, !- X,Y,Z
    Vertex 1 {m}

23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 2 {m}

13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
    Vertex 3 {m}

13.1619451669403, 70.2819899121641, 6.49999999985236; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_29_2a634042..Face3_Glz0,                  !- Name
    Window,                                           !- Surface Type
    project_window,                                    !- Construction Name
    Room_29_2a634042..Face3,                        !- Building Surface Name
    ,
    !- Outside Boundary
    Condition Object
    ,
    !- View Factor to Ground
    ,
    !- Frame and Divider Name

```

```

        ,                                     !- Multiplier
        ,                                     !- Number of Vertices
21.9015285002623, 70.2819899121669, 6.04999999986618, !- X,Y,Z
    Vertex 1 {m}
21.9015285002654, 70.2819899121794, 4.04999999986618, !- X,Y,Z
    Vertex 2 {m}
21.0890285002666, 70.2819899121794, 4.04999999986489, !- X,Y,Z
    Vertex 3 {m}
21.0890285002634, 70.2819899121669, 6.04999999986489; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_29_2a634042..Face3_Glz1,           !- Name
    Window,                                 !- Surface Type
    project_window,                         !- Construction Name
    Room_29_2a634042..Face3,                !- Building Surface Name
    ,                                       !- Outside Boundary
    Condition Object
    ,                                         !- View Factor to Ground
    ,                                         !- Frame and Divider Name
    ,                                         !- Multiplier
    ,                                         !- Number of Vertices
18.5681951669335, 70.2819899121669, 6.04999999986091, !- X,Y,Z
    Vertex 1 {m}
18.5681951669367, 70.2819899121794, 4.04999999986091, !- X,Y,Z
    Vertex 2 {m}
17.7556951669378, 70.2819899121794, 4.04999999985962, !- X,Y,Z
    Vertex 3 {m}
17.7556951669347, 70.2819899121669, 6.04999999985962; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_29_2a634042..Face3_Glz2,           !- Name
    Window,                                 !- Surface Type
    project_window,                         !- Construction Name
    Room_29_2a634042..Face3,                !- Building Surface Name

```

```

,
!- Outside Boundary

Condition Object

,
!- View Factor to Ground

,
!- Frame and Divider Name

,
!- Multiplier

,
!- Number of Vertices

15.2348618336048, 70.2819899121669, 6.04999999985564, !- X,Y,Z

Vertex 1 {m}

15.234861833608, 70.2819899121794, 4.04999999985564, !- X,Y,Z

Vertex 2 {m}

14.4223618336091, 70.2819899121794, 4.04999999985435, !- X,Y,Z

Vertex 3 {m}

14.4223618336059, 70.2819899121669, 6.04999999985435; !- X,Y,Z

Vertex 4 {m}

BuildingSurface:Detailed,

Room_29_2a634042..Face4, !- Name

Floor, !- Surface Type

project_floor, !- Construction Name

Room_29_2a634042, !- Zone Name

Surface, !- Outside Boundary

Condition

Room_30_98f1d6c8..Face5, !- Outside Boundary

Condition Object

NoSun, !- Sun Exposure

NoWind, !- Wind Exposure

,
!- View Factor to Ground

,
!- Number of Vertices

23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z

Vertex 1 {m}

19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z

Vertex 2 {m}

16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z

Vertex 3 {m}

13.1619451669316, 70.2819899121844, 3.24999999985236; !- X,Y,Z

Vertex 4 {m}

```

```

BuildingSurface:Detailed,
  Room_29_2a634042..Face5,                               !- Name
  Ceiling,                                                 !- Surface Type
  project_ceiling_int,                                   !- Construction Name
  Room_29_2a634042,                                     !- Zone Name
  Surface,                                                !- Outside Boundary
  Condition
    Room_28_d6ed2799..Face4,                             !- Outside Boundary
    Condition Object
      NoSun,                                              !- Sun Exposure
      NoWind,                                             !- Wind Exposure
      ,                                                    !- View Factor to Ground
      ,                                                    !- Number of Vertices
      19.8286118336069, 65.2819899121641, 6.4999999989867, !- X,Y,Z
      Vertex 1 {m}
      23.1619451669403, 70.2819899121641, 6.4999999986818, !- X,Y,Z
      Vertex 2 {m}
      13.1619451669403, 70.2819899121641, 6.4999999985236, !- X,Y,Z
      Vertex 3 {m}
      16.4952785002736, 65.2819899121641, 6.499999998934; !- X,Y,Z
      Vertex 4 {m}

ZoneControl:Thermostat,
  Room_29_2a634042 Thermostat,                         !- Name
  Room_29_2a634042,                                    !- Zone or ZoneList Name
  Room_29_2a634042 Thermostat Schedule,                !- Control Type Schedule
  Name
  ThermostatSetpoint:DualSetpoint,                      !- Control 1 Object Type
  Thermostat Setpoint Dual Setpoint 14,                 !- Control 1 Name
  ,                                                       !- Control 2 Object Type
  ,                                                       !- Control 2 Name
  ,                                                       !- Control 3 Object Type
  ,                                                       !- Control 3 Name
  ,                                                       !- Control 4 Object Type
  ,                                                       !- Control 4 Name

```

```

0;                                     !- Temperature Difference
    Between Cutout And Setpoint {deltaC}

Schedule:Compact,
    Room_29_2a634042 Thermostat Schedule,      !- Name
    Room_29_2a634042 Thermostat Schedule Type Limits, !- Schedule Type
        Limits Name
    Through: 12/31,                           !- Field 1
    For: AllDays,                            !- Field 2
    Until: 24:00,                            !- Field 3
    4;                                      !- Field 4

ScheduleTypeLimits,
    Room_29_2a634042 Thermostat Schedule Type Limits, !- Name
    0,                                         !- Lower Limit Value {
        BasedOnField A3}
    4,                                         !- Upper Limit Value {
        BasedOnField A3}
    DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint,
    Thermostat Setpoint Dual Setpoint 14,      !- Name
    project_heat,                            !- Heating Setpoint
        Temperature Schedule Name
    Clg-SetP-Sch;                            !- Cooling Setpoint
        Temperature Schedule Name

ZoneHVAC:EquipmentConnections,
    Room_29_2a634042,                        !- Zone Name
    Room_29_2a634042 Equipment List,         !- Zone Conditioning
        Equipment List Name
    Room_29_2a634042 Inlet Node List,       !- Zone Air Inlet Node or
        NodeList Name
    Room_29_2a634042 Exhaust Node List,     !- Zone Air Exhaust Node
        or NodeList Name
    Room_29_2a634042 Zone Air Node,         !- Zone Air Node Name

```

```

Room_29_2a634042 Return Node List;           !- Zone Return Air Node or
    NodeList Name

NodeList,
    Room_29_2a634042 Inlet Node List,         !- Name
    Room_29_2a634042 Air Terminal Outlet Air Node, !- Node Name 1
    Room_29_2a634042 VRF Terminal Unit Outlet Air Node; !- Node Name 2

NodeList,
    Room_29_2a634042 Exhaust Node List,        !- Name
    Room_29_2a634042 VRF Terminal Unit Inlet Air Node; !- Node Name 1

NodeList,
    Room_29_2a634042 Return Node List,         !- Name
    Room_29_2a634042 Return Air Node;          !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat,
    Room_29_2a634042 Air Terminal,             !- Name
    Always On Discrete,                      !- Availability Schedule
        Name
    Room_29_2a634042 Air Terminal Inlet Air Node, !- Air Inlet Node
        Name
    Room_29_2a634042 Air Terminal Outlet Air Node, !- Air Outlet Node
        Name
    AutoSize;                                !- Maximum Air Flow Rate {
        m3/s}

ZoneHVAC:AirDistributionUnit,
    ADU Room_29_2a634042 Air Terminal,        !- Name
    Room_29_2a634042 Air Terminal Outlet Air Node, !- Air Distribution
        Unit Outlet Node Name
    AirTerminal:SingleDuct:ConstantVolume>NoReheat, !- Air Terminal
        Object Type
    Room_29_2a634042 Air Terminal;           !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow,

```

```

Room_29_2a634042 VRF Terminal Unit,      !- Zone Terminal Unit Name
Always On Discrete,                      !- Terminal Unit

Availability Schedule

Room_29_2a634042 VRF Terminal Unit Inlet Air Node, !- Terminal
Unit Air Inlet Node Name

Room_29_2a634042 VRF Terminal Unit Outlet Air Node, !- Terminal
Unit Air Outlet Node Name

Autosize,                                !- Cooling Supply Air Flow
    Rate {m3/s}

Autosize,                                !- No Cooling Supply Air
    Flow Rate {m3/s}

Autosize,                                !- Heating Supply Air Flow
    Rate {m3/s}

Autosize,                                !- No Heating Supply Air
    Flow Rate {m3/s}

Autosize,                                !- Cooling Outdoor Air
    Flow Rate {m3/s}

Autosize,                                !- Heating Outdoor Air
    Flow Rate {m3/s}

Autosize,                                !- No Load Outdoor Air
    Flow Rate {m3/s}

Always Off Discrete,                     !- Supply Air Fan
    Operating Mode Schedule Name

DrawThrough,                             !- Supply Air Fan
    Placement

Fan:OnOff,                               !- Supply Air Fan Object
    Type

Room_29_2a634042 VRF Unit Cycling Fan,   !- Supply Air Fan Object
Name

OutdoorAir:Mixer,                        !- Outside Air Mixer
    Object Type

Room_29_2a634042 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
Object Name

Coil:Cooling:DX:VariableRefrigerantFlow, !- Cooling Coil Object
Type

```

```

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
13, !- Cooling Coil Object Name
Coil:Heating:DX:VariableRefrigerantFlow, !- Heating Coil Object
Type
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
13, !- Heating Coil Object Name
30,                                     !- Zone Terminal Unit On
    Parasitic Electric Energy Use {W}
20,                                     !- Zone Terminal Unit Off
    Parasitic Electric Energy Use {W}
1,                                         !- Rated Heating Capacity
    Sizing Ratio {W/W}
,
                                         !- Availability Manager
List Name
,
                                         !- Design Specification
ZoneHVAC Sizing Object Name
,
                                         !- Supplemental Heating
Coil Object Type
,
                                         !- Supplemental Heating
Coil Name
Autosize,                               !- Maximum Supply Air
    Temperature from Supplemental Heater {C}
21;                                     !- Maximum Outdoor Dry-
    Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
    Room_29_2a634042 VRF Terminal Unit OA Mixer, !- Name
    Room_29_2a634042 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
    Node Name
    Room_29_2a634042 VRF Terminal Unit Outdoor Air Node, !- Outdoor
    Air Stream Node Name
    Room_29_2a634042 VRF Terminal Unit Relief Node Name, !- Relief Air
    Stream Node Name
    Room_29_2a634042 VRF Terminal Unit Inlet Air Node; !- Return Air
    Stream Node Name

```

```

OutdoorAir:NodeList ,
Room_29_2a634042 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow ,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
13, !- Name
Always On Discrete, !- Availability Schedule
Name
Autosize, !- Gross Rated Total
Cooling Capacity {W}
Autosize, !- Gross Rated Sensible
Heat Ratio
Autosize, !- Rated Air Flow Rate {m3
/s}
VRFTUCoolCapFT 13, !- Cooling Capacity Ratio
Modifier Function of Temperature Curve Name
VRFACCoolCapFFF 13, !- Cooling Capacity
Modifier Curve Function of Flow Fraction Name
Room_29_2a634042 VRF Terminal Unit Mixer Outlet Node, !- Coil Air
Inlet Node
Room_29_2a634042 VRF Terminal Unit Cooling Coil Outlet Node; !-
Coil Air Outlet Node

Curve:Biquadratic ,
VRFTUCoolCapFT 13, !- Name
0.0585884077803259, !- Coefficient1 Constant
0.0587396532718384, !- Coefficient2 x
-0.000210274979759697, !- Coefficient3 x**2
0.0109370473889647, !- Coefficient4 y
-0.0001219549, !- Coefficient5 y**2
-0.0005246615, !- Coefficient6 x*y
15, !- Minimum Value of x {
BasedOnField A2}
23.89, !- Maximum Value of x {
BasedOnField A2}

```

```

20,                                     !- Minimum Value of y {
    BasedOnField A3}

43.33,                                    !- Maximum Value of y {
    BasedOnField A3}

0.8083,                                   !- Minimum Curve Output {
    BasedOnField A4}

1.2583;                                    !- Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic,
    VRFACCCoolCapFFF 13,                  !- Name
    0.8,                                     !- Coefficient1 Constant
    0.2,                                     !- Coefficient2 x
    0,                                         !- Coefficient3 x**2
    0.5,                                     !- Minimum Value of x {
        BasedOnField A2}

1.5;                                       !- Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
    Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
    13, !- Name
    Always On Discrete,                      !- Availability Schedule
    Autosize,                                !- Gross Rated Heating
    Capacity {W}
    Autosize,                               !- Rated Air Flow Rate {m3
    /s}

Room_29_2a634042 VRF Terminal Unit Cooling Coil Outlet Node, !-
    Coil Air Inlet Node

Room_29_2a634042 VRF Terminal Unit Heating Coil Outlet Node, !-
    Coil Air Outlet Node

Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 13, !-
    Heating Capacity Ratio Modifier Function of Temperature Curve
    Name

Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 13; !-
    Heating Capacity Modifier Function of Flow Fraction Curve Name

```

```

Curve:Biquadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 13, !-
Name
0.375443994956127,                               !- Coefficient1 Constant
0.0668190645147821,                             !- Coefficient2 x
-0.00194171026482001,                           !- Coefficient3 x**2
0.0442618420640187,                            !- Coefficient4 y
-0.0004009578,                                !- Coefficient5 y**2
-0.0014819801,                                !- Coefficient6 x*y
21.11,                                         !- Minimum Value of x {
BasedOnField A2}
27.22,                                         !- Maximum Value of x {
BasedOnField A2}
-15,                                            !- Minimum Value of y {
BasedOnField A3}
18.33,                                         !- Maximum Value of y {
BasedOnField A3}
0.6074,                                         !- Minimum Curve Output {
BasedOnField A4}
1;                                              !- Maximum Curve Output {
BasedOnField A4}

Curve:Quadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 13, !-
Name
0.8,                                             !- Coefficient1 Constant
0.2,                                             !- Coefficient2 x
0,                                               !- Coefficient3 x**2
0.5,                                             !- Minimum Value of x {
BasedOnField A2}
1.5;                                            !- Maximum Value of x {
BasedOnField A2}

Fan:OnOff ,
Room_29_2a634042 VRF Unit Cycling Fan,   !- Name

```

```

Always On Discrete ,                               ! - Availability Schedule
  Name
  0.6 ,                                         ! - Fan Total Efficiency
  300 ,                                         ! - Pressure Rise {Pa}
  Autosize ,                                    ! - Maximum Flow Rate {m3/s
  }
  0.8 ,                                         ! - Motor Efficiency
  1 ,                                           ! - Motor In Airstream
  Fraction
Room_29_2a634042 VRF Terminal Unit Heating Coil Outlet Node , !-
  Air Inlet Node Name
Room_29_2a634042 VRF Terminal Unit Outlet Air Node , !- Air Outlet
  Node Name
Fan On Off Power Curve 13 ,                      ! - Fan Power Ratio
  Function of Speed Ratio Curve Name
Fan On Off Efficiency Curve 13 ,                 ! - Fan Efficiency Ratio
  Function of Speed Ratio Curve Name
General ;                                       ! - End-Use Subcategory

Curve:Exponent ,
  Fan On Off Power Curve 13 ,                   ! - Name
  1 ,                                         ! - Coefficient1 Constant
  0 ,                                         ! - Coefficient2 Constant
  0 ,                                         ! - Coefficient3 Constant
  0 ,                                         ! - Minimum Value of x {
  BasedOnField A2}
  1;                                         ! - Maximum Value of x {
  BasedOnField A2}

Curve:Cubic ,
  Fan On Off Efficiency Curve 13 ,             ! - Name
  1 ,                                         ! - Coefficient1 Constant
  0 ,                                         ! - Coefficient2 x
  0 ,                                         ! - Coefficient3 x**2
  0 ,                                         ! - Coefficient4 x**3

```

```

0,                                     !- Minimum Value of x {
    BasedOnField A2}

1;                                     !- Maximum Value of x {
    BasedOnField A2}

ZoneHVAC:EquipmentList,
    Room_29_2a634042 Equipment List,      !- Name
    SequentialLoad,                      !- Load Distribution
        Scheme
    ZoneHVAC:AirDistributionUnit,         !- Zone Equipment Object
        Type 1
        ADU Room_29_2a634042 Air Terminal,   !- Zone Equipment Name 1
        1,                                     !- Zone Equipment Cooling
            Sequence 1
        1,                                     !- Zone Equipment Heating
            or No-Load Sequence 1
        Schedule Constant 27,                 !- Zone Equipment
            Sequential Cooling Fraction Schedule Name 1
        Schedule Constant 28,                 !- Zone Equipment
            Sequential Heating Fraction Schedule Name 1
    ZoneHVAC:TerminalUnit:VariableRefrigerantFlow, !- Zone Equipment
        Object Type 2
        Room_29_2a634042 VRF Terminal Unit,   !- Zone Equipment Name 2
        2,                                     !- Zone Equipment Cooling
            Sequence 2
        2,                                     !- Zone Equipment Heating
            or No-Load Sequence 2
        ,
            !- Zone Equipment
            Sequential Cooling Fraction Schedule Name 2
        ;
            !- Zone Equipment
            Sequential Heating Fraction Schedule Name 2

Sizing:Zone,
    Room_29_2a634042,                    !- Zone or ZoneList Name
    SupplyAirTemperature,                !- Zone Cooling Design
        Supply Air Temperature Input Method

```

```

12.77777777777778,           !- Zone Cooling Design
Supply Air Temperature {C}
11.11,                         !- Zone Cooling Design
Supply Air Temperature Difference {deltaC}
SupplyAirTemperature,           !- Zone Heating Design
Supply Air Temperature Input Method
40.00000000000001,            !- Zone Heating Design
Supply Air Temperature {C}
11.11,                         !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                         !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                          !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                    !- Design Specification
Outdoor Air Object Name
,                               !- Zone Heating Sizing
Factor
,                               !- Zone Cooling Sizing
Factor
DesignDay,                      !- Cooling Design Air Flow
Method
0,                             !- Cooling Design Air Flow
Rate {m3/s}
0.000762,                       !- Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                             !- Cooling Minimum Air
Flow {m3/s}
0,                             !- Cooling Minimum Air
Flow Fraction
DesignDay,                      !- Heating Design Air Flow
Method
0,                             !- Heating Design Air Flow
Rate {m3/s}
0.002032,                       !- Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}

```

```

0.1415762,                                     ! - Heating Maximum Air
Flow {m3/s}

0.3,                                         ! - Heating Maximum Air
Flow Fraction

,                                              ! - Design Specification
Zone Air Distribution Object Name

Yes,                                         ! - Account for Dedicated
Outdoor Air System

NeutralSupplyAir,                                ! - Dedicated Outdoor Air
System Control Strategy

15.55555555555556,                            ! - Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}

21.1111111111111;                            ! - Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

Zone,
Room_30_98f1d6c8,                             ! - Name
0,                                               ! - Direction of Relative
North {deg}

0,                                               ! - X Origin {m}
0,                                               ! - Y Origin {m}
0,                                               ! - Z Origin {m}
,                                                 ! - Type
1,                                               ! - Multiplier
,                                                 ! - Ceiling Height {m}
,                                                 ! - Volume {m3}
,                                                 ! - Floor Area {m2}
,                                                 ! - Zone Inside Convection
Algorithm

,                                                 ! - Zone Outside Convection
Algorithm

Yes;                                            ! - Part of Total Floor
Area

BuildingSurface:Detailed,
Room_30_98f1d6c8..Face0,                      ! - Name

```

```

Wall,                                     !- Surface Type
project_wall_int,                         !- Construction Name
Room_30_98f1d6c8,                         !- Zone Name
Surface,                                    !- Outside Boundary
Condition
Room_24_159d21b7..Face2,                  !- Outside Boundary
Condition Object
NoSun,                                      !- Sun Exposure
NoWind,                                     !- Wind Exposure
,
,                                           !- View Factor to Ground
,                                           !- Number of Vertices
16.495278500265, 65.2819899121844, 3.2499999998934, !- X,Y,Z
Vertex 1 {m}
13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
Vertex 2 {m}
13.161945166923, 70.2819899122047, -1.47642430239901e-10, !- X,Y,Z
Vertex 3 {m}
16.4952785002563, 65.2819899122047, -1.06597558445733e-10; !- X,Y,
Z Vertex 4 {m}

BuildingSurface:Detailed,
Room_30_98f1d6c8..Face1,                  !- Name
Wall,                                      !- Surface Type
project_wall_int,                         !- Construction Name
Room_30_98f1d6c8,                         !- Zone Name
Surface,                                    !- Outside Boundary
Condition
Room_21_4c523269..Face2,                  !- Outside Boundary
Condition Object
NoSun,                                      !- Sun Exposure
NoWind,                                     !- Wind Exposure
,
,                                           !- View Factor to Ground
,                                           !- Number of Vertices
19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
Vertex 1 {m}

```

```

16.495278500265 , 65.2819899121844 , 3.2499999998934 , !- X,Y,Z
    Vertex 2 {m}
16.4952785002563 , 65.2819899122047 , -1.06597558445733e-10 , !- X,Y,
    Z Vertex 3 {m}
19.8286118335897 , 65.2819899122047 , -1.0132554747248e-10; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_30_98f1d6c8..Face2 , !- Name
Wall , !- Surface Type
project_wall_int , !- Construction Name
Room_30_98f1d6c8 , !- Zone Name
Surface , !- Outside Boundary
Condition
Room_27_0080b418..Face1 , !- Outside Boundary
Condition Object
NoSun , !- Sun Exposure
NoWind , !- Wind Exposure
, !- View Factor to Ground
, !- Number of Vertices
19.8286118335983 , 65.2819899121844 , 3.24999999989868 , !- X,Y,Z
    Vertex 1 {m}
19.8286118335897 , 65.2819899122047 , -1.0132554747248e-10 , !- X,Y,Z
    Vertex 2 {m}
23.161945166923 , 70.2819899122047 , -1.3182639732014e-10 , !- X,Y,Z
    Vertex 3 {m}
23.1619451669316 , 70.2819899121844 , 3.24999999986817; !- X,Y,Z
    Vertex 4 {m}

BuildingSurface:Detailed ,
Room_30_98f1d6c8..Face3 , !- Name
Wall , !- Surface Type
project_wall , !- Construction Name
Room_30_98f1d6c8 , !- Zone Name
Outdoors , !- Outside Boundary
Condition

```

```

        ,                                         !- Outside Boundary
    Condition Object
SunExposed,                                     !- Sun Exposure
WindExposed,                                     !- Wind Exposure
,
,                                         !- View Factor to Ground
,                                         !- Number of Vertices
23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 1 {m}
23.161945166923, 70.2819899122047, -1.3182639732014e-10, !- X,Y,Z
    Vertex 2 {m}
13.161945166923, 70.2819899122047, -1.47642430239901e-10, !- X,Y,Z
    Vertex 3 {m}
13.1619451669316, 70.2819899121844, 3.24999999985236; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,
    Room_30_98f1d6c8..Face3_Glz0,           !- Name
    Window,                                 !- Surface Type
    project_window,                         !- Construction Name
    Room_30_98f1d6c8..Face3,                !- Building Surface Name
    ,
    !- Outside Boundary
    Condition Object
    ,
    !- View Factor to Ground
    ,
    !- Frame and Divider Name
    ,
    !- Multiplier
    ,
    !- Number of Vertices
21.9015285002536, 70.2819899121873, 2.79999999986618, !- X,Y,Z
    Vertex 1 {m}
21.9015285002568, 70.2819899121997, 0.79999999986618, !- X,Y,Z
    Vertex 2 {m}
21.0890285002579, 70.2819899121997, 0.799999999864895, !- X,Y,Z
    Vertex 3 {m}
21.0890285002548, 70.2819899121873, 2.7999999998649; !- X,Y,Z
    Vertex 4 {m}

FenestrationSurface:Detailed,

```

```

Room_30_98f1d6c8..Face3_Glz1 ,           !- Name
Window ,                                  !- Surface Type
project_window ,                         !- Construction Name
Room_30_98f1d6c8..Face3 ,                !- Building Surface Name
,
!- Outside Boundary

Condition Object

,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
18.5681951669249 , 70.2819899121873 , 2.79999999986091 , !- X,Y,Z
Vertex 1 {m}
18.5681951669281 , 70.2819899121997 , 0.799999999860908 , !- X,Y,Z
Vertex 2 {m}
17.7556951669292 , 70.2819899121997 , 0.799999999859623 , !- X,Y,Z
Vertex 3 {m}
17.755695166926 , 70.2819899121873 , 2.79999999985962 ; !- X,Y,Z
Vertex 4 {m}

FenestrationSurface:Detailed ,
Room_30_98f1d6c8..Face3_Glz2 ,           !- Name
Window ,                                  !- Surface Type
project_window ,                         !- Construction Name
Room_30_98f1d6c8..Face3 ,                !- Building Surface Name
,
!- Outside Boundary

Condition Object

,                                         !- View Factor to Ground
,                                         !- Frame and Divider Name
,                                         !- Multiplier
,                                         !- Number of Vertices
15.2348618335962 , 70.2819899121873 , 2.79999999985564 , !- X,Y,Z
Vertex 1 {m}
15.2348618335993 , 70.2819899121997 , 0.799999999855636 , !- X,Y,Z
Vertex 2 {m}
14.4223618336004 , 70.2819899121997 , 0.799999999854351 , !- X,Y,Z
Vertex 3 {m}

```

```

14.4223618335973, 70.2819899121873, 2.79999999985435; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_30_98f1d6c8..Face4, !- Name
Floor, !- Surface Type
project_slab, !- Construction Name
Room_30_98f1d6c8, !- Zone Name
Ground, !- Outside Boundary
Condition
,
!- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure
,
!- View Factor to Ground
,
!- Number of Vertices
23.161945166923, 70.2819899122047, -1.3182639732014e-10, !- X,Y,Z
Vertex 1 {m}
19.8286118335897, 65.2819899122047, -1.0132554747248e-10, !- X,Y,Z
Vertex 2 {m}
16.4952785002563, 65.2819899122047, -1.06597558445733e-10, !- X,Y,
Z Vertex 3 {m}
13.161945166923, 70.2819899122047, -1.47642430239901e-10; !- X,Y,Z
Vertex 4 {m}

BuildingSurface:Detailed,
Room_30_98f1d6c8..Face5, !- Name
Ceiling, !- Surface Type
project_ceiling_int, !- Construction Name
Room_30_98f1d6c8, !- Zone Name
Surface, !- Outside Boundary
Condition
Room_29_2a634042..Face4, !- Outside Boundary
Condition Object
NoSun, !- Sun Exposure
NoWind, !- Wind Exposure

```

```

        ,                                     !- View Factor to Ground
        ,                                     !- Number of Vertices
19.8286118335983, 65.2819899121844, 3.24999999989868, !- X,Y,Z
    Vertex 1 {m}
23.1619451669316, 70.2819899121844, 3.24999999986817, !- X,Y,Z
    Vertex 2 {m}
13.1619451669316, 70.2819899121844, 3.24999999985236, !- X,Y,Z
    Vertex 3 {m}
16.495278500265, 65.2819899121844, 3.2499999998934; !- X,Y,Z
    Vertex 4 {m}

ZoneControl:Thermostat,
    Room_30_98f1d6c8 Thermostat,           !- Name
    Room_30_98f1d6c8,                     !- Zone or ZoneList Name
    Room_30_98f1d6c8 Thermostat Schedule, !- Control Type Schedule
        Name
    ThermostatSetpoint:DualSetpoint,       !- Control 1 Object Type
    Thermostat Setpoint Dual Setpoint 15,   !- Control 1 Name
    ,                                     !- Control 2 Object Type
    ,                                     !- Control 2 Name
    ,                                     !- Control 3 Object Type
    ,                                     !- Control 3 Name
    ,                                     !- Control 4 Object Type
    ,                                     !- Control 4 Name
    0;                                    !- Temperature Difference
        Between Cutout And Setpoint {deltaC}

Schedule:Compact,
    Room_30_98f1d6c8 Thermostat Schedule,   !- Name
    Room_30_98f1d6c8 Thermostat Schedule Type Limits, !- Schedule Type
        Limits Name
    Through: 12/31,                         !- Field 1
    For: AllDays,                           !- Field 2
    Until: 24:00,                            !- Field 3
    4;                                     !- Field 4

```

```

ScheduleTypeLimits ,
  Room_30_98f1d6c8 Thermostat Schedule Type Limits, !- Name
    0,                                     !- Lower Limit Value {
      BasedOnField A3}
    4,                                     !- Upper Limit Value {
      BasedOnField A3}
  DISCRETE;                                !- Numeric Type

ThermostatSetpoint:DualSetpoint ,
  Thermostat Setpoint Dual Setpoint 15,     !- Name
  project_heat,                            !- Heating Setpoint
  Temperature Schedule Name
  Clg-SetP-Sch;                           !- Cooling Setpoint
  Temperature Schedule Name

ZoneHVAC:EquipmentConnections ,
  Room_30_98f1d6c8 ,                      !- Zone Name
  Room_30_98f1d6c8 Equipment List,        !- Zone Conditioning
  Equipment List Name
  Room_30_98f1d6c8 Inlet Node List,       !- Zone Air Inlet Node or
  NodeList Name
  Room_30_98f1d6c8 Exhaust Node List,     !- Zone Air Exhaust Node
  or NodeList Name
  Room_30_98f1d6c8 Zone Air Node,         !- Zone Air Node Name
  Room_30_98f1d6c8 Return Node List;      !- Zone Return Air Node or
  NodeList Name

  NodeList,
    Room_30_98f1d6c8 Inlet Node List,      !- Name
    Room_30_98f1d6c8 Air Terminal Outlet Air Node, !- Node Name 1
    Room_30_98f1d6c8 VRF Terminal Unit Outlet Air Node; !- Node Name 2

  NodeList,
    Room_30_98f1d6c8 Exhaust Node List,    !- Name
    Room_30_98f1d6c8 VRF Terminal Unit Inlet Air Node; !- Node Name 1

```

```

NodeList ,
    Room_30_98f1d6c8 Return Node List ,           !- Name
    Room_30_98f1d6c8 Return Air Node;           !- Node Name 1

AirTerminal:SingleDuct:ConstantVolume>NoReheat ,
    Room_30_98f1d6c8 Air Terminal ,             !- Name
    Always On Discrete ,                      !- Availability Schedule
        Name
    Room_30_98f1d6c8 Air Terminal Inlet Air Node , !- Air Inlet Node
        Name
    Room_30_98f1d6c8 Air Terminal Outlet Air Node , !- Air Outlet Node
        Name
    AutoSize;                                !- Maximum Air Flow Rate {
        m3/s}

ZoneHVAC:AirDistributionUnit ,
    ADU Room_30_98f1d6c8 Air Terminal ,           !- Name
    Room_30_98f1d6c8 Air Terminal Outlet Air Node , !- Air Distribution
        Unit Outlet Node Name
    AirTerminal:SingleDuct:ConstantVolume>NoReheat , !- Air Terminal
        Object Type
    Room_30_98f1d6c8 Air Terminal;            !- Air Terminal Name

ZoneHVAC:TerminalUnit:VariableRefrigerantFlow ,
    Room_30_98f1d6c8 VRF Terminal Unit ,         !- Zone Terminal Unit Name
    Always On Discrete ,                      !- Terminal Unit
        Availability Schedule
    Room_30_98f1d6c8 VRF Terminal Unit Inlet Air Node , !- Terminal
        Unit Air Inlet Node Name
    Room_30_98f1d6c8 VRF Terminal Unit Outlet Air Node , !- Terminal
        Unit Air Outlet Node Name
    Autosize ,                               !- Cooling Supply Air Flow
        Rate {m3/s}
    Autosize ,                               !- No Cooling Supply Air
        Flow Rate {m3/s}

```

```

Autosize,                                     !- Heating Supply Air Flow
    Rate {m3/s}

Autosize,                                     !- No Heating Supply Air
    Flow Rate {m3/s}

Autosize,                                     !- Cooling Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- Heating Outdoor Air
    Flow Rate {m3/s}

Autosize,                                     !- No Load Outdoor Air
    Flow Rate {m3/s}

Always Off Discrete,                         !- Supply Air Fan
    Operating Mode Schedule Name

DrawThrough,                                  !- Supply Air Fan
    Placement

Fan:OnOff,                                    !- Supply Air Fan Object
    Type

Room_30_98f1d6c8 VRF Unit Cycling Fan,     !- Supply Air Fan Object
    Name

OutdoorAir:Mixer,                            !- Outside Air Mixer
    Object Type

Room_30_98f1d6c8 VRF Terminal Unit OA Mixer, !- Outside Air Mixer
    Object Name

Coil:Cooling:DX:VariableRefrigerantFlow,   !- Cooling Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
14, !- Cooling Coil Object Name

Coil:Heating:DX:VariableRefrigerantFlow,   !- Heating Coil Object
    Type

Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
14, !- Heating Coil Object Name

30,                                         !- Zone Terminal Unit On
    Parasitic Electric Energy Use {W}

20,                                         !- Zone Terminal Unit Off
    Parasitic Electric Energy Use {W}

1,                                           !- Rated Heating Capacity
    Sizing Ratio {W/W}

```

```

        ,                                     !- Availability Manager
List Name

        ,                                     !- Design Specification
ZoneHVAC Sizing Object Name

        ,                                     !- Supplemental Heating
Coil Object Type

        ,                                     !- Supplemental Heating
Coil Name

Autosize,                                !- Maximum Supply Air
Temperature from Supplemental Heater {C}
21;                                      !- Maximum Outdoor Dry-
Bulb Temperature for Supplemental Heater Operation {C}

OutdoorAir:Mixer,
Room_30_98f1d6c8 VRF Terminal Unit OA Mixer, !- Name
Room_30_98f1d6c8 VRF Terminal Unit Mixer Outlet Node, !- Mixed Air
Node Name
Room_30_98f1d6c8 VRF Terminal Unit Outdoor Air Node, !- Outdoor
Air Stream Node Name
Room_30_98f1d6c8 VRF Terminal Unit Relief Node Name, !- Relief Air
Stream Node Name
Room_30_98f1d6c8 VRF Terminal Unit Inlet Air Node; !- Return Air
Stream Node Name

OutdoorAir:NodeList,
Room_30_98f1d6c8 VRF Terminal Unit Outdoor Air Node; !- Node or
NodeList Name 1

Coil:Cooling:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Cooling Coil
14, !- Name
Always On Discrete,                      !- Availability Schedule
Name
Autosize,                                !- Gross Rated Total
Cooling Capacity {W}

```

```

Autosize,                                     ! - Gross Rated Sensible
Heat Ratio

Autosize,                                     ! - Rated Air Flow Rate {m3
/s}

VRFTUCoolCapFT 14,                          ! - Cooling Capacity Ratio
Modifier Function of Temperature Curve Name

VRFACCoolCapFFF 14,                         ! - Cooling Capacity
Modifier Curve Function of Flow Fraction Name

Room_30_98f1d6c8 VRF Terminal Unit Mixer Outlet Node, ! - Coil Air
Inlet Node

Room_30_98f1d6c8 VRF Terminal Unit Cooling Coil Outlet Node; ! -
Coil Air Outlet Node

Curve:Biquadratic,
VRFTUCoolCapFT 14,                           ! - Name
0.0585884077803259,                         ! - Coefficient1 Constant
0.0587396532718384,                         ! - Coefficient2 x
-0.000210274979759697,                      ! - Coefficient3 x**2
0.0109370473889647,                         ! - Coefficient4 y
-0.0001219549,                             ! - Coefficient5 y**2
-0.0005246615,                             ! - Coefficient6 x*y
15,                                         ! - Minimum Value of x {
BasedOnField A2}                            ! - Maximum Value of x {
23.89,                                       ! - Minimum Value of y {
BasedOnField A2}                            ! - Maximum Value of y {
20,                                         ! - Minimum Value of y {
BasedOnField A3}                            ! - Maximum Value of y {
43.33,                                       ! - Minimum Curve Output {
BasedOnField A3}                            ! - Maximum Curve Output {
0.8083,                                      ! - Minimum Curve Output {
BasedOnField A4}                            ! - Maximum Curve Output {
1.2583;                                     ! - Minimum Curve Output {
BasedOnField A4}                            ! - Maximum Curve Output {

Curve:Quadratic,
VRFACCoolCapFFF 14,                         ! - Name

```

```

0.8,                                     !- Coefficient1 Constant
0.2,                                     !- Coefficient2 x
0,                                         !- Coefficient3 x**2
0.5,                                     !- Minimum Value of x {
    BasedOnField A2}
1.5;                                      !- Maximum Value of x {
    BasedOnField A2}

Coil:Heating:DX:VariableRefrigerantFlow,
Zone HVAC Terminal Unit Variable Refrigerant Flow 1 Heating Coil
14, !- Name
Always On Discrete,                      !- Availability Schedule
Autosize,                                 !- Gross Rated Heating
Capacity {W}
Autosize,                                 !- Rated Air Flow Rate {m3
/s}
Room_30_98f1d6c8 VRF Terminal Unit Cooling Coil Outlet Node, !-
Coil Air Inlet Node
Room_30_98f1d6c8 VRF Terminal Unit Heating Coil Outlet Node, !-
Coil Air Outlet Node
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 14, !-
Heating Capacity Ratio Modifier Function of Temperature Curve
Name
Coil Heating DX Variable Refrigerant Flow 1 VRFACCCoolCapFFF 14; !-
Heating Capacity Modifier Function of Flow Fraction Curve Name

Curve:Biquadratic,
Coil Heating DX Variable Refrigerant Flow 1 VRFTUHeatCAPFT 14, !-
Name
0.375443994956127,                      !- Coefficient1 Constant
0.0668190645147821,                      !- Coefficient2 x
-0.00194171026482001,                    !- Coefficient3 x**2
0.0442618420640187,                      !- Coefficient4 y
-0.0004009578,                           !- Coefficient5 y**2
-0.0014819801,                           !- Coefficient6 x*y

```

```

21.11 ,                                     ! - Minimum Value of x {
    BasedOnField A2}

27.22 ,                                     ! - Maximum Value of x {
    BasedOnField A2}

-15 ,                                       ! - Minimum Value of y {
    BasedOnField A3}

18.33 ,                                      ! - Maximum Value of y {
    BasedOnField A3}

0.6074 ,                                     ! - Minimum Curve Output {
    BasedOnField A4}

1;                                           ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Quadratic ,
Coil Heating DX Variable Refrigerant Flow 1 VRFACCoolCapFFF 14, !-
    Name

0.8,                                         ! - Coefficient1 Constant
0.2,                                         ! - Coefficient2 x
0,                                            ! - Coefficient3 x**2
0.5,                                         ! - Minimum Value of x {
    BasedOnField A2}

1.5;                                         ! - Maximum Value of x {
    BasedOnField A2}

Fan:OnOff ,
Room_30_98f1d6c8 VRF Unit Cycling Fan,   ! - Name
Always On Discrete,                         ! - Availability Schedule
    Name

0.6,                                         ! - Fan Total Efficiency
300,                                         ! - Pressure Rise {Pa}
Autosize,                                    ! - Maximum Flow Rate {m3/s
    }

0.8,                                         ! - Motor Efficiency
1,                                           ! - Motor In Airstream
    Fraction

```

```

Room_30_98f1d6c8 VRF Terminal Unit Heating Coil Outlet Node, !-
Air Inlet Node Name

Room_30_98f1d6c8 VRF Terminal Unit Outlet Air Node, !- Air Outlet
Node Name

Fan On Off Power Curve 14,           !- Fan Power Ratio
Function of Speed Ratio Curve Name

Fan On Off Efficiency Curve 14,      !- Fan Efficiency Ratio
Function of Speed Ratio Curve Name

General;                           !- End-Use Subcategory

Curve:Exponent,
Fan On Off Power Curve 14,          !- Name
1,                                    !- Coefficient1 Constant
0,                                    !- Coefficient2 Constant
0,                                    !- Coefficient3 Constant
0,                                    !- Minimum Value of x {
BasedOnField A2}
1;                                   !- Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Fan On Off Efficiency Curve 14,     !- Name
1,                                    !- Coefficient1 Constant
0,                                    !- Coefficient2 x
0,                                    !- Coefficient3 x**2
0,                                    !- Coefficient4 x**3
0,                                    !- Minimum Value of x {
BasedOnField A2}
1;                                   !- Maximum Value of x {
BasedOnField A2}

ZoneHVAC:EquipmentList,
Room_30_98f1d6c8 Equipment List,    !- Name
SequentialLoad,                     !- Load Distribution
Scheme

```

```

ZoneHVAC:AirDistributionUnit ,           !- Zone Equipment Object
  Type 1
ADU Room_30_98f1d6c8 Air Terminal ,     !- Zone Equipment Name 1
1,                                     !- Zone Equipment Cooling
  Sequence 1
1,                                     !- Zone Equipment Heating
  or No-Load Sequence 1
Schedule Constant 29 ,                  !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 1
Schedule Constant 30 ,                  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 1
ZoneHVAC:TerminalUnit:VariableRefrigerantFlow , !- Zone Equipment
  Object Type 2
Room_30_98f1d6c8 VRF Terminal Unit ,    !- Zone Equipment Name 2
2,                                     !- Zone Equipment Cooling
  Sequence 2
2,                                     !- Zone Equipment Heating
  or No-Load Sequence 2
,
  !- Zone Equipment
  Sequential Cooling Fraction Schedule Name 2
;
  !- Zone Equipment
  Sequential Heating Fraction Schedule Name 2

Sizing:Zone ,
Room_30_98f1d6c8 ,                   !- Zone or ZoneList Name
SupplyAirTemperature ,                 !- Zone Cooling Design
  Supply Air Temperature Input Method
12.77777777777778 ,                !- Zone Cooling Design
  Supply Air Temperature {C}
11.11 ,                               !- Zone Cooling Design
  Supply Air Temperature Difference {deltaC}
SupplyAirTemperature ,                 !- Zone Heating Design
  Supply Air Temperature Input Method
40.0000000000001 ,                  !- Zone Heating Design
  Supply Air Temperature {C}

```

```

11.11,                                     !- Zone Heating Design
Supply Air Temperature Difference {deltaC}
0.0085,                                      !- Zone Cooling Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
0.008,                                       !- Zone Heating Design
Supply Air Humidity Ratio {kgWater/kgDryAir}
ventilation,                                !- Design Specification
Outdoor Air Object Name
,
!- Zone Heating Sizing
Factor
,
!- Zone Cooling Sizing
Factor
DesignDay,                                    !- Cooling Design Air Flow
Method
0,                                           !- Cooling Design Air Flow
Rate {m3/s}
0.000762,                                     !- Cooling Minimum Air
Flow per Zone Floor Area {m3/s-m2}
0,                                           !- Cooling Minimum Air
Flow {m3/s}
0,                                           !- Cooling Minimum Air
Flow Fraction
DesignDay,                                    !- Heating Design Air Flow
Method
0,                                           !- Heating Design Air Flow
Rate {m3/s}
0.002032,                                     !- Heating Maximum Air
Flow per Zone Floor Area {m3/s-m2}
0.1415762,                                    !- Heating Maximum Air
Flow {m3/s}
0.3,                                         !- Heating Maximum Air
Flow Fraction
,
!- Design Specification
Zone Air Distribution Object Name
Yes,                                         !- Account for Dedicated
Outdoor Air System

```

```

NeutralSupplyAir,                               ! - Dedicated Outdoor Air
System Control Strategy
15.55555555555556,                         ! - Dedicated Outdoor Air
Low Setpoint Temperature for Design {C}
21.1111111111111;                           ! - Dedicated Outdoor Air
High Setpoint Temperature for Design {C}

SimulationControl,
Yes,                                         ! - Do Zone Sizing
Calculation
Yes,                                         ! - Do System Sizing
Calculation
Yes,                                         ! - Do Plant Sizing
Calculation
No,                                          ! - Run Simulation for
Sizing Periods
Yes,                                         ! - Run Simulation for
Weather File Run Periods
No,                                           ! - Do HVAC Sizing
Simulation for Sizing Periods
;                                              ! - Maximum Number of HVAC
Sizing Simulation Passes

HeatBalanceAlgorithm,
ConductionTransferFunction,                  ! - Algorithm
200;                                         ! - Surface Temperature
Upper Limit {C}

RunPeriod,
Run Period 1,                                ! - Name
7,                                            ! - Begin Month
25,                                           ! - Begin Day of Month
2006,                                         ! - Begin Year
8,                                            ! - End Month
28,                                           ! - End Day of Month
2006,                                         ! - End Year

```

```

Friday ,                                         ! - Day of Week for Start
Day
No ,                                            ! - Use Weather File
Holidays and Special Days
No ,                                            ! - Use Weather File
Daylight Saving Period
No ,                                            ! - Apply Weekend Holiday
Rule
Yes ,                                           ! - Use Weather File Rain
Indicators
Yes ;                                           ! - Use Weather File Snow
Indicators

ShadowCalculation ,
PolygonClipping ,                                ! - Shading Calculation
Method
Periodic ,                                       ! - Shading Calculation
Update Frequency Method
30 ,                                              ! - Shading Calculation
Update Frequency
15000 ,                                         ! - Maximum Figures in
Shadow Overlap Calculations
SutherlandHodgman ,                               ! - Polygon Clipping
Algorithm
512 ,                                             ! - Pixel Counting
Resolution
SimpleSkyDiffuseModeling ,                        ! - Sky Diffuse Modeling
Algorithm
No ,                                              ! - Output External Shading
Calculation Results
No ,                                              ! - Disable Self-Shading
Within Shading Zone Groups
No ;                                              ! - Disable Self-Shading
From Shading Zone Groups to Other Zones

Sizing:Parameters ,

```

```

1.25,                                     ! - Heating Sizing Factor
1.15;                                      ! - Cooling Sizing Factor

GlobalGeometryRules,
UpperLeftCorner,                            ! - Starting Vertex
Position
Counterclockwise,                           ! - Vertex Entry Direction
Relative,                                    ! - Coordinate System
Relative,                                    ! - Daylighting Reference
Point Coordinate System
Relative;                                    ! - Rectangular Surface
Coordinate System

Material,
1/2 in. Gypsum Board,                      ! - Name
Smooth,                                      ! - Roughness
0.0127,                                     ! - Thickness {m}
0.159892999094055,                         ! - Conductivity {W/m-K}
800.001829191177,                          ! - Density {kg/m3}
1089.29718545594,                          ! - Specific Heat {J/kg-K}
0.9,                                         ! - Thermal Absorptance
0.7,                                         ! - Solar Absorptance
0.5;                                         ! - Visible Absorptance

Material,
1IN Stucco,                                 ! - Name
Smooth,                                      ! - Roughness
0.0253,                                     ! - Thickness {m}
0.691337354832922,                         ! - Conductivity {W/m-K}
1858.00424829652,                          ! - Density {kg/m3}
836.460315804243,                          ! - Specific Heat {J/kg-K}
0.9,                                         ! - Thermal Absorptance
0.7,                                         ! - Solar Absorptance
0.92;                                        ! - Visible Absorptance

Material,

```

Generic 25mm Insulation,	! - Name
MediumRough,	! - Roughness
0.05,	! - Thickness {m}
0.03,	! - Conductivity {W/m-K}
43,	! - Density {kg/m3}
1210,	! - Specific Heat {J/kg-K}
0.9,	! - Thermal Absorptance
0.7,	! - Solar Absorptance
0.7;	! - Visible Absorptance
Material,	
Generic 25mm Wood,	! - Name
MediumSmooth,	! - Roughness
0.0254,	! - Thickness {m}
0.15,	! - Conductivity {W/m-K}
608,	! - Density {kg/m3}
1630,	! - Specific Heat {J/kg-K}
0.9,	! - Thermal Absorptance
0.5,	! - Solar Absorptance
0.5;	! - Visible Absorptance
Material,	
Generic 50mm Insulation,	! - Name
MediumRough,	! - Roughness
0.05,	! - Thickness {m}
0.03,	! - Conductivity {W/m-K}
43,	! - Density {kg/m3}
1210,	! - Specific Heat {J/kg-K}
0.9,	! - Thermal Absorptance
0.7,	! - Solar Absorptance
0.7;	! - Visible Absorptance
Material,	
Generic Acoustic Tile,	! - Name
MediumSmooth,	! - Roughness
0.02,	! - Thickness {m}

```

0.06,                                     ! - Conductivity {W/m-K}
368,                                       ! - Density {kg/m3}
590,                                       ! - Specific Heat {J/kg-K}
0.9,                                        ! - Thermal Absorptance
0.2,                                         ! - Solar Absorptance
0.2;                                         ! - Visible Absorptance

Material,
Generic Brick,                           ! - Name
MediumRough,                            ! - Roughness
0.1,                                      ! - Thickness {m}
0.9,                                       ! - Conductivity {W/m-K}
1920,                                      ! - Density {kg/m3}
790,                                       ! - Specific Heat {J/kg-K}
0.9,                                         ! - Thermal Absorptance
0.65,                                       ! - Solar Absorptance
0.65;                                       ! - Visible Absorptance

Material,
Generic Ceiling Air Gap,                 ! - Name
Smooth,                                    ! - Roughness
0.1,                                       ! - Thickness {m}
0.556,                                     ! - Conductivity {W/m-K}
1.28,                                       ! - Density {kg/m3}
1000,                                       ! - Specific Heat {J/kg-K}
0.9,                                         ! - Thermal Absorptance
0.7,                                         ! - Solar Absorptance
0.7;                                         ! - Visible Absorptance

Material,
Generic Gypsum Board,                   ! - Name
MediumSmooth,                            ! - Roughness
0.0127,                                    ! - Thickness {m}
0.16,                                       ! - Conductivity {W/m-K}
800,                                         ! - Density {kg/m3}
1090,                                       ! - Specific Heat {J/kg-K}

```

```

0.9,                                     ! - Thermal Absorptance
0.5,                                     ! - Solar Absorptance
0.5;                                     ! - Visible Absorptance

Material,
Generic HW Concrete,                     ! - Name
MediumRough,                             ! - Roughness
0.2,                                     ! - Thickness {m}
1.95,                                    ! - Conductivity {W/m-K}
2240,                                    ! - Density {kg/m3}
900,                                     ! - Specific Heat {J/kg-K}
0.9,                                     ! - Thermal Absorptance
0.8,                                     ! - Solar Absorptance
0.8;                                     ! - Visible Absorptance

Material,
Generic LW Concrete,                     ! - Name
MediumRough,                             ! - Roughness
0.1,                                     ! - Thickness {m}
0.53,                                    ! - Conductivity {W/m-K}
1280,                                    ! - Density {kg/m3}
840,                                     ! - Specific Heat {J/kg-K}
0.9,                                     ! - Thermal Absorptance
0.8,                                     ! - Solar Absorptance
0.8;                                     ! - Visible Absorptance

Material,
Generic Painted Metal,                   ! - Name
Smooth,                                  ! - Roughness
0.0015,                                 ! - Thickness {m}
45,                                      ! - Conductivity {W/m-K}
7690,                                    ! - Density {kg/m3}
410,                                     ! - Specific Heat {J/kg-K}
0.9,                                     ! - Thermal Absorptance
0.5,                                     ! - Solar Absorptance
0.5;                                     ! - Visible Absorptance

```

```

Material ,
  Generic Roof Membrane , ! - Name
  MediumRough , ! - Roughness
  0.01 , ! - Thickness {m}
  0.16 , ! - Conductivity {W/m-K}
  1120 , ! - Density {kg/m3}
  1460 , ! - Specific Heat {J/kg-K}
  0.9 , ! - Thermal Absorptance
  0.65 , ! - Solar Absorptance
  0.65; ! - Visible Absorptance

Material ,
  Generic Wall Air Gap , ! - Name
  Smooth , ! - Roughness
  0.1 , ! - Thickness {m}
  0.667 , ! - Conductivity {W/m-K}
  1.28 , ! - Density {kg/m3}
  1000 , ! - Specific Heat {J/kg-K}
  0.9 , ! - Thermal Absorptance
  0.7 , ! - Solar Absorptance
  0.7; ! - Visible Absorptance

Material ,
  Material 1 , ! - Name
  Smooth , ! - Roughness
  0.1 , ! - Thickness {m}
  0.1 , ! - Conductivity {W/m-K}
  0.1 , ! - Density {kg/m3}
  100 , ! - Specific Heat {J/kg-K}
  0.9 , ! - Thermal Absorptance
  0.65 , ! - Solar Absorptance
  0.65; ! - Visible Absorptance

Material ,
  Material 2 , ! - Name

```

```

Smooth ,                                         ! - Roughness
0.1 ,                                           ! - Thickness {m}
0.1 ,                                           ! - Conductivity {W/m-K}
0.1 ,                                           ! - Density {kg/m3}
100 ,                                          ! - Specific Heat {J/kg-K}
0.9 ,                                           ! - Thermal Absorptance
0.8 ,                                           ! - Solar Absorptance
0.8;                                            ! - Visible Absorptance

Material ,
project_concrete_floor ,                      ! - Name
MediumRough ,                                    ! - Roughness
0.203200406400813 ,                           ! - Thickness {m}
1.728 ,                                         ! - Conductivity {W/m-K}
2243 ,                                          ! - Density {kg/m3}
836.46 ,                                         ! - Specific Heat {J/kg-K}
0.9 ,                                           ! - Thermal Absorptance
0.65 ,                                           ! - Solar Absorptance
0.65;                                            ! - Visible Absorptance

Material ,
project_concrete_int_wall ,                   ! - Name
MediumRough ,                                    ! - Roughness
0.15240030480061 ,                           ! - Thickness {m}
1 ,                                              ! - Conductivity {W/m-K}
2243 ,                                          ! - Density {kg/m3}
836.46 ,                                         ! - Specific Heat {J/kg-K}
0.9 ,                                           ! - Thermal Absorptance
0.65 ,                                           ! - Solar Absorptance
0.65;                                            ! - Visible Absorptance

Material ,
project_concrete_roof ,                        ! - Name
MediumRough ,                                    ! - Roughness
0.203200406400813 ,                           ! - Thickness {m}
1.728 ,                                         ! - Conductivity {W/m-K}

```

```

2243,                                     ! - Density {kg/m3}
836.46,                                    ! - Specific Heat {J/kg-K}
0.9,                                       ! - Thermal Absorptance
0.65,                                      ! - Solar Absorptance
0.65;                                       ! - Visible Absorptance

Material,
project_concrete_slab,                      ! - Name
MediumRough,                                 ! - Roughness
0.101600203200406,                         ! - Thickness {m}
1.728,                                      ! - Conductivity {W/m-K}
2243,                                       ! - Density {kg/m3}
836.46,                                     ! - Specific Heat {J/kg-K}
0.9,                                         ! - Thermal Absorptance
0.65,                                       ! - Solar Absorptance
0.65;                                       ! - Visible Absorptance

Material,
project_concrete_wall,                      ! - Name
MediumRough,                                ! - Roughness
0.203200406400813,                         ! - Thickness {m}
1.728,                                      ! - Conductivity {W/m-K}
2243,                                       ! - Density {kg/m3}
836.46,                                     ! - Specific Heat {J/kg-K}
0.9,                                         ! - Thermal Absorptance
0.65,                                       ! - Solar Absorptance
0.65;                                       ! - Visible Absorptance

Material:NoMass,
project_roof_surface,                      ! - Name
MediumRough,                                ! - Roughness
0.2,                                       ! - Thermal Resistance {m2-
K/W}
0.3,                                       ! - Thermal Absorptance
0.3,                                       ! - Solar Absorptance
0.3;                                       ! - Visible Absorptance

```

```

Material:NoMass ,
    Typical Insulation-R12 ,                               ! - Name
    MediumSmooth ,                                         ! - Roughness
    2.11332220571862 ,                                    ! - Thermal Resistance {m2-
        K/W}
    0.9 ,                                                 ! - Thermal Absorptance
    0.7 ,                                                 ! - Solar Absorptance
    0.7;                                                 ! - Visible Absorptance

Material:NoMass ,
    Typical Insulation-R25 ,                               ! - Name
    MediumSmooth ,                                         ! - Roughness
    4.40275459524712 ,                                    ! - Thermal Resistance {m2-
        K/W}
    0.9 ,                                                 ! - Thermal Absorptance
    0.7 ,                                                 ! - Solar Absorptance
    0.7;                                                 ! - Visible Absorptance

WindowMaterial:Gas ,
    Generic Window Air Gap ,                            ! - Name
    Air ,                                               ! - Gas Type
    0.0127;                                            ! - Thickness {m}

WindowMaterial:Gas ,
    Generic Window Argon Gap ,                         ! - Name
    Argon ,                                             ! - Gas Type
    0.0127;                                            ! - Thickness {m}

WindowMaterial:Glazing ,
    Generic Clear Glass ,                            ! - Name
    SpectralAverage ,                                ! - Optical Data Type
    ,                                                 ! - Window Glass Spectral
    Data Set Name
    0.006 ,                                            ! - Thickness {m}

```

```

0.77,                                     ! - Solar Transmittance at
    Normal Incidence

0.07,                                      ! - Front Side Solar
    Reflectance at Normal Incidence

0.07,                                      ! - Back Side Solar
    Reflectance at Normal Incidence

0.88,                                      ! - Visible Transmittance
    at Normal Incidence

0.08,                                      ! - Front Side Visible
    Reflectance at Normal Incidence

0.08,                                      ! - Back Side Visible
    Reflectance at Normal Incidence

0,                                           ! - Infrared Transmittance
    at Normal Incidence

0.84,                                      ! - Front Side Infrared
    Hemispherical Emissivity

0.84,                                      ! - Back Side Infrared
    Hemispherical Emissivity

1,                                           ! - Conductivity {W/m-K}
1,                                           ! - Dirt Correction Factor
    for Solar and Visible Transmittance

No;                                         ! - Solar Diffusing

WindowMaterial:Glazing,
    Generic Low-e Glass,                      ! - Name
    SpectralAverage,                         ! - Optical Data Type
    ,                                         ! - Window Glass Spectral
        Data Set Name

0.006,                                     ! - Thickness {m}
0.45,                                      ! - Solar Transmittance at
    Normal Incidence

0.36,                                      ! - Front Side Solar
    Reflectance at Normal Incidence

0.36,                                      ! - Back Side Solar
    Reflectance at Normal Incidence

```

```

0.71,                                     !- Visible Transmittance
    at Normal Incidence
0.21,                                     !- Front Side Visible
    Reflectance at Normal Incidence
0.21,                                     !- Back Side Visible
    Reflectance at Normal Incidence
0,                                         !- Infrared Transmittance
    at Normal Incidence
0.84,                                     !- Front Side Infrared
    Hemispherical Emissivity
0.047,                                    !- Back Side Infrared
    Hemispherical Emissivity
1,                                         !- Conductivity {W/m-K}
1,                                         !- Dirt Correction Factor
    for Solar and Visible Transmittance
No;                                        !- Solar Diffusing

WindowMaterial:SimpleGlazingSystem,
    project_glass,                         !- Name
    3.61,                                    !- U-Factor {W/m2-K}
    0.4,                                     !- Solar Heat Gain
    Coefficient
    0.6;                                    !- Visible Transmittance

Construction,
    Generic Context,                      !- Name
    Material 2;                           !- Layer 1

Construction,
    Generic Double Pane,                  !- Name
    Generic Low-e Glass,                 !- Layer 1
    Generic Window Air Gap,              !- Layer 2
    Generic Clear Glass;                !- Layer 3

Construction,
    Generic Exposed Floor,               !- Name

```

```
Generic Painted Metal,           !- Layer 1
Generic Ceiling Air Gap,         !- Layer 2
Generic 50mm Insulation,        !- Layer 3
Generic LW Concrete;           !- Layer 4
```

```
Construction,
Generic Exterior Door,          !- Name
Generic Painted Metal,           !- Layer 1
Generic 25mm Insulation,         !- Layer 2
Generic Painted Metal;           !- Layer 3
```

```
Construction,
Generic Exterior Wall,           !- Name
Generic Brick,                  !- Layer 1
Generic LW Concrete,             !- Layer 2
Generic 50mm Insulation,         !- Layer 3
Generic Wall Air Gap,            !- Layer 4
Generic Gypsum Board;           !- Layer 5
```

```
Construction,
Generic Ground Slab,             !- Name
Generic 50mm Insulation,          !- Layer 1
Generic HW Concrete;              !- Layer 2
```

```
Construction,
Generic Interior Ceiling,        !- Name
Generic LW Concrete,              !- Layer 1
Generic Ceiling Air Gap,          !- Layer 2
Generic Acoustic Tile;            !- Layer 3
```

```
Construction,
Generic Interior Door,            !- Name
Generic 25mm Wood;                !- Layer 1
```

```
Construction,
Generic Interior Floor,           !- Name
```

```
Generic Acoustic Tile,           !- Layer 1
Generic Ceiling Air Gap,        !- Layer 2
Generic LW Concrete;           !- Layer 3
```

```
Construction,
Generic Interior Wall,          !- Name
Generic Gypsum Board,           !- Layer 1
Generic Wall Air Gap,            !- Layer 2
Generic Gypsum Board;           !- Layer 3
```

```
Construction,
Generic Roof,                  !- Name
Generic Roof Membrane,          !- Layer 1
Generic 50mm Insulation,         !- Layer 2
Generic LW Concrete,             !- Layer 3
Generic Ceiling Air Gap,          !- Layer 4
Generic Acoustic Tile;           !- Layer 5
```

```
Construction,
Generic Shade,                  !- Name
Material 1;                     !- Layer 1
```

```
Construction,
Generic Single Pane,             !- Name
Generic Clear Glass;             !- Layer 1
```

```
Construction,
Generic Underground Roof,        !- Name
Generic 50mm Insulation,          !- Layer 1
Generic HW Concrete,              !- Layer 2
Generic Ceiling Air Gap,           !- Layer 3
Generic Acoustic Tile;            !- Layer 4
```

```
Construction,
Generic Underground Wall,         !- Name
Generic 50mm Insulation,          !- Layer 1
```

```

Generic HW Concrete,           !- Layer 2
Generic Wall Air Gap,          !- Layer 3
Generic Gypsum Board;          !- Layer 4

Construction,
    project_ceiling_int,        !- Name
    1/2 in. Gypsum Board,        !- Layer 1
    project_concrete_floor,      !- Layer 2
    Generic 25mm Wood;          !- Layer 3

Construction,
    project_floor,              !- Name
    Generic 25mm Wood,          !- Layer 1
    project_concrete_floor,      !- Layer 2
    1/2 in. Gypsum Board;        !- Layer 3

Construction,
    project_roof,                !- Name
    project_roof_surface,         !- Layer 1
    Typical Insulation-R25,       !- Layer 2
    project_concrete_roof,        !- Layer 3
    1/2 in. Gypsum Board;        !- Layer 4

Construction,
    project_slab,                !- Name
    Generic 50mm Insulation,      !- Layer 1
    project_concrete_slab,        !- Layer 2
    Generic 25mm Wood;           !- Layer 3

Construction,
    project_wall,                !- Name
    1IN Stucco,                  !- Layer 1
    Typical Insulation-R12,       !- Layer 2
    project_concrete_wall,        !- Layer 3
    1/2 in. Gypsum Board;        !- Layer 4

```

```

Construction ,
  project_wall_int ,                               !- Name
  1/2 in. Gypsum Board ,                         !- Layer 1
  project_concrete_int_wall ,                    !- Layer 2
  1/2 in. Gypsum Board;                         !- Layer 3

Construction ,
  project_window ,                                !- Name
  project_glass;                                 !- Layer 1

Construction:AirBoundary ,
  Generic Air Boundary ,                         !- Name
  None ,                                         !- Air Exchange Method
  0,                                              !- Simple Mixing Air
  Changes per Hour {1/hr}
;
  !- Simple Mixing Schedule
  Name

ScheduleTypeLimits ,
  Activity Level ,                                !- Name
  0,                                               !- Lower Limit Value {
  BasedOnField A3}
;
  !- Upper Limit Value {
  BasedOnField A3}
  Continuous ,                                    !- Numeric Type
  activitylevel;                                 !- Unit Type

ScheduleTypeLimits ,
  Fractional ,                                   !- Name
  0,                                               !- Lower Limit Value {
  BasedOnField A3}
  1,                                              !- Upper Limit Value {
  BasedOnField A3}
  Continuous ,                                    !- Numeric Type
  dimensionless;                                !- Unit Type

```

```

ScheduleTypeLimits ,
    OnOff ,                                     ! - Name
    0,                                         ! - Lower Limit Value {
        BasedOnField A3}
    1,                                         ! - Upper Limit Value {
        BasedOnField A3}
    Discrete,                                    ! - Numeric Type
    availability;                                ! - Unit Type

ScheduleTypeLimits ,
    OnOff 1,                                     ! - Name
    0,                                         ! - Lower Limit Value {
        BasedOnField A3}
    1,                                         ! - Upper Limit Value {
        BasedOnField A3}
    Discrete,                                    ! - Numeric Type
    availability;                                ! - Unit Type

ScheduleTypeLimits ,
    Temperature 1,                               ! - Name
    ,                                           ! - Lower Limit Value {
        BasedOnField A3}
    ,                                           ! - Upper Limit Value {
        BasedOnField A3}
    Continuous,                                 ! - Numeric Type
    temperature;                                ! - Unit Type

Schedule:Constant ,
    Schedule Constant 1,                         ! - Name
    Fractional,                                 ! - Schedule Type Limits
    Name
    0;                                         ! - Hourly Value

Schedule:Constant ,
    Schedule Constant 10,                        ! - Name

```

```

Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 11, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 12, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 13, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 14, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 15, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 16, ! - Name

```

```

Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 17, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 18, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 19, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 2, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 20, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 21, ! - Name

```

```

Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 22, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 23, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 24, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 25, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 26, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 27, ! - Name

```

```

Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 28, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 29, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 3, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 30, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 4, ! - Name
Fractional , ! - Schedule Type Limits
  Name
0; ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 5, ! - Name

```

```

Fractional ,                                     ! - Schedule Type Limits
  Name
0;                                              ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 6,                         ! - Name
  Fractional ,                                  ! - Schedule Type Limits
  Name
0;                                              ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 7,                         ! - Name
  Fractional ,                                  ! - Schedule Type Limits
  Name
0;                                              ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 8,                         ! - Name
  Fractional ,                                  ! - Schedule Type Limits
  Name
0;                                              ! - Hourly Value

Schedule:Constant ,
  Schedule Constant 9,                         ! - Name
  Fractional ,                                  ! - Schedule Type Limits
  Name
0;                                              ! - Hourly Value

Schedule:Day:Interval ,
  Always On_Day Schedule ,                     ! - Name
  Fractional ,                                ! - Schedule Type Limits
  Name
No ,                                           ! - Interpolate to Timestep
24:00 ,                                         ! - Time 1 {hh:mm}
1;                                              ! - Value Until Time 1

```

```

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_Hol , !- Name
Fractional , !- Schedule Type Limits
Name
No , !- Interpolate to Timestep
07:00 , !- Time 1 {hh:mm}
0.958332824583389 , !- Value Until Time 1
08:00 , !- Time 2 {hh:mm}
0.814582900895881 , !- Value Until Time 2
09:00 , !- Time 3 {hh:mm}
0.373749801587522 , !- Value Until Time 3
16:00 , !- Time 4 {hh:mm}
0.239583206145847 , !- Value Until Time 4
17:00 , !- Time 5 {hh:mm}
0.287499847375017 , !- Value Until Time 5
18:00 , !- Time 6 {hh:mm}
0.498333068783362 , !- Value Until Time 6
21:00 , !- Time 7 {hh:mm}
0.833749557387549 , !- Value Until Time 7
24:00 , !- Time 8 {hh:mm}
0.958332824583389; !- Value Until Time 8

```

```

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_Hol 1 , !- Name
Fractional , !- Schedule Type Limits
Name
No , !- Interpolate to Timestep
07:00 , !- Time 1 {hh:mm}
0.958332824583389 , !- Value Until Time 1
08:00 , !- Time 2 {hh:mm}
0.814582900895881 , !- Value Until Time 2
09:00 , !- Time 3 {hh:mm}
0.373749801587522 , !- Value Until Time 3
16:00 , !- Time 4 {hh:mm}
0.239583206145847 , !- Value Until Time 4
17:00 , !- Time 5 {hh:mm}

```

```

0.287499847375017 , !- Value Until Time 5
18:00 , !- Time 6 {hh:mm}
0.498333068783362 , !- Value Until Time 6
21:00 , !- Time 7 {hh:mm}
0.833749557387549 , !- Value Until Time 7
24:00 , !- Time 8 {hh:mm}
0.958332824583389; !- Value Until Time 8

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_Monday , !- Name
Fractional , !- Schedule Type Limits
Name
No , !- Interpolate to Timestep
07:00 , !- Time 1 {hh:mm}
0.958332824583389 , !- Value Until Time 1
08:00 , !- Time 2 {hh:mm}
0.814582900895881 , !- Value Until Time 2
09:00 , !- Time 3 {hh:mm}
0.415416977004133 , !- Value Until Time 3
12:00 , !- Time 4 {hh:mm}
0.281250381562458 , !- Value Until Time 4
13:00 , !- Time 5 {hh:mm}
0.260416793854153 , !- Value Until Time 5
16:00 , !- Time 6 {hh:mm}
0.281250381562458 , !- Value Until Time 6
17:00 , !- Time 7 {hh:mm}
0.329167022791627 , !- Value Until Time 7
18:00 , !- Time 8 {hh:mm}
0.498333068783362 , !- Value Until Time 8
21:00 , !- Time 9 {hh:mm}
0.833749557387549 , !- Value Until Time 9
24:00 , !- Time 10 {hh:mm}
0.958332824583389; !- Value Until Time 10

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_SmrDsn , !- Name

```

Fractional ,	! - Schedule Type Limits
Name	
No ,	! - Interpolate to Timestep
07:00 ,	! - Time 1 {hh:mm}
0.958332824583389 ,	! - Value Until Time 1
08:00 ,	! - Time 2 {hh:mm}
0.814582900895881 ,	! - Value Until Time 2
09:00 ,	! - Time 3 {hh:mm}
0.373749801587522 ,	! - Value Until Time 3
16:00 ,	! - Time 4 {hh:mm}
0.239583206145847 ,	! - Value Until Time 4
17:00 ,	! - Time 5 {hh:mm}
0.287499847375017 ,	! - Value Until Time 5
18:00 ,	! - Time 6 {hh:mm}
0.498333068783362 ,	! - Value Until Time 6
21:00 ,	! - Time 7 {hh:mm}
0.833749557387549 ,	! - Value Until Time 7
24:00 ,	! - Time 8 {hh:mm}
0.958332824583389 ;	! - Value Until Time 8

Schedule:Day:Interval ,	
MidriseApartment Building_People_Occ Schedule_SmrDsn 1 ,	! - Name
Fractional ,	! - Schedule Type Limits
Name	
No ,	! - Interpolate to Timestep
07:00 ,	! - Time 1 {hh:mm}
0.958332824583389 ,	! - Value Until Time 1
08:00 ,	! - Time 2 {hh:mm}
0.814582900895881 ,	! - Value Until Time 2
09:00 ,	! - Time 3 {hh:mm}
0.373749801587522 ,	! - Value Until Time 3
16:00 ,	! - Time 4 {hh:mm}
0.239583206145847 ,	! - Value Until Time 4
17:00 ,	! - Time 5 {hh:mm}
0.287499847375017 ,	! - Value Until Time 5
18:00 ,	! - Time 6 {hh:mm}

```

0.498333068783362 , !- Value Until Time 6
21:00 , !- Time 7 {hh:mm}
0.833749557387549 , !- Value Until Time 7
24:00 , !- Time 8 {hh:mm}
0.958332824583389; !- Value Until Time 8

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_Sunday , !- Name
Fractional , !- Schedule Type Limits
Name
No , !- Interpolate to Timestep
07:00 , !- Time 1 {hh:mm}
0.958332824583389 , !- Value Until Time 1
08:00 , !- Time 2 {hh:mm}
0.814582900895881 , !- Value Until Time 2
09:00 , !- Time 3 {hh:mm}
0.373749801587522 , !- Value Until Time 3
16:00 , !- Time 4 {hh:mm}
0.239583206145847 , !- Value Until Time 4
17:00 , !- Time 5 {hh:mm}
0.287499847375017 , !- Value Until Time 5
18:00 , !- Time 6 {hh:mm}
0.498333068783362 , !- Value Until Time 6
21:00 , !- Time 7 {hh:mm}
0.833749557387549 , !- Value Until Time 7
24:00 , !- Time 8 {hh:mm}
0.958332824583389; !- Value Until Time 8

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_WntrDsn , !- Name
Fractional , !- Schedule Type Limits
Name
No , !- Interpolate to Timestep
07:00 , !- Time 1 {hh:mm}
0.958332824583389 , !- Value Until Time 1
08:00 , !- Time 2 {hh:mm}

```

```

0.814582900895881 , !- Value Until Time 2
09:00 , !- Time 3 {hh:mm}
0.373749801587522 , !- Value Until Time 3
16:00 , !- Time 4 {hh:mm}
0.239583206145847 , !- Value Until Time 4
17:00 , !- Time 5 {hh:mm}
0.287499847375017 , !- Value Until Time 5
18:00 , !- Time 6 {hh:mm}
0.498333068783362 , !- Value Until Time 6
21:00 , !- Time 7 {hh:mm}
0.833749557387549 , !- Value Until Time 7
24:00 , !- Time 8 {hh:mm}
0.958332824583389; !- Value Until Time 8

Schedule:Day:Interval ,
MidriseApartment Building_People_Occ Schedule_WntrDsn 1, !- Name
Fractional , !- Schedule Type Limits
Name
No , !- Interpolate to Timestep
07:00 , !- Time 1 {hh:mm}
0.958332824583389 , !- Value Until Time 1
08:00 , !- Time 2 {hh:mm}
0.814582900895881 , !- Value Until Time 2
09:00 , !- Time 3 {hh:mm}
0.373749801587522 , !- Value Until Time 3
16:00 , !- Time 4 {hh:mm}
0.239583206145847 , !- Value Until Time 4
17:00 , !- Time 5 {hh:mm}
0.287499847375017 , !- Value Until Time 5
18:00 , !- Time 6 {hh:mm}
0.498333068783362 , !- Value Until Time 6
21:00 , !- Time 7 {hh:mm}
0.833749557387549 , !- Value Until Time 7
24:00 , !- Time 8 {hh:mm}
0.958332824583389; !- Value Until Time 8

```

```

Schedule:Day:Interval ,
  Schedule Day 1,                               !- Name
  Fractional,                                !- Schedule Type Limits
    Name
    No,                                         !- Interpolate to Timestep
    07:00,                                       !- Time 1 {hh:mm}
    0.958332824583389,                         !- Value Until Time 1
    08:00,                                       !- Time 2 {hh:mm}
    0.814582900895881,                         !- Value Until Time 2
    09:00,                                       !- Time 3 {hh:mm}
    0.415416977004133,                         !- Value Until Time 3
    12:00,                                       !- Time 4 {hh:mm}
    0.281250381562458,                         !- Value Until Time 4
    13:00,                                       !- Time 5 {hh:mm}
    0.260416793854153,                         !- Value Until Time 5
    16:00,                                       !- Time 6 {hh:mm}
    0.281250381562458,                         !- Value Until Time 6
    17:00,                                       !- Time 7 {hh:mm}
    0.329167022791627,                         !- Value Until Time 7
    18:00,                                       !- Time 8 {hh:mm}
    0.498333068783362,                         !- Value Until Time 8
    21:00,                                       !- Time 9 {hh:mm}
    0.833749557387549,                         !- Value Until Time 9
    24:00,                                       !- Time 10 {hh:mm}
    0.958332824583389;                        !- Value Until Time 10

Schedule:Day:Interval ,
  Schedule Day 2,                               !- Name
  Temperature 1,                                !- Schedule Type Limits
    Name
    No,                                         !- Interpolate to Timestep
    24:00,                                       !- Time 1 {hh:mm}
    60;                                         !- Value Until Time 1

Schedule:Day:Interval ,
  Schedule Day 3,                               !- Name

```

```

        ,
        ! - Schedule Type Limits

    Name
    No,
        ! - Interpolate to Timestep
    24:00,
        ! - Time 1 {hh:mm}
    0.2;
        ! - Value Until Time 1

Schedule:Day:Interval,
    Schedule Day 4,
        ! - Name
        ,
        ! - Schedule Type Limits

    Name
    No,
        ! - Interpolate to Timestep
    24:00,
        ! - Time 1 {hh:mm}
    0.05;
        ! - Value Until Time 1

Schedule:Day:Interval,
    Schedule Day 5,
        ! - Name
    Temperature 1,
        ! - Schedule Type Limits

    Name
    No,
        ! - Interpolate to Timestep
    24:00,
        ! - Time 1 {hh:mm}
    60;
        ! - Value Until Time 1

Schedule:Day:Interval,
    Seated Adult Activity_Day Schedule,
        ! - Name
    Activity Level,
        ! - Schedule Type Limits

    Name
    No,
        ! - Interpolate to Timestep
    24:00,
        ! - Time 1 {hh:mm}
    120;
        ! - Value Until Time 1

Schedule:Day:Interval,
    Standard_Cooling_Hol,
        ! - Name
    Temperature,
        ! - Schedule Type Limits

    Name
    No,
        ! - Interpolate to Timestep
    24:00,
        ! - Time 1 {hh:mm}

```

```

23;                                     ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Cooling_SmrDsn ,           ! - Name
  Temperature ,                      ! - Schedule Type Limits
    Name
  No ,                                ! - Interpolate to Timestep
  24:00 ,                             ! - Time 1 {hh:mm}
  23;                                 ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Cooling_WntrDsn ,          ! - Name
  Temperature ,                      ! - Schedule Type Limits
    Name
  No ,                                ! - Interpolate to Timestep
  24:00 ,                             ! - Time 1 {hh:mm}
  23;                                 ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Ventilation_Hol ,          ! - Name
  On-Off ,                            ! - Schedule Type Limits
    Name
  No ,                                ! - Interpolate to Timestep
  24:00 ,                             ! - Time 1 {hh:mm}
  1;                                  ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Ventilation_SmrDsn ,        ! - Name
  On-Off ,                            ! - Schedule Type Limits
    Name
  No ,                                ! - Interpolate to Timestep
  24:00 ,                             ! - Time 1 {hh:mm}
  1;                                  ! - Value Until Time 1

Schedule:Day:Interval,
  Standard_Ventilation_WntrDsn ,       ! - Name

```

```

On-Off , ! - Schedule Type Limits
  Name

No , ! - Interpolate to Timestep
24:00 , ! - Time 1 {hh:mm}
1; ! - Value Until Time 1

Schedule:Week:Daily ,
  0.05 Hot Water Latent Fraction Week Rule - Jan1-Dec31 , !- Name
  Schedule Day 4, ! - Sunday Schedule:Day
    Name
  Schedule Day 4, ! - Monday Schedule:Day
    Name
  Schedule Day 4, ! - Tuesday Schedule:Day
    Name
  Schedule Day 4, ! - Wednesday Schedule:Day
    Name
  Schedule Day 4, ! - Thursday Schedule:Day
    Name
  Schedule Day 4, ! - Friday Schedule:Day
    Name
  Schedule Day 4, ! - Saturday Schedule:Day
    Name
  Schedule Day 4, ! - Holiday Schedule:Day
    Name
  Schedule Day 4, ! - SummerDesignDay
    Schedule:Day Name
  Schedule Day 4, ! - WinterDesignDay
    Schedule:Day Name
  Schedule Day 4, ! - CustomDay1 Schedule:Day
    Name
  Schedule Day 4; ! - CustomDay2 Schedule:Day
    Name

Schedule:Year ,
  0.05 Hot Water Latent Fraction , ! - Name

```

```

        ,                                     ! - Schedule Type Limits
      Name
0.05 Hot Water Latent Fraction Week Rule - Jan1-Dec31, !- Schedule
:Week Name 1

1,                                         ! - Start Month 1
1,                                         ! - Start Day 1
12,                                         ! - End Month 1
31;                                         ! - End Day 1

Schedule:Week:Daily,
0.2 Hot Water Sensible Fraction Week Rule - Jan1-Dec31, !- Name
Schedule Day 3,                           ! - Sunday Schedule:Day
Name
Schedule Day 3,                           ! - Monday Schedule:Day
Name
Schedule Day 3,                           ! - Tuesday Schedule:Day
Name
Schedule Day 3,                           ! - Wednesday Schedule:Day
Name
Schedule Day 3,                           ! - Thursday Schedule:Day
Name
Schedule Day 3,                           ! - Friday Schedule:Day
Name
Schedule Day 3,                           ! - Saturday Schedule:Day
Name
Schedule Day 3,                           ! - Holiday Schedule:Day
Name
Schedule Day 3,                           ! - SummerDesignDay
Schedule:Day Name
Schedule Day 3,                           ! - WinterDesignDay
Schedule:Day Name
Schedule Day 3,                           ! - CustomDay1 Schedule:Day
Name
Schedule Day 3;                          ! - CustomDay2 Schedule:Day
Name

```

```

Schedule:Year,
  0.2 Hot Water Sensible Fraction,      !- Name
  ,                                     !- Schedule Type Limits
  Name
  0.2 Hot Water Sensible Fraction Week Rule - Jan1-Dec31, !-
    Schedule:Week Name 1
  1,                                     !- Start Month 1
  1,                                     !- Start Day 1
  12,                                    !- End Month 1
  31;                                    !- End Day 1

Schedule:Week:Daily,
  60.0C Hot Water Week Rule - Jan1-Dec31, !- Name
  Schedule Day 2,                      !- Sunday Schedule:Day
  Name
  Schedule Day 2,                      !- Monday Schedule:Day
  Name
  Schedule Day 2,                      !- Tuesday Schedule:Day
  Name
  Schedule Day 2,                      !- Wednesday Schedule:Day
  Name
  Schedule Day 2,                      !- Thursday Schedule:Day
  Name
  Schedule Day 2,                      !- Friday Schedule:Day
  Name
  Schedule Day 2,                      !- Saturday Schedule:Day
  Name
  Schedule Day 2,                      !- Holiday Schedule:Day
  Name
  Schedule Day 2,                      !- SummerDesignDay
  Schedule:Day Name
  Schedule Day 2,                      !- WinterDesignDay
  Schedule:Day Name
  Schedule Day 2,                      !- CustomDay1 Schedule:Day
  Name

```

```

Schedule Day 2;                                ! - CustomDay2 Schedule:Day
    Name

Schedule:Year,
    60.0C Hot Water,                            ! - Name
    Temperature 1,                             ! - Schedule Type Limits
        Name
    60.0C Hot Water Week Rule - Jan1-Dec31,   ! - Schedule:Week Name 1
    1,                                         ! - Start Month 1
    1,                                         ! - Start Day 1
    12,                                         ! - End Month 1
    31;                                         ! - End Day 1

Schedule:Week:Daily,
    60C Hot Water Week Rule - Jan1-Dec31,      ! - Name
    Schedule Day 5,                           ! - Sunday Schedule:Day
        Name
    Schedule Day 5,                           ! - Monday Schedule:Day
        Name
    Schedule Day 5,                           ! - Tuesday Schedule:Day
        Name
    Schedule Day 5,                           ! - Wednesday Schedule:Day
        Name
    Schedule Day 5,                           ! - Thursday Schedule:Day
        Name
    Schedule Day 5,                           ! - Friday Schedule:Day
        Name
    Schedule Day 5,                           ! - Saturday Schedule:Day
        Name
    Schedule Day 5,                           ! - Holiday Schedule:Day
        Name
    Schedule Day 5,                           ! - SummerDesignDay
        Schedule:Day Name
    Schedule Day 5,                           ! - WinterDesignDay
        Schedule:Day Name

```

```

Schedule Day 5,                                ! - CustomDay1 Schedule:Day
    Name

Schedule Day 5;                                ! - CustomDay2 Schedule:Day
    Name

Schedule:Year,
    60C Hot Water,                            ! - Name
    Temperature 1,                           ! - Schedule Type Limits
    Name

60C Hot Water Week Rule - Jan1-Dec31,        ! - Schedule:Week Name 1
    1,                                         ! - Start Month 1
    1,                                         ! - Start Day 1
    12,                                         ! - End Month 1
    31;                                         ! - End Day 1

Schedule:Week:Daily,
    Always On Week Rule - Jan1-Dec31,          ! - Name
    Always On_Day Schedule,                   ! - Sunday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Monday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Tuesday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Wednesday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Thursday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Friday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Saturday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - Holiday Schedule:Day
    Name
    Always On_Day Schedule,                  ! - SummerDesignDay
    Schedule:Day Name

```

```

Always On_Day Schedule,           ! - WinterDesignDay
  Schedule:Day Name

Always On_Day Schedule,          ! - CustomDay1 Schedule:Day
  Name

Always On_Day Schedule;          ! - CustomDay2 Schedule:Day
  Name

Schedule:Year,
  Always On,                      ! - Name
  Fractional,                     ! - Schedule Type Limits
    Name

  Always On Week Rule - Jan1-Dec31, ! - Schedule:Week Name 1
  1,                                ! - Start Month 1
  1,                                ! - Start Day 1
  12,                               ! - End Month 1
  31;                               ! - End Day 1

Schedule:Week:Daily,
  MidriseApartment Building_People_Occ Schedule Week Rule - Jan1-
  Dec31, ! - Name

  MidriseApartment Building_People_Occ Schedule_Sunday, ! - Sunday
  Schedule:Day Name

  Schedule Day 1,                  ! - Monday Schedule:Day
    Name

  Schedule Day 1,                  ! - Tuesday Schedule:Day
    Name

  Schedule Day 1,                  ! - Wednesday Schedule:Day
    Name

  Schedule Day 1,                  ! - Thursday Schedule:Day
    Name

  Schedule Day 1,                  ! - Friday Schedule:Day
    Name

  MidriseApartment Building_People_Occ Schedule_Sunday, ! - Saturday
  Schedule:Day Name

  MidriseApartment Building_People_Occ Schedule_Hol 1, ! - Holiday
  Schedule:Day Name

```

```

MidriseApartment Building_People_Occ Schedule_SmrDsn 1, !-
    SummerDesignDay Schedule:Day Name
MidriseApartment Building_People_Occ Schedule_WntrDsn 1, !-
    WinterDesignDay Schedule:Day Name
MidriseApartment Building_People_Occ Schedule_Sunday, !-
    CustomDay1 Schedule:Day Name
MidriseApartment Building_People_Occ Schedule_Sunday; !-
    CustomDay2 Schedule:Day Name

Schedule:Year,
    MidriseApartment Building_People_Occ Schedule, !- Name
    Fractional,                                     !- Schedule Type Limits
        Name
    MidriseApartment Building_People_Occ Schedule Week Rule - Jan1-
        Dec31, !- Schedule:Week Name 1
        1,                                              !- Start Month 1
        1,                                              !- Start Day 1
        12,                                             !- End Month 1
        31;                                             !- End Day 1

Schedule:Week:Daily,
    Seated Adult Activity Week Rule - Jan1-Dec31, !- Name
    Seated Adult Activity_Day Schedule,           !- Sunday Schedule:Day
        Name
    Seated Adult Activity_Day Schedule,           !- Monday Schedule:Day
        Name
    Seated Adult Activity_Day Schedule,           !- Tuesday Schedule:Day
        Name
    Seated Adult Activity_Day Schedule,           !- Wednesday Schedule:Day
        Name
    Seated Adult Activity_Day Schedule,           !- Thursday Schedule:Day
        Name
    Seated Adult Activity_Day Schedule,           !- Friday Schedule:Day
        Name
    Seated Adult Activity_Day Schedule,           !- Saturday Schedule:Day
        Name

```

```

Seated Adult Activity_Day Schedule,      !- Holiday Schedule:Day
    Name

Seated Adult Activity_Day Schedule,      !- SummerDesignDay
    Schedule:Day Name

Seated Adult Activity_Day Schedule,      !- WinterDesignDay
    Schedule:Day Name

Seated Adult Activity_Day Schedule,      !- CustomDay1 Schedule:Day
    Name

Seated Adult Activity_Day Schedule;     !- CustomDay2 Schedule:Day
    Name

Schedule:Year,
    Seated Adult Activity,               !- Name
    Activity Level,                    !- Schedule Type Limits
        Name

Seated Adult Activity Week Rule - Jan1-Dec31, !- Schedule:Week
    Name 1
    1,                                !- Start Month 1
    1,                                !- Start Day 1
    12,                               !- End Month 1
    31;                               !- End Day 1

Schedule:File,
    project_equipment,                !- Name
    Fractional,                      !- Schedule Type Limits
        Name
    /content/drive/My Drive/Kuwait/reference_schedules/
        project_equipment.csv, !- File Name
    1,                                !- Column Number
    1,                                !- Rows to Skip at Top
    ,                                 !- Number of Hours of Data
    Comma,                            !- Column Separator
    No,                               !- Interpolate to Timestep
    60;                               !- Minutes per Item

Schedule:File,

```

```

project_gas,
           !- Name
Fractional,
           !- Schedule Type Limits
Name
/content/drive/My Drive/Kuwait/reference_schedules/project_gas.csv
, !- File Name
1,                      !- Column Number
1,                      !- Rows to Skip at Top
,                       !- Number of Hours of Data
Comma,                  !- Column Separator
No,                     !- Interpolate to Timestep
60;                     !- Minutes per Item

Schedule:File,
project_hot_water,
           !- Name
Fractional,
           !- Schedule Type Limits
Name
/content/drive/My Drive/Kuwait/reference_schedules/
project_hot_water.csv, !- File Name
1,                      !- Column Number
1,                      !- Rows to Skip at Top
,                       !- Number of Hours of Data
Comma,                  !- Column Separator
No,                     !- Interpolate to Timestep
60;                     !- Minutes per Item

Schedule:File,
project_light,
           !- Name
Fractional,
           !- Schedule Type Limits
Name
/content/drive/My Drive/Kuwait/reference_schedules/project_light.csv
, !- File Name
1,                      !- Column Number
1,                      !- Rows to Skip at Top
,                       !- Number of Hours of Data
Comma,                  !- Column Separator
No,                     !- Interpolate to Timestep

```

```

60;                                     !- Minutes per Item

Schedule:Constant,
    Always On Continuous,                !- Name
    ,
    !- Schedule Type Limits
    Name
    1;                                    !- Hourly Value

OutdoorAir:Node,
    Model Outdoor Air Node;            !- Name

AirLoopHVAC,
    Cooler - 15 Zone DOAS,             !- Name
    ,
    !- Controller List Name
    Air Loop HVAC 1 AvailabilityManagerAssignmentList, !- Availability
    Manager List Name
    AutoSize,                          !- Design Supply Air Flow
    Rate {m3/s}
    Cooler - 15 Zone DOAS Supply Branches,   !- Branch List Name
    ,
    !- Connector List Name
    15 Zone DOAS Supply Inlet Node,        !- Supply Side Inlet Node
    Name
    15 Zone DOAS Demand Outlet Node,      !- Demand Side Outlet Node
    Name
    Cooler - 15 Zone DOAS Demand Inlet Nodes, !- Demand Side Inlet
    Node Names
    Cooler - 15 Zone DOAS Supply Outlet Nodes, !- Supply Side Outlet
    Node Names
    1;                                    !- Design Return Air Flow
    Fraction of Supply Air Flow

NodeList,
    Cooler - 15 Zone DOAS Supply Outlet Nodes, !- Name
    15 Zone DOAS Supply Outlet Node;           !- Node Name 1

NodeList,

```

```

Cooler - 15 Zone DOAS Demand Inlet Nodes, !- Name
15 Zone DOAS Demand Inlet Node;           !- Node Name 1

Sizing:System,
  Cooler - 15 Zone DOAS,                  !- AirLoop Name
  VentilationRequirement,                !- Type of Load to Size On
  Autosize,                            !- Design Outdoor Air Flow
    Rate {m3/s}
  1,                                     !- Central Heating Maximum
    System Air Flow Ratio
  7,                                     !- Preheat Design
    Temperature {C}
  0.008,                                !- Preheat Design Humidity
    Ratio {kgWater/kgDryAir}
  12.8,                                  !- Precool Design
    Temperature {C}
  0.008,                                !- Precool Design Humidity
    Ratio {kgWater/kgDryAir}
  15.5555555555556,                     !- Central Cooling Design
    Supply Air Temperature {C}
  21.1111111111111,                     !- Central Heating Design
    Supply Air Temperature {C}
  Coincident,                           !- Type of Zone Sum to Use
  Yes,                                   !- 100% Outdoor Air in
    Cooling
  Yes,                                   !- 100% Outdoor Air in
    Heating
  0.0085,                               !- Central Cooling Design
    Supply Air Humidity Ratio {kgWater/kgDryAir}
  0.008,                                !- Central Heating Design
    Supply Air Humidity Ratio {kgWater/kgDryAir}
  DesignDay,                            !- Cooling Supply Air Flow
    Rate Method
  0,                                     !- Cooling Supply Air Flow
    Rate {m3/s}

```

```

0.0099676501,                                     ! - Cooling Supply Air Flow
    Rate Per Floor Area {m3/s-m2}

1,                                              ! - Cooling Fraction of
    Autosized Cooling Supply Air Flow Rate

3.9475456e-05,                                    ! - Cooling Supply Air Flow
    Rate Per Unit Cooling Capacity {m3/s-W}

DesignDay,                                         ! - Heating Supply Air Flow
    Rate Method

0,                                              ! - Heating Supply Air Flow
    Rate {m3/s}

0.0099676501,                                     ! - Heating Supply Air Flow
    Rate Per Floor Area {m3/s-m2}

1,                                              ! - Heating Fraction of
    Autosized Heating Supply Air Flow Rate

1,                                              ! - Heating Fraction of
    Autosized Cooling Supply Air Flow Rate

3.1588213e-05,                                    ! - Heating Supply Air Flow
    Rate Per Unit Heating Capacity {m3/s-W}

ZoneSum,                                           ! - System Outdoor Air
    Method

1,                                              ! - Zone Maximum Outdoor
    Air Fraction {dimensionless}

CoolingDesignCapacity,                            ! - Cooling Design Capacity
    Method

Autosize,                                         ! - Cooling Design Capacity
    {W}

234.7,                                            ! - Cooling Design Capacity
    Per Floor Area {W/m2}

1,                                              ! - Fraction of Autosized
    Cooling Design Capacity

HeatingDesignCapacity,                           ! - Heating Design Capacity
    Method

Autosize,                                         ! - Heating Design Capacity
    {W}

157,                                             ! - Heating Design Capacity
    Per Floor Area {W/m2}

```

```

1,                                     !- Fraction of Autosized
Heating Design Capacity
OnOff;                                !- Central Cooling
Capacity Control Method

AvailabilityManagerAssignmentList,
Air Loop HVAC 1 AvailabilityManagerAssignmentList, !- Name
AvailabilityManager:NightCycle,           !- Availability Manager
Object Type 1
Availability Manager Night Cycle 1;      !- Availability Manager
Name 1

AvailabilityManager:NightCycle,
Availability Manager Night Cycle 1,      !- Name
Always On Discrete,                     !- Applicability Schedule
Name
Standard_Ventilation,                  !- Fan Schedule Name
CycleOnAnyZoneFansOnly,                !- Control Type
1,                                      !- Thermostat Tolerance {
deltaC}
FixedRunTime,                          !- Cycling Run Time
Control Type
3600;                                  !- Cycling Run Time {s}

BranchList,
Cooler - 15 Zone DOAS Supply Branches, !- Name
Cooler - 15 Zone DOAS Main Branch;     !- Branch Name 1

Branch,
Cooler - 15 Zone DOAS Main Branch,     !- Name
,                                     !- Pressure Drop Curve
Name
Fan:ConstantVolume,                   !- Component Object Type 1
DOAS Exhaust Fan,                   !- Component Name 1
15 Zone DOAS Supply Inlet Node,     !- Component Inlet Node
Name 1

```

```

DOAS Exhaust Fan Outlet Air Node,           !- Component Outlet Node
  Name 1

AirLoopHVAC:OutdoorAirSystem,              !- Component Object Type 2
  15 Zone DOAS OA System,                  !- Component Name 2
DOAS Exhaust Fan Outlet Air Node,           !- Component Inlet Node
  Name 2

15 Zone DOAS Mixed Air Node,               !- Component Outlet Node
  Name 2

CoilSystem:Cooling:DX,                     !- Component Object Type 3
  15 Zone DOAS 2spd DX Clg Coil CoilSystem, !- Component Name 3
  15 Zone DOAS Mixed Air Node,             !- Component Inlet Node
    Name 3

  15 Zone DOAS 2spd DX Clg Coil Outlet Air Node, !- Component Outlet
    Node Name 3

CoilSystem:Heating:DX,                     !- Component Object Type 4
  15 Zone DOAS Htg Coil CoilSystem,       !- Component Name 4
  15 Zone DOAS 2spd DX Clg Coil Outlet Air Node, !- Component Inlet
    Node Name 4

  15 Zone DOAS Htg Coil Outlet Air Node,   !- Component Outlet Node
    Name 4

Coil:Heating:Electric,                   !- Component Object Type 5
  15 Zone DOAS Backup Htg Coil,           !- Component Name 5
  15 Zone DOAS Htg Coil Outlet Air Node, !- Component Inlet Node
    Name 5

  15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Component Outlet
    Node Name 5

Fan:ConstantVolume,                      !- Component Object Type 6
  DOAS Supply Fan,                      !- Component Name 6
  15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Component Inlet
    Node Name 6

  15 Zone DOAS Supply Outlet Node;      !- Component Outlet Node
    Name 6

Fan:ConstantVolume,
  DOAS Exhaust Fan,                   !- Name

```

```

Standard_Ventilation , !- Availability Schedule
  Name
  0.58175 , !- Fan Total Efficiency
  373.633365 , !- Pressure Rise {Pa}
  AutoSize , !- Maximum Flow Rate {m3/s}
  }
  0.895 , !- Motor Efficiency
  1 , !- Motor In Airstream
  Fraction
  15 Zone DOAS Supply Inlet Node , !- Air Inlet Node Name
  DOAS Exhaust Fan Outlet Air Node , !- Air Outlet Node Name
  DOAS Fans; !- End-Use Subcategory

SetpointManager:MixedAir ,
  DOAS Exhaust Fan Outlet Air Node OS Default SPM , !- Name
  Temperature , !- Control Variable
  15 Zone DOAS Supply Outlet Node , !- Reference Setpoint Node
  Name
  15 Zone DOAS Backup Htg Coil Outlet Air Node , !- Fan Inlet Node
  Name
  15 Zone DOAS Supply Outlet Node , !- Fan Outlet Node Name
  DOAS Exhaust Fan Outlet Air Node ; !- Setpoint Node or
  NodeList Name

AirLoopHVAC:OutdoorAirSystem ,
  15 Zone DOAS OA System , !- Name
  15 Zone DOAS OA System Controller List , !- Controller List Name
  15 Zone DOAS OA System Equipment List , !- Outdoor Air Equipment
  List Name
  15 Zone DOAS OA System Availability Manager List; !- Availability
  Manager List Name

AirLoopHVAC:ControllerList ,
  15 Zone DOAS OA System Controller List , !- Name
  Controller:OutdoorAir , !- Controller Object Type
  1

```

```

15 Zone DOAS Outdoor Air Controller;      !- Controller Name 1

Controller:OutdoorAir,
  15 Zone DOAS Outdoor Air Controller,      !- Name
  15 Zone DOAS Relief Air Node,           !- Relief Air Outlet Node
    Name
  DOAS Exhaust Fan Outlet Air Node,       !- Return Air Node Name
  15 Zone DOAS Mixed Air Node,            !- Mixed Air Node Name
  15 Zone DOAS Outdoor Air Node,          !- Actuator Node Name
    Autosize,                            !- Minimum Outdoor Air
    Flow Rate {m3/s}
  Autosize,                            !- Maximum Outdoor Air
    Flow Rate {m3/s}
  NoEconomizer,                         !- Economizer Control Type
  ModulateFlow,                          !- Economizer Control
    Action Type
  ,
    Limit Dry-Bulb Temperature {C}        !- Economizer Maximum
  ,
    Limit Enthalpy {J/kg}                !- Economizer Maximum
  ,
    Limit Dewpoint Temperature {C}       !- Electronic Enthalpy
  ,
    Limit Curve Name                   !- Economizer Minimum
  ,
    Limit Dry-Bulb Temperature {C}
  NoLockout,                            !- Lockout Type
  FixedMinimum,                          !- Minimum Limit Type
  Standard_Ventilation,                 !- Minimum Outdoor Air
    Schedule Name
  ,
    !- Minimum Fraction of
    Outdoor Air Schedule Name
  ,
    !- Maximum Fraction of
    Outdoor Air Schedule Name
  15 Zone DOAS Mechanical Ventilation Controller, !- Mechanical
    Ventilation Controller Name

```

```

        ,                                     !- Time of Day Economizer
Control Schedule Name

No,                                         !- High Humidity Control
,
                                         !- Humidistat Control Zone
Name
,
                                         !- High Humidity Outdoor
Air Flow Ratio

Yes,                                         !- Control High Indoor
Humidity Based on Outdoor Humidity Ratio
BypassWhenWithinEconomizerLimits;          !- Heat Recovery Bypass
Control Type

AvailabilityManagerAssignmentList,
15 Zone DOAS OA System Availability Manager List, !- Name
AvailabilityManager:Scheduled,              !- Availability Manager
Object Type 1
15 Zone DOAS OA System Availability Manager; !- Availability
Manager Name 1

AvailabilityManager:Scheduled,
15 Zone DOAS OA System Availability Manager, !- Name
Always On Discrete;                      !- Schedule Name

OutdoorAir:NodeList,
15 Zone DOAS Outdoor Air Node;           !- Node or NodeList Name 1

AirLoopHVAC:OutdoorAirSystem:EquipmentList,
15 Zone DOAS OA System Equipment List,   !- Name
OutdoorAir:Mixer,                        !- Component Object Type 1
15 Zone DOAS OA System Outdoor Air Mixer; !- Component Name 1

OutdoorAir:Mixer,
15 Zone DOAS OA System Outdoor Air Mixer, !- Name
15 Zone DOAS Mixed Air Node,             !- Mixed Air Node Name
15 Zone DOAS Outdoor Air Node,          !- Outdoor Air Stream Node
Name

```

```

15 Zone DOAS Relief Air Node,           !- Relief Air Stream Node
      Name

DOAS Exhaust Fan Outlet Air Node;     !- Return Air Stream Node
      Name

SetpointManager:MixedAir,
  15 Zone DOAS Mixed Air Node OS Default SPM, !- Name
  Temperature,                         !- Control Variable
  15 Zone DOAS Supply Outlet Node,      !- Reference Setpoint Node
      Name
  15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Fan Inlet Node
      Name
  15 Zone DOAS Supply Outlet Node,      !- Fan Outlet Node Name
  15 Zone DOAS Mixed Air Node;         !- Setpoint Node or
      NodeList Name

CoilSystem:Cooling:DX,
  15 Zone DOAS 2spd DX Clg Coil CoilSystem, !- Name
  Always On Discrete,                  !- Availability Schedule
      Name
  15 Zone DOAS Mixed Air Node,         !- DX Cooling Coil System
      Inlet Node Name
  15 Zone DOAS 2spd DX Clg Coil Outlet Air Node, !- DX Cooling Coil
      System Outlet Node Name
  15 Zone DOAS 2spd DX Clg Coil Outlet Air Node, !- DX Cooling Coil
      System Sensor Node Name
  Coil:Cooling:DX:TwoSpeed,           !- Cooling Coil Object
      Type
  15 Zone DOAS 2spd DX Clg Coil;      !- Cooling Coil Name

Coil:Cooling:DX:TwoSpeed,
  15 Zone DOAS 2spd DX Clg Coil,      !- Name
  Always On Discrete,                !- Availability Schedule
      Name
  Autosize,                          !- High Speed Gross Rated
  Total Cooling Capacity {W}

```

```

Autosize,                                !- High Speed Rated
    Sensible Heat Ratio
4.5,                                     !- High Speed Gross Rated
    Cooling COP {W/W}
Autosize,                                !- High Speed Rated Air
    Flow Rate {m3/s}
773.3,                                    !- Unit Internal Static
    Air Pressure {Pa}
15 Zone DOAS Mixed Air Node,             !- Air Inlet Node Name
15 Zone DOAS 2spd DX Clg Coil Outlet Air Node, !- Air Outlet Node
Name
Curve Biquadratic 1,                      !- Total Cooling Capacity
    Function of Temperature Curve Name
Curve Quadratic 3,                        !- Total Cooling Capacity
    Function of Flow Fraction Curve Name
Curve Biquadratic 2,                      !- Energy Input Ratio
    Function of Temperature Curve Name
Curve Quadratic 4,                        !- Energy Input Ratio
    Function of Flow Fraction Curve Name
Curve Quadratic 5,                        !- Part Load Fraction
    Correlation Curve Name
Autosize,                                !- Low Speed Gross Rated
    Total Cooling Capacity {W}
0.69,                                     !- Low Speed Gross Rated
    Sensible Heat Ratio
4.5,                                     !- Low Speed Gross Rated
    Cooling COP {W/W}
Autosize,                                !- Low Speed Rated Air
    Flow Rate {m3/s}
Curve Biquadratic 3,                      !- Low Speed Total Cooling
    Capacity Function of Temperature Curve Name
Curve Biquadratic 4,                      !- Low Speed Energy Input
    Ratio Function of Temperature Curve Name
,                                         !- Condenser Air Inlet
    Node Name
AirCooled,                               !- Condenser Type

```

```

-25,                                     !- Minimum Outdoor Dry-
Bulb Temperature for Compressor Operation {C}
0,                                         !- High Speed Evaporative
Condenser Effectiveness {dimensionless}
Autosize,                                    !- High Speed Evaporative
Condenser Air Flow Rate {m3/s}
Autosize,                                    !- High Speed Evaporative
Condenser Pump Rated Power Consumption {W}
0,                                         !- Low Speed Evaporative
Condenser Effectiveness {dimensionless}
Autosize,                                    !- Low Speed Evaporative
Condenser Air Flow Rate {m3/s}
Autosize,                                    !- Low Speed Evaporative
Condenser Pump Rated Power Consumption {W}
,
                                         !- Supply Water Storage
Tank Name
,
                                         !- Condensate Collection
Water Storage Tank Name
10,                                         !- Basin Heater Capacity {
W/K}
2;                                         !- Basin Heater Setpoint
Temperature {C}

SetpointManager:MixedAir,
15 Zone DOAS 2spd DX Clg Coil Outlet Air Node OS Default SPM, !-
Name
Temperature,                                !- Control Variable
15 Zone DOAS Supply Outlet Node,           !- Reference Setpoint Node
Name
15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Fan Inlet Node
Name
15 Zone DOAS Supply Outlet Node,           !- Fan Outlet Node Name
15 Zone DOAS 2spd DX Clg Coil Outlet Air Node; !- Setpoint Node or
NodeList Name

Curve:Biquadratic,

```

```

Curve Biquadratic 1,
0.42415,                                     ! - Name
0.04426,                                     ! - Coefficient1 Constant
-0.00042,                                     ! - Coefficient2 x
0.00333,                                     ! - Coefficient3 x**2
-8e-05,                                       ! - Coefficient4 y
-0.00021,                                     ! - Coefficient5 y**2
17,                                            ! - Coefficient6 x*y
                                                ! - Minimum Value of x {
BasedOnField A2}

22,                                            ! - Maximum Value of x {
BasedOnField A2}

13,                                            ! - Minimum Value of y {
BasedOnField A3}

46;                                            ! - Maximum Value of y {
BasedOnField A3}

Curve:Quadratic ,
Curve Quadratic 3,                           ! - Name
0.77136,                                     ! - Coefficient1 Constant
0.34053,                                     ! - Coefficient2 x
-0.11088,                                     ! - Coefficient3 x**2
0.75918,                                     ! - Minimum Value of x {
BasedOnField A2}

1.13877;                                      ! - Maximum Value of x {
BasedOnField A2}

Curve:Biquadratic ,
Curve Biquadratic 2,                           ! - Name
1.23649,                                     ! - Coefficient1 Constant
-0.02431,                                     ! - Coefficient2 x
0.00057,                                     ! - Coefficient3 x**2
-0.01434,                                     ! - Coefficient4 y
0.00063,                                     ! - Coefficient5 y**2
-0.00038,                                     ! - Coefficient6 x*y
17,                                            ! - Minimum Value of x {
BasedOnField A2}

```

```

22,                                     ! - Maximum Value of x {
    BasedOnField A2}

13,                                      ! - Minimum Value of y {
    BasedOnField A3}

46;                                     ! - Maximum Value of y {
    BasedOnField A3}

Curve:Quadratic,
    Curve Quadratic 4,                  ! - Name
    1.2055,                            ! - Coefficient1 Constant
    -0.32953,                           ! - Coefficient2 x
    0.12308,                            ! - Coefficient3 x**2
    0.75918,                            ! - Minimum Value of x {
    BasedOnField A2}                   ! - Maximum Value of x {
    1.13877;                           ! - Maximum Value of x {
    BasedOnField A2}                   ! - Maximum Value of x {

Curve:Quadratic,
    Curve Quadratic 5,                  ! - Name
    0.771,                             ! - Coefficient1 Constant
    0.229,                            ! - Coefficient2 x
    0,                                 ! - Coefficient3 x**2
    0,                                 ! - Minimum Value of x {
    BasedOnField A2}                   ! - Maximum Value of x {
    1;                                ! - Maximum Value of x {
    BasedOnField A2}                   ! - Maximum Value of x {

Curve:Biquadratic,
    Curve Biquadratic 3,                ! - Name
    0.42415,                           ! - Coefficient1 Constant
    0.04426,                           ! - Coefficient2 x
    -0.00042,                           ! - Coefficient3 x**2
    0.00333,                            ! - Coefficient4 y
    -8e-05,                            ! - Coefficient5 y**2
    -0.00021,                           ! - Coefficient6 x*y

```

```

17,                                     ! - Minimum Value of x {
    BasedOnField A2}

22,                                     ! - Maximum Value of x {
    BasedOnField A2}

13,                                     ! - Minimum Value of y {
    BasedOnField A3}

46;                                     ! - Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic,
Curve Biquadratic 4,                      ! - Name
1.23649,                                  ! - Coefficient1 Constant
-0.02431,                                 ! - Coefficient2 x
0.00057,                                  ! - Coefficient3 x**2
-0.01434,                                 ! - Coefficient4 y
0.00063,                                  ! - Coefficient5 y**2
-0.00038,                                 ! - Coefficient6 x*y
17,                                      ! - Minimum Value of x {
    BasedOnField A2}

22,                                      ! - Maximum Value of x {
    BasedOnField A2}

13,                                      ! - Minimum Value of y {
    BasedOnField A3}

46;                                      ! - Maximum Value of y {
    BasedOnField A3}

CoilSystem:Heating:DX,
15 Zone DOAS Htg Coil CoilSystem,        ! - Name
Always On Discrete,                      ! - Availability Schedule
Name

Coil:Heating:DX:SingleSpeed,              ! - Heating Coil Object
Type

15 Zone DOAS Htg Coil;                  ! - Heating Coil Name

Coil:Heating:DX:SingleSpeed,
15 Zone DOAS Htg Coil,                  ! - Name

```

```

Always On Discrete , !- Availability Schedule
  Name

Autosize , !- Gross Rated Heating
  Capacity {W}

3.3 , !- Gross Rated Heating COP
  {W/W}

Autosize , !- Rated Air Flow Rate {m3
/s}

773.3 , !- Rated Supply Fan Power
  Per Volume Flow Rate {W/(m3/s)}

15 Zone DOAS 2spd DX Clg Coil Outlet Air Node , !- Air Inlet Node
  Name

15 Zone DOAS Htg Coil Outlet Air Node , !- Air Outlet Node Name

15 Zone DOAS Htg Coil Htg Cap Func of Temp Curve , !- Heating
  Capacity Function of Temperature Curve Name

15 Zone DOAS Htg Coil Htg Cap Func of Flow Frac Curve , !- Heating
  Capacity Function of Flow Fraction Curve Name

15 Zone DOAS Htg Coil EIR Func of Temp Curve , !- Energy Input
  Ratio Function of Temperature Curve Name

15 Zone DOAS Htg Coil EIR Func of Flow Frac Curve , !- Energy Input
  Ratio Function of Flow Fraction Curve Name

15 Zone DOAS Htg Coil PLR Correlation Curve , !- Part Load Fraction
  Correlation Curve Name

15 Zone DOAS Htg Coil Defrost EIR Func of Temp Curve , !- Defrost
  Energy Input Ratio Function of Temperature Curve Name

-8 , !- Minimum Outdoor Dry-
  Bulb Temperature for Compressor Operation {C}
  ,
  !- Outdoor Dry-Bulb
  Temperature to Turn On Compressor {C}

5 , !- Maximum Outdoor Dry-
  Bulb Temperature for Defrost Operation {C}

0 , !- Crankcase Heater
  Capacity {W}

10 , !- Maximum Outdoor Dry-
  Bulb Temperature for Crankcase Heater Operation {C}

ReverseCycle , !- Defrost Strategy

```

```

OnDemand ,                                     !- Defrost Control
0.166667 ,                                    !- Defrost Time Period
    Fraction
2000;                                         !- Resistive Defrost
    Heater Capacity {W}

Curve:Cubic,
15 Zone DOAS Htg Coil Htg Cap Func of Temp Curve, !- Name
0.758746,                                      !- Coefficient1 Constant
0.027626,                                      !- Coefficient2 x
0.000148716,                                    !- Coefficient3 x**2
3.4992e-06,                                     !- Coefficient4 x**3
-20,                                            !- Minimum Value of x {
    BasedOnField A2}
20;                                              !- Maximum Value of x {
    BasedOnField A2}

Curve:Cubic,
15 Zone DOAS Htg Coil Htg Cap Func of Flow Frac Curve, !- Name
0.84,                                           !- Coefficient1 Constant
0.16,                                           !- Coefficient2 x
0,                                               !- Coefficient3 x**2
0,                                               !- Coefficient4 x**3
0.5,                                            !- Minimum Value of x {
    BasedOnField A2}
1.5;                                             !- Maximum Value of x {
    BasedOnField A2}

Curve:Cubic,
15 Zone DOAS Htg Coil EIR Func of Temp Curve, !- Name
1.19248,                                         !- Coefficient1 Constant
-0.0300438,                                      !- Coefficient2 x
0.00103745,                                     !- Coefficient3 x**2
-2.3328e-05,                                     !- Coefficient4 x**3
-20,                                            !- Minimum Value of x {
    BasedOnField A2}

```

```

20;                                     ! - Maximum Value of x {
    BasedOnField A2}

Curve:Quadratic,
15 Zone DOAS Htg Coil EIR Func of Flow Frac Curve, !- Name
1.3824,                                     !- Coefficient1 Constant
-0.4336,                                     !- Coefficient2 x
0.0512,                                     !- Coefficient3 x**2
0,                                           !- Minimum Value of x {
    BasedOnField A2}
1;                                             !- Maximum Value of x {
    BasedOnField A2}

Curve:Quadratic,
15 Zone DOAS Htg Coil PLR Correlation Curve, !- Name
0.85,                                         !- Coefficient1 Constant
0.15,                                         !- Coefficient2 x
0,                                            !- Coefficient3 x**2
0,                                           !- Minimum Value of x {
    BasedOnField A2}
1;                                             !- Maximum Value of x {
    BasedOnField A2}

Curve:Biquadratic,
15 Zone DOAS Htg Coil Defrost EIR Func of Temp Curve, !- Name
0.297145,                                     !- Coefficient1 Constant
0.0430933,                                     !- Coefficient2 x
-0.000748766,                                    !- Coefficient3 x**2
0.00597727,                                     !- Coefficient4 y
0.000482112,                                    !- Coefficient5 y**2
-0.000956448,                                    !- Coefficient6 x*y
-23.33333,                                      !- Minimum Value of x {
    BasedOnField A2}
29.44444,                                     !- Maximum Value of x {
    BasedOnField A2}

```

```

-23.33333,                                     !- Minimum Value of y {
BasedOnField A3}

29.44444;                                      !- Maximum Value of y {
BasedOnField A3}

SetpointManager:MixedAir,
15 Zone DOAS Htg Coil Outlet Air Node OS Default SPM, !- Name
Temperature,                                     !- Control Variable
15 Zone DOAS Supply Outlet Node,                !- Reference Setpoint Node
Name
15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Fan Inlet Node
Name
15 Zone DOAS Supply Outlet Node,                !- Fan Outlet Node Name
15 Zone DOAS Htg Coil Outlet Air Node;         !- Setpoint Node or
NodeList Name

Coil:Heating:Electric,
15 Zone DOAS Backup Htg Coil,                  !- Name
Always On Discrete,                           !- Availability Schedule
Name
1,                                              !- Efficiency
Autosize,                                       !- Nominal Capacity {W}
15 Zone DOAS Htg Coil Outlet Air Node,        !- Air Inlet Node Name
15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Air Outlet Node
Name
15 Zone DOAS Backup Htg Coil Outlet Air Node; !- Temperature
Setpoint Node Name

SetpointManager:MixedAir,
15 Zone DOAS Backup Htg Coil Outlet Air Node OS Default SPM, !-
Name
Temperature,                                     !- Control Variable
15 Zone DOAS Supply Outlet Node,                !- Reference Setpoint Node
Name
15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Fan Inlet Node
Name

```

```

15 Zone DOAS Supply Outlet Node,           !- Fan Outlet Node Name
15 Zone DOAS Backup Htg Coil Outlet Air Node; !- Setpoint Node or
NodeList Name

Fan:ConstantVolume,
DOAS Supply Fan,                         !- Name
Standard_Ventilation,                    !- Availability Schedule
Name
0.58175,                                !- Fan Total Efficiency
622.722275,                             !- Pressure Rise {Pa}
AutoSize,                                 !- Maximum Flow Rate {m3/s
}
0.895,                                  !- Motor Efficiency
1,                                       !- Motor In Airstream
Fraction

15 Zone DOAS Backup Htg Coil Outlet Air Node, !- Air Inlet Node
Name

15 Zone DOAS Supply Outlet Node,           !- Air Outlet Node Name
DOAS Fans;                               !- End-Use Subcategory

SetpointManager:OutdoorAirReset,
15 Zone DOAS SAT Reset,                  !- Name
Temperature,                            !- Control Variable
21.1111111111111,                      !- Setpoint at Outdoor Low
Temperature {C}
12.77777777777778,                   !- Outdoor Low Temperature
{C}
15.5555555555556,                     !- Setpoint at Outdoor
High Temperature {C}
21.111111111111,                      !- Outdoor High
Temperature {C}
15 Zone DOAS Supply Outlet Node;       !- Setpoint Node or
NodeList Name

AirLoopHVAC:SupplyPath,

```

```

Cooler - 15 Zone DOAS 15 Zone DOAS Demand Inlet Node Supply Path,
!- Name

15 Zone DOAS Demand Inlet Node,           !- Supply Air Path Inlet
Node Name

AirLoopHVAC:ZoneSplitter,                 !- Component Object Type 1
Air Loop HVAC Zone Splitter 1;           !- Component Name 1

AirLoopHVAC:ZoneSplitter,
Air Loop HVAC Zone Splitter 1,           !- Name
15 Zone DOAS Demand Inlet Node,         !- Inlet Node Name
Room_16_3d8c5364 Air Terminal Inlet Air Node, !- Outlet Node Name
1
Room_17_fb615533 Air Terminal Inlet Air Node, !- Outlet Node Name
2
Room_18_6cc35095 Air Terminal Inlet Air Node, !- Outlet Node Name
3
Room_19_6ae0f9a9 Air Terminal Inlet Air Node, !- Outlet Node Name
4
Room_20_4d060559 Air Terminal Inlet Air Node, !- Outlet Node Name
5
Room_21_4c523269 Air Terminal Inlet Air Node, !- Outlet Node Name
6
Room_22_f3ee5a53 Air Terminal Inlet Air Node, !- Outlet Node Name
7
Room_23_e751e71f Air Terminal Inlet Air Node, !- Outlet Node Name
8
Room_24_159d21b7 Air Terminal Inlet Air Node, !- Outlet Node Name
9
Room_25_d27e0933 Air Terminal Inlet Air Node, !- Outlet Node Name
10
Room_26_f4ea3797 Air Terminal Inlet Air Node, !- Outlet Node Name
11
Room_27_0080b418 Air Terminal Inlet Air Node, !- Outlet Node Name
12
Room_28_d6ed2799 Air Terminal Inlet Air Node, !- Outlet Node Name
13

```

```

Room_29_2a634042 Air Terminal Inlet Air Node, !- Outlet Node Name
14

Room_30_98f1d6c8 Air Terminal Inlet Air Node; !- Outlet Node Name
15

AirLoopHVAC:ReturnPath,
    Cooler - 15 Zone DOAS Return Path,      !- Name
    15 Zone DOAS Demand Outlet Node,        !- Return Air Path Outlet
    Node Name

AirLoopHVAC:ZoneMixer,                      !- Component Object Type 1
    Air Loop HVAC Zone Mixer 1;            !- Component Name 1

AirLoopHVAC:ZoneMixer,
    Air Loop HVAC Zone Mixer 1,           !- Name
    15 Zone DOAS Demand Outlet Node,     !- Outlet Node Name
    Room_16_3d8c5364 Return Air Node,    !- Inlet Node Name 1
    Room_17_fb615533 Return Air Node,    !- Inlet Node Name 2
    Room_18_6cc35095 Return Air Node,    !- Inlet Node Name 3
    Room_19_6ae0f9a9 Return Air Node,    !- Inlet Node Name 4
    Room_20_4d060559 Return Air Node,    !- Inlet Node Name 5
    Room_21_4c523269 Return Air Node,    !- Inlet Node Name 6
    Room_22_f3ee5a53 Return Air Node,    !- Inlet Node Name 7
    Room_23_e751e71f Return Air Node,    !- Inlet Node Name 8
    Room_24_159d21b7 Return Air Node,    !- Inlet Node Name 9
    Room_25_d27e0933 Return Air Node,    !- Inlet Node Name 10
    Room_26_f4ea3797 Return Air Node,    !- Inlet Node Name 11
    Room_27_0080b418 Return Air Node,    !- Inlet Node Name 12
    Room_28_d6ed2799 Return Air Node,    !- Inlet Node Name 13
    Room_29_2a634042 Return Air Node,    !- Inlet Node Name 14
    Room_30_98f1d6c8 Return Air Node;    !- Inlet Node Name 15

AirConditioner:VariableRefrigerantFlow,
    15 Zone VRF System,                  !- Heat Pump Name
    Always On Discrete,                !- Availability Schedule
    Name

```

```

Autosize,                                     !- Gross Rated Total
    Cooling Capacity {W}
4.287,                                         !- Gross Rated Cooling COP
    {W/W}
-15,                                           !- Minimum Outdoor
    Temperature in Cooling Mode {C}
50,                                            !- Maximum Outdoor
    Temperature in Cooling Mode {C}
vrf_cool_cap_f_of_low_temp,                   !- Cooling Capacity Ratio
    Modifier Function of Low Temperature Curve Name
vrf_cool_cap_ratio_boundary,                 !- Cooling Capacity Ratio
    Boundary Curve Name
vrf_cool_cap_f_of_high_temp,                  !- Cooling Capacity Ratio
    Modifier Function of High Temperature Curve Name
vrf_cool_eir_f_of_low_temp,                   !- Cooling Energy Input
    Ratio Modifier Function of Low Temperature Curve Name
vrf_cool_eir_ratio_boundary,                 !- Cooling Energy Input
    Ratio Boundary Curve Name
vrf_cool_eir_f_of_high_temp,                  !- Cooling Energy Input
    Ratio Modifier Function of High Temperature Curve Name
vrf_cool_eir_f_of_low_temp 1,                 !- Cooling Energy Input
    Ratio Modifier Function of Low Part-Load Ratio Curve Name
vrf_cooling_eir_high_plr,                    !- Cooling Energy Input
    Ratio Modifier Function of High Part-Load Ratio Curve Name
vrf_cooling_comb_ratio,                      !- Cooling Combination
    Ratio Correction Factor Curve Name
vrf_cooling_cplffplr,                        !- Cooling Part-Load
    Fraction Correlation Curve Name
Autosize,                                     !- Gross Rated Heating
    Capacity {W}
1,                                              !- Rated Heating Capacity
    Sizing Ratio {W/W}
4.147,                                         !- Gross Rated Heating COP
    {W/W}
-25,                                           !- Minimum Outdoor
    Temperature in Heating Mode {C}

```

```

16.1,                                     ! - Maximum Outdoor
Temperature in Heating Mode {C}
vrf_heat_cap_f_of_low_temp,                 ! - Heating Capacity Ratio
Modifier Function of Low Temperature Curve Name
vrf_heat_cap_ratio_boundary,                ! - Heating Capacity Ratio
Boundary Curve Name
vrf_heat_cap_f_of_high_temp,                 ! - Heating Capacity Ratio
Modifier Function of High Temperature Curve Name
vrf_heat_eir_f_of_low_temp,                  ! - Heating Energy Input
Ratio Modifier Function of Low Temperature Curve Name
vrf_heat_eir_boundary,                     ! - Heating Energy Input
Ratio Boundary Curve Name
vrf_heat_eir_f_of_high_temp,                 ! - Heating Energy Input
Ratio Modifier Function of High Temperature Curve Name
WetBulbTemperature,                       ! - Heating Performance
Curve Outdoor Temperature Type
vrf_heating_eir_low_plr,                   ! - Heating Energy Input
Ratio Modifier Function of Low Part-Load Ratio Curve Name
vrf_heating_eir_hi_plr,                    ! - Heating Energy Input
Ratio Modifier Function of High Part-Load Ratio Curve Name
vrf_heating_comb_ratio,                   ! - Heating Combination
Ratio Correction Factor Curve Name
vrf_heating_cplffplr,                     ! - Heating Part-Load
Fraction Correlation Curve Name
0.25,                                      ! - Minimum Heat Pump Part-
Load Ratio {dimensionless}
Room_16_3d8c5364,                         ! - Zone Name for Master
Thermostat Location
LoadPriority,                               ! - Master Thermostat
Priority Control Type
,                                         ! - Thermostat Priority
Schedule Name
15 Zone VRF System Terminal List,          ! - Zone Terminal Unit List
Name
Yes,                                       ! - Heat Pump Waste Heat
Recovery

```

```

30.48,                                     !- Equivalent Piping
Length used for Piping Correction Factor in Cooling Mode {m}
10.668,                                      !- Vertical Height used
for Piping Correction Factor {m}
Air Conditioner Variable Refrigerant Flow 1
CoolingLengthCorrectionFactor, !- Piping Correction Factor for
Length in Cooling Mode Curve Name
-0.000386,                                     !- Piping Correction
Factor for Height in Cooling Mode Coefficient {1/m}
30.48,                                     !- Equivalent Piping
Length used for Piping Correction Factor in Heating Mode {m}
,
!- Piping Correction
Factor for Length in Heating Mode Curve Name
0,                                         !- Piping Correction
Factor for Height in Heating Mode Coefficient {1/m}
15,                                         !- Crankcase Heater Power
per Compressor {W}
3,                                           !- Number of Compressors {
dimensionless}
0.33,                                         !- Ratio of Compressor
Size to Total Compressor Capacity {W/W}
7,                                            !- Maximum Outdoor Dry-
Bulb Temperature for Crankcase Heater {C}
ReverseCycle,                                !- Defrost Strategy
OnDemand,                                    !- Defrost Control
vrf_defrost_eir_f_of_temp,                   !- Defrost Energy Input
Ratio Modifier Function of Temperature Curve Name
0.058333,                                     !- Defrost Time Period
Fraction {dimensionless}
1e-07,                                         !- Resistive Defrost
Heater Capacity {W}
7,                                            !- Maximum Outdoor Dry-
bulb Temperature for Defrost Operation {C}
AirCooled,                                    !- Condenser Type
,
!- Condenser Inlet Node
Name

```

```

,
! - Condenser Outlet Node

Name

Autosize,
! - Water Condenser Volume

Flow Rate {m3/s}

0.9,
! - Evaporative Condenser

Effectiveness {dimensionless}

Autosize,
! - Evaporative Condenser

Air Flow Rate {m3/s}

Autosize,
! - Evaporative Condenser

Pump Rated Power Consumption {W}

,
! - Supply Water Storage

Tank Name

0,
! - Basin Heater Capacity {

W/K}

2,
! - Basin Heater Setpoint

Temperature {C}

,
! - Basin Heater Operating

Schedule Name

Electricity,
! - Fuel Type

-10,
! - Minimum Outdoor

Temperature in Heat Recovery Mode {C}

27.2,
! - Maximum Outdoor

Temperature in Heat Recovery Mode {C}

,
! - Heat Recovery Cooling

Capacity Modifier Curve Name

0.5,
! - Initial Heat Recovery

Cooling Capacity Fraction {W/W}

0.083,
! - Heat Recovery Cooling

Capacity Time Constant {hr}

,
! - Heat Recovery Cooling

Energy Modifier Curve Name

1,
! - Initial Heat Recovery

Cooling Energy Fraction {W/W}

0,
! - Heat Recovery Cooling

Energy Time Constant {hr}

```

```

,
! - Heat Recovery Heating

Capacity Modifier Curve Name
0.5, ! - Initial Heat Recovery
Heating Capacity Fraction {W/W}
0.083, ! - Heat Recovery Heating
Capacity Time Constant {hr}
,
! - Heat Recovery Heating
Energy Modifier Curve Name
0.5, ! - Initial Heat Recovery
Heating Energy Fraction {W/W}
0; ! - Heat Recovery Heating
Energy Time Constant {hr}

Curve:Biquadratic,
vrf_cool_cap_f_of_low_temp, ! - Name
-1.69653019339465, ! - Coefficient1 Constant
0.207248180531939, ! - Coefficient2 x
-0.00343146229659024, ! - Coefficient3 x**2
0.016381597419714, ! - Coefficient4 y
-6.7387172629965e-05, ! - Coefficient5 y**2
-0.000849848402870241, ! - Coefficient6 x*y
13.9, ! - Minimum Value of x {
BasedOnField A2}
23.9, ! - Maximum Value of x {
BasedOnField A2}
-5, ! - Minimum Value of y {
BasedOnField A3}
43.3, ! - Maximum Value of y {
BasedOnField A3}
0.59, ! - Minimum Curve Output {
BasedOnField A4}
1.33; ! - Maximum Curve Output {
BasedOnField A4}

Curve:Cubic,
vrf_cool_cap_ratio_boundary, ! - Name

```

```

25.73,                                     ! - Coefficient1 Constant
-0.03150043,                                ! - Coefficient2 x
-0.01416595,                                ! - Coefficient3 x**2
0,                                         ! - Coefficient4 x**3
11,                                         ! - Minimum Value of x {
    BasedOnField A2}
30;                                         ! - Maximum Value of x {
    BasedOnField A2}

Curve:Biquadratic,
vrf_cool_cap_f_of_high_temp,                 ! - Name
0.6867358,                                    ! - Coefficient1 Constant
0.0207631,                                    ! - Coefficient2 x
0.0005447,                                    ! - Coefficient3 x**2
-0.0016218,                                   ! - Coefficient4 y
-4.259e-07,                                    ! - Coefficient5 y**2
-0.0003392,                                   ! - Coefficient6 x*y
15,                                         ! - Minimum Value of x {
    BasedOnField A2}
24,                                         ! - Maximum Value of x {
    BasedOnField A2}
16,                                         ! - Minimum Value of y {
    BasedOnField A3}
43;                                         ! - Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic,
vrf_cool_eir_f_of_low_temp,                  ! - Name
-1.61908214818635,                           ! - Coefficient1 Constant
0.185964818731756,                          ! - Coefficient2 x
-0.00389610393381592,                      ! - Coefficient3 x**2
-0.00901995326324613,                      ! - Coefficient4 y
0.00030340007815629,                        ! - Coefficient5 y**2
0.000476048529099348,                      ! - Coefficient6 x*y
13.9,                                         ! - Minimum Value of x {
    BasedOnField A2}

```

```

23.9,                                     ! - Maximum Value of x {
    BasedOnField A2}

-5,                                         ! - Minimum Value of y {
    BasedOnField A3}

43.3,                                     ! - Maximum Value of y {
    BasedOnField A3}

0.27,                                       ! - Minimum Curve Output {
    BasedOnField A4}

1.15;                                       ! - Maximum Curve Output {
    BasedOnField A4}

Curve:Cubic,
vrf_cool_eir_ratio_boundary,               ! - Name
25.73473775,                                ! - Coefficient1 Constant
-0.03150043,                                 ! - Coefficient2 x
-0.01416595,                                 ! - Coefficient3 x**2
0,                                            ! - Coefficient4 x**3
15,                                           ! - Minimum Value of x {
    BasedOnField A2}

24;                                         ! - Maximum Value of x {
    BasedOnField A2}

Curve:Biquadratic,
vrf_cool_eir_f_of_high_temp,                 ! - Name
-1.4395110176,                               ! - Coefficient1 Constant
0.1619850459,                                ! - Coefficient2 x
-0.0034911781,                               ! - Coefficient3 x**2
0.0269442645,                                ! - Coefficient4 y
0.0001346163,                                ! - Coefficient5 y**2
-0.0006714941,                               ! - Coefficient6 x*y
15,                                           ! - Minimum Value of x {
    BasedOnField A2}

23.9,                                       ! - Maximum Value of x {
    BasedOnField A2}

16.8,                                         ! - Minimum Value of y {
    BasedOnField A3}

```

```

43.3;                                     ! - Maximum Value of y {
    BasedOnField A3}

Curve:Cubic,
    vrf_cool_eir_f_of_low_temp 1,           ! - Name
    0.0734992169827752,                   ! - Coefficient1 Constant
    0.334783365234032,                   ! - Coefficient2 x
    0.591613015486343,                   ! - Coefficient3 x**2
    0,                                     ! - Coefficient4 x**3
    0.25,                                  ! - Minimum Value of x {
        BasedOnField A2}
    1,                                     ! - Maximum Value of x {
        BasedOnField A2}
    0,                                     ! - Minimum Curve Output {
        BasedOnField A3}
    1;                                     ! - Maximum Curve Output {
        BasedOnField A3}

Curve:Cubic,
    vrf_cooling_eir_high_plr,             ! - Name
    1,                                     ! - Coefficient1 Constant
    0,                                     ! - Coefficient2 x
    0,                                     ! - Coefficient3 x**2
    0,                                     ! - Coefficient4 x**3
    1,                                     ! - Minimum Value of x {
        BasedOnField A2}
    1.5;                                   ! - Maximum Value of x {
        BasedOnField A2}

Curve:Cubic,
    vrf_cooling_comb_ratio,               ! - Name
    0.24034,                             ! - Coefficient1 Constant
    -0.21873,                            ! - Coefficient2 x
    1.97941,                             ! - Coefficient3 x**2
    -1.02636,                            ! - Coefficient4 x**3

```

```

0.5,                                     ! - Minimum Value of x {
    BasedOnField A2}

2,                                         ! - Maximum Value of x {
    BasedOnField A2}

0.5,                                     ! - Minimum Curve Output {
    BasedOnField A3}

1.056;                                    ! - Maximum Curve Output {
    BasedOnField A3}

Curve:Cubic,
    vrf_cooling_cplffplr,                  ! - Name
    0.85,                                    ! - Coefficient1 Constant
    0.15,                                    ! - Coefficient2 x
    0,                                         ! - Coefficient3 x**2
    0,                                         ! - Coefficient4 x**3
    1,                                         ! - Minimum Value of x {
        BasedOnField A2}
    1;                                         ! - Maximum Value of x {
        BasedOnField A2}

Curve:Biquadratic,
    vrf_heat_cap_f_of_low_temp,             ! - Name
    0.983220174655636,                    ! - Coefficient1 Constant
    0.0157167577703294,                  ! - Coefficient2 x
    -0.000835032422884084,              ! - Coefficient3 x**2
    0.0522939264581759,                  ! - Coefficient4 y
    -0.000531556035364549,              ! - Coefficient5 y**2
    -0.00190605953116024,                ! - Coefficient6 x*y
    16.1,                                    ! - Minimum Value of x {
        BasedOnField A2}
    23.9,                                    ! - Maximum Value of x {
        BasedOnField A2}

    -25,                                     ! - Minimum Value of y {
        BasedOnField A3}

    13.3,                                    ! - Maximum Value of y {
        BasedOnField A3}

```

```

0.51515151515151515 ,                               ! - Minimum Curve Output {
BasedOnField A4}

1.2;                                                 ! - Maximum Curve Output {
BasedOnField A4}

Curve:Cubic ,
vrf_heat_cap_ratio_boundary ,                      ! - Name
58.577 ,                                         ! - Coefficient1 Constant
-3.0255 ,                                         ! - Coefficient2 x
0.0193 ,                                         ! - Coefficient3 x**2
0 ,                                               ! - Coefficient4 x**3
15 ,                                              ! - Minimum Value of x {
BasedOnField A2}

23.9;                                              ! - Maximum Value of x {
BasedOnField A2}

Curve:Biquadratic ,
vrf_heat_cap_f_of_high_temp ,                      ! - Name
2.5859872368 ,                                     ! - Coefficient1 Constant
-0.0953227101 ,                                    ! - Coefficient2 x
0.0009553288 ,                                    ! - Coefficient3 x**2
0 ,                                               ! - Coefficient4 y
0 ,                                               ! - Coefficient5 y**2
0 ,                                               ! - Coefficient6 x*y
21.1 ,                                             ! - Minimum Value of x {
BasedOnField A2}

27.2 ,                                              ! - Maximum Value of x {
BasedOnField A2}

-944 ,                                             ! - Minimum Value of y {
BasedOnField A3}

15;                                                 ! - Maximum Value of y {
BasedOnField A3}

Curve:Biquadratic ,
vrf_heat_eir_f_of_low_temp ,                      ! - Name
0.756830029796909 ,                            ! - Coefficient1 Constant

```

```

0.0457499799042671 ,                               ! - Coefficient2 x
-0.00136357240431388 ,                           ! - Coefficient3 x**2
0.0554884599902023 ,                           ! - Coefficient4 y
-0.00120700875497686 ,                           ! - Coefficient5 y**2
-0.00303329271420931 ,                           ! - Coefficient6 x*y
16.1,                                              ! - Minimum Value of x {
BasedOnField A2}

23.9,                                              ! - Maximum Value of x {
BasedOnField A2}

-25,                                              ! - Minimum Value of y {
BasedOnField A3}

13.3,                                              ! - Maximum Value of y {
BasedOnField A3}

0.7,                                              ! - Minimum Curve Output {
BasedOnField A4}

1.184;                                             ! - Maximum Curve Output {
BasedOnField A4}

Curve:Cubic,
vrf_heat_eir_boundary ,                         ! - Name
58.577 ,                                         ! - Coefficient1 Constant
-3.0255 ,                                         ! - Coefficient2 x
0.0193 ,                                         ! - Coefficient3 x**2
0,                                                 ! - Coefficient4 x**3
15,                                               ! - Minimum Value of x {
BasedOnField A2}

23.9;                                              ! - Maximum Value of x {
BasedOnField A2}

Curve:Biquadratic,
vrf_heat_eir_f_of_high_temp ,                     ! - Name
1.3885703646 ,                                    ! - Coefficient1 Constant
-0.0229771462 ,                                   ! - Coefficient2 x
0.000537274 ,                                     ! - Coefficient3 x**2
-0.0273936962 ,                                   ! - Coefficient4 y
0.0004030426 ,                                   ! - Coefficient5 y**2

```

```

-5.9786e-05,                                     ! - Coefficient6 x*y
21.1,                                            ! - Minimum Value of x {
BasedOnField A2}                                 ! - Maximum Value of x {
27.2,                                            ! - Minimum Value of y {
BasedOnField A2}                                 ! - Maximum Value of y {
0,                                                 BasedOnField A3}
BasedOnField A3}                                 ! - Maximum Value of y {

Curve:Cubic,
vrf_heating_eir_low_plr,                         ! - Name
0.0724906507105475,                            ! - Coefficient1 Constant
0.658189977561701,                            ! - Coefficient2 x
0.269259536275246,                            ! - Coefficient3 x**2
0,                                                 ! - Coefficient4 x**3
0.25,                                             ! - Minimum Value of x {
BasedOnField A2}                                 ! - Maximum Value of x {
1,                                                 BasedOnField A2}
BasedOnField A2}                                 ! - Minimum Curve Output {
0,                                                 BasedOnField A3}
BasedOnField A3}                                 ! - Maximum Curve Output {
1;                                               BasedOnField A3}

Curve:Cubic,
vrf_heating_eir_hi_plr,                         ! - Name
1,                                                ! - Coefficient1 Constant
0,                                                ! - Coefficient2 x
0,                                                ! - Coefficient3 x**2
0,                                                ! - Coefficient4 x**3
1,                                               ! - Minimum Value of x {
BasedOnField A2}                                 ! - Maximum Value of x {
1.5;                                              BasedOnField A2}
BasedOnField A2}

```

```

Curve:Cubic,
    vrf_heating_comb_ratio,                               !- Name
    0.62115,                                         !- Coefficient1 Constant
    -1.55798,                                         !- Coefficient2 x
    3.36817,                                         !- Coefficient3 x**2
    -1.4224,                                         !- Coefficient4 x**3
    0.5,                                              !- Minimum Value of x {
        BasedOnField A2}
    2,                                                 !- Maximum Value of x {
        BasedOnField A2}
    0.5,                                              !- Minimum Curve Output {
        BasedOnField A3}
    1.155;                                            !- Maximum Curve Output {
        BasedOnField A3}

Curve:Cubic,
    vrf_heating_cplffplr,                               !- Name
    0.85,                                             !- Coefficient1 Constant
    0.15,                                             !- Coefficient2 x
    0,                                                !- Coefficient3 x**2
    0,                                                !- Coefficient4 x**3
    1,                                              !- Minimum Value of x {
        BasedOnField A2}
    1;                                                 !- Maximum Value of x {
        BasedOnField A2}

Curve:Biquadratic,
    Air Conditioner Variable Refrigerant Flow 1
    CoolingLengthCorrectionFactor, !- Name
    2.0388158625,                                     !- Coefficient1 Constant
    -0.0024260645,                                    !- Coefficient2 x
    3.5512e-06,                                       !- Coefficient3 x**2
    -1.6858129772,                                    !- Coefficient4 y
    0.668703358,                                      !- Coefficient5 y**2
    -4.5706e-05,                                       !- Coefficient6 x*y

```

```

7.62,                                     ! - Minimum Value of x {
    BasedOnField A2}

182.88,                                    ! - Maximum Value of x {
    BasedOnField A2}

0.8,                                       ! - Minimum Value of y {
    BasedOnField A3}

1.5;                                       ! - Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic,
vrf_defrost_eir_f_of_temp,                  ! - Name
-1.61908214818635,                        ! - Coefficient1 Constant
0.185964818731756,                         ! - Coefficient2 x
-0.00389610393381592,                      ! - Coefficient3 x**2
-0.00901995326324613,                      ! - Coefficient4 y
0.00030340007815629,                       ! - Coefficient5 y**2
0.000476048529099348,                      ! - Coefficient6 x*y
13.9,                                       ! - Minimum Value of x {
    BasedOnField A2}

23.9,                                       ! - Maximum Value of x {
    BasedOnField A2}

-5,                                         ! - Minimum Value of y {
    BasedOnField A3}

50,                                          ! - Maximum Value of y {
    BasedOnField A3}

0.27,                                         ! - Minimum Curve Output {
    BasedOnField A4}

1.155;                                       ! - Maximum Curve Output {
    BasedOnField A4}

ZoneTerminalUnitList,
15 Zone VRF System Terminal List,           ! - Zone Terminal Unit List
    Name

Room_16_3d8c5364 VRF Terminal Unit,        ! - Zone Terminal Unit Name
    1

```

Room_17_fb615533 VRF Terminal Unit ,	! - Zone Terminal Unit Name
2	
Room_18_6cc35095 VRF Terminal Unit ,	! - Zone Terminal Unit Name
3	
Room_19_6ae0f9a9 VRF Terminal Unit ,	! - Zone Terminal Unit Name
4	
Room_20_4d060559 VRF Terminal Unit ,	! - Zone Terminal Unit Name
5	
Room_21_4c523269 VRF Terminal Unit ,	! - Zone Terminal Unit Name
6	
Room_22_f3ee5a53 VRF Terminal Unit ,	! - Zone Terminal Unit Name
7	
Room_23_e751e71f VRF Terminal Unit ,	! - Zone Terminal Unit Name
8	
Room_24_159d21b7 VRF Terminal Unit ,	! - Zone Terminal Unit Name
9	
Room_25_d27e0933 VRF Terminal Unit ,	! - Zone Terminal Unit Name
10	
Room_26_f4ea3797 VRF Terminal Unit ,	! - Zone Terminal Unit Name
11	
Room_27_0080b418 VRF Terminal Unit ,	! - Zone Terminal Unit Name
12	
Room_28_d6ed2799 VRF Terminal Unit ,	! - Zone Terminal Unit Name
13	
Room_29_2a634042 VRF Terminal Unit ,	! - Zone Terminal Unit Name
14	
Room_30_98fid6c8 VRF Terminal Unit ;	! - Zone Terminal Unit Name
15	
 PlantLoop ,	
Service Hot Water Loop ,	! - Name
Water ,	! - Fluid Type
,	! - User Defined Fluid Type
Service Hot Water Loop Operation Schemes ,	! - Plant Equipment
Operation Scheme Name	

```

Node 2,                                     !- Loop Temperature
  Setpoint Node Name
  60,                                         !- Maximum Loop
    Temperature {C}
  10,                                         !- Minimum Loop
    Temperature {C}
  Autosize,                                    !- Maximum Loop Flow Rate
    {m3/s}
  0,                                           !- Minimum Loop Flow Rate
    {m3/s}
  Autocalculate,                                !- Plant Loop Volume {m3}
  Node 1,                                       !- Plant Side Inlet Node
    Name
  Node 2,                                       !- Plant Side Outlet Node
    Name
  Service Hot Water Loop Supply Branches, !- Plant Side Branch List
    Name
  Service Hot Water Loop Supply Connector List, !- Plant Side
    Connector List Name
  Node 4,                                       !- Demand Side Inlet Node
    Name
  Node 5,                                       !- Demand Side Outlet Node
    Name
  Service Hot Water Loop Demand Branches, !- Demand Side Branch List
    Name
  Service Hot Water Loop Demand Connector List, !- Demand Side
    Connector List Name
  Optimal,                                      !- Load Distribution
    Scheme
  ,                                             !- Availability Manager
    List Name
  SingleSetpoint,                                !- Plant Loop Demand
    Calculation Scheme
  ;                                              !- Common Pipe Simulation

Sizing:Plant,

```

```

Service Hot Water Loop,           !- Plant or Condenser Loop
  Name
  Heating,                      !- Loop Type
  60,                           !- Design Loop Exit
    Temperature {C}
  5,                            !- Loop Design Temperature
    Difference {deltaC}
  NonCoincident,                !- Sizing Option
  1,                            !- Zone Timesteps in
    Averaging Window
None;                          !- Coincident Sizing
  Factor Mode

BranchList,
  Service Hot Water Loop Supply Branches, !- Name
  Service Hot Water Loop Supply Inlet Branch, !- Branch Name 1
  Service Hot Water Loop Supply Branch 1, !- Branch Name 2
  Service Hot Water Loop Supply Outlet Branch; !- Branch Name 3

ConnectorList,
  Service Hot Water Loop Supply Connector List, !- Name
  Connector:Splitter,                  !- Connector Object Type 1
  Service Hot Water Loop Supply Splitter, !- Connector Name 1
  Connector:Mixer,                   !- Connector Object Type 2
  Service Hot Water Loop Supply Mixer; !- Connector Name 2

Connector:Splitter,
  Service Hot Water Loop Supply Splitter, !- Name
  Service Hot Water Loop Supply Inlet Branch, !- Inlet Branch Name
  Service Hot Water Loop Supply Branch 1; !- Outlet Branch Name 1

Connector:Mixer,
  Service Hot Water Loop Supply Mixer,     !- Name
  Service Hot Water Loop Supply Outlet Branch, !- Outlet Branch Name
  Service Hot Water Loop Supply Branch 1; !- Inlet Branch Name 1

```

```

Branch,
  Service Hot Water Loop Supply Inlet Branch, !- Name
  ,
  !- Pressure Drop Curve
  Name
Pump:ConstantSpeed,
  Service Hot Water Pump, !- Component Object Type 1
  Node 1, !- Component Name 1
  Name 1 !- Component Inlet Node
  Node 7; !- Component Outlet Node
  Name 1

Pump:ConstantSpeed,
  Service Hot Water Pump, !- Name
  Node 1, !- Inlet Node Name
  Node 7, !- Outlet Node Name
  Autosize, !- Design Flow Rate {m3/s}
  29891, !- Design Pump Head {Pa}
  Autosize, !- Design Power
  Consumption {W}
  0.9, !- Motor Efficiency
  0, !- Fraction of Motor
  Inefficiencies to Fluid Stream
  Intermittent, !- Pump Control Type
  ,
  !- Pump Flow Rate Schedule
  Name
  ,
  !- Pump Curve Name
  ,
  !- Impeller Diameter {m}
  ,
  !- Rotational Speed {rev/
  min}
  ,
  !- Zone Name
  ,
  !- Skin Loss Radiative
  Fraction
PowerPerFlowPerPressure, !- Design Power Sizing
  Method
  348701.1, !- Design Electric Power
  per Unit Flow Rate {W/(m3/s)}

```

```

1.282051282,                                     !- Design Shaft Power per
Unit Flow Rate per Unit Head {W-s/m3-Pa}
General;                                         !- End-Use Subcategory

Branch,
  Service Hot Water Loop Supply Branch 1, !- Name
  ,                                         !- Pressure Drop Curve
    Name
  DistrictHeating,                         !- Component Object Type 1
  Service Hot Water District Heat,          !- Component Name 1
  Node 3,                                  !- Component Inlet Node
    Name 1
  Node 8;                                  !- Component Outlet Node
    Name 1

DistrictHeating,
  Service Hot Water District Heat,          !- Name
  Node 3,                                  !- Hot Water Inlet Node
    Name
  Node 8,                                  !- Hot Water Outlet Node
    Name
  1000000;                                !- Nominal Capacity {W}

Branch,
  Service Hot Water Loop Supply Outlet Branch, !- Name
  ,                                         !- Pressure Drop Curve
    Name
  Pipe:Adiabatic,                          !- Component Object Type 1
  Service Hot Water Loop Supply Outlet Pipe, !- Component Name 1
  Service Hot Water Loop Supply Outlet Pipe Node, !- Component Inlet
    Node Name 1
  Node 2;                                  !- Component Outlet Node
    Name 1

Pipe:Adiabatic,
  Service Hot Water Loop Supply Outlet Pipe, !- Name

```

```

Service Hot Water Loop Supply Outlet Pipe Node, !- Inlet Node Name
Node 2;                                !- Outlet Node Name

BranchList,
  Service Hot Water Loop Demand Branches, !- Name
  Service Hot Water Loop Demand Inlet Branch, !- Branch Name 1
  Service Hot Water Loop Demand Branch 1, !- Branch Name 2
  Service Hot Water Loop Demand Branch 2, !- Branch Name 3
  Service Hot Water Loop Demand Branch 3, !- Branch Name 4
  Service Hot Water Loop Demand Branch 4, !- Branch Name 5
  Service Hot Water Loop Demand Branch 5, !- Branch Name 6
  Service Hot Water Loop Demand Branch 6, !- Branch Name 7
  Service Hot Water Loop Demand Branch 7, !- Branch Name 8
  Service Hot Water Loop Demand Branch 8, !- Branch Name 9
  Service Hot Water Loop Demand Branch 9, !- Branch Name 10
  Service Hot Water Loop Demand Branch 10, !- Branch Name 11
  Service Hot Water Loop Demand Branch 11, !- Branch Name 12
  Service Hot Water Loop Demand Branch 12, !- Branch Name 13
  Service Hot Water Loop Demand Branch 13, !- Branch Name 14
  Service Hot Water Loop Demand Branch 14, !- Branch Name 15
  Service Hot Water Loop Demand Branch 15, !- Branch Name 16
  Service Hot Water Loop Demand Bypass Branch, !- Branch Name 17
  Service Hot Water Loop Demand Outlet Branch; !- Branch Name 18

ConnectorList,
  Service Hot Water Loop Demand Connector List, !- Name
  Connector:Splitter,                      !- Connector Object Type 1
  Service Hot Water Loop Demand Splitter, !- Connector Name 1
  Connector:Mixer,                        !- Connector Object Type 2
  Service Hot Water Loop Demand Mixer;    !- Connector Name 2

Connector:Splitter,
  Service Hot Water Loop Demand Splitter, !- Name
  Service Hot Water Loop Demand Inlet Branch, !- Inlet Branch Name
  Service Hot Water Loop Demand Branch 1, !- Outlet Branch Name 1
  Service Hot Water Loop Demand Branch 2, !- Outlet Branch Name 2

```

```
Service Hot Water Loop Demand Branch 3, !- Outlet Branch Name 3
Service Hot Water Loop Demand Branch 4, !- Outlet Branch Name 4
Service Hot Water Loop Demand Branch 5, !- Outlet Branch Name 5
Service Hot Water Loop Demand Branch 6, !- Outlet Branch Name 6
Service Hot Water Loop Demand Branch 7, !- Outlet Branch Name 7
Service Hot Water Loop Demand Branch 8, !- Outlet Branch Name 8
Service Hot Water Loop Demand Branch 9, !- Outlet Branch Name 9
Service Hot Water Loop Demand Branch 10, !- Outlet Branch Name 10
Service Hot Water Loop Demand Branch 11, !- Outlet Branch Name 11
Service Hot Water Loop Demand Branch 12, !- Outlet Branch Name 12
Service Hot Water Loop Demand Branch 13, !- Outlet Branch Name 13
Service Hot Water Loop Demand Branch 14, !- Outlet Branch Name 14
Service Hot Water Loop Demand Branch 15, !- Outlet Branch Name 15
Service Hot Water Loop Demand Bypass Branch; !- Outlet Branch Name
```

16

Connector:Mixer,

```
Service Hot Water Loop Demand Mixer,      !- Name
Service Hot Water Loop Demand Outlet Branch, !- Outlet Branch Name
Service Hot Water Loop Demand Branch 1, !- Inlet Branch Name 1
Service Hot Water Loop Demand Branch 2, !- Inlet Branch Name 2
Service Hot Water Loop Demand Branch 3, !- Inlet Branch Name 3
Service Hot Water Loop Demand Branch 4, !- Inlet Branch Name 4
Service Hot Water Loop Demand Branch 5, !- Inlet Branch Name 5
Service Hot Water Loop Demand Branch 6, !- Inlet Branch Name 6
Service Hot Water Loop Demand Branch 7, !- Inlet Branch Name 7
Service Hot Water Loop Demand Branch 8, !- Inlet Branch Name 8
Service Hot Water Loop Demand Branch 9, !- Inlet Branch Name 9
Service Hot Water Loop Demand Branch 10, !- Inlet Branch Name 10
Service Hot Water Loop Demand Branch 11, !- Inlet Branch Name 11
Service Hot Water Loop Demand Branch 12, !- Inlet Branch Name 12
Service Hot Water Loop Demand Branch 13, !- Inlet Branch Name 13
Service Hot Water Loop Demand Branch 14, !- Inlet Branch Name 14
Service Hot Water Loop Demand Branch 15, !- Inlet Branch Name 15
Service Hot Water Loop Demand Bypass Branch; !- Inlet Branch Name
```

16

```

Branch,
  Service Hot Water Loop Demand Inlet Branch, !- Name
  ,
  !- Pressure Drop Curve
  Name
Pipe:Adiabatic,           !- Component Object Type 1
Service Hot Water Loop Demand Inlet Pipe, !- Component Name 1
Node 4,                   !- Component Inlet Node
  Name 1
Service Hot Water Loop Demand Inlet Pipe Node; !- Component Outlet
  Node Name 1

Pipe:Adiabatic,
  Service Hot Water Loop Demand Inlet Pipe, !- Name
  Node 4,                   !- Inlet Node Name
  Service Hot Water Loop Demand Inlet Pipe Node; !- Outlet Node Name

Branch,
  Service Hot Water Loop Demand Branch 1, !- Name
  ,
  !- Pressure Drop Curve
  Name
WaterUse:Connections,      !- Component Object Type 1
Water Use Connections 1,   !- Component Name 1
Node 6,                   !- Component Inlet Node
  Name 1
Node 9;                  !- Component Outlet Node
  Name 1

WaterUse:Connections,
  Water Use Connections 1,      !- Name
  Node 6,                   !- Inlet Node Name
  Node 9,                   !- Outlet Node Name
  ,
  !- Supply Water Storage
  Tank Name
  ,
  !- Reclamation Water
  Storage Tank Name

```

```

60.0C Hot Water, !- Hot Water Supply
Temperature Schedule Name

, !- Cold Water Supply

Temperature Schedule Name

None, !- Drain Water Heat

Exchanger Type

Plant, !- Drain Water Heat

Exchanger Destination

, !- Drain Water Heat

Exchanger U-Factor Times Area {W/K}

hotwater..Room_16_3d8c5364; !- Water Use Equipment

Name 1


WaterUse:Equipment,
hotwater..Room_16_3d8c5364, !- Name
General, !- End-Use Subcategory
1.19318518518519e-06, !- Peak Flow Rate {m3/s}
project_hot water, !- Flow Rate Fraction

Schedule Name
60.0C Hot Water, !- Target Temperature

Schedule Name

, !- Hot Water Supply

Temperature Schedule Name

, !- Cold Water Supply

Temperature Schedule Name

Room_16_3d8c5364, !- Zone Name
0.2 Hot Water Sensible Fraction, !- Sensible Fraction

Schedule Name
0.05 Hot Water Latent Fraction; !- Latent Fraction

Schedule Name


Branch,
Service Hot Water Loop Demand Branch 2, !- Name
, !- Pressure Drop Curve

Name

WaterUse:Connections, !- Component Object Type 1

```

```

Water Use Connections 2,           ! - Component Name 1
Node 10,                          ! - Component Inlet Node
Name 1
Node 11;                         ! - Component Outlet Node
Name 1

WaterUse:Connections ,
Water Use Connections 2,          ! - Name
Node 10,                          ! - Inlet Node Name
Node 11,                          ! - Outlet Node Name
,
! - Supply Water Storage
Tank Name
,
! - Reclamation Water
Storage Tank Name
60.0C Hot Water,                 ! - Hot Water Supply
Temperature Schedule Name
,
! - Cold Water Supply
Temperature Schedule Name
None,                            ! - Drain Water Heat
Exchanger Type
Plant,                            ! - Drain Water Heat
Exchanger Destination
,
! - Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_17_fb615533;      ! - Water Use Equipment
Name 1

WaterUse:Equipment ,
hotwater..Room_17_fb615533,       ! - Name
General,                          ! - End-Use Subcategory
1.19318518518518e-06,           ! - Peak Flow Rate {m3/s}
project_hot water,                ! - Flow Rate Fraction
Schedule Name
60.0C Hot Water,                 ! - Target Temperature
Schedule Name

```

```

,
! - Hot Water Supply

Temperature Schedule Name
,
! - Cold Water Supply

Temperature Schedule Name
Room_17_fb615533,
! - Zone Name
0.2 Hot Water Sensible Fraction, ! - Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction; ! - Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 3, ! - Name
,
! - Pressure Drop Curve

Name
WaterUse:Connections, ! - Component Object Type 1
Water Use Connections 3, ! - Component Name 1
Node 12, ! - Component Inlet Node
Name 1
Node 13; ! - Component Outlet Node
Name 1

WaterUse:Connections,
Water Use Connections 3, ! - Name
Node 12, ! - Inlet Node Name
Node 13, ! - Outlet Node Name
,
! - Supply Water Storage
Tank Name
,
! - Reclamation Water

Storage Tank Name
60.0C Hot Water, ! - Hot Water Supply
Temperature Schedule Name
,
! - Cold Water Supply

Temperature Schedule Name
None, ! - Drain Water Heat
Exchanger Type

```

```

Plant ,                                         ! - Drain Water Heat
    Exchanger Destination
,
    Exchanger U-Factor Times Area {W/K}          ! - Drain Water Heat
hotwater..Room_18_6cc35095;                   ! - Water Use Equipment
    Name 1

WaterUse:Equipment ,
    hotwater..Room_18_6cc35095 ,                ! - Name
    General ,                                     ! - End-Use Subcategory
    1.19318518518518e-06 ,                      ! - Peak Flow Rate {m3/s}
    project_hot water ,                         ! - Flow Rate Fraction
        Schedule Name
    60.0C Hot Water ,                           ! - Target Temperature
        Schedule Name
,
        ! - Hot Water Supply
    Temperature Schedule Name
,
        ! - Cold Water Supply
    Temperature Schedule Name
Room_18_6cc35095 ,                           ! - Zone Name
0.2 Hot Water Sensible Fraction ,            ! - Sensible Fraction
    Schedule Name
0.05 Hot Water Latent Fraction;             ! - Latent Fraction
    Schedule Name

Branch ,
    Service Hot Water Loop Demand Branch 4, ! - Name
,
        ! - Pressure Drop Curve
    Name
WaterUse:Connections ,                      ! - Component Object Type 1
Water Use Connections 4 ,                   ! - Component Name 1
Node 14 ,                                    ! - Component Inlet Node
    Name 1
Node 15;                                     ! - Component Outlet Node
    Name 1

```

```

WaterUse:Connections ,
  Water Use Connections 4,                               !- Name
  Node 14,                                              !- Inlet Node Name
  Node 15,                                              !- Outlet Node Name
  ,                                                     !- Supply Water Storage
  Tank Name
  ,                                                     !- Reclamation Water
  Storage Tank Name
  60.0C Hot Water,                                     !- Hot Water Supply
  Temperature Schedule Name
  ,
  Temperature Schedule Name
None,                                                 !- Drain Water Heat
  Exchanger Type
Plant,                                                !- Drain Water Heat
  Exchanger Destination
  ,
  Exchanger U-Factor Times Area {W/K}
hotwater..Room_19_6ae0f9a9;                           !- Water Use Equipment
  Name 1

WaterUse:Equipment ,
  hotwater..Room_19_6ae0f9a9,                           !- Name
  General,                                             !- End-Use Subcategory
  5.96592592592586e-07,                             !- Peak Flow Rate {m3/s}
  project_hot water,                                 !- Flow Rate Fraction
  Schedule Name
  60.0C Hot Water,                                    !- Target Temperature
  Schedule Name
  ,
  Temperature Schedule Name
  ,
  Temperature Schedule Name
Room_19_6ae0f9a9,                                     !- Zone Name
  0.2 Hot Water Sensible Fraction,                   !- Sensible Fraction
  Schedule Name

```

```

0.05 Hot Water Latent Fraction;           ! - Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 5, ! - Name
,                                         ! - Pressure Drop Curve
Name
WaterUse:Connections,                   ! - Component Object Type 1
Water Use Connections 5,                ! - Component Name 1
Node 16,                                ! - Component Inlet Node
Name 1
Node 17;                                ! - Component Outlet Node
Name 1

WaterUse:Connections,
Water Use Connections 5,                ! - Name
Node 16,                                ! - Inlet Node Name
Node 17,                                ! - Outlet Node Name
,                                         ! - Supply Water Storage
Tank Name
,                                         ! - Reclamation Water
Storage Tank Name
60.0C Hot Water,                        ! - Hot Water Supply
Temperature Schedule Name
,                                         ! - Cold Water Supply
Temperature Schedule Name
None,                                    ! - Drain Water Heat
Exchanger Type
Plant,                                    ! - Drain Water Heat
Exchanger Destination
,                                         ! - Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_20_4d060559;            ! - Water Use Equipment
Name 1

WaterUse:Equipment,

```

```

hotwater..Room_20_4d060559 , !- Name
General , !- End-Use Subcategory
5.96592592592586e-07 , !- Peak Flow Rate {m3/s}
project_hot water , !- Flow Rate Fraction
Schedule Name
60.0C Hot Water , !- Target Temperature
Schedule Name
,
!- Hot Water Supply
Temperature Schedule Name
,
!- Cold Water Supply
Temperature Schedule Name
Room_20_4d060559 , !- Zone Name
0.2 Hot Water Sensible Fraction , !- Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction; !- Latent Fraction
Schedule Name

Branch ,
Service Hot Water Loop Demand Branch 6, !- Name
,
!- Pressure Drop Curve
Name
WaterUse:Connections , !- Component Object Type 1
Water Use Connections 6, !- Component Name 1
Node 18, !- Component Inlet Node
Name 1
Node 19; !- Component Outlet Node
Name 1

WaterUse:Connections ,
Water Use Connections 6, !- Name
Node 18, !- Inlet Node Name
Node 19, !- Outlet Node Name
,
!- Supply Water Storage
Tank Name
,
!- Reclamation Water
Storage Tank Name

```

```

60.0C Hot Water, ! - Hot Water Supply
Temperature Schedule Name
,
! - Cold Water Supply
Temperature Schedule Name
None, ! - Drain Water Heat
Exchanger Type
Plant, ! - Drain Water Heat
Exchanger Destination
,
! - Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_21_4c523269; ! - Water Use Equipment
Name 1

WaterUse:Equipment,
hotwater..Room_21_4c523269, ! - Name
General, ! - End-Use Subcategory
5.96592592592604e-07, ! - Peak Flow Rate {m3/s}
project_hot water, ! - Flow Rate Fraction
Schedule Name
60.0C Hot Water, ! - Target Temperature
Schedule Name
,
! - Hot Water Supply
Temperature Schedule Name
,
! - Cold Water Supply
Temperature Schedule Name
Room_21_4c523269, ! - Zone Name
0.2 Hot Water Sensible Fraction, ! - Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction; ! - Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 7, ! - Name
,
! - Pressure Drop Curve
Name
WaterUse:Connections, ! - Component Object Type 1

```

```

Water Use Connections 7,           ! - Component Name 1
Node 20,                          ! - Component Inlet Node
Name 1
Node 21;                         ! - Component Outlet Node
Name 1

WaterUse:Connections ,
Water Use Connections 7,          ! - Name
Node 20,                          ! - Inlet Node Name
Node 21,                          ! - Outlet Node Name
,
! - Supply Water Storage
Tank Name
,
! - Reclamation Water
Storage Tank Name
60.0C Hot Water,                 ! - Hot Water Supply
Temperature Schedule Name
,
! - Cold Water Supply
Temperature Schedule Name
None,                            ! - Drain Water Heat
Exchanger Type
Plant,                            ! - Drain Water Heat
Exchanger Destination
,
! - Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_22_f3ee5a53;      ! - Water Use Equipment
Name 1

WaterUse:Equipment ,
hotwater..Room_22_f3ee5a53,       ! - Name
General,                          ! - End-Use Subcategory
1.19318518518517e-06,           ! - Peak Flow Rate {m3/s}
project_hot water,                ! - Flow Rate Fraction
Schedule Name
60.0C Hot Water,                 ! - Target Temperature
Schedule Name

```

```

,
! - Hot Water Supply

Temperature Schedule Name

,
! - Cold Water Supply

Temperature Schedule Name

Room_22_f3ee5a53,
! - Zone Name

0.2 Hot Water Sensible Fraction,
! - Sensible Fraction

Schedule Name

0.05 Hot Water Latent Fraction;
! - Latent Fraction

Schedule Name

Branch,
Service Hot Water Loop Demand Branch 8, ! - Name
,
! - Pressure Drop Curve

Name

WaterUse:Connections,
! - Component Object Type 1

Water Use Connections 8,
! - Component Name 1

Node 22,
! - Component Inlet Node

Name 1

Node 23;
! - Component Outlet Node

Name 1

WaterUse:Connections,
Water Use Connections 8,
! - Name

Node 22,
! - Inlet Node Name

Node 23,
! - Outlet Node Name

,
! - Supply Water Storage

Tank Name
,
! - Reclamation Water

Storage Tank Name

60.0C Hot Water,
! - Hot Water Supply

Temperature Schedule Name

,
! - Cold Water Supply

Temperature Schedule Name

None,
! - Drain Water Heat

Exchanger Type

```

```

Plant ,
      !- Drain Water Heat
Exchanger Destination
,
      !- Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_23_e751e71f;           !- Water Use Equipment
Name 1

WaterUse:Equipment ,
hotwater..Room_23_e751e71f ,          !- Name
General ,                            !- End-Use Subcategory
1.19318518518521e-06 ,              !- Peak Flow Rate {m3/s}
project_hot water ,                  !- Flow Rate Fraction
Schedule Name
60.0C Hot Water ,                   !- Target Temperature
Schedule Name
,
      !- Hot Water Supply
Temperature Schedule Name
,
      !- Cold Water Supply
Temperature Schedule Name
Room_23_e751e71f ,                  !- Zone Name
0.2 Hot Water Sensible Fraction ,   !- Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction;     !- Latent Fraction
Schedule Name

Branch ,
Service Hot Water Loop Demand Branch 9, !- Name
,
      !- Pressure Drop Curve
Name
WaterUse:Connections ,               !- Component Object Type 1
Water Use Connections 9 ,            !- Component Name 1
Node 24 ,                           !- Component Inlet Node
Name 1
Node 25;                            !- Component Outlet Node
Name 1

```

```

WaterUse:Connections ,
  Water Use Connections 9,                               !- Name
  Node 24,                                              !- Inlet Node Name
  Node 25,                                              !- Outlet Node Name
  ,                                                     !- Supply Water Storage
  Tank Name
  ,                                                     !- Reclamation Water
  Storage Tank Name
  60.0C Hot Water,                                     !- Hot Water Supply
  Temperature Schedule Name
  ,
  Temperature Schedule Name
None,                                                 !- Drain Water Heat
  Exchanger Type
Plant,                                                !- Drain Water Heat
  Exchanger Destination
  ,
  Exchanger U-Factor Times Area {W/K}
hotwater..Room_24_159d21b7;                         !- Water Use Equipment
  Name 1

WaterUse:Equipment ,
  hotwater..Room_24_159d21b7,                           !- Name
  General,                                             !- End-Use Subcategory
  1.19318518518517e-06,                                !- Peak Flow Rate {m3/s}
  project_hot water,                                    !- Flow Rate Fraction
  Schedule Name
  60.0C Hot Water,                                     !- Target Temperature
  Schedule Name
  ,
  Temperature Schedule Name
  ,
  Temperature Schedule Name
Room_24_159d21b7,                                     !- Zone Name
  0.2 Hot Water Sensible Fraction,                      !- Sensible Fraction
  Schedule Name

```

```

0.05 Hot Water Latent Fraction;           !- Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 10, !- Name
,                                         !- Pressure Drop Curve
Name
WaterUse:Connections,                   !- Component Object Type 1
Water Use Connections 10,              !- Component Name 1
Node 26,                                !- Component Inlet Node
Name 1
Node 27;                                !- Component Outlet Node
Name 1

WaterUse:Connections,
Water Use Connections 10,               !- Name
Node 26,                                !- Inlet Node Name
Node 27,                                !- Outlet Node Name
,                                         !- Supply Water Storage
Tank Name
,                                         !- Reclamation Water
Storage Tank Name
60.0C Hot Water,                        !- Hot Water Supply
Temperature Schedule Name
,                                         !- Cold Water Supply
Temperature Schedule Name
None,                                    !- Drain Water Heat
Exchanger Type
Plant,                                    !- Drain Water Heat
Exchanger Destination
,                                         !- Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_25_d27e0933;            !- Water Use Equipment
Name 1

WaterUse:Equipment,

```

```

hotwater..Room_25_d27e0933 , !- Name
General , !- End-Use Subcategory
1.19318518518521e-06 , !- Peak Flow Rate {m3/s}
project_hot water , !- Flow Rate Fraction
Schedule Name
60.0C Hot Water , !- Target Temperature
Schedule Name
,
!- Hot Water Supply
Temperature Schedule Name
,
!- Cold Water Supply
Temperature Schedule Name
Room_25_d27e0933 , !- Zone Name
0.2 Hot Water Sensible Fraction , !- Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction; !- Latent Fraction
Schedule Name

Branch ,
Service Hot Water Loop Demand Branch 11, !- Name
,
!- Pressure Drop Curve
Name
WaterUse:Connections , !- Component Object Type 1
Water Use Connections 11, !- Component Name 1
Node 28 , !- Component Inlet Node
Name 1
Node 29; !- Component Outlet Node
Name 1

WaterUse:Connections ,
Water Use Connections 11, !- Name
Node 28 , !- Inlet Node Name
Node 29 , !- Outlet Node Name
,
!- Supply Water Storage
Tank Name
,
!- Reclamation Water
Storage Tank Name

```

```

60.0C Hot Water, !- Hot Water Supply
Temperature Schedule Name
,
!- Cold Water Supply
Temperature Schedule Name
None, !- Drain Water Heat
Exchanger Type
Plant, !- Drain Water Heat
Exchanger Destination
,
!- Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_26_f4ea3797; !- Water Use Equipment
Name 1

WaterUse:Equipment,
hotwater..Room_26_f4ea3797, !- Name
General, !- End-Use Subcategory
1.19318518518517e-06, !- Peak Flow Rate {m3/s}
project_hot water, !- Flow Rate Fraction
Schedule Name
60.0C Hot Water, !- Target Temperature
Schedule Name
,
!- Hot Water Supply
Temperature Schedule Name
,
!- Cold Water Supply
Temperature Schedule Name
Room_26_f4ea3797, !- Zone Name
0.2 Hot Water Sensible Fraction, !- Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction; !- Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 12, !- Name
,
!- Pressure Drop Curve
Name
WaterUse:Connections, !- Component Object Type 1

```

```

Water Use Connections 12,
Node 30,                                     !- Component Name 1
Name 1                                         !- Component Inlet Node
Node 31;                                       !- Component Outlet Node
Name 1                                         !- Component Name 1

WaterUse:Connections ,
Water Use Connections 12,                      !- Name
Node 30,                                       !- Inlet Node Name
Node 31,                                       !- Outlet Node Name
,                                              !- Supply Water Storage
Tank Name                                     !- Reclamation Water
,
Storage Tank Name                            !- Hot Water Supply
60.0C Hot Water,                             !- Hot Water Supply
Temperature Schedule Name                   !- Cold Water Supply
,
Temperature Schedule Name
None,                                         !- Drain Water Heat
Exchanger Type                               !- Drain Water Heat
Plant,                                         !- Drain Water Heat
Exchanger Destination                         !- Drain Water Heat
,
Exchanger U-Factor Times Area {W/K}
hotwater..Room_27_0080b418;                  !- Water Use Equipment
Name 1                                         !- Water Use Equipment

WaterUse:Equipment ,
hotwater..Room_27_0080b418,                  !- Name
General,                                      !- End-Use Subcategory
1.19318518518517e-06,                      !- Peak Flow Rate {m3/s}
project_hot water,                           !- Flow Rate Fraction
Schedule Name                                !- Target Temperature
60.0C Hot Water,                            !- Target Temperature
Schedule Name

```

```

,
! - Hot Water Supply

Temperature Schedule Name
,
! - Cold Water Supply

Temperature Schedule Name
Room_27_0080b418,
! - Zone Name
0.2 Hot Water Sensible Fraction,
! - Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction;
! - Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 13, !- Name
,
! - Pressure Drop Curve
Name
WaterUse:Connections,
! - Component Object Type 1
Water Use Connections 13,
! - Component Name 1
Node 32,
! - Component Inlet Node
Name 1
Node 33;
! - Component Outlet Node
Name 1

WaterUse:Connections,
Water Use Connections 13,
! - Name
Node 32,
! - Inlet Node Name
Node 33,
! - Outlet Node Name
,
! - Supply Water Storage
Tank Name
,
! - Reclamation Water
Storage Tank Name
60.0C Hot Water,
! - Hot Water Supply
Temperature Schedule Name
,
! - Cold Water Supply
Temperature Schedule Name
None,
! - Drain Water Heat
Exchanger Type

```

```

Plant ,
      !- Drain Water Heat
Exchanger Destination
,
      !- Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_28_d6ed2799;           !- Water Use Equipment
Name 1

WaterUse:Equipment ,
hotwater..Room_28_d6ed2799 ,          !- Name
General ,                            !- End-Use Subcategory
1.19318518518518e-06 ,              !- Peak Flow Rate {m3/s}
project_hot water ,                  !- Flow Rate Fraction
Schedule Name
60.0C Hot Water ,                   !- Target Temperature
Schedule Name
,
      !- Hot Water Supply
Temperature Schedule Name
,
      !- Cold Water Supply
Temperature Schedule Name
Room_28_d6ed2799 ,                  !- Zone Name
0.2 Hot Water Sensible Fraction ,    !- Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction;     !- Latent Fraction
Schedule Name

Branch ,
Service Hot Water Loop Demand Branch 14, !- Name
,
      !- Pressure Drop Curve
Name
WaterUse:Connections ,               !- Component Object Type 1
Water Use Connections 14,            !- Component Name 1
Node 34,                            !- Component Inlet Node
Name 1
Node 35;                            !- Component Outlet Node
Name 1

```

```

WaterUse:Connections ,
  Water Use Connections 14,           !- Name
  Node 34,                         !- Inlet Node Name
  Node 35,                         !- Outlet Node Name
  ,                                 !- Supply Water Storage
    Tank Name
  ,
    !- Reclamation Water
  Storage Tank Name
  60.0C Hot Water,                 !- Hot Water Supply
    Temperature Schedule Name
  ,
    !- Cold Water Supply
  Temperature Schedule Name
None,                                !- Drain Water Heat
  Exchanger Type
Plant,                                !- Drain Water Heat
  Exchanger Destination
  ,
    !- Drain Water Heat
  Exchanger U-Factor Times Area {W/K}
hotwater..Room_29_2a634042;          !- Water Use Equipment
  Name 1

WaterUse:Equipment ,
  hotwater..Room_29_2a634042,        !- Name
  General,                          !- End-Use Subcategory
  1.19318518518518e-06,            !- Peak Flow Rate {m3/s}
  project_hot water,               !- Flow Rate Fraction
    Schedule Name
  60.0C Hot Water,                 !- Target Temperature
    Schedule Name
  ,
    !- Hot Water Supply
  Temperature Schedule Name
  ,
    !- Cold Water Supply
  Temperature Schedule Name
Room_29_2a634042,                   !- Zone Name
  0.2 Hot Water Sensible Fraction,   !- Sensible Fraction
    Schedule Name

```

```

0.05 Hot Water Latent Fraction;           !- Latent Fraction
Schedule Name

Branch,
Service Hot Water Loop Demand Branch 15, !- Name
,                                         !- Pressure Drop Curve
Name
WaterUse:Connections,                   !- Component Object Type 1
Water Use Connections 15,              !- Component Name 1
Node 36,                                !- Component Inlet Node
Name 1
Node 37;                                !- Component Outlet Node
Name 1

WaterUse:Connections,
Water Use Connections 15,               !- Name
Node 36,                                !- Inlet Node Name
Node 37,                                !- Outlet Node Name
,                                         !- Supply Water Storage
Tank Name
,                                         !- Reclamation Water
Storage Tank Name
60.0C Hot Water,                        !- Hot Water Supply
Temperature Schedule Name
,                                         !- Cold Water Supply
Temperature Schedule Name
None,                                    !- Drain Water Heat
Exchanger Type
Plant,                                    !- Drain Water Heat
Exchanger Destination
,                                         !- Drain Water Heat
Exchanger U-Factor Times Area {W/K}
hotwater..Room_30_98f1d6c8;            !- Water Use Equipment
Name 1

WaterUse:Equipment,

```

```

hotwater..Room_30_98f1d6c8 , !- Name
General , !- End-Use Subcategory
1.19318518518519e-06 , !- Peak Flow Rate {m3/s}
project_hot water , !- Flow Rate Fraction
Schedule Name
60.0C Hot Water , !- Target Temperature
Schedule Name
,
!- Hot Water Supply
Temperature Schedule Name
,
!- Cold Water Supply
Temperature Schedule Name
Room_30_98f1d6c8 , !- Zone Name
0.2 Hot Water Sensible Fraction , !- Sensible Fraction
Schedule Name
0.05 Hot Water Latent Fraction; !- Latent Fraction
Schedule Name

Branch ,
Service Hot Water Loop Demand Bypass Branch , !- Name
,
!- Pressure Drop Curve
Name
Pipe:Adiabatic , !- Component Object Type 1
Service Hot Water Loop Demand Bypass Pipe , !- Component Name 1
Service Hot Water Loop Demand Bypass Pipe Inlet Node , !- Component
Inlet Node Name 1
Service Hot Water Loop Demand Bypass Pipe Outlet Node ; !-
Component Outlet Node Name 1

Pipe:Adiabatic ,
Service Hot Water Loop Demand Bypass Pipe , !- Name
Service Hot Water Loop Demand Bypass Pipe Inlet Node , !- Inlet
Node Name
Service Hot Water Loop Demand Bypass Pipe Outlet Node ; !- Outlet
Node Name

Branch ,

```

```

Service Hot Water Loop Demand Outlet Branch, !- Name
,
                                         !- Pressure Drop Curve
Name
Pipe:Adiabatic,                               !- Component Object Type 1
Service Hot Water Loop Demand Outlet Pipe, !- Component Name 1
Service Hot Water Loop Demand Outlet Pipe Node, !- Component Inlet
Node Name 1
Node 5;                                     !- Component Outlet Node
Name 1

Pipe:Adiabatic,
Service Hot Water Loop Demand Outlet Pipe, !- Name
Service Hot Water Loop Demand Outlet Pipe Node, !- Inlet Node Name
Node 5;                                     !- Outlet Node Name

PlantEquipmentOperationSchemes,
Service Hot Water Loop Operation Schemes, !- Name
PlantEquipmentOperation:HeatingLoad,        !- Control Scheme Object
Type 1
Service Hot Water Loop Heating Operation Scheme, !- Control Scheme
Name 1
Always On Discrete;                         !- Control Scheme Schedule
Name 1

PlantEquipmentOperation:HeatingLoad,
Service Hot Water Loop Heating Operation Scheme, !- Name
0,                                            !- Load Range Lower Limit
1 {W}
1000000000,                                    !- Load Range Upper Limit
1 {W}
Service Hot Water Loop Heating Equipment List; !- Range Equipment
List Name 1

PlantEquipmentList,
Service Hot Water Loop Heating Equipment List, !- Name
DistrictHeating,                                !- Equipment Object Type 1

```

```

Service Hot Water District Heat;           ! - Equipment Name 1

Output:Table:SummaryReports ,
AllSummary;                                ! - Report Name 1

Site:Location ,
Site 1,                                     ! - Name
0,                                           ! - Latitude {deg}
0,                                           ! - Longitude {deg}
0,                                           ! - Time Zone {hr}
0;                                           ! - Elevation {m}

Site:WaterMainsTemperature ,
CorrelationFromWeatherFile;                 ! - Calculation Method

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg .4% Condns DB=>MWB , ! - Name
7,                                            ! - Month
21,                                           ! - Day of Month
SummerDesignDay,                            ! - Day Type
47.9,                                         ! - Maximum Dry-Bulb
Temperature {C}
15.6,                                         ! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers,                         ! - Dry-Bulb Temperature
Range Modifier Type
,                                              ! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Wetbulb,                                       ! - Humidity Condition Type
20.9,                                         ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,                                              ! - Humidity Condition Day
Schedule Name
,                                              ! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}

```

```

        ,                                     ! - Enthalpy at Maximum Dry
        -Bulb {J/kg}

        ,                                     ! - Daily Wet-Bulb

        Temperature Range {deltaC}
        100666,                                ! - Barometric Pressure {Pa}
        }

        6.4,                                    ! - Wind Speed {m/s}
        320,                                    ! - Wind Direction {deg}
        No,                                     ! - Rain Indicator
        No,                                     ! - Snow Indicator
        No,                                     ! - Daylight Saving Time
        Indicator

        ASHRAETau,                             ! - Solar Model Indicator
        ,

        Name
        ,                                     ! - Diffuse Solar Day

        Schedule Name
        0.748,                                 ! - ASHRAE Clear Sky
        Optical Depth for Beam Irradiance (taub) {dimensionless}
        1.315;                                 ! - ASHRAE Clear Sky
        Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
        Kuwait Intl Airport Ann Clg .4% Condns DP=>MDB, !- Name
        7,                                      ! - Month
        21,                                     ! - Day of Month
        SummerDesignDay,                        ! - Day Type
        32.6,                                   ! - Maximum Dry-Bulb
        Temperature {C}
        15.6,                                   ! - Daily Dry-Bulb

        Temperature Range {deltaC}
        DefaultMultipliers,                    ! - Dry-Bulb Temperature
        Range Modifier Type
        ,                                     ! - Dry-Bulb Temperature
        Range Modifier Day Schedule Name
        Dewpoint,                               ! - Humidity Condition Type

```

```

26.4,                                     ! - Wetbulb or DewPoint at
    Maximum Dry-Bulb {C}                    ! - Humidity Condition Day

,
    Schedule Name                         ! - Humidity Ratio at

,
    Maximum Dry-Bulb {kgWater/kgDryAir}   ! - Enthalpy at Maximum Dry

,
    -Bulb {J/kg}                          ! - Daily Wet-Bulb

,
    Temperature Range {deltaC}           ! - Barometric Pressure {Pa}

100666,                                     !
    }

6.4,                                         ! - Wind Speed {m/s}
320,                                         ! - Wind Direction {deg}
No,                                           ! - Rain Indicator
No,                                           ! - Snow Indicator
No,                                           ! - Daylight Saving Time
    Indicator

ASHRAETau,                                    ! - Solar Model Indicator
,
    Name                                     ! - Beam Solar Day Schedule

,
    ! - Diffuse Solar Day

Schedule Name

0.748,                                       ! - ASHRAE Clear Sky
    Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                         ! - ASHRAE Clear Sky
    Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
    Kuwait Intl Airport Ann Clg .4% Condns Enth=>MDB, !- Name
7,                                              ! - Month
21,                                             ! - Day of Month
SummerDesignDay,                                ! - Day Type
35.1,                                            ! - Maximum Dry-Bulb
    Temperature {C}

```

```

15.6,                                     ! - Daily Dry-Bulb
Temperature Range {deltaC}

DefaultMultipliers,                      ! - Dry-Bulb Temperature
Range Modifier Type

,                                         ! - Dry-Bulb Temperature
Range Modifier Day Schedule Name

Enthalpy,                                    ! - Humidity Condition Type
,                                         ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}                       ! - Humidity Condition Day

,                                         ! - Humidity Ratio at
Schedule Name

,                                         ! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}

91200,                                      ! - Enthalpy at Maximum Dry
-Bulb {J/kg}

,                                         ! - Daily Wet-Bulb
Temperature Range {deltaC}

100666,                                     ! - Barometric Pressure {Pa}
}

6.4,                                         ! - Wind Speed {m/s}
320,                                         ! - Wind Direction {deg}
No,                                           ! - Rain Indicator
No,                                           ! - Snow Indicator
No,                                           ! - Daylight Saving Time
Indicator

ASHRAETau,                                    ! - Solar Model Indicator
,                                         ! - Beam Solar Day Schedule
Name

,                                         ! - Diffuse Solar Day
Schedule Name

0.748,                                       ! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                       ! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,

```

```

Kuwait Intl Airport Ann Clg .4% Condns WB=>MDB , !- Name
7,                                     !- Month
21,                                     !- Day of Month
SummerDesignDay ,                      !- Day Type
35.2,                                    !- Maximum Dry-Bulb
    Temperature {C}
15.6,                                    !- Daily Dry-Bulb
    Temperature Range {deltaC}
DefaultMultipliers ,                   !- Dry-Bulb Temperature
    Range Modifier Type
,
    Range Modifier Day Schedule Name
Wetbulb ,                                !- Humidity Condition Type
28.2 ,                                   !- Wetbulb or DewPoint at
    Maximum Dry-Bulb {C}
,
    Schedule Name
,
    Maximum Dry-Bulb {kgWater/kgDryAir}      !- Humidity Ratio at
,
    -Bulb {J/kg}                            !- Enthalpy at Maximum Dry
,
    Temperature Range {deltaC}              !- Daily Wet-Bulb
100666 ,                                 !- Barometric Pressure {Pa}
}
6.4 ,                                     !- Wind Speed {m/s}
320 ,                                    !- Wind Direction {deg}
No ,                                      !- Rain Indicator
No ,                                      !- Snow Indicator
No ,                                      !- Daylight Saving Time
    Indicator
ASHRAETau ,                               !- Solar Model Indicator
,
    Name
,
    Schedule Name

```

```

0.748,                                     !- ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                      !- ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 1% Condns DB=>MWB , !- Name
7,                                           !- Month
21,                                          !- Day of Month
SummerDesignDay ,                           !- Day Type
46.9,                                         !- Maximum Dry-Bulb
Temperature {C}
15.6,                                         !- Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers ,                        !- Dry-Bulb Temperature
Range Modifier Type
,                                              !- Dry-Bulb Temperature
Range Modifier Day Schedule Name
Wetbulb ,                                     !- Humidity Condition Type
20.6 ,                                         !- Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,                                              !- Humidity Condition Day
Schedule Name
,                                              !- Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}
,                                              !- Enthalpy at Maximum Dry
-Bulb {J/kg}
,                                              !- Daily Wet-Bulb
Temperature Range {deltaC}
100666 ,                                       !- Barometric Pressure {Pa}
}
6.4 ,                                         !- Wind Speed {m/s}
320 ,                                         !- Wind Direction {deg}
No ,                                           !- Rain Indicator
No ,                                           !- Snow Indicator

```

```

No , ! - Daylight Saving Time
Indicator
ASHRAETau , ! - Solar Model Indicator
,
! - Beam Solar Day Schedule
Name
,
! - Diffuse Solar Day
Schedule Name
0.748 , ! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315; ! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 1% Condns DP=>MDB , ! - Name
7 , ! - Month
21 , ! - Day of Month
SummerDesignDay , ! - Day Type
31.2 , ! - Maximum Dry-Bulb
Temperature {C}
15.6 , ! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers , ! - Dry-Bulb Temperature
Range Modifier Type
,
! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Dewpoint , ! - Humidity Condition Type
24.1 , ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,
! - Humidity Condition Day
Schedule Name
,
! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}
,
! - Enthalpy at Maximum Dry
-Bulb {J/kg}
,
! - Daily Wet-Bulb
Temperature Range {deltaC}

```

```

100666,                                     ! - Barometric Pressure {Pa}
}

6.4,                                         ! - Wind Speed {m/s}
320,                                         ! - Wind Direction {deg}
No,                                           ! - Rain Indicator
No,                                           ! - Snow Indicator
No,                                           ! - Daylight Saving Time
Indicator

ASHRAETau,                                    ! - Solar Model Indicator
,
Name
,
! - Diffuse Solar Day

Schedule Name

0.748,                                       ! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                         ! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 1% Condns Enth=>MDB, ! - Name
7,                                              ! - Month
21,                                             ! - Day of Month
SummerDesignDay,                                ! - Day Type
34,                                              ! - Maximum Dry-Bulb
Temperature {C}
15.6,                                            ! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers,                            ! - Dry-Bulb Temperature
Range Modifier Type
,
! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Enthalpy,                                       ! - Humidity Condition Type
,
! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,
! - Humidity Condition Day
Schedule Name

```

```

,
! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}
82200,
! - Enthalpy at Maximum Dry
-Bulb {J/kg}

,
! - Daily Wet-Bulb
Temperature Range {deltaC}
100666,
! - Barometric Pressure {Pa}
}

6.4,
! - Wind Speed {m/s}
320,
! - Wind Direction {deg}
No,
! - Rain Indicator
No,
! - Snow Indicator
No,
! - Daylight Saving Time
Indicator
ASHRAETau,
! - Solar Model Indicator
,
! - Beam Solar Day Schedule
Name
,
! - Diffuse Solar Day
Schedule Name
0.748,
! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;
! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 1% Condns WB=>MDB, !- Name
7,
! - Month
21,
! - Day of Month
SummerDesignDay ,
! - Day Type
34.7,
! - Maximum Dry-Bulb
Temperature {C}
15.6,
! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers ,
! - Dry-Bulb Temperature
Range Modifier Type

```

```

,
! - Dry-Bulb Temperature

Range Modifier Day Schedule Name

Wetbulb,
! - Humidity Condition Type

26.3,
! - Wetbulb or DewPoint at

Maximum Dry-Bulb {C}
,
! - Humidity Condition Day

Schedule Name
,
! - Humidity Ratio at

Maximum Dry-Bulb {kgWater/kgDryAir}
,
! - Enthalpy at Maximum Dry

-Bulb {J/kg}
,
! - Daily Wet-Bulb

Temperature Range {deltaC}
100666,
! - Barometric Pressure {Pa}

}
6.4,
! - Wind Speed {m/s}
320,
! - Wind Direction {deg}
No,
! - Rain Indicator
No,
! - Snow Indicator
No,
! - Daylight Saving Time

Indicator
ASHRAETau,
! - Solar Model Indicator
,
! - Beam Solar Day Schedule

Name
,
! - Diffuse Solar Day

Schedule Name
0.748,
! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;
! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 2% Condns DB=>MWB , ! - Name
7,
! - Month
21,
! - Day of Month
SummerDesignDay ,
! - Day Type

```

```

45.9,                                     ! - Maximum Dry-Bulb
Temperature {C}

15.6,                                      ! - Daily Dry-Bulb
Temperature Range {deltaC}

DefaultMultipliers,                         ! - Dry-Bulb Temperature
Range Modifier Type

,                                         ! - Dry-Bulb Temperature
Range Modifier Day Schedule Name

Wetbulb,                                     ! - Humidity Condition Type
20.3,                                         ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}

,                                         ! - Humidity Condition Day
Schedule Name

,                                         ! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}

,                                         ! - Enthalpy at Maximum Dry
-Bulb {J/kg}

,                                         ! - Daily Wet-Bulb
Temperature Range {deltaC}

100666,                                     ! - Barometric Pressure {Pa}
}

6.4,                                         ! - Wind Speed {m/s}
320,                                         ! - Wind Direction {deg}
No,                                           ! - Rain Indicator
No,                                           ! - Snow Indicator
No,                                           ! - Daylight Saving Time
Indicator

ASHRAETau,                                    ! - Solar Model Indicator
,
Name

,                                         ! - Diffuse Solar Day
Schedule Name

0.748,                                       ! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                       ! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

```

```

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 2% Condns DP=>MDB , !- Name
7, !- Month
21, !- Day of Month
SummerDesignDay, !- Day Type
30.2, !- Maximum Dry-Bulb
Temperature {C}
15.6, !- Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers, !- Dry-Bulb Temperature
Range Modifier Type
,
!- Dry-Bulb Temperature
Range Modifier Day Schedule Name
Dewpoint, !- Humidity Condition Type
21.9, !- Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,
!- Humidity Condition Day
Schedule Name
,
!- Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}
,
!- Enthalpy at Maximum Dry
-Bulb {J/kg}
,
!- Daily Wet-Bulb
Temperature Range {deltaC}
100666, !- Barometric Pressure {Pa}
}
6.4, !- Wind Speed {m/s}
320, !- Wind Direction {deg}
No, !- Rain Indicator
No, !- Snow Indicator
No, !- Daylight Saving Time
Indicator
ASHRAETau, !- Solar Model Indicator
,
!- Beam Solar Day Schedule
Name

```

```

        ,                                     ! - Diffuse Solar Day
    Schedule Name
0.748,                                     ! - ASHRAE Clear Sky
    Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                      ! - ASHRAE Clear Sky
    Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
    Kuwait Intl Airport Ann Clg 2% Condns Enth=>MDB, ! - Name
    7,                                         ! - Month
    21,                                        ! - Day of Month
    SummerDesignDay,                         ! - Day Type
    34.4,                                       ! - Maximum Dry-Bulb
    Temperature {C}
    15.6,                                       ! - Daily Dry-Bulb
    Temperature Range {deltaC}
DefaultMultipliers,                         ! - Dry-Bulb Temperature
    Range Modifier Type
    ,                                           ! - Dry-Bulb Temperature
    Range Modifier Day Schedule Name
Enthalpy,                                    ! - Humidity Condition Type
    ,
    Maximum Dry-Bulb {C}                      ! - Wetbulb or DewPoint at
    ,                                           ! - Humidity Condition Day
    Schedule Name
    ,                                           ! - Humidity Ratio at
    Maximum Dry-Bulb {kgWater/kgDryAir}
75100,                                         ! - Enthalpy at Maximum Dry
    -Bulb {J/kg}
    ,                                           ! - Daily Wet-Bulb
    Temperature Range {deltaC}
100666,                                         ! - Barometric Pressure {Pa}
    }
6.4,                                            ! - Wind Speed {m/s}
320,                                            ! - Wind Direction {deg}
No,                                             ! - Rain Indicator

```

```

No,                                     ! - Snow Indicator
No,                                     ! - Daylight Saving Time
Indicator
ASHRAETau,                                ! - Solar Model Indicator
,
,                                         ! - Beam Solar Day Schedule
Name
,
,                                         ! - Diffuse Solar Day
Schedule Name
0.748,                                    ! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
1.315;                                     ! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Clg 2% Condns WB=>MDB , !- Name
7,                                         ! - Month
21,                                         ! - Day of Month
SummerDesignDay,                           ! - Day Type
34.2,                                       ! - Maximum Dry-Bulb
Temperature {C}
15.6,                                       ! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers,                         ! - Dry-Bulb Temperature
Range Modifier Type
,
,                                         ! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Wetbulb,                                    ! - Humidity Condition Type
24.7,                                       ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,
,                                         ! - Humidity Condition Day
Schedule Name
,
,                                         ! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}
,
,                                         ! - Enthalpy at Maximum Dry
-Bulb {J/kg}

```

```

,
!- Daily Wet-Bulb

Temperature Range {deltaC}
100666,
!- Barometric Pressure {Pa}

}
!- Wind Speed {m/s}

6.4,
!- Wind Direction {deg}

320,
!- Rain Indicator

No,
!- Snow Indicator

No,
!- Daylight Saving Time

Indicator

ASHRAETau,
!- Solar Model Indicator

,
!- Beam Solar Day Schedule

Name

,
!- Diffuse Solar Day

Schedule Name

0.748,
!- ASHRAE Clear Sky

Optical Depth for Beam Irradiance (taub) {dimensionless}

1.315;
!- ASHRAE Clear Sky

Optical Depth for Diffuse Irradiance (taud) {dimensionless}

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Htg 99% Condns DB, !- Name

1,
!- Month

21,
!- Day of Month

WinterDesignDay,
!- Day Type

5.8,
!- Maximum Dry-Bulb

Temperature {C}

0,
!- Daily Dry-Bulb

Temperature Range {deltaC}

DefaultMultipliers,
!- Dry-Bulb Temperature

Range Modifier Type
,
!- Dry-Bulb Temperature

Range Modifier Day Schedule Name

Wetbulb,
!- Humidity Condition Type

5.8,
!- Wetbulb or DewPoint at

Maximum Dry-Bulb {C}

```

```

        ,                                     ! - Humidity Condition Day
    Schedule Name

    ,                                     ! - Humidity Ratio at
    Maximum Dry-Bulb {kgWater/kgDryAir}

    ,                                     ! - Enthalpy at Maximum Dry
    -Bulb {J/kg}

    ,                                     ! - Daily Wet-Bulb
    Temperature Range {deltaC}
100666,                                     ! - Barometric Pressure {Pa}
}

1.9,                                     ! - Wind Speed {m/s}
300,                                     ! - Wind Direction {deg}
No,                                      ! - Rain Indicator
No,                                      ! - Snow Indicator
No,                                      ! - Daylight Saving Time
Indicator

ASHRAEClearSky,                           ! - Solar Model Indicator
,
! - Beam Solar Day Schedule
Name

,
! - Diffuse Solar Day

Schedule Name

,
! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
,
! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}
0;                                         ! - Sky Clearness

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Htg 99.6% Condns DB, ! - Name
1,                                         ! - Month
21,                                         ! - Day of Month
WinterDesignDay,                           ! - Day Type
4.1,                                         ! - Maximum Dry-Bulb
Temperature {C}
0,                                         ! - Daily Dry-Bulb
Temperature Range {deltaC}

```

```

DefaultMultipliers , ! - Dry-Bulb Temperature
    Range Modifier Type
,
! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Wetbulb , ! - Humidity Condition Type
4.1 , ! - Wetbulb or DewPoint at
    Maximum Dry-Bulb {C} ! - Humidity Condition Day
,
    Schedule Name ! - Humidity Ratio at
,
    Maximum Dry-Bulb {kgWater/kgDryAir} ! - Enthalpy at Maximum Dry
,
    -Bulb {J/kg} ! - Daily Wet-Bulb
,
    Temperature Range {deltaC}
100666 , ! - Barometric Pressure {Pa}
}
1.9 , ! - Wind Speed {m/s}
300 , ! - Wind Direction {deg}
No , ! - Rain Indicator
No , ! - Snow Indicator
No , ! - Daylight Saving Time
    Indicator
ASHRAEClearSky , ! - Solar Model Indicator
,
! - Beam Solar Day Schedule
    Name ! - Diffuse Solar Day
,
    Schedule Name ! - ASHRAE Clear Sky
,
Optical Depth for Beam Irradiance (taub) {dimensionless} ! - ASHRAE Clear Sky
,
Optical Depth for Diffuse Irradiance (taud) {dimensionless}
0; ! - Sky Clearness

SizingPeriod:DesignDay ,
Kuwait Intl Airport Ann Htg Wind 99% Condns WS=>MCDB , ! - Name

```

```

1,                                     ! - Month
21,                                     ! - Day of Month
WinterDesignDay,                         ! - Day Type
16.6,                                    ! - Maximum Dry-Bulb
Temperature {C}                           ! - Daily Dry-Bulb
0,                                       Temperature Range {deltaC}
                                         ! - Dry-Bulb Temperature
DefaultMultipliers,                      ! - Dry-Bulb Temperature
Range Modifier Type
,
                                         ! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Wetbulb,                                  ! - Humidity Condition Type
16.6,                                     ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}                      ! - Humidity Condition Day
,
                                         ! - Humidity Ratio at
Schedule Name
,
                                         ! - Enthalpy at Maximum Dry
Maximum Dry-Bulb {kgWater/kgDryAir}       ! - Enthalpy at Maximum Dry
,
                                         ! - Daily Wet-Bulb
-Bulb {J/kg}
,
                                         ! - Daily Wet-Bulb
Temperature Range {deltaC}
100666,                                    ! - Barometric Pressure {Pa}
}
10.2,                                     ! - Wind Speed {m/s}
300,                                       ! - Wind Direction {deg}
No,                                         ! - Rain Indicator
No,                                         ! - Snow Indicator
No,                                         ! - Daylight Saving Time
Indicator
ASHRAEClearSky,                           ! - Solar Model Indicator
,
                                         ! - Beam Solar Day Schedule
Name
,
                                         ! - Diffuse Solar Day
Schedule Name

```

```

        ,                                     ! - ASHRAE Clear Sky
    Optical Depth for Beam Irradiance (taub) {dimensionless}
    ,
        ,                                     ! - ASHRAE Clear Sky
    Optical Depth for Diffuse Irradiance (taud) {dimensionless}
0;                                         ! - Sky Clearness

SizingPeriod:DesignDay ,
    Kuwait Intl Airport Ann Htg Wind 99.6% Condns WS=>MCDB , ! - Name
    1,                                         ! - Month
    21,                                        ! - Day of Month
    WinterDesignDay ,                         ! - Day Type
    16.9,                                       ! - Maximum Dry-Bulb
        Temperature {C}
    0,                                         ! - Daily Dry-Bulb
        Temperature Range {deltaC}
DefaultMultipliers ,                      ! - Dry-Bulb Temperature
    Range Modifier Type
    ,
        ! - Dry-Bulb Temperature
    Range Modifier Day Schedule Name
Wetbulb ,                                    ! - Humidity Condition Type
    16.9,                                       ! - Wetbulb or DewPoint at
        Maximum Dry-Bulb {C}
    ,
        ! - Humidity Condition Day
    Schedule Name
    ,
        ! - Humidity Ratio at
    Maximum Dry-Bulb {kgWater/kgDryAir}
    ,
        ! - Enthalpy at Maximum Dry
    -Bulb {J/kg}
    ,
        ! - Daily Wet-Bulb
    Temperature Range {deltaC}
100666 ,                                     ! - Barometric Pressure {Pa}
    }
    11.3 ,                                     ! - Wind Speed {m/s}
    300 ,                                       ! - Wind Direction {deg}
    No ,                                         ! - Rain Indicator
    No ,                                         ! - Snow Indicator

```

```

No, ! - Daylight Saving Time
Indicator
ASHRAEClearSky, ! - Solar Model Indicator
,
! - Beam Solar Day Schedule
Name
,
! - Diffuse Solar Day
Schedule Name
,
! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
,
! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}
0; ! - Sky Clearness

SizingPeriod:DesignDay,
Kuwait Intl Airport Ann Hum_n 99% Condns DP=>MCDB, ! - Name
1, ! - Month
21, ! - Day of Month
WinterDesignDay, ! - Day Type
26.8, ! - Maximum Dry-Bulb
Temperature {C}
0, ! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers, ! - Dry-Bulb Temperature
Range Modifier Type
,
! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Dewpoint, ! - Humidity Condition Type
-9, ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}
,
! - Humidity Condition Day
Schedule Name
,
! - Humidity Ratio at
Maximum Dry-Bulb {kgWater/kgDryAir}
,
! - Enthalpy at Maximum Dry
-Bulb {J/kg}

```

```

,
! - Daily Wet-Bulb
Temperature Range {deltaC}
100666,
! - Barometric Pressure {Pa}
}
1.9,
! - Wind Speed {m/s}
300,
! - Wind Direction {deg}
No,
! - Rain Indicator
No,
! - Snow Indicator
No,
! - Daylight Saving Time
Indicator
ASHRAEClearSky,
! - Solar Model Indicator
,
! - Beam Solar Day Schedule
Name
,
! - Diffuse Solar Day
Schedule Name
,
! - ASHRAE Clear Sky
Optical Depth for Beam Irradiance (taub) {dimensionless}
,
! - ASHRAE Clear Sky
Optical Depth for Diffuse Irradiance (taud) {dimensionless}
0; ! - Sky Clearness

SizingPeriod:DesignDay,
Kuwait Intl Airport Ann Hum_n 99.6% Condns DP=>MCDB, ! - Name
1, ! - Month
21, ! - Day of Month
WinterDesignDay, ! - Day Type
27.7, ! - Maximum Dry-Bulb
Temperature {C}
0, ! - Daily Dry-Bulb
Temperature Range {deltaC}
DefaultMultipliers, ! - Dry-Bulb Temperature
Range Modifier Type
, ! - Dry-Bulb Temperature
Range Modifier Day Schedule Name
Dewpoint, ! - Humidity Condition Type

```

```

-11.9,                                     ! - Wetbulb or DewPoint at
Maximum Dry-Bulb {C}                         ! - Humidity Condition Day

,
Schedule Name                                 ! - Humidity Ratio at

,
Maximum Dry-Bulb {kgWater/kgDryAir}          ! - Enthalpy at Maximum Dry
,
-Bulb {J/kg}                                ! - Daily Wet-Bulb

,
Temperature Range {deltaC}                  ! - Barometric Pressure {Pa}
100666,                                     !
}

1.9,                                         ! - Wind Speed {m/s}
300,                                         ! - Wind Direction {deg}
No,                                           ! - Rain Indicator
No,                                           ! - Snow Indicator
No,                                           ! - Daylight Saving Time
Indicator

ASHRAEClearSky,                            ! - Solar Model Indicator
,
Name                                         ! - Beam Solar Day Schedule

,
! - Diffuse Solar Day

Schedule Name                               ! - ASHRAE Clear Sky

,
Optical Depth for Beam Irradiance (taub) {dimensionless} ! - ASHRAE Clear Sky
,
Optical Depth for Diffuse Irradiance (taud) {dimensionless}
0;                                            ! - Sky Clearness

ZoneList,
kuwait_apartment_building,                 ! - Name
Room_16_3d8c5364,                          ! - Zone Name 1
Room_17_fb615533,                          ! - Zone Name 2
Room_18_6cc35095,                          ! - Zone Name 3
Room_19_6ae0f9a9,                          ! - Zone Name 4
Room_20_4d060559,                          ! - Zone Name 5

```

```

Room_21_4c523269 , !- Zone Name 6
Room_22_f3ee5a53 , !- Zone Name 7
Room_23_e751e71f , !- Zone Name 8
Room_24_159d21b7 , !- Zone Name 9
Room_25_d27e0933 , !- Zone Name 10
Room_26_f4ea3797 , !- Zone Name 11
Room_27_0080b418 , !- Zone Name 12
Room_28_d6ed2799 , !- Zone Name 13
Room_29_2a634042 , !- Zone Name 14
Room_30_98f1d6c8; !- Zone Name 15

Lights ,
lights , !- Name
kuwait_apartment_building , !- Zone or ZoneList Name
project_light , !- Schedule Name
Watts/Area , !- Design Level

Calculation Method
,
5 , !- Lighting Level {W}
Area {W/m2} !- Watts per Zone Floor
,
person} !- Watts per Person {W/
0 , !- Return Air Fraction
0.6 , !- Fraction Radiant
0.2 , !- Fraction Visible
1 , !- Fraction Replaceable
General ; !- End-Use Subcategory

People ,
occupancy , !- Name
kuwait_apartment_building , !- Zone or ZoneList Name
MidriseApartment Building_People_Occ Schedule , !- Number of People
Schedule Name
People/Area , !- Number of People
Calculation Method
, !- Number of People

```

```

0.01,                                     !- People per Zone Floor
Area {person/m2}

,
                                         !- Zone Floor Area per

Person {m2/person}

0.3,                                      !- Fraction Radiant
,
                                         !- Sensible Heat Fraction

Seated Adult Activity,                   !- Activity Level Schedule

Name

0.0000000382,                           !- Carbon Dioxide Generation Rate {m3/s-W
}

No,                                       !- Enable ASHRAE 55 Comfort Warnings

ZoneAveraged,                            !- Mean Radiant Temperature Calculation

Type

,
                                         !- Surface Name/Angle Factor List Name

Work Eff Sch,                            !- Work Efficiency Schedule Name

ClothingInsulationSchedule,   !- Clothing Insulation Calculation

Method

,
                                         !- Clothing Insulation Calculation Method

Schedule Name

Clothing Sch,                            !- Clothing Insulation Schedule Name

Air Velo Sch,                            !- Air Velocity Schedule Name

Fanger,                                    !- Thermal Comfort Model 1 Type

Pierce,                                    !- Thermal Comfort Model 2 Type

AdaptiveASH55,                            !- Thermal Comfort Model 3 Type

KSU;                                     !- Thermal Comfort Model 4 Type

Schedule:Compact,
Air Velo Sch,                            !- Name
Fractional,                               !- Schedule Type Limits Name
Through: 12/31,                            !- Field 1
For: AllDays,                             !- Field 2
Until: 24:00,                             !- Field 3
0.35;                                    !- Field 4

Schedule:Compact,
Clothing Sch,                            !- Name

```

```

Fractional,                               !- Schedule Type Limits Name
Through: 12/31,                            !- Field 1
For: AllDays,                             !- Field 2
Until: 24:00,                             !- Field 3
0.5;                                     !- Field 4

Schedule:Compact,
Work Eff Sch,                           !- Name
Fractional,                               !- Schedule Type Limits Name
Through: 12/31,                            !- Field 1
For: AllDays,                             !- Field 2
Until: 24:00,                             !- Field 3
0;                                       !- Field 4

Schedule:Compact,
fan_sch,                                 !- Name
Fractional,                               !- Schedule Type Limits Name
Through: 12/31,                            !- Field 1
For: AllDays,                             !- Field 2
Until: 24:00,                             !- Field 3
1;                                       !- Field 4

ElectricEquipment,
ceiling_fan,                            !- Name
Room_16_3d8c5364,                         !- Zone or ZoneList Name
fan_sch,                                 !- Schedule Name
EquipmentLevel,                          !- Design Level Calculation Method
345,                                     !- Design Level {W}
,                                         !- Watts per Zone Floor Area {W/m2}
,                                         !- Watts per Person {W/person}
0,                                         !- Fraction Latent
0.4,                                      !- Fraction Radiant
0,                                         !- Fraction Lost
General;                                 !- End-Use Subcategory

ElectricEquipment,

```

```

electric_equip,
kuwait_apartment_building,
project_equipment,
Watts/Area,
    Calculation Method
,
13.4,
    Area {W/m2}
,
    person}
0,
0.5,
0,
General;                                !- End-Use Subcategory

GasEquipment,
gas equipment,
kuwait_apartment_building,
project_gas,
Watts/Area,
    Calculation Method
,
5.5,
    Area {W/m2}
,
    person}
0,
0.2,
0,
,
Generation Rate {m3/s-W}
General;                                !- End-Use Subcategory

ZoneInfiltration:DesignFlowRate,
infiltration,
kuwait_apartment_building,               !- Zone or ZoneList Name
                                         !- Name
                                         !- Schedule Name
                                         !- Design Level
                                         !- Design Level {W}
                                         !- Watts per Zone Floor
                                         !- Watts per Person {W/
                                         !- Fraction Latent
                                         !- Fraction Radiant
                                         !- Fraction Lost
                                         !- End-Use Subcategory

                                         !- Name
                                         !- Zone or ZoneList Name
                                         !- Schedule Name
                                         !- Design Level
                                         !- Design Level {W}
                                         !- Power per Zone Floor
                                         !- Power per Person {W/
                                         !- Fraction Latent
                                         !- Fraction Radiant
                                         !- Fraction Lost
                                         !- Carbon Dioxide
                                         !- End-Use Subcategory

```

```

Always On,                                ! - Schedule Name
Flow/ExteriorArea,                         ! - Design Flow Rate
Calculation Method
,
,
! - Design Flow Rate {m3/s}
,
! - Flow per Zone Floor
Area {m3/s-m2}
0.0003,                                     ! - Flow per Exterior
Surface Area {m3/s-m2}
,
! - Air Changes per Hour
{1/hr}
1,                                            ! - Constant Term
Coefficient
0,                                            ! - Temperature Term
Coefficient
0,                                            ! - Velocity Term
Coefficient
;
! - Velocity Squared Term
Coefficient

Curve:Biquadratic,
Air Conditioner Variable Refrigerant Flow 1 VRFCoolCapFT, !- Name
0.576882692,                                 ! - Coefficient1 Constant
0.017447952,                                 ! - Coefficient2 x
0.000583269,                                 ! - Coefficient3 x**2
-1.76324e-06,                                ! - Coefficient4 y
-7.474e-09,                                   ! - Coefficient5 y**2
-1.30413e-07,                                ! - Coefficient6 x*y
15,                                           ! - Minimum Value of x {
BasedOnField A2}
24,                                           ! - Maximum Value of x {
BasedOnField A2}
-5,                                           ! - Minimum Value of y {
BasedOnField A3}
23;                                           ! - Maximum Value of y {
BasedOnField A3}

```

```

Curve:Biquadratic ,
Air Conditioner Variable Refrigerant Flow 1 VRFCoolCapFTHi , !-
Name
0.6867358,                                     !- Coefficient1 Constant
0.0207631,                                     !- Coefficient2 x
0.0005447,                                     !- Coefficient3 x**2
-0.0016218,                                     !- Coefficient4 y
-4.259e-07,                                     !- Coefficient5 y**2
-0.0003392,                                     !- Coefficient6 x*y
15,                                              !- Minimum Value of x {
BasedOnField A2}
24,                                              !- Maximum Value of x {
BasedOnField A2}
16,                                              !- Minimum Value of y {
BasedOnField A3}
43;                                              !- Maximum Value of y {
BasedOnField A3}

Curve:Biquadratic ,
Air Conditioner Variable Refrigerant Flow 1 VRFCoolEIRFT, !- Name
0.989010541,                                     !- Coefficient1 Constant
-0.02347967,                                     !- Coefficient2 x
0.000199711,                                     !- Coefficient3 x**2
0.005968336,                                     !- Coefficient4 y
-1.0289e-07,                                     !- Coefficient5 y**2
-0.00015686,                                     !- Coefficient6 x*y
15,                                              !- Minimum Value of x {
BasedOnField A2}
24,                                              !- Maximum Value of x {
BasedOnField A2}
-5,                                              !- Minimum Value of y {
BasedOnField A3}
23;                                              !- Maximum Value of y {
BasedOnField A3}

Curve:Biquadratic ,

```

```

Air Conditioner Variable Refrigerant Flow 1 VRFCooleIRFTHi , !-
  Name
  -1.4395110176 ,                               !- Coefficient1 Constant
  0.1619850459 ,                               !- Coefficient2 x
  -0.0034911781 ,                               !- Coefficient3 x**2
  0.0269442645 ,                               !- Coefficient4 y
  0.0001346163 ,                               !- Coefficient5 y**2
  -0.0006714941 ,                               !- Coefficient6 x*y
  15 ,                                         !- Minimum Value of x {
    BasedOnField A2}
  23.9 ,                                         !- Maximum Value of x {
    BasedOnField A2}
  16.8 ,                                         !- Minimum Value of y {
    BasedOnField A3}
  43.3;                                         !- Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic ,
  Air Conditioner Variable Refrigerant Flow 1 VRFHeatCapFT , !- Name
  1.012090154 ,                               !- Coefficient1 Constant
  -0.0012467553 ,                               !- Coefficient2 x
  -0.0001271847 ,                               !- Coefficient3 x**2
  0.0267564328 ,                               !- Coefficient4 y
  -4.986e-07 ,                                 !- Coefficient5 y**2
  -0.0002635239 ,                               !- Coefficient6 x*y
  21.1 ,                                         !- Minimum Value of x {
    BasedOnField A2}
  27.2 ,                                         !- Maximum Value of x {
    BasedOnField A2}
  -20 ,                                         !- Minimum Value of y {
    BasedOnField A3}
  3.33;                                         !- Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic ,

```

```

Air Conditioner Variable Refrigerant Flow 1 VRFHeatCapFTHi , !-
  Name
  2.5859872368 ,                               !- Coefficient1 Constant
  -0.0953227101 ,                            !- Coefficient2 x
  0.0009553288 ,                            !- Coefficient3 x**2
  0 ,                                         !- Coefficient4 y
  0 ,                                         !- Coefficient5 y**2
  0 ,                                         !- Coefficient6 x*y
  21.1 ,                                     !- Minimum Value of x {
    BasedOnField A2}
  27.2 ,                                     !- Maximum Value of x {
    BasedOnField A2}
  -9.44 ,                                    !- Minimum Value of y {
    BasedOnField A3}
  15;                                         !- Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic ,
  Air Conditioner Variable Refrigerant Flow 1 VRFHeatEIRFT , !- Name
  0.7224292683 ,                            !- Coefficient1 Constant
  0.0034566628 ,                            !- Coefficient2 x
  0.0006507028 ,                            !- Coefficient3 x**2
  -0.0026435362 ,                           !- Coefficient4 y
  0.0012464766 ,                            !- Coefficient5 y**2
  -0.0001009161 ,                           !- Coefficient6 x*y
  21.1 ,                                     !- Minimum Value of x {
    BasedOnField A2}
  27.2 ,                                     !- Maximum Value of x {
    BasedOnField A2}
  -20 ,                                       !- Minimum Value of y {
    BasedOnField A3}
  3.33;                                      !- Maximum Value of y {
    BasedOnField A3}

Curve:Biquadratic ,

```

```

Air Conditioner Variable Refrigerant Flow 1 VRFHeatEIRFTHi , !-
  Name
  1.3885703646 ,                               !- Coefficient1 Constant
  -0.0229771462 ,                             !- Coefficient2 x
  0.000537274 ,                               !- Coefficient3 x**2
  -0.0273936962 ,                            !- Coefficient4 y
  0.0004030426 ,                            !- Coefficient5 y**2
  -5.9786e-05 ,                                !- Coefficient6 x*y
  21.1 ,                                     !- Minimum Value of x {
    BasedOnField A2}
  27.2 ,                                     !- Maximum Value of x {
    BasedOnField A2}
  0 ,                                         !- Minimum Value of y {
    BasedOnField A3}
  1;                                         !- Maximum Value of y {
    BasedOnField A3}

Curve:Cubic ,
  Air Conditioner Variable Refrigerant Flow 1 CoolingCombRatio , !-
    Name
    0.576593263 ,                           !- Coefficient1 Constant
    0.6349408697 ,                         !- Coefficient2 x
    -0.3076093963 ,                        !- Coefficient3 x**2
    0.0960752636 ,                         !- Coefficient4 x**3
    1 ,                                       !- Minimum Value of x {
      BasedOnField A2}
    1.5;                                      !- Maximum Value of x {
      BasedOnField A2}

Curve:Cubic ,
  Air Conditioner Variable Refrigerant Flow 1 CoolingEIRHiPLR , !-
    Name
    1 ,                                       !- Coefficient1 Constant
    0 ,                                         !- Coefficient2 x
    0 ,                                         !- Coefficient3 x**2
    0 ,                                         !- Coefficient4 x**3

```

```

1,                                     ! - Minimum Value of x {
BasedOnField A2}

1.5;                                    ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Air Conditioner Variable Refrigerant Flow 1 CoolingEIRLowPLR, !-
Name
0.4541226192,                           ! - Coefficient1 Constant
-0.1729687081,                          ! - Coefficient2 x
1.0828661347,                           ! - Coefficient3 x**2
-0.3618480897,                          ! - Coefficient4 x**3
0.5,                                     ! - Minimum Value of x {
BasedOnField A2}

1;                                       ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Air Conditioner Variable Refrigerant Flow 1 HeatingCombRatio, !-
Name
0.7667196604,                           ! - Coefficient1 Constant
0.2617302019,                           ! - Coefficient2 x
-0.0159110245,                          ! - Coefficient3 x**2
-0.0125388376,                          ! - Coefficient4 x**3
1,                                       ! - Minimum Value of x {
BasedOnField A2}

1.5;                                     ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Air Conditioner Variable Refrigerant Flow 1 HeatingEIRHiPLR, !-
Name
1,                                       ! - Coefficient1 Constant
0,                                       ! - Coefficient2 x
0,                                       ! - Coefficient3 x**2
0,                                       ! - Coefficient4 x**3

```

```

1,                                     ! - Minimum Value of x {
BasedOnField A2}

1.5;                                    ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Air Conditioner Variable Refrigerant Flow 1 HeatingEIRLowPLR, !-
Name
0.3924742025,                           ! - Coefficient1 Constant
0.076016374,                            ! - Coefficient2 x
0.6983235783,                           ! - Coefficient3 x**2
-0.1688407813,                          ! - Coefficient4 x**3
0.5,                                     ! - Minimum Value of x {
BasedOnField A2}

1;                                       ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Air Conditioner Variable Refrigerant Flow 1 VRFCoolCapFTBoundary, !-
Name
25.73,                                    ! - Coefficient1 Constant
-0.03150043,                            ! - Coefficient2 x
-0.01416595,                            ! - Coefficient3 x**2
0,                                         ! - Coefficient4 x**3
11,                                        ! - Minimum Value of x {
BasedOnField A2}

30;                                       ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Air Conditioner Variable Refrigerant Flow 1 VRFCoolEIRFTBoundary, !-
Name
25.73473775,                            ! - Coefficient1 Constant
-0.03150043,                            ! - Coefficient2 x
-0.01416595,                            ! - Coefficient3 x**2
0,                                         ! - Coefficient4 x**3

```

```

15,                                     !- Minimum Value of x {
    BasedOnField A2}

24;                                     !- Maximum Value of x {
    BasedOnField A2}

Curve:Cubic,
    Air Conditioner Variable Refrigerant Flow 1 VRFCPLFFPLR, !- Name
    0.85,                                         !- Coefficient1 Constant
    0.15,                                         !- Coefficient2 x
    0,                                              !- Coefficient3 x**2
    0,                                              !- Coefficient4 x**3
    1,                                              !- Minimum Value of x {
        BasedOnField A2}
    1;                                              !- Maximum Value of x {
        BasedOnField A2}

Curve:Cubic,
    Air Conditioner Variable Refrigerant Flow 1 VRFHeatCapFTBoundary,
    !- Name
    58.577,                                         !- Coefficient1 Constant
    -3.0255,                                         !- Coefficient2 x
    0.0193,                                         !- Coefficient3 x**2
    0,                                              !- Coefficient4 x**3
    15,                                             !- Minimum Value of x {
        BasedOnField A2}
    23.9;                                            !- Maximum Value of x {
        BasedOnField A2}

Curve:Cubic,
    Air Conditioner Variable Refrigerant Flow 1 VRFHeatEIRFTBoundary,
    !- Name
    58.577,                                         !- Coefficient1 Constant
    -3.0255,                                         !- Coefficient2 x
    0.0193,                                         !- Coefficient3 x**2
    0,                                              !- Coefficient4 x**3

```

```

15,                                     ! - Minimum Value of x {
BasedOnField A2}

23.9;                                     ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Curve Cubic 1,                           ! - Name
0.758746,                                ! - Coefficient1 Constant
0.027626,                                ! - Coefficient2 x
0.000148716,                             ! - Coefficient3 x**2
3.4992e-06,                               ! - Coefficient4 x**3
-20,                                      ! - Minimum Value of x {
BasedOnField A2}

20;                                       ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Curve Cubic 2,                           ! - Name
0.84,                                     ! - Coefficient1 Constant
0.16,                                     ! - Coefficient2 x
0,                                         ! - Coefficient3 x**2
0,                                         ! - Coefficient4 x**3
0.5,                                      ! - Minimum Value of x {
BasedOnField A2}

1.5;                                      ! - Maximum Value of x {
BasedOnField A2}

Curve:Cubic,
Curve Cubic 3,                           ! - Name
1.19248,                                 ! - Coefficient1 Constant
-0.0300438,                             ! - Coefficient2 x
0.00103745,                            ! - Coefficient3 x**2
-2.3328e-05,                            ! - Coefficient4 x**3
-20,                                     ! - Minimum Value of x {
BasedOnField A2}

```

```

20;                                     ! - Maximum Value of x {
    BasedOnField A2}

Curve:Quadratic,
    Curve Quadratic 1,                      ! - Name
    1.3824,                                  ! - Coefficient1 Constant
    -0.4336,                                 ! - Coefficient2 x
    0.0512,                                 ! - Coefficient3 x**2
    0,                                       ! - Minimum Value of x {
        BasedOnField A2}
    1;                                         ! - Maximum Value of x {
        BasedOnField A2}

Curve:Quadratic,
    Curve Quadratic 2,                      ! - Name
    0.75,                                    ! - Coefficient1 Constant
    0.25,                                    ! - Coefficient2 x
    0,                                       ! - Coefficient3 x**2
    0,                                       ! - Minimum Value of x {
        BasedOnField A2}
    1;                                         ! - Maximum Value of x {
        BasedOnField A2}

SetpointManager:Scheduled,
    Setpoint Manager Scheduled 1,           ! - Name
    Temperature,                            ! - Control Variable
    60C Hot Water,                         ! - Schedule Name
    Node 2;                                ! - Setpoint Node or
    NodeList Name

LifeCycleCost:NonrecurringCost,
    Default Cost,                          ! - Name
    Construction,                         ! - Category
    0,                                     ! - Cost

```

```

ServicePeriod;                                ! - Start of Costs

Site:GroundTemperature:BuildingSurface ,
23.07 ,                                     ! - January Ground Temperature {C}
23.01 ,                                     ! - February Ground Temperature {C}
23.2 ,                                       ! - March Ground Temperature {C}
23.43 ,                                     ! - April Ground Temperature {C}
23.84 ,                                     ! - May Ground Temperature {C}
24.14 ,                                     ! - June Ground Temperature {C}
24.32 ,                                     ! - July Ground Temperature {C}
24.39 ,                                     ! - August Ground Temperature {C}
24.22 ,                                     ! - September Ground Temperature {C}
23.97 ,                                     ! - October Ground Temperature {C}
23.56 ,                                     ! - November Ground Temperature {C}
23.14;                                      ! - December Ground Temperature {C}

***** ****

ElectricLoadCenter:Distribution ,
PV Array Load Center,           ! - Name
Generator List,                 ! - Generator List Name
TrackElectrical,                ! - Generator Operation Scheme Type
0,                               ! - Generator Demand Limit Scheme
Purchased Electric Demand Limit {W}

```

```

        ,                                     !- Generator Track Schedule Name Scheme
Schedule Name

        ,                                     !- Generator Track Meter Scheme Meter
Name

DirectCurrentWithInverterDCStorage,   !- Electrical Buss Type
PV Inverter,                      !- Inverter Name
LiIonBattery,                     !- Electrical Storage Object Name
,
!- Transformer Object Name
TrackChargeDischargeSchedules,    !- Storage Operation Scheme
,
!- Storage Control Track Meter Name
Storage Converter,                !- Storage Converter Object Name
0.95,                             !- Maximum Storage State of Charge
Fraction
0.2,                             !- Minimum Storage State of Charge
Fraction
16978,                           !- Design Storage Control Charge
Power
charge_sch,                      !- Storage Charge Power Fraction
Schedule Name
10700,                           !- Design Storage Control Discharge
Power
discharge_sch,                   !- Storage Discharge Power Fraction
Schedule Name
,
!- Storage Control Utility Demand
Target
;
!- Storage Control Utility Demand
Target Fraction Schedule Name

ElectricLoadCenter:Storage:Converter ,
Storage Converter , !- Name
ALWAYS_ON , !- Availability Schedule Name
SimpleFixed , !- Power Conversion Efficiency Method
0.95 ,       !- Simple Fixed Efficiency
,           !- Design Maximum Continuous Input Power
,           !- Efficiency Function of Power Curve Name 20
,           !- Ancillary Power Consumed In Standby

```

```

        ,           !- Zone Name 0.25
        ;           !- Radiative Fraction

Curve:DoubleExponentialDecay ,
    Doubleexponential,          !- Name
    1380,                      !- Coefficient1 C1
    6834,                      !- Coefficient2 C2
    -8.75,                     !- Coefficient3 C3
    6747,                      !- Coefficient4 C4
    -6.22,                     !- Coefficient5 C5
    0,                         !- Minimum Value of x
    1,                         !- Maximum Value of x
    ,                          !- Minimum Curve Output
    ,                          !- Maximum Curve Output
    Dimensionless,             !- Input Unit Type for x
    Dimensionless;             !- Output Unit Type

ElectricLoadCenter:Storage:LithiumIONBattery ,
    LithiumBattery,            !- Name
    ALWAYS_ON,                 !- Availability Schedule Name
    ,                         !- Zone Name
    0,                         !- Radiative Fraction
    KandlerSmith,              !- Lifetime Model
    139,                       !- Number of Cells in Series
    50,                        !- Number of Strings in Parallel
    0.7,                       !- Initial Fractional State of Charge
    ,                          !- DC to DC Charging Efficiency
    342,                       !- Battery Mass
    4.26,                      !- Battery Surface Area
    ,                          !- Battery Specific Heat Capacity
    ;                          !- Heat Transfer Coefficient Between
                                Battery and Ambient

ElectricLoadCenter:Inverter:LookUpTable ,
    PV Inverter,               !- Name
    ALWAYS_ON,                 !- Availability Schedule Name

```

```

        ,                                     !- Zone Name
0.25,                                     !- Radiative Fraction
14000,                                    !- Rated Maximum Continuous Output
Power {W}
200.0,                                     !- Night Tare Loss Power {W}
368,                                       !- Nominal Voltage Input {V}
0.839,                                     !- Efficiency at 10% Power and Nominal
Voltage
0.897,                                     !- Efficiency at 20% Power and Nominal
Voltage
0.916,                                     !- Efficiency at 30% Power and Nominal
Voltage
0.931,                                     !- Efficiency at 50% Power and Nominal
Voltage
0.934,                                     !- Efficiency at 75% Power and Nominal
Voltage
0.930;                                      !- Efficiency at 100% Power and Nominal
Voltage

ElectricLoadCenter:Generators,
Generator List,                         !- Name
PV_roof_front,   !- Generator 1 Name
Generator:Photovoltaic,    !- Generator 1 Object Type
9000.0,                                     !- Generator 1 Rated Electric Power
Output {W}
,                                         !- Generator 1 Availability Schedule
Name
,                                         !- Generator 1 Rated Thermal to
Electrical Power Ratio
PV_roof_left,   !- Generator 2 Name
Generator:Photovoltaic,    !- Generator 1 Object Type
9000.0,                                     !- Generator 1 Rated Electric Power
Output {W}
,                                         !- Generator 1 Availability Schedule
Name

```

```

,
      !- Generator 1 Rated Thermal to
Electrical Power Ratio

PV_roof_middle,  !- Generator 3 Name
Generator:Photovoltaic,  !- Generator 1 Object Type
9000.0,           !- Generator 1 Rated Electric Power
Output {W}
,
      !- Generator 1 Availability Schedule
Name
,
      !- Generator 1 Rated Thermal to
Electrical Power Ratio

PV_roof_right,  !- Generator 4 Name
Generator:Photovoltaic,  !- Generator 1 Object Type
9000.0,           !- Generator 1 Rated Electric Power
Output {W}
,
      !- Generator 1 Availability Schedule
Name
,
      !- Generator 1 Rated Thermal to
Electrical Power Ratio

PV_roof_back,  !- Generator 5 Name
Generator:Photovoltaic,  !- Generator 2 Object Type
9000.0,           !- Generator 2 Rated Electric Power
Output {W}
,
      !- Generator 2 Availability Schedule
Name
;
      !- Generator 2 Rated Thermal to
Electrical Power Ratio

PhotovoltaicPerformance:Simple,
20percentEffPVhalfArea,  !- Name
1,                      !- Fraction of Surface Area with Active
Solar Cells {dimensionless}
Fixed,                  !- Conversion Efficiency Input Mode
0.20,                  !- Value for Cell Efficiency if Fixed

```

```

;                                         !- Efficiency Schedule Name

Generator:Photovoltaic,
PV_roof_front,   !- Name
Room_18_6cc35095..Face5,!- Surface Name
PhotovoltaicPerformance:Simple,   !- Photovoltaic Performance
Object Type
20percentEffPVhalfArea,   !- Module Performance Name
Decoupled,           !- Heat Transfer Integration Mode
1.0,                 !- Number of Series Strings in Parallel
{dimensionless}
1.0;                  !- Number of Modules in Series {
dimensionless}

ComponentCost:LineItem,
PV_roof_front,   !- Name
,                !- Type
Generator:Photovoltaic,   !- Line Item Type
PV_roof_front,   !- Item Name
,                !- Object End-Use Key
,                !- Cost per Each {$}
,                !- Cost per Area {$/m2}
9000.0000,       !- Cost per Unit of Output Capacity ${/
kW}
,                !- Cost per Unit of Output Capacity per
COP {$/kW}
,                !- Cost per Volume ${/m3}
,                !- Cost per Volume Rate ${/(m3/s)}
,                !- Cost per Energy per Temperature
Difference ${/(W/K)}
;                !- Quantity {dimensionless}

Generator:Photovoltaic,
PV_roof_left,   !- Name
Room_19_6ae0f9a9..Face5,!- Surface Name

```

```

PhotovoltaicPerformance:Simple,   !- Photovoltaic Performance
Object Type
20percentEffPVhalfArea,   !- Module Performance Name
Decoupled,           !- Heat Transfer Integration Mode
1.0,                 !- Number of Series Strings in Parallel
{dimensionless}
1.0;                  !- Number of Modules in Series {
dimensionless}

ComponentCost:LineItem,
PV_roof_left,   !- Name
,               !- Type
Generator:Photovoltaic, !- Line Item Type
PV_roof_left,   !- Item Name
,               !- Object End-Use Key
,               !- Cost per Each {$}
,               !- Cost per Area {$/m2}
9000.0000,     !- Cost per Unit of Output Capacity {$/kW}
,               !- Cost per Unit of Output Capacity per
COP {$/kW}
,               !- Cost per Volume {$/m3}
,               !- Cost per Volume Rate {$(m3/s)}
,               !- Cost per Energy per Temperature
Difference {$(W/K)}
;               !- Quantity {dimensionless}

Generator:Photovoltaic,
PV_roof_middle,   !- Name
Room_22_f3ee5a53..Face5,!- Surface Name
PhotovoltaicPerformance:Simple,   !- Photovoltaic Performance
Object Type
20percentEffPVhalfArea,   !- Module Performance Name
Decoupled,           !- Heat Transfer Integration Mode
1.0,                 !- Number of Series Strings in Parallel
{dimensionless}

```

```

1.0;                               !- Number of Modules in Series {
dimensionless}

ComponentCost:LineItem,
PV_roof_middle,   !- Name
,                  !- Type
Generator:Photovoltaic, !- Line Item Type
PV_roof_middle,   !- Item Name
,                  !- Object End-Use Key
,                  !- Cost per Each {$}
,                  !- Cost per Area {$/m2}
9000.0000,        !- Cost per Unit of Output Capacity {$/kW}
,                  !- Cost per Unit of Output Capacity per COP {$/kW}
,                  !- Cost per Volume {$/m3}
,                  !- Cost per Volume Rate {$(m3/s)}
,                  !- Cost per Energy per Temperature Difference {$(W/K)}
;

                                         !- Quantity {dimensionless}

Generator:Photovoltaic,
PV_roof_right,   !- Name
Room_25_d27e0933..Face5,!- Surface Name
PhotovoltaicPerformance:Simple,   !- Photovoltaic Performance Object Type
20percentEffPVhalfArea,   !- Module Performance Name
Decoupled,           !- Heat Transfer Integration Mode
1.0,                !- Number of Series Strings in Parallel {dimensionless}
1.0;                !- Number of Modules in Series {
dimensionless}

ComponentCost:LineItem,
PV_roof_right,   !- Name
,                  !- Type

```

```

Generator:Photovoltaic,   !- Line Item Type
PV_roof_right,   !- Item Name
,
          !- Object End-Use Key
,
          !- Cost per Each {$}
,
          !- Cost per Area {$/m2}
9000.0000,           !- Cost per Unit of Output Capacity {$/kW}
,
          !- Cost per Unit of Output Capacity per COP {$/kW}
,
          !- Cost per Volume {$/m3}
,
          !- Cost per Volume Rate {$(m3/s)}
,
          !- Cost per Energy per Temperature Difference {$(W/K)}
;
          !- Quantity {dimensionless}

Generator:Photovoltaic,
PV_roof_back,   !- Name
Room_28_d6ed2799..Face5,!- Surface Name
PhotovoltaicPerformance:Simple,   !- Photovoltaic Performance Object Type
20percentEffPVhalfArea,   !- Module Performance Name
Decoupled,           !- Heat Transfer Integration Mode
1.0,                 !- Number of Series Strings in Parallel {dimensionless}
1.0;                  !- Number of Modules in Series {
dimensionless}

ComponentCost:LineItem,
PV_roof_back,   !- Name
,
          !- Type
Generator:Photovoltaic,   !- Line Item Type
PV_roof_back,   !- Item Name
,
          !- Object End-Use Key
,
          !- Cost per Each {$}
,
          !- Cost per Area {$/m2}

```

```

9000.0000,                                     !- Cost per Unit of Output Capacity {$/kW}
,
                                     !- Cost per Unit of Output Capacity per COP {$/kW}
,
                                     !- Cost per Volume {$/m3}
,
                                     !- Cost per Volume Rate {$(m3/s)}
,
                                     !- Cost per Energy per Temperature Difference {$(W/K)}
;
                                     !- Quantity {dimensionless}

Output:VariableDictionary,
IDF;                               !- Key Field

Output:Variable,*,Site Outdoor Air Drybulb Temperature,hourly; !-
Zone Average [C]

Output:Variable,*,Facility Total Electricity Demand Rate,hourly; !-
HVAC Average [W]

Output:Variable,*,Zone Thermal Comfort Pierce Model Standard Effective Temperature,hourly; !- Zone Average [C]

Output:Variable,*,Electric Load Center Produced Electricity Rate, hourly;

Output:Variable,
*,                                         !- Key Value
Electric Storage Charge Power,      !- Variable Name
hourly;                                !- Reporting Frequency

Output:Variable,
*,                                         !- Key Value
Electric Storage Discharge Power,    !- Variable Name

```

hourly;

! - Reporting Frequency

Output:Variable ,\*, Facility Net Purchased Electricity Rate ,hourly;



# Bibliography

- [1] Building energy codes program, prototype building models. accessed 17 November 2021.
- [2] Energyplus. accessed 17 November 2021.
- [3] eppy. accessed 17 November 2021.
- [4] geomeppy. accessed 17 November 2021.
- [5] A. Y. Al-Hasan, A. A. Ghoneim, and A. H. Abdullah. Optimizing electrical load pattern in kuwait using grid connected photovoltaic systems. *Energy Conversion and Management*, 45(4):483–494, Mar 2004.
- [6] Morshed Alam, Jay Sanjayan, and Patrick X. W. Zou. *Chapter Eleven - Balancing Energy Efficiency and Heat Wave Resilience in Building Design*, page 329–349. Butterworth-Heinemann, Jan 2019.
- [7] Mubarak Alawadhi and Patrick E. Phelan. Review of residential air conditioning systems operating under high ambient temperatures. *Energies*, 15(88):2880, Jan 2022.
- [8] Fadi Alsaleem, Mehari K. Tesfay, Mostafa Rafaie, Kevin Sinkar, Dhaman Besarla, and Parthiban Arunasalam. An iot framework for modeling and controlling thermal comfort in buildings. *Frontiers in Built Environment*, 6, 2020.

- [9] SL Arun and MP Selvan. Smart residential energy management system for demand response in buildings with energy storage devices. *Frontiers in Energy*, 13(4):715–730, 2019.
- [10] Surat Atthajariyakul and Charoenporn Lertsatit-tanakorn. Small fan assisted air conditioner for thermal comfort and energy saving in thailand. *Energy Conversion and Management*, 49(10):2499–2504, Oct 2008.
- [11] Andris Auliciems and S. V. Szokolay. *Thermal comfort*. PLEA notes. PLEA in association with Dept. of Architecture, University of Queensland, 1997.
- [12] Jane Wilson Baldwin, Jay Benjamin Dessy, Gabriel A. Vecchi, and Michael Oppenheimer. Temporally compound heat wave events and global warming: An emerging hazard. *Earth's Future*, 7(4):411–427, 2019.
- [13] Rupa Basu and Jonathan M. Samet. Relation between elevated ambient temperature and mortality: A review of the epidemiologic evidence. *Epidemiologic Reviews*, 24(2):190–202, Dec 2002.
- [14] Abdullatif E. Ben-Nakhi and Mohamed A. Mahmoud. Cooling load prediction for buildings using general regression neural networks. *Energy Conversion and Management*, 45(13):2127–2141, 2004.
- [15] Pablo Bermejo, Luis Redondo, Luis de la Ossa, Daniel Rodríguez, Julia Flores, Carmen Urea, José A. Gámez, and José M. Puerta. Design and simulation of a thermal

- comfort adaptive system based on fuzzy logic and on-line learning. *Energy and Buildings*, 49:367–379, Jun 2012.
- [16] Dimitris Bertsimas and John Tsitsiklis. *Introduction to Linear Optimization*. 01 1998.
- [17] Gail S. Brager and Richard J. de Dear. *Historical and Cultural Influences on Comfort Expectations*, page 177–201. John Wiley Sons, Ltd, 2003.
- [18] James E. Braun. Load control using building thermal mass. *Journal of Solar Energy Engineering*, 125(3):292–301, Aug 2003.
- [19] Federico M. Butera. Chapter 3—principles of thermal comfort. *Renewable and Sustainable Energy Reviews*, 2(1):39–66, Jun 1998.
- [20] Berk Celik, Robin Roche, David Bouquain, and Abdel-latif Miraoui. Coordinated neighborhood energy sharing using game theory and multi-agent systems. In *2017 IEEE Manchester PowerTech*, page 1–6, Jun 2017.
- [21] Carlos Cerezo, Julia Sokol, Saud AlKhaled, Christoph Reinhart, Adil Al-Mumin, and Ali Hajiah. Comparison of four building archetype characterization methods in urban building energy modeling (ubem): A residential case study in kuwait city. *Energy and Buildings*, 154:321–334, Nov 2017.
- [22] JP Coniff. Strategies for reducing peak air conditioning loads by using heat storage in the building structure. *ASHRAE Transactions*, 97(1):704–709, 1991.

- [23] Charles D. Corbin, Gregor P. Henze, and Peter May-Ostendorp. A model predictive control optimization environment for real-time commercial building application. *Journal of Building Performance Simulation*, 6(3):159–174, May 2013.
- [24] TensorFlow Developers. Tensorflow. May 2022.
- [25] Steven Diamond and Stephen Boyd. CVXPY: A Python-embedded modeling language for convex optimization. *Journal of Machine Learning Research*, 17(83):1–5, 2016.
- [26] Nicholas DiOrio, Aron Dobos, Steven Janzou, Austin Nelson, and Blake Lundstrom. *Technoeconomic Modeling of Battery Energy Storage in SAM*. Number NREL/TP-6A20-64641, 1225314. Sep 2015.
- [27] Bing Dong and Khee Poh Lam. A real-time model predictive control for building heating and cooling systems based on the occupancy behavior pattern detection and local weather forecasting. *Building Simulation*, 7(1):89–106, Feb 2014.
- [28] P. O. Fanger. Thermal comfort. analysis and applications in environmental engineering. *Thermal comfort. Analysis and applications in environmental engineering.*, 1970.
- [29] Yanxiao Feng, Shichao Liu, Julian Wang, Jing Yang, Ying-Ling Jao, and Nan Wang. Data-driven personal thermal comfort prediction: A literature review. 161:112357, Jun 2022.
- [30] P.M. Ferreira, A.E. Ruano, S. Silva, and E.Z.E. Conceição. Neural networks based predictive control for ther-

- mal comfort and energy savings in public buildings. *Energy and Buildings*, 55:238–251, Dec 2012.
- [31] M. Fountain and Edward Arens. Air movement and thermal comfort. *Ashrae Journal - ASHRAE J*, 35:26–29, Jan 1993.
  - [32] AP Gagge, J Nishi, and RR Gonzales. Standard effective temperature, symposium thermal comfort and moderate heat stress. *CIB Commission W*, 45, 1972.
  - [33] Pedro A. González and Jesús M. Zamarreño. Prediction of hourly energy consumption in buildings based on a feedback artificial neural network. *Energy and Buildings*, 37(6):595–601, Jun 2005.
  - [34] Rajat Gupta, Adorkor Bruce-Konuah, and Alastair Howard. Achieving energy resilience through smart storage of solar electricity at dwelling and community level. *Energy and Buildings*, 195:1–15, Jul 2019.
  - [35] Son H. Ho, Luis Rosario, and Muhammad M. Rahman. Thermal comfort enhancement by using a ceiling fan. *Applied Thermal Engineering*, 29(8):1648–1656, Jun 2009.
  - [36] A.J. Hoffman. Peak demand control in commercial buildings with target peak adjustment based on load forecasting. In *Proceedings of the 1998 IEEE International Conference on Control Applications (Cat. No.98CH36104)*, volume 2, page 1292–1296 vol.2, Sep 1998.
  - [37] Holger H Hoos and Thomas Stützle. *Stochastic local search: Foundations and applications*. Elsevier, 2004.

- [38] Zhijian Hou and Zhiwei Lian. An application of support vector machines in cooling load prediction. In *2009 International Workshop on Intelligent Systems and Applications*, page 1–4, May 2009.
- [39] Shih-Wen Hsiao, Hsin-Hung Lin, and Chi-Hung Lo. A study of thermal comfort enhancement by the optimization of airflow induced by a ceiling fan. *Journal of Interdisciplinary Mathematics*, 19(4):859–891, Jul 2016.
- [40] Madhavi Indraganti and Kavita Rao. Effect of age, gender, economic group and tenure on thermal comfort: A field study in residential buildings in hot and dry climate with seasonal variations. 2010.
- [41] Babak Jeddi, Yateendra Mishra, and Gerard Ledwich. Distributed load scheduling in residential neighborhoods for coordinated operation of multiple home energy management systems. *Applied Energy*, 300:117353, Oct 2021.
- [42] Sami Karjalainen. Gender differences in thermal comfort and use of thermostats in everyday thermal environments. *Building and Environment*, 42(4):1594–1603, Apr 2007.
- [43] Kevin J Kircher, Yuan Cai, Leslie K Norford, and Steven B Leeb. Controlling big, diverse, nonlinear load aggregations for grid services by adjusting device set-points. *IEEE Conference on Decision and Control*, page 8, 2021.
- [44] Jochen Klenk, Clemens Becker, and Kilian Rapp. Heat-related mortality in residents of nursing homes. *Age and Ageing*, 39(2):245–252, Mar 2010.

- [45] Joshua Kneifel and Eric O'Rear. Reducing the impacts of weather variability on long-term building energy performance by adopting energy-efficient measures and systems: a case study. *Journal of Building Performance Simulation*, 10(1):58–71, Jan 2017.
- [46] R. Sari Kovats and Shakoor Hajat. Heat stress and public health: A critical review. *Annual Review of Public Health*, 29(1):41–55, Apr 2008.
- [47] Dieter Kraft. *A software package for sequential quadratic programming*. DFVLR, Koln, 1988. Open Library ID: OL18926873M.
- [48] Cho Kwong Charlie Lam and Jian Hang. Solar radiation intensity and outdoor thermal comfort in royal botanic garden melbourne during heatwave conditions. *Procedia Engineering*, 205:3456–3462, 2017.
- [49] Zachary E. Lee and K. Max Zhang. Scalable identification and control of residential heat pumps: A minimal hardware approach. *Applied Energy*, 286:116544, Mar 2021.
- [50] Julien Legriel, Colas Le Guernic, Scott Cotton, and Oded Maler. Approximating the pareto front of multi-criteria optimization problems. In Javier Esparza and Rupak Majumdar, editors, *Tools and Algorithms for the Construction and Analysis of Systems*, Lecture Notes in Computer Science, page 69–83. Springer, 2010.
- [51] Qiong Li, Qinglin Meng, Jiejin Cai, Hiroshi Yoshino, and Akashi Mochida. Applying support vector machine to

- predict hourly cooling load in the building. *Applied Energy*, 86(10):2249–2256, Oct 2009.
- [52] Shuo Liu, Aleksandra Lipczynska, Stefano Schiavon, and Edward Arens. Detailed experimental investigation of air speed field induced by ceiling fans. *Building and Environment*, 142:342–360, Sep 2018.
- [53] Shuo Liu, Le Yin, Stefano Schiavon, Weng Khuen Ho, and Keck Voon Ling. Coordinate control of air movement for optimal thermal comfort. *Science and Technology for the Built Environment*, 24(8):886–896, Sep 2018.
- [54] Maohui Luo, Hui Zhang, Zi Wang, Edward Arens, Chen Wenhua, Fred Bauman, and Paul Raftery. Ceiling-fan-integrated air-conditioning: thermal comfort evaluations. *Buildings and Cities*, 2, Dec 2021.
- [55] R. K. Macpherson. Thermal stress and thermal comfort. *Ergonomics*, 16(5):611–622, Sep 1973.
- [56] A. Megri, I. E. Naqa, and F. Haghighat. A learning machine approach for predicting thermal comfort indices. 2005.
- [57] Sakshi Mishra and Praveen Palanisamy. Efficient power flow management and peak shaving in a microgrid-pv system. page 3792–3798, Sep 2018.
- [58] Shreshth Nagpal, Caitlin Mueller, Arfa Aijazi, and Christoph F. Reinhart. A methodology for auto-calibrating urban building energy models using surrogate modeling techniques. *Journal of Building Performance Simulation*, 12(1):1–16, Jan 2019.

- [59] Kizito N. Nkurikiyeye, Yuta Suzuki, and Guillaume F. Lopez. Heart rate variability as a predictive biomarker of thermal comfort. *Journal of Ambient Intelligence and Humanized Computing*, 9(5):1465–1477, Oct 2018.
- [60] Baltazar Nunes, Eleonora Paixão, Carlos Matias Dias, Paulo Nogueira, and José Marinho Falcão. Air conditioning and intrahospital mortality during the 2003 heatwave in portugal: evidence of a protective effect. *Occupational and Environmental Medicine*, 68(3):218–223, Mar 2011.
- [61] J. Patz, D. Campbell-Lendrum, T. Holloway, and J. Foley. Impact of regional climate change on human health. *Nature*, 2005.
- [62] Bo Peng and Sheng-Jen Hsieh. Data-driven thermal comfort prediction with support vector machine. In *Volume 3: Manufacturing Equipment and Systems*, page V003T04A044, Los Angeles, California, USA, Jun 2017. American Society of Mechanical Engineers.
- [63] S. M. Porritt, P. C. Cropper, L. Shao, and C. I. Goodier. Ranking of interventions to reduce dwelling overheating during heat waves. *Energy and Buildings*, 55:16–27, Dec 2012.
- [64] Maruthi Prasanna. A novel approach for optimal allocation of a distributed generator in a radial distribution feeder for loss minimization and tail end node voltage improvement during peak load. *International Transaction of Electrical and Computer Engineers System*, Mar 2014.

- [65] Peter J. Robinson. On the definition of a heat wave. *Journal of Applied Meteorology and Climatology*, 40(4):762–775, Apr 2001.
- [66] Chengcheng Shan, Hu Jiawen, Jianhong Wu, Aili Zhang, Guoliang Ding, and Lisa Xuemin Xu. Towards non-intrusive and high accuracy prediction of personal thermal comfort using a few sensitive physiological parameters. *Energy and Buildings*, 207:109594, 2020.
- [67] Raimo Simson, Jarek Kurnitski, and Mikk Maivel. Summer thermal comfort: compliance assessment and overheating prevention in new apartment buildings in estonia. *Journal of Building Performance Simulation*, 10(4):378–391, Jul 2017.
- [68] Mary Taylor, Nathan C. Brown, and Donghyun Rim. Optimizing thermal comfort and energy use for learning environments. *Energy and Buildings*, 248:111181, Oct 2021.
- [69] Jacopo Torriti. Price-based demand side management: Assessing the impacts of time-of-use tariffs on residential electricity demand and peak shifting in northern italy. *Energy*, 44(1):576–583, Aug 2012.
- [70] S. Vandentorren, P. Bretin, A Zeghnoun, L. Mandereau-Bruno, A. Croisier, C. Cochet, J. Ribéron, I. Siberan, B. Declercq, and M. Ledrans. August 2003 heat wave in france: Risk factors for death of elderly people living at home. *European Journal of Public Health*, 16(6):583–591, Dec 2006.

- [71] David M. Ward. The effect of weather on grid systems and the reliability of electricity supply. *Climatic Change*, 121(1):103–113, Nov 2013.
- [72] Johannes Weniger. Optimale dimensionierung von pv-speichersystemen. page 6, 2013.
- [73] Johannes Weniger, Tjarko Tjaden, and Volker Quaschning. Sizing of residential pv battery systems. *Energy Procedia*, 46:78–87, Dec 2014.
- [74] Meng Wu, Hailong Li, and Hongzhi Qi. Using electroencephalogram to continuously discriminate feelings of personal thermal comfort between uncomfortably hot and comfortable environments. *Indoor Air*, 30(3):534–543, 2020.
- [75] Fang Yuan Xu, Tao Zhang, Loi Lei Lai, and Hao Zhou. Shifting boundary for price-based residential demand response and applications. *Applied Energy*, 146:353–370, May 2015.
- [76] Suchart Yammen, Sureerat Tang, and Mahesh Kumar Reddy Vennapusa. Iot based speed control of smart fan. In *2019 Joint International Conference on Digital Arts, Media and Technology with ECTI Northern Section Conference on Electrical, Electronics, Computer and Telecommunications Engineering (ECTI DAMT-NCON)*, page 17–20, Jan 2019.
- [77] Bin Yang, Stefano Schiavon, Chandra Sekhar, David Cheong, Kwok Wai Tham, and William W Nazaroff.

Cooling efficiency of a brushless direct current stand fan. *Building and Environment*, 85:196–204, Feb 2015.

- [78] Yang Yang, Takashi Nishikawa, and Adilson E. Motter. Small vulnerable sets determine large network cascades in power grids. *Science (New York, N.Y.)*, 358(6365):eaan3184, Nov 2017.
- [79] Y.H. Yau and Syafawati Hasbi. A review of climate change impacts on commercial buildings and their technical services in the tropics. *Renewable and Sustainable Energy Reviews*, 18:430–441, Feb 2013.
- [80] Kyungtae Yun, Rogelio Luck, Pedro J. Mago, and Heejin Cho. Building hourly thermal load prediction using an indexed arx model. *Energy and Buildings*, 54:225–233, Nov 2012.
- [81] Hai-xiang Zhao and Frédéric Magoulès. A review on the prediction of building energy consumption. *Renewable and Sustainable Energy Reviews*, 16(6):3586–3592, Aug 2012.
- [82] Qianchuan Zhao, Yin Zhao, Fulin Wang, Jinlong Wang, Yi Jiang, and Fan Zhang. A data-driven method to describe the personalized dynamic thermal comfort in ordinary office environment: From model to application. *Building and Environment*, 72:309–318, Feb 2014.
- [83] Levent Özgür, Vahid Khalipour Akram, Moharram Chalenger, and Orhan Dağdeviren. An iot based smart thermostat. In *2018 5th International Conference on Electrical*

*cal and Electronic Engineering (ICEEE)*, page 252–256,  
May 2018.