Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

Airborne Transmission of Covid-19

Anita Klein - Mariam Grigoryan - Steve de Rose

The Concept

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

- ▶ Covid 19 virus reported to the World Health Organization (WHO) on December 31, 2019.
- ▶ Reduce/Prevent its spread
- ▶ Cemosis and Synapse-Concept project 4fastsim-ibat.
- ▶ Air quality since Covid-19.

Collaboration Cemosis/Synapse

- ▶ Cemosis created in January 2013 by Christophe Prud'homme.
- ▶ Strasbourg Centre for Modelling and Simulation.
- ▶ Synapse-Concept created in November 1999.
- ▶ Specialised in engineering and technical studies.

Project

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

- ▶ Study of the airborne transmission of COVID-19 in an indoor space.
- ▶ The air in the room follows an advection-diffusion-reaction equation.
- ▶ With only one infectious person in the room.
- ▶ Room of size $8m(l) \times 8m(w) \times 3m(h)$.
- ▶ Breathing/Talking with and without a face mask.

Illustration

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

Figure – Virus airborne transmission in an office

Methodology I

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

- ▶ Firstly, 2D model to study/reproduce the concentration of airborne infectious particles.
- ▶ Using the advection–reaction–diffusion equation.
- ▶ Assumptions :
  - particles released from the infected person with zero initial velocity.
  - transported via advection due to the airflow in the room and diffusion due to turbulent mixing
  - the advection velocity of the air, $v(m/s)$ controlled by the air-conditioning unit.
  - the recirculation of air leads to turbulent mixing of the infectious particles.

ARD Equation

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

▶ Hence, the advection–reaction–diffusion equation :

$$\frac{\partial C}{\partial t} = \nabla.(K\nabla C) - \nabla.(\overrightarrow{v}C) + S.$$

▶ C = concentration of airborne infectious particles
  t = time
  ∇ = two-dimensional gradient operator
  K = isotropic eddy diffusion coefficient (turbulent diffusion)
  $\overrightarrow{v}$ = advection velocity of the air
  S = sum of sources and sinks of viral particles.

Methodology II

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

▶ Secondly, using «N-point ASOM» (air supply opening model).

▶ Developped in 2003 by Bin Zhaoa, Xianting Lib and Qisen Yanb at Tsinghua University, Beijing, China.

▶ Replace the real diffuser by several simple openings, maintaining the inlet momentum and mass flows.

The Tools

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

- ▶ Feel++ to solve advection–reaction–diffusion equation.
- ▶ Paraview to visualize the solution.
- ▶ Antora to generate the documentation site.
- ▶ Visual Studio Code.

References

Airborne
Transmission of
Covid-19

Anita Klein -
Mariam Grigoryan
- Steve de Rose

▶ Z. Lau, K. Kaouri, I. Griffiths. Modelling Airborne
  Transmission of COVID-19 in Indoor Spaces Using
  anAdvection–Diffusion–Reaction Equation.School of
  Mathematics, Cardiff University and Mathematical Institute,
  University of Oxford.

▶ B. Zhao and X. Li. A simplified system for indoor airflow
  simulation. Building and Environment · April 2003

▶ Zohra Djatouti, Christophe Prud'homme, Vincent Chabannes,
  Romain Hild IBat Website https://twitter.com/T_
  Fiolet/status/1378989583682179075?s=09