C.H INSPECTION RELEASE CERTIFICATE No. IRC-47148
Purchase Order No. PO-458082   Supplier: Pellam Pumps Ltd

Ref | Item | Material | Heat No. | Qty released | Shell test pressure achieved (bar) | Remark
C.1 | HX-538 | ASTM A105 | H300939 | 124 | 383 |
C.2 | FL-129 | ASTM A182 F316L | H896078 | 15 | 232 |
C.3 | BV-992 | ASTM A350 LF2 | H783577 | 66 | 233 |
C.4 | CV-903 | ASTM A351 CF8M | H567777 | 38 | 383 | Partial release; balance of 3 to follow under same PO
C.5 | PU-971 | ASTM A216 WCB | H351375 | 82 | 78 |
C.6 | GV-996 | ASTM A216 WCB | H753484 | 16 | 383 |

CT.1 Date of test: 3 September 2026
CT.2 Pressure gauge calibration certificate valid until: 2 August 2026
CT.3 Purchaser's inspector attended the shell test.
C.SIG Signed: M. Tennant (QA Manager, Pellam Pumps Ltd)   Date: 5 September 2026