C.H INSPECTION RELEASE CERTIFICATE No. IRC-58628
Purchase Order No. PO-455635   Supplier: Tavis Instrumentation Ltd

Ref | Item | Material | Heat No. | Qty released | Shell test pressure achieved (bar) | Remark
C.1 | BV-322 | ASTM A350 LF2 | H469375 | 68 | 77 |
C.2 | PU-841 | ASTM A105 | H391391 | 63 | 79 |
C.3 | GV-425 | ASTM A182 F316L | H151988 | 69 | 231 |
C.4 | CV-161 | ASTM A216 WCB | H738407 | 51 | 31 |
C.5 | SK-939 | ASTM A105 | H681204 | 62 | 80 |

CT.1 Date of test: 22 July 2026
CT.2 Pressure gauge calibration certificate valid until: 13 May 2026
CT.3 Purchaser's inspector attended the shell test.
C.SIG Signed: M. Tennant (QA Manager, Tavis Instrumentation Ltd)   Date: 24 July 2026