C.H INSPECTION RELEASE CERTIFICATE No. IRC-97337
Purchase Order No. PO-457068   Supplier: Halden Valve Works Ltd

Ref | Item | Material | Heat No. | Qty released | Shell test pressure achieved (bar) | Remark
C.1 | HX-366 | ASTM A182 F316L | H416535 | 41 | 155 |
C.2 | PT-195 | ASTM A216 WCB | H184793 | 66 | 31 |
C.3 | SK-166 | ASTM A105 | H998241 | 148 | 155 |
C.4 | PU-782 | ASTM A351 CF8M | H901508 | 151 | 29 | Partial release; balance of 3 to follow under same PO
C.5 | GV-501 | ASTM A182 F316L | H939083 | 20 | 232 |
C.6 | BV-303 | ASTM A182 F316L | H346530 | 38 | 232 |
C.7 | CV-491 | ASTM A350 LF2 | H837665 | 158 | 232 |

CT.1 Date of test: 26 August 2026
CT.2 Pressure gauge calibration certificate valid until: 24 December 2026
CT.3 Purchaser's inspector attended the shell test.
C.SIG Signed: M. Tennant (QA Manager, Halden Valve Works Ltd)   Date: 28 August 2026