C.H INSPECTION RELEASE CERTIFICATE No. IRC-71536
Purchase Order No. PO-458273   Supplier: Pellam Pumps Ltd

Ref | Item | Material | Heat No. | Qty released | Shell test pressure achieved (bar) | Remark
C.1 | HX-994 | ASTM A351 CF8M | H791034 | 126 | 29 |
C.2 | SK-863 | ASTM A216 WCB | H500071 | 25 | 233 |
C.3 | PU-266 | ASTM A351 CF8M | H404618 | 47 | 153 |
C.4 | BV-400 | ASTM A182 F316L | H230387 | 83 | 30 |
C.5 | CV-294 | ASTM A105 | H279735 | 12 | 32 |
C.6 | FL-383 | ASTM A216 WCB | H339067 | 23 | 384 |

CT.1 Date of test: 18 October 2026
CT.2 Pressure gauge calibration certificate valid until: 18 October 2026
CT.3 Purchaser's inspector attended the shell test.
C.SIG Signed: M. Tennant (QA Manager, Pellam Pumps Ltd)   Date: 20 October 2026