



↑ Orleans 2,4 m | 8 ft height steel door ■ Gentek, Black 525



 Fire-Rated Doors ↗ Important Information

Constructions	N300 and N600	N950
	Available in a 20-minute fire-rated version, up to a maximum of 36" × 80". 24 Ga steel faced door with foam core and wood edge.	Certified for 20-minute fire resistance, up to a maximum of 36" × 95". 24 Ga steel faced door with foam core and wood edge.
CERTIFICATIONS	Canada: UL 10B, CAN/ULC S-104 UL, NFPA 252 (neutral pressure with hose stream test). United States: UL 10C, NFPA 252 (positive pressure without hose stream test).	Canada: UL 10B, CAN/ULC S-104 UL, NFPA 252 (neutral pressure with hose stream test). United States: UL 10C, NFPA 252 (positive pressure with hose stream test).
INSTALLATION	In accordance with NFPA 80, with: • Type C approved frame (45 min) • Category G (graphite) intumescent seals • Category H seals for S designation (smoke control)	In accordance with NFPA 80, with: • Type C approved frame (45 min) • Category G (graphite) intumescent seals • Category H seals for S designation (smoke control)

Options when ordering

1. Fully machined fire-rated door by Novatech

Available to all pre-hangers.

- Machining: Handle & bolt bore, deadbolt bore, mortises, hinges.
- Official Intertek WH (Warnock Hersey) fire-rated label, serialized and listed, and subject to Intertek audits.
- Official labels may under no circumstances be shipped separately from the door.
- Documentation and invoicing will clearly state “fire-rated door”.

2. Partially machined or non-machined fire-rated door

Reserved for pre-hangers certified under Intertek’s CMP (Certified Machiner Program ^{NOTE 1}).

- Machining: Partial machining or none (to be completed by the CMP pre-hanger).
- No official Intertek WHI fire-rated label will be affixed to the door, and Novatech will not supply these labels separately.
- Customers must obtain their official WHI labels directly from Intertek and secure ATM (Authorization to Mark) approval to affix them.
- Customers must maintain a record of the serial numbers corresponding to door preparations. This record is subject to Intertek audits.



Limitations and modifications

- Only holes authorized by NFPA 80 are permitted (approved viewers, door closers, panic bars, surface-mounted door sweeps, maximum diameter $\leq 1"$).
- No doorglass (glass inserts) are permitted.
- Any unauthorized modification voids the fire-rating certification.
- Doors may be painted, but the label must remain intact, visible, and legible.
- Removing the label makes the door non-compliant.

^{NOTE 1} The certification process must be completed directly with Intertek and is entirely the responsibility of the pre-hanger. The Certified Machiner Program (CMP) involves fees. For more information, please contact Intertek directly. Novatech disclaims all responsibility with respect to this process.