## **CONCRETE TEST REPORT**

TO ABC ENGINEERING LTD.
545 SYCAMORE WAY
WINDY CITY, AB

**PROJECT NAME:** Local Business

Complex

**SCOPE:** MATERIAL TESTING

SAMPLE	ТҮРЕ	CURE LOC.	TEST DATE	AGE (DAYS)	AVG. DIAMETER (mm)	AVG. LENGTH (mm)	MAX. LOAD (kN)	COMPRESSIVE STRENGTH (MPa)	FRACTURE TYPE
Α	Cylinder	Lab	2021-08-04	7	101.6	203.2	237	29.3	b
В	Cylinder	Lab	2021-08-25	28	101.6	203.2	365	45.1	b
С	Cylinder	Lab	2021-08-25	28	101.6	203.2	348	43.0	b
	Cylinder	Lab			101.6	203.2			С

SPEC. STRENGT	ГН	45	MPa	@	28	DAYS	CONCRETE TEN		24.0 mm	°C AIR TEMP. SPEC. SLUMP		°C mm
CEMENT TYPE						GU/GUL	SLUMP FLOW AIR CONTENT	1.2		SPEC. FLOW		
SCM CONTENT MAXIMUM SIZE BATCH TIME ADMIXTURES SUPER-P JAZZ	AGG	REGA	TE		14 2:12 1	FLY ASH mm	CAST TIME CAST DATE  LOCATION LO8, E Elev Core COMMENTS	-	07-28	CAST BY	CMF	
SUPPLIER MIX NO.	LTD. KJF93	CONC 3390	RETE	TIC	VFT	20050						
TRUCK NO.  LOAD VOL.  WATER ADDED	129		:	NO 16 AU	m3	28858						
							PREPARED BY SO	ME CO	MPANY			
							BY TECH INITIALS	5				