

THIS DRAWING GIVES THE BASIC INSTRUCTIONS FOR PROVIDING THE SUPPLY SERVICES AND ENVIRONMENT THAT GUARANTEES THE PROPER FUNCTIONNING OF THE PRODUCTS FROM THIS COMPANY, THE PURCHASER, AND THE PURCHARSER'S INSTALLERS SHALL PROVIDE THE SUPPLY LINES NECESSARY FOR EACH PRODUCT IN ACCORDANCE WITH ESTABLISHED APPLICABLE NORMS AND REGIL ATIONS. THE COMPANY DECLINES ALL RESPONSABILITY FOR FAILURE TO COMPLY WITH SUCH LAWS AND REGULATIONS

THIS COMPANY RESERVES THE RIGHT TO MODIFY THIS DRAWING ACCORDING TO THE TECHNICAL DEVELOPMENT OF THE EQUIPMENT

A. AIR INTAKE FREE OF IMPURITIES Ø 1/4". FILTERED AND REGULATED AT A PRESSURE OF 6-7 bar , FLOW OF 0.0083 Nm3/min, APROX CYCLE CONSUMPTION 0.005 Nm3/min, PLACED THE WALL WITH BUILT-IN AND ACCESSIBLE KEY

THIS INTAKE WILL BE PROVIDED ONLY IF THE CUSTOMER HAS AIR NETWORK

- 1 COLD WATER INTAKE OF \$1/2" TEMPERATURE OF WATER 25°C CONSUMPTION PER CYCLE 10~300 LITERS. (WATER CONSUMPTION DETERMINED BY DRYING TIME) THE VACUUM PUMP 10 L/MIN. PRESSURE OF WATER 0.5~10 bar . HARDNESS OF WATER 0.9°fH(0.09mmol/L) . pH 7~9 . THE CHLORIDES LEVEL WILL BE ≤ 0.1 mg/I, PLACED THE WALL WITH BUILT-IN AND ACCESSIBLE KEY
- 2.COLD TREATEDWATER INTAKE OF \$\phi/2\cong SUPPLIED AT TEMPERATURE OF 25\cdot CONSUMPTION PER 13L/CYC. PRESSURE OF WATER 0.5~10 bar \ HARDNESS OF WATER ≤ 0.2°fH(0.02mmol/L) \ PH 5~7AND WITH CONDUCTIVITY < 15 " S/cm PLACED THE WALL WITH BUILT-IN AND ACCESSIBLE KEY

EACH TIME THE STEAM GENERATOR IS EMPTIED FOR CLEANING OR MAINTENANCE, A FURTHER 15 LITER OF WATER ARE NEEDED TO FILL IT UP AGAIN.

- 3. DRAINAGE PIPE Ø≥ 1" METALLIC PIPE, CORROSION RESISTANCE 2"G. AND A TEMPERATURE OF 100°C ABOVE
- 4.ELECTRIC INTAKE + 12kW, WIRE 4 m LONG. (GENERAL POWER SUPPLY TO THE STERILIZER)

230VAC 380VAC 415VAC 440VAC $3 \phi 4 \% 34.35 \text{A} 20.72 \text{A} 19.07 \text{A} 18.07 \text{A}$

NOTE: POWER INPUT MUST BE INSTALLED ACCORDING TO LOCAL APPLICABLE NORMS


- 5. CEILING MOUNTED AIR EXTRACTION WITH GRILLE DRAW 200 Kcal/h (LOADING / UNLOADING AREA).
- 5-1 CEILING MOUNTED AIR EXTRACTION WITH GRILLE DRAW 400 Kcal/h (STERILIZE AREA).
- 6. A CHECK VALVE SHALL BE FITTED AS INDICATED IN THE DRAWING (6) and (7)
- B. THE EQUIPMENT SHALL BE ADJUST TO A ANGLE OF 1°~2° WITH REAR SITE HIGHER THAN FRONT SITE FOR THE PROPER OPERATION OF DRY AND DRAINAGE.

IMPORTANT: ENVIRONMENT CONDITIONS IN THE STERILE AREA

- THE STERILE AREA TEMPERATURE MUST BE ≤ 40°C; HUMIDITY ≤ 85%RH
- TO KEEP THESE CONDITIONS IN THE STERILE AREA AND DEPENDING ON THE Kcal LOST BY THE EQUIPMENT INDICATED IN THE ITEMS 5 & 5-1, WE SUGGEST THAT THE EXTRACTOR AND THE DIAMETER OF THE EXTRACTION TUBE ARE CALCULATED AND MADE BY A SPECIALIZED COMPANY.

ATTENTION

- THE ELECTRIC WIRES TO THE STERILIZER SHOULD BE DRIVEN BY AN HERMETIC CONDUIT.
- THE INDICATED AIR EXTRACTION IS ONLY TO DISSIPATE THE HEAT OF THE MACHINE AND MUST BE INDEPENDENT OF THE CLIMATE CONTROL SYSTEM OF THE ZONE
- CHAMBER DIMENSIONS W510mmxH510mmxD1000 mm
- DEVICE OUTSIDE DIMENSIONS: W1025mmxH1793mmxD1020mm
- ALL THE OUTLETS MUST BE INSTALLED ACCORDING TO LOCAL APPLICABLE NORMS
- IF THERE IS NO FALSE CEILING. THE AIR EXTRACTION, MUST BE INSTALLED IN THE WALL, AND HAVE THE SAME CAPACITY AS THOSE OF THE FALSE CEILING, SO THE AIR CAN BE CARRIED OUTSIDE OF THE BUILDING. IT ALSO NEEDS TO BE EQUIPPED WITH A GRILLE
- THE INSTALLATION UP TO THE MACHINE AS WELL AS THE SUPPLY OF ACCESSIBLE KEY ACCORDING TO THE SPECIFICATIONS INDICATED IN THE DRAWING, ARE CHARGEABLE TO THE PURCHASERS
- IF THERE IS ANY KIND OF PROBLEM DURING INSTALLATION FOR THE VARIOUS INTAKES NOT INDICATED IN THE DRAWING, PLEASE CONTACT OUR TECHNICAL SERVICE DEPT. FOR FURTHER ASSISTANCE
- THE MEASUREMENTS OF THIS DRAWING ARE CONSIDERING FINISHED WALLS.
- THE SPACES OF MAINTENANCE MUST BE SUFFICIENTLY ILLUMINATED



201~500±1

比例 1:46

ANGLE ±1°

SAT-S0260DW

mm

0~10 ±0.2 51~100±0.6

材質 SURFACE FINISHING

表面處理

11~50 ±0.4 |101~200±0.8 |501~X ±2

文管中心

R3-058-06

核准:

繪圖:

Jenny

MAME 名SAT-S0260DW INSTALLATION PLAN

SAT-S0260DW-HE-001-01

Joe