



# Qualissure Laboratory Services

361, Prantick Pally, 45/361, Bose Pukur Road, Kolkata -700107  
Email : [qualissure@gmail.com](mailto:qualissure@gmail.com); [info@qualissure.com](mailto:info@qualissure.com) ; Mob.No. 98312 87086 ; 9830093976



DOC NO: QLS/SAMP/08-D/00

## TEST REPORT

|                                 |                     |                                              |
|---------------------------------|---------------------|----------------------------------------------|
| Name & Address of the Customer: | ULR No.             | : TC62712600004972F                          |
|                                 | Report No.          | : QLS/P-01/26-27/C/225                       |
|                                 | Date                | : 24.08.2026                                 |
|                                 | Sample No.          | : QLS/P-01/26-27/225                         |
|                                 | Sample Description  | : Drinking Water                             |
|                                 | Sample Mark         | : Bore Well Outlet                           |
|                                 | Date of Performance | : 20.08.2026 - 22.08.2026                    |
|                                 | Sample Submitted On | : 20.08.2026                                 |
|                                 | Sample Collected By | : JM Biotech Representative (Mr. Prabir Roy) |
|                                 | Ref No. & Date      | : Mail Confirmation                          |

## Microbiological Analysis

| Sl. No. | Characteristic                    | Limit as Per IS 10500 :2012 (RA 2018) Amd. 2 | Test Method           | Result       |
|---------|-----------------------------------|----------------------------------------------|-----------------------|--------------|
| 1.      | E. Coli CfU/100ml                 | Not Detectable                               | IS:1622-1981(RA 2019) | Not Detected |
| 2.      | Total Coliform Bacteria CfU/100ml | Not Detectable                               | IS:1622-1981(RA 2019) | Not Detected |

Report Prepared By:

for Qualissure Laboratory Services  
Reviewed & Authorized By

Soumy Chakraborty, Microbiologist  
(Authorized Signatory)

-----End of the Report-----

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced without the permission of Qualissure Laboratory Services.
- The reserved part of sample(s), except perishable sample(s), shall be retained for 30 days from the date of issue of the Test Report.



# JM Biotech (Pvt.) Ltd. (Laboratory)

Testing Research & Analytical Consultants



AN ISO 9001:2015 & 14001:2005 CERTIFIED COMPANY

## TEST REPORT

ULR No.TC78622600000920F

Format No. JMB/LAB/PM/46C

Test Report No.: JMB/2026/DW(D)/1025

Date of issue of Test report: 24.08.2026

Sample Drawn By Lab Representative :

Page 1 of 1

Client Name : St. Vincent's Academy.  
Client Address : Nandur, Joteram, Burdwan, Purba Bardhaman, Pin-713104.  
Sample identification no : JMB/2026/DW/0371 Sampling Source : Borewell outlet  
Sample description : Drinking Water Date of receipt of sample in lab: 19.08.2026  
Sample condition : Sealed Date of Testing: 19.08.2026-22.08.2026.  
Date of sampling : 19.08.2026 Location where tests are performed:- At Laboratory  
Sample quantity : 1lit Laboratory Environmental condition:- Temp. (°C): 27.4  
Sample Collected By : Mr. Prabir Roy (Lab Staff) Humidity (RH%): 53  
Method of Sampling : APHA 24th Edition, 1060 B  
Mode of Sampling : Grab

### CHEMICAL TEST FINDINGS:

#### A. PHYSICAL PARAMETERS :

| Sl No. | Test Parameters        | Test Method                          | Unit | Result            | Norms as per IS 10500:2012 |               |
|--------|------------------------|--------------------------------------|------|-------------------|----------------------------|---------------|
|        |                        |                                      |      |                   | AL (Max.)                  | PL (Max.)     |
| 1      | pH at 25°C             | APHA 24th Edn, 4500 H <sup>+</sup> B | --   | 6.7               | 6.5 - 8.5                  | No Relaxation |
| 2      | Turbidity              | APHA 24th Edn, 2130-B                | NTU  | BDL<br>(DL:2 NTU) | 1                          | 5             |
| 3      | Total Dissolved Solids | APHA 24th Edn, 2540-C                | mg/L | 110.0             | 500                        | 2000          |

#### B. GENERAL PARAMETERS :

|    |                                 |                                                      |      |       |     |               |
|----|---------------------------------|------------------------------------------------------|------|-------|-----|---------------|
| 4  | Calcium as Ca                   | APHA 24th Edn, 3500- Ca B                            | mg/L | 22.18 | 75  | 200           |
| 5  | Chloride as Cl                  | APHA 24th Edn, 4500 Cl-B                             | mg/L | 11.66 | 250 | 1000          |
| 6  | Iron as Fe                      | APHA 24th Edn, 3500- Fe B                            | mg/L | <0.1  | 1   | No Relaxation |
| 7  | Magnesium as Mg                 | APHA 24th Edn, 3500- Mg B                            | mg/L | 6.73  | 30  | 100           |
| 8  | Sulphate as SO <sub>4</sub>     | APHA 24th Edn, 4500- SO <sub>4</sub> <sup>2-</sup> E | mg/L | 11.0  | 200 | 400           |
| 9  | Alkalinity as CaCO <sub>3</sub> | APHA 24th Edn, 2320-B                                | mg/L | 80.4  | 200 | 600           |
| 10 | Total Hardness                  | APHA 24th Edn, 2340-C                                | mg/L | 83.16 | 200 | 600           |

Note: Below Detection Limit (BDL), Detection Limit (DL)

Note : 1. AL - Acceptable Limit. 2. PL - Permissible Limit.

Statement of Conformity : Satisfactory for the above tested parameters.

Subarna Guha

...END OF TEST REPORT...

Reviewed by  
Name : DR. Subarna Guha  
(Technical Manager)



For J.M. Biotech (P) Ltd.

Name: Tanmay Sengupta  
(Authorised Signatory)  
Designation: CEO-Lab

Remarks: When Statement of Conformity required by customer to a specification or standard for the test then laboratory's decision rule will be applied for those tests for which statement of conformity has been claimed by customer.

Laboratory's Decision Rule: 'When providing statement of conformity'-Measurement Uncertainty is taken into account to determine whether a result passes, fails or is indeterminate. Such as.

- PASS: Test results  $\pm$  Measurement Uncertainty (at 95% confidence level) is within specification/standard's requirements
- FAIL: Test results  $\pm$  Measurement Uncertainty (at 95% confidence level) exceeds specification/standard's requirements.
- INDETERMINANT: Test results  $\pm$  Measurement Uncertainty (at 95% confidence level) overlaps specification/standard's requirements.

**Disclaimer :** The contents of the report shall not be reproduced either in full or in part without prior written consent of the issuing authority. The results relate only to the items tested as received.