


MD-3.2 ISOMETRIC VIEW
LOOKING NORTH WEST

REFERENCES

MDL ITEM #	MPWA MDL DESCRIPTION	DETAILS FOR
1	FOUNDATION PLAN AND SUMMARY LOADING DATA FOR MODULE GT ENCLOSURE	GENERAL LOCATION
20	GA DRAWING FOR MODULARIZED JAC GT ENCLOSURE	GENERAL LOCATION

NOTES

1. DIMENSIONS : MM [INCHES]
2. LABELING
   - ××XXXXXX ——PIPE LINE
   - (××XXX-X) ——SPOOL NO
3. SOME STRUCTURAL MEMBERS AND GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. WP : WORKING POINT FOR SLOPE LINE

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	01.MAY.2024	S.H.	M.F.	N.K.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:

This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2024 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: –

ITEM NO: MDL–150

DWG NAME: MD–3.2 PIPING SUPPORT & SPOOLS GENERAL ARRANGEMENTS DRAWINGS **(GA FOR SPOOLS)**


REF.DWG.NO.: –

PREPARED BY: cimtas


JOB NO	SHEET	SCALE	SIZE
2E00140	1/1	1/25	A1

DRAWING NO: 2E00140–PI–094–001–MD–3.2

REV. 0



MD-3.2 SECTION 'A-A'
(PLAN VIEW)



MD-3.2 SECTION 'B-B'
(PLAN VIEW)

REFERENCES

MDL ITEM #	MPWA MDL DESCRIPTION	DETAILS FOR
1	FOUNDATION PLAN AND SUMMARY LOADING DATA FOR MODULE GT ENCLOSURE	GENERAL LOCATION
20	GA DRAWING FOR MODULARIZED JAC GT ENCLOSURE	GENERAL LOCATION

NOTES

1. DIMENSIONS : MM [INCHES]
2. LABELING
   - ××XXXXXX —— PIPE LINE
   - (××XXX-X) —— SPOOL NO
3. SOME STRUCTURAL MEMBERS AND GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. WP : WORKING POINT FOR SLOPE LINE

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	01.MAY.2024	S.H.	M.F.	N.K.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2024 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO
–

ITEM NO
MDL–150

DWG NAME
MD–3.2 PIPING SUPPORT & SPOOLS GENERAL ARRANGEMENTS DRAWINGS **(GA FOR SPOOLS)**


REF.DWG.NO.
–

PREPARED BY
cimtas


JOB NO	SHEET	SCALE	SIZE
2E00140	1/1	1/25	A1

DRAWING NO
2E00140–PI–094–001–MD–3.2

REV.
0



MD-3.2 ELEVATION VIEW
SECTION 'C-C'



MD-3.2 ELEVATION VIEW
SECTION 'D-D'

REFERENCES

MDL ITEM #	MPWA MDL DESCRIPTION	DETAILS FOR
1	FOUNDATION PLAN AND SUMMARY LOADING DATA FOR MODULE GT ENCLOSURE	GENERAL LOCATION
20	GA DRAWING FOR MODULARIZED JAC GT ENCLOSURE	GENERAL LOCATION

NOTES

1. DIMENSIONS : MM [INCHES]
2. LABELING
   - **XXXXXX —— PIPE LINE
   - (**XXX-X) —— SPOOL NO
3. SOME STRUCTURAL MEMBERS AND GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. WP : WORKING POINT FOR SLOPE LINE

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	01.MAY.2024	S.H.	M.F.	N.K.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:

This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2024 Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: –

ITEM NO: MDL–150

DWG NAME: MD–3.2 PIPING SUPPORT & SPOOLS GENERAL ARRANGEMENTS DRAWINGS **(GA FOR SPOOLS)**


REF.DWG.NO.: –

PREPARED BY: cimtas


JOB NO	SHEET	SCALE	SIZE
2E00140	1/1	1/25	A1

DRAWING NO: 2E00140–PI–094–001–MD–3.2


REV.: 0



MD-3.2 SECTION 'E-E'
(LOOKING EAST)



MD-3.2 SECTION 'F-F'
(LOOKING EAST)



MD-3.2 SECTION 'G-G'
(LOOKING EAST)

REFERENCES

MDL ITEM #	MPWA MDL DESCRIPTION	DETAILS FOR
1	FOUNDATION PLAN AND SUMMARY LOADING DATA FOR MODULE GT ENCLOSURE	GENERAL LOCATION
20	GA DRAWING FOR MODULARIZED JAC GT ENCLOSURE	GENERAL LOCATION

NOTES

1. DIMENSIONS : MM [INCHES]
2. LABELING
   - ××XXXXXX ——PIPE LINE
   - (××XXX-X) ——SPOOL NO
3. SOME STRUCTURAL MEMBERS AND GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. WP : WORKING POINT FOR SLOPE LINE

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	01.MAY.2024	S.H.	M.F.	N.K.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2024 Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: –

ITEM NO: MDL-150

DWG NAME: MD-3.2 PIPING SUPPORT & SPOOLS GENERAL ARRANGEMENTS DRAWINGS **(GA FOR SPOOLS)**

REF.DWG.NO.: –


PREPARED BY: cimtas

JOB NO	SHEET	SCALE	SIZE
2E00140	1/1	1/25	A1

DRAWING NO: 2E00140-PI-094-001-MD-3.2

REV.: 0

REVISION RECORD



LEGEND:

PIPELINE / SPOOL	INDICATES PIPELINE ON THE TOP AND SPOOL ON THE BOTTOM.
SUPPORT	INDICATES SUPPORT.
TERMINAL POINT	INDICATES TERMINAL POINT.
– – – – – – –	INDICATES TRACING.

ORIGIN:	MITSUBISHI POWER-LAKE MARY	DATE:	MITSUBISHI POWER DRAWING NUMBER:	REV. NO.:	SYSTEM CODE:
PREPARED BY:	D. DURAPAU	10/22/2025	**N05-003580**	**0**	**24A0A**
REVIEWED BY:	D.MAZQUIARAN / N.JAMSHIDI	10/28/2025	**INSTRUMENT AIR PIPING**		
APPROVED BY:	U. KASINATHAN	10/31/2025	**INTERNAL TO GT PACKAGE**		
			FOR FABRICATION & ERECTION		
			N05-ISO-QFF-BR-AA		
			P&ID DRAWING NUMBER: N01-PID-QFF-00-02		
			M501JAC GAS TURBINE		
PROJECT CODE:	-	P&ID:	-		
PIPELINE:	-	PAGE NUMBER:	5 OF 8		

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2025 , Mitsubishi Power Americas, Inc.

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations, diversion contrary to U.S. law is prohibited.

MITSUBISHI POWER


ECCN: EAR99 No License Req'd

SL2

DEPARTMENT: MITSUBISHI POWER ENGINEERING

SECTION: PLANT ENGINEERING

DRAWING DISTRIBUTION LIST



ADDITIONAL NOTES:
WELDING AT PIPES MARKED WITH ✎ SHALL BE ADJUSTED AT SHOP TO FIT DURING ASSEMBLY.
THE MARK ✎ ON THE DRAWING INDICATES AN EXCESS LENGTH OF 4" (100mm) ADDED TO THE PIPE FOR ADJUSTED DURING ASSEMBLY.

WELD NO	WELD TYPE	WELD CAT	NPD	QTY
41	SW	S	1 1/2"	1
40	SW	S	1 1/2"	1
39	SW	S	1 1/2"	1
38	SW	S	1 1/2"	1
37	SW	S	1 1/2"	1
36	SW	S	1 1/2"	1
35	SW	S	1 1/2"	1
34	SW	S	1 1/2"	1
33	SW	S	1 1/2"	1
32	SW	S	1 1/2"	1
31	SW	S	1 1/2"	1
30	SW	S	1 1/2"	1
29	SW	S	1 1/2"	1
60	SW	S	1 1/2"	1
45	SW	S	1 1/2"	1
26	SW	S	1 1/2"	1

SHOP MATERIALS - FABRICATION ONLY

PT NO	DESCRIPTION	NPD (IN)	CMDTY CODE	QTY
1	PIPE, S-40S, PE, ASME B36.19M, ASTM A312-TP304, SEAMLESS	1 1/2	MPAAZZBPZZABBANI	9.2'
2	TEE, CL3000, SWE, ASME B16.11, ASTM A182-F304	1 1/2X1 1/2	MMDJAWBVZZAAGALO	1
3	90 DEG ELBOW, CL3000, SWE, ASME B16.11, ASTM A182-F304	1 1/2	MMCKAWBVZZAAGALO	3
4	45 DEG ELBOW, CL3000, SWE, ASME B16.11, ASTM A182-F304	1 1/2	MMBWAWBVZZAAGALO	2
5	FLANGE SW, CL150, RFFE, ASME B16.5, ASTM A182-F304	1 1/2	MFABAHABZZAADALO	2

OTHER THAN SHOP MATERIALS - ERECTION ONLY

PT NO	DESCRIPTION	NPD (IN)	CMDTY CODE	QTY
6	GASKET, FLAT RING, CL150, 0.0625" THK, ASME B16.21, COMPRESSED NON ASBESTOS FIBER	1 1/2	MITAHAAAALBMNUS	1
7	STUD, CONTINUOUS THREAD, ASME B18.31.2, ASTM A193-B8 CL1, 13-UNC - 3.5 in. Length	1/2	MBAZZACZZIAGBLJZ	4
8	NUT, HEAVY HEX, ASME B18.2.2, ASTM A194-8, 13-UNC	1/2	MNOZZACAAZPCJAFU	8
9	WASHER, SPECIAL SHAPED LOCK, 1.5in NPD, 0.8mm THK, MHPSA G1-90942, ASTM A240-304	1/2	MWQZZZZBUIBBAMDP	8
10	GLOBE VALVE, CL800, SWE, ASME B16.34, ASTM A182-F316	1 1/2	MVALAQBVZZAATALS	1
	PIPE SUPPORTS			
11	PIPE SUPPORT	1 1/2	**24A0A-PS-57	1
12	PIPE SUPPORT	1 1/2	**24A0A-PS-55	1
	SPOOLS			
	**24A0A-31, **24A0A-90			

CUT PIPE LENGTH

PIECE NO	LENGTH (FT-INS)	NPD (IN)	REMARKS	END ONE	END TWO	ITEM CODE
<6>	7 1/2"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<7>	2'0 15/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<8>	2'9 15/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<9>	7 9/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<10>	10 9/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<11>	1'0 1/4"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<12>	8 15/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<19>	4 5/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI

ACTUAL QUANTITY OF WASHERS SHALL BE CONSIDERED AS HALF OF THE QUANTITY SHOWN ON ISOMETRICS

NOTES:
1. THE X AND Y COORDINATES ARE WITH RESPECT TO THE INTERSECTION OF THE CENTERLINE OF THE GAS TURBINE (GT) AND THE INLET MANIFOLD (IM). THE Z (EL) COORDINATE IS WITH RESPECT TO THE TOP OF CONCRETE, WHICH IS 15'-9" [4800 mm] BELOW THE CENTERLINE OF THE GT AND IS 0'-0".
2. ALL PIPE SUPPORT COORDINATES ARE WITH RESPECT TO THE CENTERLINE OF THE INSTALLED SUPPORTED PIPE.
3. THE MARK 'FFW' (FIELD FIT WELD) IN THE DRAWING INDICATES EXCESS LENGTH OF APPROX. 4 INCHES IDENTIFIED AS LOOSE IN THE DRAWING TO BE CUT AND ADJUSTED AT THE FIELD.
4. ALL WELDING TO BE DONE AND INSPECTED PER LATEST APPLICABLE EDITION OF ASME B31.1 AND SECTION IX AVAILABLE ON THE PROJECT AWARD DATE.
5. PIPING SHALL BE INSTALLED PER THE INDICATED SLOPE.
6. FOR ANY FURTHER INFORMATION REQUIRED DURING INSTALLATION, CONSULT MITSUBISHI POWER TFA (TECHNICAL FIELD ADVISOR) AT SITE.
7. 〈XXX## ###〉 INDICATES PIPING TERMINAL POINT.

ORIGIN:	MITSUBISHI POWER-LAKE MARY	DATE:	MITSUBISHI POWER DRAWING NUMBER:	REV. NO.:	SYSTEM CODE:
PREPARED BY:	D. DURAPAU	10/22/2025	**N05-003580**	**0**	**24A0A**
REVIEWED BY:	D.MAZQUIARAN / N.JAMSHIDI	10/28/2025	**INSTRUMENT AIR PIPING**		
APPROVED BY:	U. KASINATHAN	10/31/2025	**INTERNAL TO GT PACKAGE**		
			FOR FABRICATION & ERECTION		
			N05-ISO-QFF-BR-AA		
			P&ID DRAWING NUMBER: N01-PID-QFF-00-02		
			M501JAC GAS TURBINE		
			PROJECT CODE: -	P&ID: -	
			PIPELINE:	PAGE NUMBER:	
			**QFF11BR676	2 OF 5	

PIPING SPEC:	SAC	PAINTING SPEC: PER PROJECT SPECIFICATION	REVISION RECORD					
FLUID CODE:	IA, INSTRUMENT AIR	INTERIOR SURFACE TREATMENT SPEC: LU-00129	REV. #	DESCRIPTION	BY	CHK	APP	DATE
MAX. PRESS.:	150.00 psig / 1.03 MPag							
TEST PRESS.:	225.00 psig / 1.55 MPag							
MAX. TEMP:	140 F / 60 C							
INSULATION SPEC:	NOT INSULATED							

WELD TYPE IDENTIFIER:
BW - BUTT WELD
SW - SOCKET WELD
SOF - SLIP-ON FLANGE
SOB - SET-ON BRANCH
LET - OLET, LATROLET OR HALF COUPLING
TW - TACK WELD
MW - MITER WELD

WELD CATEGORY IDENTIFICATION:
● S - SHOP
⊗ FW - FIELD WELD
⊗ FFW - FIELD FIT WELD

SYMBOLOGY:
⬭ WELD NUMBER
▭ PART NUMBER (PT NO)
< > CUT LIST PIECE NUMBER


SYMBOL IDENTIFIER:
F - FLANGE
G - GASKET
B - BOLT
N - NUT
W - WASHER
O - O-RING
L - LOCK WIRE

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2025 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations. diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd
SL2
MITSUBISHI POWER ENGINEERING
PLANT ENGINEERING
DEPARTMENT:
SECTION:
DRAWING DISTRIBUTION LIST



SHOP MATERIALS - FABRICATION ONLY

PT NO	DESCRIPTION	NPD (IN)	CMDTY CODE	QTY
1	PIPE, S-40S, PE, ASME B36.19M, ASTM A312-TP304, SEAMLESS	1 1/2	MPAAZZBPZZABBANI	11.2'
2	TEE, CL3000, SWE, ASME B16.11, ASTM A182-F304	1 1/2X1 1/2	MMDJAWBVZZAAGALO	1
3	90 DEG ELBOW, CL3000, SWE, ASME B16.11, ASTM A182-F304	1 1/2	MMCKAWBVZZAAGALO	1
4	FLANGE SW, CL150, RFFE, ASME B16.5, ASTM A182-F304	1 1/2	MFABAHABZZAADALO	2

OTHER THAN SHOP MATERIALS - ERECTION ONLY

PT NO	DESCRIPTION	NPD (IN)	CMDTY CODE	QTY
5	GASKET, FLAT RING, CL150, 0.0625" THK, ASME B16.21, COMPRESSED NON ASBESTOS FIBER	1 1/2	MITAHAAAALBMNUS	2
6	STUD, CONTINUOUS THREAD, ASME B18.31.2, ASTM A193-B8 CL1, 13-UNC - 3.5 in. Length	1/2	MBAZZACZZIAGBLJZ	8
7	NUT, HEAVY HEX, ASME B18.2.2, ASTM A194-8, 13-UNC	1/2	MNOZZACAAZPCJAFU	16
8	WASHER, SPECIAL SHAPED LOCK, 1.5in NPD, 0.8mm THK, MHPSA G1-90942, ASTM A240-304	1/2	MWQZZZZBUIBBAMDP	16
9	GLOBE VALVE, CL800, SWE, ASME B16.34, ASTM A182-F316	1 1/2	MVALAQBVZZAATALS	2
	PIPE SUPPORTS			
10	PIPE SUPPORT	1 1/2	**24A0A-PS-127	1
11	PIPE SUPPORT	1 1/2	**24A0A-PS-128	1
12	PIPE SUPPORT	1 1/2	**24A0A-PS-129	1

CUT PIPE LENGTH

PIECE NO	LENGTH (FT-INS)	NPD (IN)	REMARKS	END ONE	END TWO	ITEM CODE
<13>	6'2 13/16"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<14>	5 7/8"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<15>	1'2 1/2"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<16>	1'6 3/8"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<17>	5 7/8"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI
<18>	1'2 1/2"	1 1/2		SQ.CUT	SQ.CUT	MPAAZZBPZZABBANI

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations, diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd

SL2

MITSUBISHI POWER ENGINEERING
PLANT ENGINEERING

DEPARTMENT: SECTION:

DRAWING DISTRIBUTION LIST

ACTUAL QUANTITY OF WASHERS SHALL BE CONSIDERED AS HALF OF THE QUANTITY SHOWN ON ISOMETRICS

NOTES:
1. THE X AND Y COORDINATES ARE WITH RESPECT TO THE INTERSECTION OF THE CENTERLINE OF THE GAS TURBINE (GT) AND THE INLET MANIFOLD (IM). THE Z (EL) COORDINATE IS WITH RESPECT TO THE TOP OF CONCRETE, WHICH IS 15'-9" [4800 mm] BELOW THE CENTERLINE OF THE GT AND IS 0'-0".
2. ALL PIPE SUPPORT COORDINATES ARE WITH RESPECT TO THE CENTERLINE OF THE INSTALLED SUPPORTED PIPE.
3. THE MARK 'FFW' (FIELD FIT WELD) IN THE DRAWING INDICATES EXCESS LENGTH OF APPROX. 4 INCHES IDENTIFIED AS LOOSE IN THE DRAWING TO BE CUT AND ADJUSTED AT THE FIELD.
4. ALL WELDING TO BE DONE AND INSPECTED PER LATEST APPLICABLE EDITION OF ASME B31.1 AND SECTION IX AVAILABLE ON THE PROJECT AWARD DATE.
5. PIPING SHALL BE INSTALLED PER THE INDICATED SLOPE.
6. FOR ANY FURTHER INFORMATION REQUIRED DURING INSTALLATION, CONSULT MITSUBISHI POWER TFA (TECHNICAL FIELD ADVISOR) AT SITE.
7. 〈XXX##-###〉 INDICATES PIPING TERMINAL POINT.

ADDITIONAL NOTES:
WELDING AT PIPES MARKED WITH ✱ SHALL BE ADJUSTED AT SHOP TO FIT DURING ASSEMBLY.
THE MARK ✱ ON THE DRAWING INDICATES AN EXCESS LENGTH OF 4" (100mm) ADDED TO THE PIPE FOR ADJUSTED DURING ASSEMBLY.

WELD NO	WELD TYPE	WELD CAT	NPD	QTY
46	SW	S	1 1/2"	1
49	SW	S	1 1/2"	1
56	SW	S	1 1/2"	1
61	SW	S	1 1/2"	1
58	SW	S	1 1/2"	1
59	SW	S	1 1/2"	1
50	SW	S	1 1/2"	1
51	SW	S	1 1/2"	1
52	SW	S	1 1/2"	1
53	SW	S	1 1/2"	1
54	SW	S	1 1/2"	1
55	SW	S	1 1/2"	1

PIPING SPEC:	SAC	PAINTING SPEC: PER PROJECT SPECIFICATION	REVISION RECORD				
FLUID CODE:	IA, INSTRUMENT AIR	INTERIOR SURFACE TREATMENT SPEC: LU-00129	REV. #	DESCRIPTION	BY	CHK	APP	DATE
MAX. PRESS.:	150.00 psig / 1.03 MPag							
TEST PRESS.:	225.00 psig / 1.55 MPag							
MAX. TEMP:	140 F / 60 C							
INSULATION SPEC:	NOT INSULATED							

WELD TYPE IDENTIFIER:
BW - BUTT WELD
SW - SOCKET WELD
SOF - SLIP-ON FLANGE
SOB - SET-ON BRANCH
LET - OLET, LATROLET OR HALF COUPLING
TW - TACK WELD
MW - MITER WELD

WELD CATEGORY IDENTIFICATION:
● S - SHOP
⊗ FW - FIELD WELD
⊗ FFW - FIELD FIT WELD

SYMBOLOGY:
WELD NUMBER
PART NUMBER (PT NO)
< > CUT LIST PIECE NUMBER

SYMBOL IDENTIFIER:
F - FLANGE
G - GASKET
B - BOLT
N - NUT
W - WASHER
O - O-RING
L - LOCK WIRE

ORIGIN:	MITSUBISHI POWER-LAKE MARY	DATE:	MITSUBISHI POWER DRAWING NUMBER:	REV. NO.:	SYSTEM CODE:
PREPARED BY:	D. DURAPAU	10/22/2025	**N05-003580**	**0**	**24A0A**
REVIEWED BY:	D.MAZQUIARAN / N.JAMSHIDI	10/28/2025	**INSTRUMENT AIR PIPING**		
APPROVED BY:	U. KASINATHAN	10/31/2025	**INTERNAL TO GT PACKAGE**		
			FOR FABRICATION & ERECTION		

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2025 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

N05-ISO-QFF-BR-AA
P&ID DRAWING NUMBER: N01-PID-QFF-00-02
M501JAC GAS TURBINE

PROJECT CODE:	-	P&ID:	-
PIPELINE:		PAGE NUMBER:	
**QFF11BR676		3 OF 5	

NO	SUPPORT TAG	SPOOL NO	REMARK
1	**21A0A-PS-01	**21A0A-3	
2	**21A0B-PS-01	**21A0B-8	
3	**21A0C-PS-01	**21A0C-7	
4	**21A0C-PS-02	**21A0C-7	
5	**21A0D-PS-01	**21A0D-2	
6	**21A0D-PS-02	**21A0D-2	
7	**21A0D-PS-03	**21A0D-3	
8	**21A0D-PS-04	**21A0D-3	
9	**21A0E-PS-01	**21A0E-8	
10	**21A0E-PS-02	**21A0E-7	
11	**21A0E-PS-03	**21A0E-7	
12	**21A0E-PS-04	**21A0E-7	
13	**21A0E-PS-17	**21A0E-8	
14	**21A0H-PS-01	**21A0H-5	
15	**21A0H-PS-02	**21A0H-5	
16	**21A0H-PS-03	**21A0H-5	
17	**21A0H-PS-08	**21A0H-13	
18	**21A0H-PS-09	**21A0H-12	
19	**21A0H-PS-16	**21A0H-14	
20	**21A0H-PS-17	**21A0H-14	
21	**21A0H-PS-18	**21A0H-15	
22	**23A0C-PS-14	**23A0C-14	
23	**23A0K-PS-01	**23A0K-1	
24	**23A0K-PS-02	**23A0K-3	SEE NOTE 5
25	**23A0K-PS-22	**23A0K-20	SEE NOTE 5
26	**23A0K-PS-23	**23A0K-19	
		**23A0K-2	
27	**23A0K-PS-24	**23A0K-17	
28	**23A0U-PS-01	**23A0U-10	
29	**23A0U-PS-02	**23A0U-8	
30	**23A0U-PS-03	**23A0U-8	
31	**23A0U-PS-11	**23A0U-14	
32	**23A0U-PS-12	**23A0U-13	
33	**23A0U-PS-15	**23A0U-8	
34	**23A0U-PS-16	**23A0U-13	
35	**23A0U-PS-26	**23A0U-42	
		**23A0U-46	
36	**23A0U-PS-27	**23A0U-42	
		**23A0U-46	
37	**24A0A-PS-10	**24A0A-29	
		**24A0A-30	
38	**24A0A-PS-127	**24A0A-31	
39	**24A0A-PS-128	**24A0A-31	
40	**24A0A-PS-129	**24A0A-31	
41	**24A0A-PS-130	AIR CHAMBER	
		AIR CHAMBER	
42	**24A0A-PS-27	**24A0A-3	
43	**24A0A-PS-28	**24A0A-12	
44	**24A0A-PS-29	**24A0A-30	
45	**24A0A-PS-42	**24A0A-66	
46	**24A0A-PS-43	**24A0A-66	
47	**24A0A-PS-44	**24A0A-66	
48	**24A0A-PS-45	**24A0A-68	
49	**24A0A-PS-46	**24A0A-69	
50	**24A0A-PS-55	**24A0A-90	
51	**24A0A-PS-57	**24A0A-90	
52	**24A0A-PS-60	**24A0A-63	
53	**24A0A-PS-80	**24A0A-55	
54	**24A0A-PS-81	**24A0A-37	
55	**26A0A-PS-10	**26A0A-8	
56	**26A0A-PS-11	**26A0A-7	
57	**26A0A-PS-13	**26A0A-10	
58	**26A0A-PS-14	**26A0A-10	
59	**26A0A-PS-15	**26A0A-12	
60	**26A0A-PS-16	**26A0A-15	
61	**26A0A-PS-17	**26A0A-15	
62	**26A0A-PS-18	**26A0A-14	
63	**26A0A-PS-19	**26A0A-14	
64	**26A0A-PS-20	**26A0A-13	
65	**26A0A-PS-21	**26A0A-14	
66	**26A0A-PS-22	**26A0A-15	
67	**64A0A-PS-100	FFS	
68	**64A0A-PS-105	FFS	
69	**64A0A-PS-106	FFS	
70	**64A0A-PS-107	FFS	
71	**64A0A-PS-108	FFS	
72	**64A0A-PS-110	FFS	
73	**64A0A-PS-111	FFS	
74	**64A0A-PS-112	FFS	
75	**64A0A-PS-123	FFS	
76	**64A0A-PS-76	FFS	
77	**64A0A-PS-77	FFS	
78	**64A0A-PS-78	FFS	
79	**64A0A-PS-84	FFS	
80	**64A0A-PS-85	FFS	
81	**64A0A-PS-86	FFS	
82	**64A0A-PS-87	FFS	
83	**64A0A-PS-88	FFS	
84	**64A0A-PS-89	FFS	
85	**64A0A-PS-90	FFS	
86	**64A0A-PS-91	FFS	
87	**64A0A-PS-92	FFS	
88	**64A0A-PS-93	FFS	
89	**64A0A-PS-94	FFS	
90	**64A0A-PS-95	FFS	
91	**64A0A-PS-96	FFS	
92	**64A0A-PS-97	FFS	
93	**64A0A-PS-98	FFS	
94	**64A0A-PS-99	FFS	
95	**7A0A-PS-01	**7A0A-1	
96	**7A0A-PS-02	**7A0A-2	
97	**7A0A-PS-03	**7A0A-17	
98	**7A0A-PS-04	**7A0A-17	
99	**7A0A-PS-06	**7A0A-19	
100	**7A0A-PS-07	**7A0A-4	
101	**7A0A-PS-09	**7A0A-20	
102	**7A0A-PS-10	**7A0A-16	

REFERENCES

MDL ITEM #	MHPSA MDL DESCRIPTION	DETAILS FOR
N/A	FUEL GAS MAIN A PIPING (21A0A)	PIPE SUPPORT DRAWINGS
N/A	FUEL GAS MAIN B PIPING (21A0B)	"
N/A	FUEL GAS TOPHAT PIPING (21A0C)	"
N/A	FUEL GAS PILOT A PIPING (21A0D)	"
N/A	FUEL GAS PILOT B PIPING (21A0E)	"
N/A	FUEL GAS PIPING (21A0H)	"
N/A	HIGH PRESSURE BLEED AIR PIPING (23A0C)	"
N/A	AIR INLET PRESSURE INSTRUMENT PIPING (23A0K)	"
N/A	TURBINE BYPASS PIPING (23A0U)	"
N/A	INSTRUMENT AIR PIPING (24A0A)	"
N/A	NOZZLE SWEEP AIR PIPING (26A0A)	"
N/A	CASING COOLING AIR PIPING (INTERNAL) (7A0A)	"
39	GT ENCLOSURE MODULE 3-2 DETAIL DRAWINGS	STRUCTURE

NOTES


1. DIMENSIONS : MM [INCHES]

2. **XXXXX-XX-XX ← SUPPORT TAG

3. GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY

4. THE DIMENSIONS GIVEN IN THESE GENERAL ARRANGEMENT DRAWINGS ARE GIVEN FROM THE NEAREST PROFILES AND ARE THEORETICAL. DUE TO PRODUCTION TOLERANCES OF THE PROFILES AND MANUFACURING & ASSEMBLY TOLERANCES OF THE STEEL CONSTRUCTION SOME DIFFERENCES CAN BE OBSERVED IN REGARDS TO ORIGINAL SUPPORT THEORITICAL WORKING POINT COORDINATES AND ELEVATIONS. OUR SUGGESTION IS IN SUCH INCONVENIENT CASES, A CHECK SHALL BE MADE ACCORDING TO THE ELEVATION AND COORDINATES IN THE ORIGINAL SUPPORT DRAWINGS.

5. OFF MODULE SUPPORTS ARE GOING TO BE SITE MANUFACTURED AND ASSEMBLED.



MD-3.2 ISOMETRIC VIEW

LOOKING LUBE OIL UNIT SIDE

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	04.07.2024	N.B.	S.S.	S.O.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:

This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: -

ITEM NO: MDL-155

DWG NAME: MD-3.2 SUPPORTS GENERAL ARRANGEMENT DRAWING


REF.DWG.NO.: -

PREPARED BY: cimtas

JOB NO	SHEET	SCALE	SIZE
2E00140	2/8	1/20	A1

DRAWING NO: 2E00140-CI-026-150

REV.: 0



MD-3.2 PLAN VIEW

REFERENCES

MDL ITEM #	MHPSA MDL DESCRIPTION	DETAILS FOR
N/A	FUEL GAS MAIN A PIPING (21A0A)	PIPE SUPPORT DRAWINGS
N/A	FUEL GAS MAIN B PIPING (21A0B)	"
N/A	FUEL GAS TOPHAT PIPING (21A0C)	"
N/A	FUEL GAS PILOT A PIPING (21A0D)	"
N/A	FUEL GAS PILOT B PIPING (21A0E)	"
N/A	FUEL GAS PIPING (21A0H)	"
N/A	HIGH PRESSURE BLEED AIR PIPING (23A0C)	"
N/A	AIR INLET PRESSURE INSTRUMENT PIPING (23A0K)	"
N/A	TURBINE BYPASS PIPING (23A0U)	"
N/A	INSTRUMENT AIR PIPING (24A0A)	"
N/A	NOZZLE SWEEP AIR PIPING (26A0A)	"
N/A	CASING COOLING AIR PIPING (INTERNAL) (7A0A)	"
39	GT ENCLOSURE MODULE 3-2 DETAIL DRAWINGS	STRUCTURE

NOTES

1. DIMENSIONS : MM [INCHES]
2. **XXXXX-XX-XX ← SUPPORT TAG
3. GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. THE DIMENSIONS GIVEN IN THESE GENERAL ARRANGEMENT DRAWINGS ARE GIVEN FROM THE NEAREST PROFILES AND ARE THEORETICAL. DUE TO PRODUCTION TOLERANCES OF THE PROFILES AND MANUFACURING & ASSEMBLY TOLERANCES OF THE STEEL CONSTRUCTION SOME DIFFERENCES CAN BE OBSERVED IN REGARDS TO ORIGINAL SUPPORT THEORITICAL WORKING POINT COORDINATES AND ELEVATIONS. OUR SUGGESTION IS IN SUCH INCONVENIENT CASES, A CHECK SHALL BE MADE ACCORDING TO THE ELEVATION AND COORDINATES IN THE ORIGINAL SUPPORT DRAWINGS.
5. OFF MODULE SUPPORTS ARE GOING TO BE SITE MANUFACTURED AND ASSEMBLED.

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	04.07.2024	N.B.	S.S.	S.O.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: -

ITEM NO: MDL-155

DWG NAME: MD-3.2 SUPPORTS GENERAL ARRANGEMENT DRAWING


REF.DWG.NO.: -

PREPARED BY: cimtas

JOB NO	SHEET	SCALE	SIZE
2E00140	3/8	1/20	A1

DRAWING NO: 2E00140-CI-026-150

REV.: 0



MD-3.2 LOOKING FUEL GAS UNIT SIDE

REFERENCES

MDL ITEM #	MHPSA MDL DESCRIPTION	DETAILS FOR
N/A	FUEL GAS MAIN A PIPING (21A0A)	PIPE SUPPORT DRAWINGS
N/A	FUEL GAS MAIN B PIPING (21A0B)	"
N/A	FUEL GAS TOPHAT PIPING (21A0C)	"
N/A	FUEL GAS PILOT A PIPING (21A0D)	"
N/A	FUEL GAS PILOT B PIPING (21A0E)	"
N/A	FUEL GAS PIPING (21A0H)	"
N/A	HIGH PRESSURE BLEED AIR PIPING (23A0C)	"
N/A	AIR INLET PRESSURE INSTRUMENT PIPING (23A0K)	"
N/A	TURBINE BYPASS PIPING (23A0U)	"
N/A	INSTRUMENT AIR PIPING (24A0A)	"
N/A	NOZZLE SWEEP AIR PIPING (26A0A)	"
N/A	CASING COOLING AIR PIPING (INTERNAL) (7A0A)	"
39	GT ENCLOSURE MODULE 3-2 DETAIL DRAWINGS	STRUCTURE

NOTES

1. DIMENSIONS : MM [INCHES]
2. **XXXXX-XX-XX → SUPPORT TAG
3. GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. THE DIMENSIONS GIVEN IN THESE GENERAL ARRANGEMENT DRAWINGS ARE GIVEN FROM THE NEAREST PROFILES AND ARE THEORETICAL. DUE TO PRODUCTION TOLERANCES OF THE PROFILES AND MANUFACURING & ASSEMBLY TOLERANCES OF THE STEEL CONSTRUCTION SOME DIFFERENCES CAN BE OBSERVED IN REGARDS TO ORIGINAL SUPPORT THEORITICAL WORKING POINT COORDINATES AND ELEVATIONS. OUR SUGGESTION IS IN SUCH INCONVENIENT CASES, A CHECK SHALL BE MADE ACCORDING TO THE ELEVATION AND COORDINATES IN THE ORIGINAL SUPPORT DRAWINGS.
5. OFF MODULE SUPPORTS ARE GOING TO BE SITE MANUFACTURED AND ASSEMBLED.

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	04.07.2024	N.B.	S.S.	S.O.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023 , Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: -

ITEM NO: MDL-155

DWG NAME: MD-3.2 SUPPORTS GENERAL ARRANGEMENT DRAWING


REF.DWG.NO.: -

PREPARED BY: cimtas


JOB NO	SHEET	SCALE	SIZE
2E00140	4/8	1/20	A1

DRAWING NO: 2E00140-CI-026-150

REV.: 0



MD-3.2 SECTION A-A



MD-3.2 SECTION B-B

REFERENCES

MDL ITEM #	MHPSA MDL DESCRIPTION	DETAILS FOR
N/A	FUEL GAS MAIN A PIPING (21A0A)	PIPE SUPPORT DRAWINGS
N/A	FUEL GAS MAIN B PIPING (21A0B)	"
N/A	FUEL GAS TOPHAT PIPING (21A0C)	"
N/A	FUEL GAS PILOT A PIPING (21A0D)	"
N/A	FUEL GAS PILOT B PIPING (21A0E)	"
N/A	FUEL GAS PIPING (21A0H)	"
N/A	HIGH PRESSURE BLEED AIR PIPING (23A0C)	"
N/A	AIR INLET PRESSURE INSTRUMENT PIPING (23A0K)	"
N/A	TURBINE BYPASS PIPING (23A0U)	"
N/A	INSTRUMENT AIR PIPING (24A0A)	"
N/A	NOZZLE SWEEP AIR PIPING (26A0A)	"
N/A	CASING COOLING AIR PIPING (INTERNAL) (7A0A)	"
39	GT ENCLOSURE MODULE 3-2 DETAIL DRAWINGS	STRUCTURE

NOTES

1. DIMENSIONS : MM [INCHES]
2. **XXXXX-XX-XX ← SUPPORT TAG
3. GRATINGS ARE HIDDEN FOR A MORE CLEAR VIEW WHERE IT IS CONSIDERED NECESSARY
4. THE DIMENSIONS GIVEN IN THESE GENERAL ARRANGEMENT DRAWINGS ARE GIVEN FROM THE NEAREST PROFILES AND ARE THEORETICAL. DUE TO PRODUCTION TOLERANCES OF THE PROFILES AND MANUFACURING & ASSEMBLY TOLERANCES OF THE STEEL CONSTRUCTION SOME DIFFERENCES CAN BE OBSERVED IN REGARDS TO ORIGINAL SUPPORT THEORITICAL WORKING POINT COORDINATES AND ELEVATIONS. OUR SUGGESTION IS IN SUCH INCONVENIENT CASES, A CHECK SHALL BE MADE ACCORDING TO THE ELEVATION AND COORDINATES IN THE ORIGINAL SUPPORT DRAWINGS.
5. OFF MODULE SUPPORTS ARE GOING TO BE SITE MANUFACTURED AND ASSEMBLED.

REV.	DESCRIPTION	DATE	BY	CHECK	APPROVAL
0	ISSUED FOR CONSTRUCTION	04.07.2024	N.B.	S.S.	S.O.

This drawing is the property of Cimtas and all rights reserved

REVISIONS

CUSTOMER

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023 Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

CUSTOMER JOB NO: -

ITEM NO: MDL-155

DWG NAME: MD-3.2 SUPPORTS GENERAL ARRANGEMENT DRAWING

REF.DWG.NO.: -

PREPARED BY: cimtas

JOB NO	SHEET	SCALE	SIZE
2E00140	5/8	1/20	A1

DRAWING NO: 2E00140-CI-026-150

REV.: 0


SCALE = NONE

TOLERANCES PER MSS SP-58
UNLESS NOTED OTHERWISE


NOTES:
1. SMOOTHEN SHARP CORNERS BY GRINDING
2. WELD TO SUIT ASSEMBLY
3. ** PREFIX SHALL BE PER DOCUMENT "PLANT IDENTIFICATION NUMBERING SYSTEM"
4. PREFIX "***" IN HANGER MARK INDICATES GT UNIT NUMBER

NODE:	No C2
LINE NO:	**QFF11BR676


Pipe OD =	1.90	inch
Pipe DesignTemp.=	140	°F
Insul=	0	inch




LOOKING EXHAUST SIDE
1:5




LOOKING LUBE OIL UNIT SIDE
1:5






ISOMETRIC VIEW



1:2.5



1:2.5

Item	Description	Lisega Size/ Standard	Width in	Width mm	Length in	Length mm	Qty.	Total Weight lbf	Total Weight kg	Material
1	L50x50x6	JIS G 3192			9.53	242	1	2.36	1.07	SS400
2	PL5		1.57	40	3.94	100	1	0.35	0.16	ASTM A240-304
3	Standard U-Bolt, 1.90"	400548					1	0.13	0.06	A193GrB8Cl1
4	Heavy Hex Nut for U-Bolt 3/8"						4	0.09	0.04	STAINLESS STEEL
						GRAND TOTAL		2.93	1.33	

MODULE NO:
MD-3.2

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations; diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd

SL2

MITSUBISHI POWER ENGINEERING
PLANT ENGINEERING

DEPARTMENT:
SECTION:

DRAWING DISTRIBUTION LIST

MITSUBISHI POWER HQ-LAKE MARY

SUPPORT NUMBER: **24A0A-PS-55

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023, Mitsubishi Power Americas, Inc.

MITSUBISHI POWER


SCALE = NONE

TOLERANCES PER MSS SP-58
UNLESS NOTED OTHERWISE


NOTES:
1. SMOOTHEN SHARP CORNERS BY GRINDING
2. WELD TO SUIT ASSEMBLY
3. ** PREFIX SHALL BE PER DOCUMENT "PLANT IDENTIFICATION NUMBERING SYSTEM"
4. PREFIX "**" IN HANGER MARK INDICATES GT UNIT NUMBER

NODE:	No C2
LINE NO:	**QFF11BR676


Pipe OD =	1.90	inch
Pipe DesignTemp.=	140	°F
Insul=	0	inch




LOOKING EXHAUST SIDE
1:5




LOOKING LUBE OIL UNIT SIDE
1:5




○ P.A. = PIPE ATTACHMENT
× S.A. = STEEL ATTACHMENT(S)



ISOMETRIC VIEW



1:2.5



1:2.5

Item	Description	Lisega Size/ Standard	Width in	Width mm	Length in	Length mm	Qty.	Total Weight lbf	Total Weight kg	Material
1	L50x50x6	JIS G 3192			5.00	127	1	1.24	0.56	SS400
2	PL5		1.57	40	3.94	100	1	0.35	0.16	ASTM A240-304
3	Standard U-Bolt, 1.90"	400548					1	0.13	0.06	A193GrB8Cl1
4	Heavy Hex Nut for U-Bolt 3/8"						4	0.09	0.04	STAINLESS STEEL
5	L75x75x9	JIS G 3192			12.44	316	1	6.94	3.15	SS400
						GRAND TOTAL		8.75	3.97	

MODULE NO:
MD-3.2

MITSUBISHI POWER HQ-LAKE MARY

SUPPORT NUMBER:	**24A0A-PS-57
PAGE NUMBER:	1 OF 1

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023, Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations; diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd

SL2

MITSUBISHI POWER ENGINEERING

PLANT ENGINEERING

DEPARTMENT:

SECTION:

DRAWING DISTRIBUTION LIST


SCALE = NONE

TOLERANCES PER MSS SP-58
UNLESS NOTED OTHERWISE


NOTES:
1. SMOOTHEN SHARP CORNERS BY GRINDING
2. WELD TO SUIT ASSEMBLY
3. ** PREFIX SHALL BE PER DOCUMENT "PLANT IDENTIFICATION NUMBERING SYSTEM"
4. PREFIX "***" IN HANGER MARK INDICATES GT UNIT NUMBER

NODE:	No C2
LINE NO:	**QFF11BR676


Pipe OD =	1.90	inch
Pipe DesignTemp.=	140	°F
Insul=	0	inch




PLAN VIEW
1:5



LOOKING LUBE OIL UNIT SIDE
1:5




4 L50x50x6



1:2.5

3 PL5x100x40



1:2.5

Item	Description	Lisega Size/ Standard	Width in	Width mm	Length in	Length mm	Qty.	Total Weight lbf	Total Weight kg	Material
1	Standard U-Bolt, 1.90"	400548					1	0.37	0.17	A193GrB8CI1
2	Heavy Hex Nut for U-Bolt 3/8"						4	0.09	0.04	STAINLESS STEEL
3	PL5		1.57	40	3.94	100	1	0.35	0.16	ASTM A240-304
4	L50x50x6	JIS G 3192			6.65	169	1	1.65	0.75	SS400
						GRAND TOTAL		2.46	1.12	

MODULE NO:
MD-3.2

MITSUBISHI POWER HQ-LAKE MARY

SUPPORT NUMBER:	**24A0A-PS-127

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023, Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

PAGE NUMBER: 1 OF 1

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations, diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd

SL2

MITSUBISHI POWER ENGINEERING

PLANT ENGINEERING

DEPARTMENT:

SECTION:

DRAWING DISTRIBUTION LIST


SCALE = NONE

TOLERANCES PER MSS SP-58
UNLESS NOTED OTHERWISE


NOTES:
1. SMOOTHEN SHARP CORNERS BY GRINDING
2. WELD TO SUIT ASSEMBLY
3. ** PREFIX SHALL BE PER DOCUMENT "PLANT IDENTIFICATION NUMBERING SYSTEM"
4. PREFIX "***" IN HANGER MARK INDICATES GT UNIT NUMBER

NODE:	No C2
LINE NO:	**QFF11BR676


Pipe OD =	1.90	inch
Pipe DesignTemp.=	140	°F
Insul=	0	inch





LOOKING LUBE OIL UNIT SIDE
1:5



LOOKING INLET MANIFOLD SIDE
1:5







Item	Description	Lisega Size/ Standard	Width in	Width mm	Length in	Length mm	Qty.	Total Weight lbf	Total Weight kg	Material
1	Standard U-Bolt, 1.90"	400548					1	0.37	0.17	A193GrB8CI1
2	Heavy Hex Nut for U-Bolt 3/8"						4	0.09	0.04	STAINLESS STEEL
3	PL5		1.57	40	3.94	100	1	0.35	0.16	ASTM A240-304
4	L50x50x6	JIS G 3192			6.65	169	1	1.65	0.75	SS400
						GRAND TOTAL		2.46	1.12	

MODULE NO:
MD-3.2

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations, diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd
SL2
MITSUBISHI POWER ENGINEERING
PLANT ENGINEERING
DEPARTMENT:
SECTION:
DRAWING DISTRIBUTION LIST

MITSUBISHI POWER HQ-LAKE MARY
SUPPORT NUMBER: **24A0A-PS-128

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023, Mitsubishi Power Americas, Inc.

MITSUBISHI POWER


SCALE = NONE

TOLERANCES PER MSS SP-58
UNLESS NOTED OTHERWISE


NOTES:
1. SMOOTHEN SHARP CORNERS BY GRINDING
2. WELD TO SUIT ASSEMBLY
3. ** PREFIX SHALL BE PER DOCUMENT "PLANT IDENTIFICATION NUMBERING SYSTEM"
4. PREFIX "***" IN HANGER MARK INDICATES GT UNIT NUMBER

NODE:	No C2
LINE NO:	**QFF11BR676


Pipe OD =	1.90	inch
Pipe DesignTemp.=	140	°F
Insul=	0	inch




LOOKING LUBE OIL UNIT SIDE
1:5




LOOKING INLET MANIFOLD SIDE
1:5





1:2.5



1:2.5

Item	Description	Lisega Size/ Standard	Width in	Width mm	Length in	Length mm	Qty.	Total Weight lbf	Total Weight kg	Material
1	Standard U-Bolt, 1.90"	400548					1	0.37	0.17	A193GrB8CI1
2	Heavy Hex Nut for U-Bolt 3/8"						4	0.09	0.04	STAINLESS STEEL
3	PL5		1.57	40	3.94	100	1	0.35	0.16	ASTM A240-304
4	L50x50x6	JIS G 3192			6.65	169	1	1.65	0.75	SS400
						GRAND TOTAL		2.46	1.12	

MODULE NO:
MD-3.2

MITSUBISHI POWER HQ-LAKE MARY

SUPPORT NUMBER:	**24A0A-PS-129

PROPRIETARY AND CONFIDENTIAL:
This document contains Confidential and Proprietary information of Mitsubishi Power Americas, Inc. Neither this document, nor any information obtained therefrom is to be reproduced, transmitted or disclosed to any third party without first receiving the express written authorization of Mitsubishi Power Americas, Inc.
©2023, Mitsubishi Power Americas, Inc.

MITSUBISHI POWER

PAGE NUMBER: 1 OF 1

EXPORT CONTROL DIVERSION WARNING
This document contains data which if exported from the United States must be exported in accordance with the export administration regulations, diversion contrary to U.S. law is prohibited.

ECCN: EAR99 No License Req'd
SL2
MITSUBISHI POWER ENGINEERING
PLANT ENGINEERING
DEPARTMENT:
SECTION:
DRAWING DISTRIBUTION LIST