

GATE: CH - 45.2023

EE22BTECH11219 - Rada Sai Sujan

QUESTION

Level (h) in a steam boiler is controlled by manipulating the flow rate (F) of the break-up(fresh) water using a proportional (P) controller. The transfer function between the output and the manipulated input is

$$\frac{h(s)}{F(s)} = \frac{0.25(1-s)}{s(2s+1)}$$

The measurement and the valve transfer functions are both equal to 1. A process engineer wants to tune the controller so that the closed loop response gives the decaying oscillations under the servo mode. Which one of the following is the CORRECT value of the controller gain to be used by the engineer?

- (A) 0.25
- (B) 2
- (C) 4
- (D) 6

Solution:

PARAMETER	VALUE	DESCRIPTION
G_c	K_c	Proportional controller's transfer function
G_f	1	Valve transfer function
G_p	$\frac{0.25(1-s)}{s(2s+1)}$	Process transfer function
G_M	1	Measurement transfer function

TABLE I
CAPTION




Fig. 1. Block diagram

Characteristic equation of the above block diagram can be given by,

$$C.H = 1 + G_c G_f G_p G_M \quad (1)$$

$$= 1 + \frac{0.25K_c(1-s)}{s(2s+1)} \quad (2)$$

$$\Rightarrow 2s^2 + s(1 - 0.25K_c) + 0.25K_c = 0 \quad (3)$$

Comparing it with the equation $\tau^2 s^2 + 2\epsilon\tau s + 1$,

$$\frac{2}{\tau^2} = \frac{1 - 0.25K_c}{2\epsilon\tau} = \frac{0.25K_c}{1} \quad (4)$$

$$\therefore \tau = \sqrt{\frac{2}{0.25K_c}}, 2\epsilon\tau = \frac{1 - 0.25K_c}{0.25K_c} \quad (5)$$

For the system to produce decaying oscillations $\epsilon < 1$,

By verfyng options,

$$\therefore \boxed{K_c = 2} \quad (6)$$