



ROUTINE TEST REPORT

Test Report No : 73249677 Discipline : Electrical Testing Customer : PRABHAT WIRES LLP Customer Address : 1ST FLOOR, GOVIND NIWAS, 99/101, LOHAR CHAWL,,,MUMBAI,MUMBAI,MAHARASHTRA,400002	Sample Received On : 2023/02/25 Report Date : 2023/02/25 Group : Cables & Wires Reference Standard : Test Method : As per Reference Standard Sample Condition : Good New Cable Item Code : LVMR09CXSUYL003C2.5SA001S
--	---

INFORMATION PROVIDED BY CUSTOMER:

PO Number : PWL/PO/0019/23-24 Size : 3CX2.5 SQ MM Voltage Grade : 1100V Description : POLYCAB MAKE 1100 VOLTS, STRANDED (CLASS 2) BARE COPPER CONDUCTOR, XLPE INSULATED, INSULATED CORES LAYING FOR LAID UP, EXTRUDED ST2 PVC I/SH, SINGLE LAYER GALVANISED STEEL ROUND WIRE ARMoured AND EXTRUDED FR-LSH PVC ST2 OUTER SHEATHED LV PO WER CABLE AS PER MR.	PO Date : 13-APR-23 SO Number : 23242003772 Type : 2XWY
--	--

SR No	Drum Nos.	Job Lot Quantity (MTR)	Cond Resistance at 20 Deg C ohm/km(Max) 7.41	Core Colour	High Voltage Test at 3 kv For 5 Minute
1	2227AFG-722402	3041	7.312	BLUE	Ok
		3041	7.307	Ok	RED
		3041	7.306	Ok	YELLOW
2	2227AFG-732420	2999	7.315	BLUE	Ok
		2999	7.312	Ok	RED
		2999	7.316	Ok	YELLOW
3	2227AFG-747353	2000	7.317	BLUE	Ok
		2000	7.310	Ok	RED
		2000	7.316	Ok	YELLOW
4	2227AFG-747357	2211	7.317	BLUE	Ok
		2211	7.312	Ok	RED
		2211	7.316	Ok	YELLOW

Remarks: Outer Sheath With Anti Termite and Anti Rodent Properties

Note :

1. The cable under test confirms the requirements of reference standard with amendments & data sheet.
2. Test results relates only to item(s) tested & listed in report.
3. Any corrections/ensures invalidates this test report.
4. Any discrepancy in this report should be brought to our notice within 15 days from the date of issue.
5. Report shall not be reproduced except in full without approval of the laboratory.

END OF REPORT

Imran Bokda
Prepared By

Gaurav Trivedi
Reviewed By

Tejash Suthar
Authorized Signatory

Format No: PCTL/PIL/F/7.8.1

Rev No : 01

Revision Date: 04.06.2021

Issued No : 03

Issue Date: 24.08.2020



POLYCAB INDIA LIMITED
(formerly known as Polycab Wires Limited and Polycab Wires Private Limited)

ROUTINE TEST REPORT

Test Report No : 73249677	Sample Received On :
Discipline : Electrical Testing	Report Date : 2023/02/28
Customer : PRABHAT WIRES LLP	Group : Cables & Wires
Customer Address : 1ST FLOOR, GOVIND NIWAS, 99/101, LOHAR	Reference Standard :
CHAWL,,,MUMBAI,MUMBAI,MAHARASHTRA,400002	Test Method :
	Sample Condition :
	Item Code : LVMR09CXS WYL003C2.5SA001S

INFORMATION PROVIDED BY CUSTOMER:

PO Number : PWL/PO/0019/23-24	PO Date : 13-APR-23
Size : 3CX2.5 SQ MM	SO Number : 23242003772
Voltage Grade : 1100V	Type : 2XWY
Description : POLYCAB MAKE 1100 VOLTS, STRANDED (CLASS 2) BARE COPPER CONDUCTOR, XLPE INSULATED, INSULATED CORES LAYING FOR LAID UP, EXTRUDED ST2 PVC I/SH, SINGLE LAYER GALVANISED STEEL ROUND WIRE ARMoured AND EXTRUDED FR-LSH PVC ST2 OUTER SHEATHED LV POWER CABLE AS PER MR.	

SR No	Drum Nos.	Cond Resistance at 20 Deg C ohm/km(Max)	Core Colour	High Voltage Test at	Job Lot Quantity (MTR)
1	2227AFG-747353	0	0	0	2000
2	2227AFG-747357	0	0	0	2211

Remarks:

Note :

1. The cable under test confirms the requirements of reference standard with amendments & data sheet.
2. Test results relates only to item(s) tested & listed in report.
3. Any corrections/ensures invalidates this test report.
4. Any discrepancy in this report should be brought to our notice within 15 days from the date of issue.
5. Report shall not be reproduced except in full without approval of the laboratory.

END OF REPORT

Imran Bokda
Prepared By

Gaurav Trivedi
Reviewed By

Tejash Suthar
Authorized Signatory

Format No: PCTL/PIL/F/7.8.1

Rev No : 01

Revision Date: 04.06.2021

Issued No : 03

Issue Date: 24.08.2020