Loc. Baia, nr. 1616, DN2E km 2
Jud. Suceava, RO-727020
0230 546 696 tel
0230 206 090 fax
0743 069 587 mob
office@tehnoworld.ro
www.tehnoworld.ro
RC: J33/145/2003
CUI: RO15231305
RO87BACX0000003023781012
UNICREDIT BANK

QUALITY CERTIFICATE

No.		Date:	

Customer:	
Address:	
Invoice no :	
Product :	**Gas pipe PE100 D. SDR**
Normative:	**EN 1555-1-2**
Batch:	
Quantity:	**mt**
Marking:	

THE FINAL PRODUCT BATCH TESTING RESULTS

No. Crt.	Features		Test method	Unit	Requirements EN 1555-1-2	Results
1	Surface visual control		-	Inside and outside pipe surfaces are clean, smooth, without any scratches, deformations or foreign inclusions, without pinholes or other defects		Complied
2	Colour		visual	Black with yellow stripes		Complied
3	Dimensional test	Outside diameter	ISO 3126	mm		Complied
		Wall thickness		mm		Complied
		Ovality		mm		Complied
4	Melt flow index (MFR)		ISO 1133	g/10min	0.2 – 1.4 ± 20% of raw material MFR	Complied
5	Oxidation induction time (200°C)		ISO 11357-6	min	≥ 20	Complied
6	Tensile properties	Elongation at break	ISO 6259	%	≥ 350	Complied
7	Hydrostatic strength	PE100: 80^0 C, 5,4 MPa	ISO 1167	hours	≥ 165	Complied

Batch tested PEHD pipe meets the requirements of the reference standard EN 1555-1-2:

SC TEHNO WORLD SRL

Carmen Maria Benea

Laboratory Manager,

CC8 Place of issue: loc. Baia, jud. Suceava