(A01) TIANJIN KEFA VALVE CO.,LTD YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452 Tel: +86 22 25790656 Fax: +86 22 25799150	(A02) INSPECTION CERTIFICATE EN 10204, 3.1 (A03) CERTIFICATE NUMBER:KF-2310301	(A04) MARK OF THE MANUFACTURER	KEFA
		(A05) Producer of the document: Quality Management Departament	Page 1 of 2

(A06) Customer: Petrouzinex S.R.L
(A07) Customer's order:2045
(A08) Our order no:AW-230727
(A09) Purchase article no:2045
(A10) Technical sheet no:2045-9

SPECIFICATION	(B14 + B19)	Item	Drawing no.	Pieces	Heat no.	Item delivery condition
(B01) Product: Dismantling joint PN10 DN450		Body	2045-9	4	2308	ok
(B06) Product marking:Petrouzinex		seat	2045-9	4	2308	ok
(B07) Series number:2310301-2310304		bolt/nut	2045-9	4	2308	ok
(B08) Quantity:4						

(C71) CHEMICHAL COMPOZITION

Item	Steel designation	Heat no.	Chemichal element (%)										Analysis bulletin
			C	Mn	Si	P	S	Cr	Ni	Mo	Cu	V	
Body	GGG50	2308	3.56	0.44	3.15	0.044	0.017						pass
seat	EPDM	2308											pass
bolt/nut	Carbon steel	2308	0.65	0.68	0.23	0.028	0.015						pass

Materials meet the requirements of: body:GGG50, seat: EPDM, bolt/nut:Carbon Steel

(A01) TIANJIN KEFA VALVE CO.,LTD YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452 Tel: +86 22 25790656 Fax: +86 22 25799150	(A02) INSPECTION CERTIFICATE EN 10204, 3.1 (A03) CERTIFICATE NUMBER:KF-2310301	(A04) MARK OF THE MANUFACTURER	KEFA
		(A05) Producer of the document: Quality Management Departament	Page 2 of 2

(C00+C43) MECHANICAL TESTING

Item	Shape of the specimen	Specimen diam. mm	Direction of the test piece	Test temperature °C	Yield strength Mpa	Tensile strength Mpa	Elongation %	Reduction in/of area %	Impact test KV J	Impact test KCU J/cm²	Yield strength 450°C N/mm²	Hardness HB	Test report no.
Body	round	10	vertical	25	268	470	21					176	2363
seat													2363
bolt/nut	round	10	vertical	25	240	450	24					168	2363

Materials meet the requirements of:body:GGG50,seat: EPDM, bolt/nut:Carbon Steel
Tension testing in accordance with: EN12266-1
Impact test in accordance with: EN12266-1
Hardness test in accordance with: EN12266-1

(D01) VISUAL EXAMINATION AND SIZE CONTROL 100%: OK
(D02) NON-DESTRUCTIVE EXAMINATION: OK
(D51) OTHER TESTING ON PRODUCT:

Test denomination	Reference standard	Working fluid Denomi-nation	Working fluid Temperature °C	Test period min.	Test pressure bar	Leakage rate	Number of "close-open" cycles	Notes
Shell test	EN12266-1		25	2	15	0%	1	
Hydrostatic leakage test	EN12266-1		25	2	11	0%	1	
Air leakage test	EN12266-1		25	2	7	0%	1	

(Z01) We hereby that the product meets the requirements of customer's order:2045
The QualityManagement System is certified acc. Pressure Equipment Directive (2014/68/EU) by:Lloyd's Register Quality Assurance (Shanghai) Co., Ltd

Warranty period:12 months

(Z02)

Date::Oct 10,2023	Works inspector yuyuan	Inspector's stamp	

TIANJIN KEFA VALVE CO.,LTD
天津凯发
阀门有限公司

ROMANIA
PUNCT DE LUCRU
PETROUZINEX SRL

CONFORM CU ORIGINALUL

(A01) ITIANJIN KEFA VALVE CO.,LTD	(A02) CERTIFICAT DE INSPECȚIE	(A04) MARCA PRODUCATORULUI (A05)	KEFA
YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452	EN 10204, 3.1	Producatorul documentului:	Pagină
Tel: +86 22 25790656 Fax: +86 22 25799150	(A03) NUMARUL CERTIFICATULUI: KF-2310301	Departamentul de management al calitatii	1 of 2

(A06) Client: Petrouzinex S.R.L

(A07) Comanda clientului:2045

(A0B) Ordinul nostru nr:AW230727

(A09) Achiziționați articolul nr:2045

(A10) Fișa tehnică nr:2045 -9

SPECIFICATIE	(B14	Art	Desen nr	Bucati	Nr. sarja	Starea de livrare
(B01) Produs: Compensator cu tiranti PN10 DN450	+	Corp	2045-9	4	2308	ok
(B05) Marcarea produsului :Petrouzinex	B19)	Etansare	2045-9	4	2308	ok
(B07) Numărul de serie:2310301-2310304		surub/piulita	2045-9	4	2308	ok
(B08) Cantitate: 4						

(C71) COMPOZIȚIA CHIMICĂ

Art	Denumirea materialului	Sarja nr	Element chimic(%)										Buletin de analiză
			C	Mn	Si	p	S	Cr	Ni	Mo	Cu	V	
Corp	GGG50	2308	3.56	0.44	3.15	0.044	0.017						Aproba
Etansare	EPDM	2308											Aproba
surub/piulita	Otel carbon	2308	0.65	0.68	0.23	0.028	0.015						Aproba

Materialele îndeplinesc cerințele: corp: GGG50, scaun EPDM, surub/piulita otel carbon

I<A01) ITIANJIN KEFA VALVE CO.,LTD	(A02) CERTIFICAT DE INSPECȚIE	(A04) MARCA PRODUCATORULUI	KEFA
YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452	EN 10204, 3.1	(A05)Producatorul documentului	Pagina
Tel: +86 22 25790656 Fax: +86 22 25799150	(A03) NUMARUL CERTIFICATULUI:: KF-2310301	Departamentul de management al calitatii	2 of 2

(C00+C43) TESTARI MECANICE

Art	Forma specimenului	diametrul specimenului mm	Direcția piesei de testare	Test temperatura C	Limita de curgere Mpa	Rezistenta la tractiune Mpa	Elongatie ϕ	Reducere a în/a suprafeței	Test de impact KVI J	KCU J/cm²	Limita de curgere 450°C N/mm²	Duritate HB	Nr test raport
Corp	Rotund	10	vertical	25	266	470	21					178	2363
Etansare													2363
Surub/piulita	Rotund	10	vertical	25	240	450	24					168	2363

Materialele îndeplinesc cerințele: corp: GGG50 etansare: EPDM, surub/piulita:otel carbon

Testarea de tensiune în conformitate cu: EN 12266-1

Testarea de impact în conformitate cu: EN 12266-1

Test de duritate conform: EN12266-1

(D01) EXAMINARE VIZUALĂ ȘI CONTROLUL MĂRIMII 100%: OK

(D02) EXAMEN NEDISTRUCTIV: OK

(D51) ALTE TESTĂRI PE PRODUS:

Denumire de testare	Standard de referință	Lichid de lucru		Perioada de testare min	Test de presiune bar	Rata de scurgere	Numărul de cicluri de închidere-deschis	Note
		Denominație	Temperatura °C					
Shell test	EN12266-1		25	2	15	0%	1	
Test de scurgere hidrostatică	EN12266-1		25	2	11	0%	1	
Test de scurgere de aer	EN12266-1		25	2	7	0%	1	

(Z01)Prin prezenta, că produsul îndeplinește cerințele comenzii clientului:2045

Sistemul de management al calitatii este certificat as. Directiva privind echipamentele sub presiune (2014/68/UE) de: Lloyd's Register Quality Assurance (Shanghai) Co., Ltd

Perioada de garantie: 12 luni

(Z02)			
	Data:10 octombrie 2023	Works Inspector yuyuan	ștampila inspectorului

SC PETROUZINEX SRL PIATRA NEAMT ROMANIA