DECLARATION OF CONFORMITY No
according to Directive 2014/68/EU
for a pressure equipment

The manufacturer: TIANJIN KEFA VALVE CO.,LTD
Address:YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452

herewith declares,that the pressure equipment

Description: Resilient seat gate valves
ductile iron body, F4/F5 PN10/16 DN40 - DN1200
Type: flange and resilient seat
Max. allowable pressure:PN16/PN10
Allowable max./min temperature:130℃ /-29℃
Test pressure:2.4Mpa/1.5Mpa
Test fluid: water/air

corresponds to the Pressure Equipment Directive 2014/68/EU

Applied conformity assessment procedures: Annex III, Module H
Applied standard and technical specification: EN12266-1
Other applied EC-Directives: EN12266-1

Surveillance of the QS-System: Lloyd's Register Quality Assurance (Shanghai) Co., Ltd
Examination/inspections/test during manufacturing:
Equipment category,design pressure max/mix,design temp.range,medium

Certificates which are included
EC-Design Examination Certificate No:0038/PED/SHA/6025206/A
EC-Type Examination Certification No:0038/PED/SHA/6025206/A
EC-Certificate of conformity No:0038/PED/SHA/6025206/A

Place:Tianjin,china.
Date:01.2023

TIANJIN KEFA VALVE CO.,LTD
天津凯发
阀门有限公司

GENERAL MANAGER
YUYUAN

CONFORM CU
ORIGINALUL

SC PETROUZINEX SRL
PIATRA NEAMT
ROMANIA

DECLARATIE DE CONFORMITATE CE
in conformitate cu Directiva Europeana 2014/68/EU
pentru Echipamente sub Presiune

Producator: TIANJIN KEFA VALVE CO., LTD
Adresa: YUZHUANGCUN, HUJIAYUANJIE, TANGGU, TIANJIN, CHINA, 300452

prin prezenta, declara ca Echipamentele sub Presiune,

Descriere: Robineti cu sertar cauciucat
Material corp fonta ductila, F4/F5, PN10/16 DN40 - DN1200
Tip: cu flanse si sertar cauciucat EPDM
Presiune max. admisibila: PN16/PN10
Temperatura admisibila max./min.: 130°C /-29°C
Teste presiune:2.4Mpa/1.5Mpa
Fluid: apa/aer

corespund Directivei 2014/68/UE privind Echipamentele sub Presiune

Proceduri de evaluare a conformității aplicate: Anexa III, Modului H
Standard aplicat și specificație tehnică: EN12266-1
Alte directive CE aplicate: EN12266-1

Organismul de supraveghere a QS: Lloyd's Register Quality Assurance (Shanghai) Co., Ltd
Examinare/Inspectii/Teste pe parcursul fabricarii:
Categ. de echip., presiunea max/min de design, domeniul temp. de design, mediu de lucru

Certificate care sunt incluse:
Certificat de examinare CE - Design Nr.: 0038/PED/SHA/6025206/A
Certificat de examinare CE - Tip Nr.: 0038/PED/SHA/6025206/A
Certificat de conformitate CE Nr.: 0038/PED/SHA/6025206/A

Loc :Tianjin, China.
Data: 01.2023

GENERAL MANAGER
YUYUAN

SC PETROUZINEX SRL PIATRA NEAMT ROMÂNIA