(A01) TIANJIN KEFA VALVE CO.,LTD YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452 Tel: +86 22 25790656 Fax: +86 22 25799150	(A02) INSPECTION CERTIFICATE EN 10204, 3.1 (A03) CERTIFICATE NUMBER: KF-2319031	(A04) MARK OF THE MANUFACTURER (A05) Producer of the document: Quality Management Departament	KEFA Page 1 of 2

(A06) Customer: Petrouzinex S.R.L

(A07) Customer's order:2384

(A08) Our order no:AW-231115

(A09) Purchase article no:2384

(A10) Technical sheet no:2384-2

SPECIFICATION	(B14	Item	Drawing no.	Pieces	Heat no.	Item delivery condition
(B01) Product:Resilient gate valve PN16 DN80 F4	+	Body	2384-2	200	2311	ok
(B06) Product marking:Petrouzinex	B19)	disc	2384-2	200	2311	ok
(B07) Series number:2319031-2319230		seat	2384-2	200	2311	ok
(B08) Quantity:200		Stem	2384-2	200	2311	ok

(C71) CHEMICHAL COMPOZITION

Item	Steel designation	Heat no.	Chemichal element (%)										Analysis bulletin
			C	Mn	Si	P	S	Cr	Ni	Mo	Cu	V	
Body	GGG50	2311	3.57	0.44	3.18	0.044	0.017						pass
disc	GGG50	2311	3.57	0.44	3.18	0.044	0.017						pass
seat	EPDM	2311											pass
stem	SS416	2311	0.11	0.66	0.54	0.038	0.14	12.11					pass

Materials meet the requirements of: body:GGG50, Disc:GGG50, seat: EPDM,Stem:SS410

(A01) TIANJIN KEFA VALVE CO.,LTD YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452 Tel: +86 22 25790656 Fax: +86 22 25799150	(A02) INSPECTION CERTIFICATE EN 10204, 3.1 (A03) CERTIFICATE NUMBER: KF-2319031	(A04) MARK OF THE MANUFACTURER (A05) Producer of the document: Quality Management Departament	KEFA Page 2 of 2

(C00+C43) MECHANICAL TESTING

Item	Shape of the specimen	Specimen diam. mm	Direction of the test piece	Test temperature °C	Yield strength Mpa	Tensile strength Mpa	Elongation %	Reduction in/of area %	Impact test KV J	Impact test KCU J/cm²	Yield strength 450°C N/mm²	Hardness HB	Test report no.
Body	round	10	vertical	25	274	477	23					180	2384
disc	round	10	vertical	25	274	477	23					180	2384
seat													2384
stem	round	10	vertical	25	355	610	30	59			350	186	2384

Materials meet the requirements of: Body:GGG50,Disc:GGG50,Seat:EPDM,Stem:SS410

Tension testing in accordance with: EN12266-1

Impact test in accordance with: EN12266-1

Hardness test in accordance with: EN12266-1

(D01) VISUAL EXAMINATION AND SIZE CONTROL 100%: OK

(D02) NON-DESTRUCTIVE EXAMINATION: OK

(D51) OTHER TESTING ON PRODUCT:

Test denomination	Reference standard	Working fluid Denomi-nation	Working fluid Temperature °C	Test period min.	Test pressure bar	Leakage rate	Number of 'close-open' cycles	Notes
Shell test	EN12266-1		25	2	24	0%	1	
Hydrostatic leakage test	EN12266-1		25	2	17.6	0%	1	
Air leakage test	EN12266-1		25	2	7	0%	1	

(Z01) We hereby that the product meets the requirements of customer's order:2384

The QualityManagement System is certified acc. Pressure Equipment Directive (2014/68/EU) by:Lloyd's Register Quality Assurance (Shanghai) Co., Ltd

Warranty period:12 months

(Z02)

Date::Feb 25,2024	Works Inspector yuyuan	Inspector's stamp	

CONFORM CU ORIGINALUL

TIANJIN KEFA VALVE CO., LTD. 天津凯发阀门有限公司

SC PETROUZINEX SRL PIATRA-NEAMT ROMANIA

(A01) ITIANJIN KEFA VALVE CO.,LTD	(A02) CERTIFICAT DE INSPECȚIE	(A04) MARCA PRODUCATORULUI (A05)	KEFA
YUZHUANGCUN.HUJIAYUANJIE,TANGGU.TIANJIN,CHINA.300452	EN 10204, 3.1	Producatorul documentului:	Pagină
Tel: +86 22 25790656 Fax: +86 22 25799150	(A03) NUMARUL CERTIFICATULUI: KF-2319031	Departamentul de management al calitatii	1 of 2

(A06) Client: Petrouzinex S.R.L

(A07) Comanda clientului:2384

(A0B) Ordinul nostru nr:AW231115

(A09) Achiziționați articolul nr:2384

(A10) Fișa tehnică nr:2384-2

SPECIFICATIE	(B14 + B19)	Art	Desen nr	Bucati	Nr. sarja	Starea de livrare
(B01) Produs:Robinet cu sertar cauciucat PN16 DN80 F4		Corp	2384-2	200	2311	ok
(B05) Marcarea produsului :Petrouzinex		Sertar	2384-2	200	2311	ok
(B07) Numărul de serie:2319031-2319230		Etansare	2384-2	200	2311	ok
(B08) Cantitate: 200		tija	2384-2	200	2311	ok

(C71) COMPOZIȚIA CHIMICĂ

Art	Denumirea materialului	Sarja nr	Element chimic(%)										Buletin de analiză
			C	Mn	Si	p	S	Cr	Ni	Mo	Cu	V	
Corp	GGG50	2311	3.57	0.44	3.18	0.044	0.017						Aproba
Sertar	GGG50	2311	3.57	0.44	3.18	0.044	0.017						Aproba
Etansare	EPDM	2311											Aproba
Tija	SS416	2311	0.11	0.66	0.54	0.038	0.14	12.11					Aproba

Materialele îndeplinesc cerințele: corp/sertar:GGG50, etansare:EPDM, tijă: SS410

(A01) ITIANJIN KEFA VALVE CO.,LTD	(A02) CERTIFICAT DE INSPECȚIE	(A04) MARCA PRODUCATORULUI	KEFA
YUZHUANGCUN,HUJIAYUANJIE,TANGGU,TIANJIN,CHINA,300452	EN 10204, 3.1	(A05)Producatorul documentului	Pagina
Tel: +86 22 25790656 Fax: +86 22 25799150	(A03) NUMARUL CERTIFICATULUI:: KF-2319031	Departamentul de management al calitatii	2 of 2

(C00+C43) TESTARI MECANICE

Art	Forma specimenului	diametrul specimenului mm	Direcția piesei de testare	Test temperatura C	Limita de curgere Mpa	Rezistenta la tractiune Mpa	Elongatie ϕ	Reducere a în/a suprafeței	Test de impact KVI J	KCU J/cm²	Limita de curgere 450°C N/mm²	Duritate HB	Nr test raport
Corp	Rotund	10	vertical	25	274	477	23					180	2384
Sertar	Rotund	10	vertical	25	274	477	23					180	2384
Etansare													2384
Tija	Rotund	10	vertical	25	355	610	30	59			350	186	2384

Materialele îndeplinesc cerințele: corp: GGG50, sertar:GGG50, etansare EPDM tijă: SS410

Testare de tensiune în conformitate cu: EN 12266-1

Testare de impact în conformitate cu: EN 12266-1

Test de duritate conform: EN12266-1

(D01) EXAMINARE VIZUALĂ ȘI CONTROLUL MĂRIMII 100%: OK

(D02) EXAMEN NEDISTRUCTIV: OK

(D51) ALTE TESTĂRI PE PRODUS:

Denumire de testare	Standard de referință	Lichid de lucru		Perioada de testare min	Test de presiune bar	Rata de scurgere	Numărul de cicluri de închidere-deschis	Nota
		Denominație	Temperatura °C					
Shell test	EN12266-1		25	2	24	0%	1	
Test de scurgere hidrostatică	EN12266-1		25	2	17.6	0%	1	
Test de scurgere de aer	EN12266-1		25	2	7	0%	1	

(201)Prin prezenta, că produsul îndeplinește cerințele comenzii clientului:2384

Sistemul de management al calitatii este certificat as. Directiva privind echipamentele sub presiune (2014/68/UE) de: Lloyd's Register Quality Assurance (Shanghai) Co., Ltd

Perioada de garantie: 12 luni

(202)			
Data:25.02.2024	Works Inspector yuyuan	Stampila inspectorului	

PETROUZINEX SRL PIATRA NEAMT ROMANIA