

DOCUMENT TYPE: Geotechnical Investigation Report
REPORT NO: GEO-DMV7-P42-011
DATE: 02-May-2019
PROJECT: Delhi Metro Viaduct Package DMV-7 (fictional)
STRUCTURE: Pier P-42

FINDINGS:

Supplementary boring conducted at P-42 (BH-P42-S1) during foundation excavation revealed a localized soft clay pocket at depth 6.5m-8.2m, not identified in the original 2017 geotechnical investigation (GI-DMV7-2017). Standard Penetration Test (SPT) N-values in this zone are lower than design assumptions.

RECOMMENDATION:

Design team to review pier foundation and reinforcement adequacy in light of revised soil parameters. Additional reinforcement or foundation modification may be required at P-42.

Prepared by: Geotechnical Consultant

Distribution: Design Consultant, Resident Engineer, Contractor (site copy)