

Engineer's Assessment of Variation Quotation — VO-NRB4-004

Nandira River Bridge Project — Package NRB-4

Document Reference:	ENG-NRB4-0031
Date:	05-Nov-2021
Contract No.:	NHIA/NRB4/CW/2020-01
From:	Engineer, Meridian Engineering Consultants
To:	Contractor, Sagara Constructions Pvt. Ltd.
CC:	National Highways Infrastructure Authority

Subject: Assessment of Variation Quotation CTR-NRB4-0067 — VO-NRB4-004

We refer to your quotation CTR-NRB4-0067 dated 22-Oct-2021 for the varied works instructed under VO-NRB4-004, and respond within the 14-day period provided in Sub-Clause 13.3.

ASSESSMENT BY ITEM:

Item 1 (Excavation and disposal, 48 m3): Accepted in full. Amount: VTD 88,800.

Item 2 (Mass concrete replacement fill, 22 m3): Accepted in full. Amount: VTD 140,800.

Item 3 (Additional reinforced concrete, Grade M40): Our own measurement against as-built dimensions recorded against drawing DRG-NRB4-P3-PC-Rev02 indicates a quantity of 24 m3, not the 28 m3 quoted. Adjusted amount: 24 m3 x VTD 8,200/m3 = VTD 196,800.

Item 4 (Additional reinforcement steel): Our measurement, cross-checked against the bar bending schedule DRG-NRB4-P3-PC-Rev02-BBS, indicates a quantity of 2.6 tonnes, not 3.1 tonnes. Adjusted amount: 2.6 t x VTD 42,000/t = VTD 109,200.

Item 5 (Additional formwork, 38 m2): Accepted in full. Amount: VTD 55,100.

Item 6 (Disruption and extended standing time, lump sum VTD 42,900): Not accepted. Valuation of a Variation under Sub-Clause 13.3 values the varied work itself; it is not the mechanism for valuing standing time or disruption arising from the period before an instruction is issued. Any such claim would fall to be considered, if pursued, as a separate claim under Sub-Clause 20.1, supported by its own notice and particulars, none of which has been submitted. This item is accordingly valued at nil under this assessment, without prejudice to the Contractor's right to pursue it separately in accordance with Sub-Clause 20.1.

ENGINEER'S RECOMMENDED VALUATION: VTD 590,700 (Items 1–5 as adjusted; Item 6 nil).

As this valuation exceeds the threshold in Particular Conditions Part E.1, it is submitted to the Employer for approval and does not fall within the Resident Engineer's delegated authority under Particular Conditions Part B.1. We will confirm the Employer's decision separately.

MERIDIAN

Engineering Consultants
Meridian Engineering Consultants
Meridian House, 22 Riverside Avenue, Vantara City

ENGINEER'S ASSESSMENT

Signed: Engineer's Representative
Meridian Engineering Consultants