

Standard Operating Procedure - Fire Water Pump

Last Verified: 2024-01-01

Equipment: FW-001

Procedure: Run auxiliary diesel engine for 15 minutes weekly.