



Initial Environmental Examination

PUBLIC

February 2026

India: Tamil Nadu Urban Flagship Investment Program- Tranche 2

Subproject: Dedicated Water Supply Scheme for Madurai Municipal Corporation from Mullai Periyar River at Lower Camp
Part 3 of 3: Annexures (Continued)

Prepared by Madurai City Municipal Corporation for the Asian Development Bank (ADB). This is an updated version of the draft Initial Environmental Examination originally posted in July 2019 available on <https://www.adb.org/projects/documents/ind-49107-005-iee-0>.

Asian Development Bank

This initial environmental examination is a document of the borrower. The views expressed herein do not necessarily represent those of ADB's Board of Directors, Management, or Staff, and may be preliminary in nature. Your attention is directed to the 'terms of use' section of ADB's website.

In preparing any country program or strategy, financing any project, or by making any designation of or reference to a particular territory or geographic area in this document, ADB does not intend to make any judgments as to the legal or other status of any territory or area.

TEST REPORT

 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

WATER ANALYSIS

Report No :	ECI-NN-WA-212/10/2020	Report Date :	21.10.2020	
Customer Name & Address	M/s. P&C Projects (P) Ltd., WTP Project Site Pannaipatti, Viralipatti, Nilakottai Taluk, Battalagundu, Dindigul Dist.			
Customer Reference :	IWO Dt:14/10/2020	Sample Reference No :	ECI-NN-WA-212/10/2020	
Sample Drawn By :	Customer	Sample Received On :	15.10.2020	
Sample Collected Date :	14.10.2020	Test Commenced On :	15.10.2020	
Qty of Sample Received :	2 L	Test Completed On :	21.10.2020	
Sample Description :	Water	Sampling Method :	--	
Latitude :	10.0978763 N	Longitude :	77.7207064 E	
Sample Mark:	400m South East Side of WTP (Mr. Siva Garden)			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1.	Bio chemical oxygen demand (BOD @ 27°C for 3 days)	mg/L	< 1.0	IS 3025:Part 44
2.	Calcium(as Ca)	mg/L	114	IS 3025:Part 40
3.	Chemical Oxygen Demand (COD)	mg/L	< 1.0	IS 3025:Part 58
4.	Chlorides(as Cl)	mg/L	466	IS 3025:Part 32
5.	Color	Hazen	< 1.0	IS 3025:Part 04
6.	Dissolved Oxygen	mg/L	6.1	IS 3025:Part 38
7.	Fluoride (as F)	mg/L	< 0.1	IS 3025:Part 60
8.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53
9.	Magnesium (as Mg)	mg/L	41	IS 3025 Part 46
10.	Nitrite Nitrogen(as NO ₂)	mg/L	BDL (DL = 0.01)	IS 3025:Part 34
11.	pH Value @ 25°C	--	7.3	IS 3025:Part 11
12.	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025 Part 26
13.	Sodium(as Na)	mg/L	105	IS 3025 :Part 45
14.	Sulphates (as SO ₄ ²⁻)	mg/L	219	IS 3025 Part 24

 CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

Note : 1. The results relate only to this item tested.

2. Any correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.


4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

Report No : ECI-NN-WA-212/10/2020				
15.	Total Alkalinity (as CaCO ₃)	mg/L	166	IS 3025 Part 23
16.	Total Dissolved Solids(TDS) @ 105°C	mg/L	1247	IS 3025:Part 16
17.	Total Hardness(as CaCO ₃)	mg/L	217	IS 3025 Part 21
18.	Total Suspended Solids(TSS) @105°C	mg/L	< 1.0	IS 3025 Part 17
19.	Turbidity	NTU	< 0.5	IS 3025:Part 10
<--- End of Report --->				
Verified By : 				
Remarks : BDL –Below Detectable Limit, DL – Detectable Limit		For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory		

CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

- Note :**
1. The results relate only to this item tested.
 2. Any correction not attested shall invalidate this report.
 3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
 4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
 5. Total liability of our laboratory is limited to the invoice amount.
 6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT

Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

WATER ANALYSIS

Report No :	ECI-NN-WA-213/10/2020	Report Date :	21.10.2020	
Customer Name & Address	M/s. P&C Projects (P) Ltd., WTP Project Site Pannaipatti, Viraliipatti, Nilakottai Taluk, Battalagundu, Dindigul Dist.			
Customer Reference :	IWO Dt: 14/10/2020	Sample Reference No :	ECI-NN-WA-213/10/2020	
Sample Drawn By :	Customer	Sample Received On :	15.10.2020	
Sample Collected Date :	14.10.2020	Test Commenced On :	15.10.2020	
Qty of Sample Received :	2 L	Test Completed On :	21.10.2020	
Sample Description :	Water	Sampling Method :	--	
Latitude :	10.1135325 N	Longitude :	77.77353723 E	
Sample Mark:	Ground Water in Existing Plant Area			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1.	Bio chemical oxygen demand (BOD @ 27°C for 3 days)	mg/L	<1.0	IS 3025:Part 44
2.	Calcium(as Ca)	mg/L	52	IS 3025:Part 40
3.	Chemical Oxygen Demand (COD)	mg/L	<1.0	IS 3025:Part 58
4.	Chlorides(as Cl)	mg/L	195	IS 3025:Part 32
5.	Color	Hazen	<1.0	IS 3025:Part 04
6.	Cyanide(as CN)	mg/L	< 0.02	IS 3025 Part 27
7.	Dissolved Oxygen	mg/L	6.4	IS 3025:Part 38
8.	Fluoride (as F)	mg/L	< 0.1	IS 3025:Part 60
9.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53
10.	Magnesium (as Mg)	mg/L	18	IS 3025 Part 46
11.	Nitrite Nitrogen(as NO ₂)	mg/L	BDL (DL = 0.01)	IS 3025 Part 34
12.	pH Value @ 25°C	--	7.7	IS 3025:Part 11
13.	Phenolic Compound (as C ₆ H ₅ OH)	mg/L	< 0.001	IS 3025 Part 43
14.	Potassium (as K)	mg/L	18	IS 3025:Part 45
15.	Reactive Silica (as SiO ₂)	mg/L	19.8	IS 3025:Part 35

CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com



- Note :**
1. The results relate only to this item tested.
 2. Any correction not attested shall invalidate this report.
 3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
 4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
 5. Total liability of our laboratory is limited to the invoice amount.
 6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

Report No : ECI-NN-WA-213/10/2020				
16	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025 Part 26
17	Sodium(as Na)	mg/L	46	IS 3025 :Part 45
18	Sulphates (as SO_4^{2-})	mg/L	93	IS 3025 Part 24
19	Total Alkalinity (as CaCO_3)	mg/L	142	IS 3025 Part 23
20	Total Chromium (as Cr)	mg/L	BDL (DL = 0.01)	IS 3025 Part 52
21	Total Dissolved Solids(TDS) @ 105°C	mg/L	512	IS 3025:Part 16
22	Total Hardness(as CaCO_3)	mg/L	170	IS 3025 Part 21
23	Total Suspended Solids(TSS) @105°C	mg/L	<1.0	IS 3025 Part 17
24	Turbidity	NTU	< 0.5	IS 3025:Part 10

<--- End of Report --->

Verified By : 	For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory
--	---

Remarks : BDL –Below Detectable Limit, DL – Detectable Limit

For ENVIRO CARE INDIA PRIVATE LIMITED
 (Laboratory Division)

Authorized Signatory
CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

Note : 1. The results relate only to this item tested.

2. Any correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016
WATER ANALYSIS

Report No :	ECI-NN-WA-214/10/2020	Report Date :	21.10.2020	
Customer Name & Address	M/s. P&C Projects (P) Ltd., WTP Project Site Pannaipatti, Viralipatti, Nilakottai Taluk, Battalagundu, Dindigul Dist.			
Customer Reference :	IWO Dt:14/10/2020	Sample Reference No :	ECI-NN-WA-214/10/2020	
Sample Drawn By :	Customer	Sample Received On :	15.10.2020	
Sample Collected Date :	14.10.2020	Test Commenced On :	15.10.2020	
Qty of Sample Received :	2 L	Test Completed On :	21.10.2020	
Sample Description :	Water	Sampling Method :	--	
Latitude :	10.1062153 N	Longitude :	77.73255108 E	
Sample Mark:	Ground Water-1- South West Side (Mr.Perumal Garden)			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1.	Bio chemical oxygen demand (BOD @ 27°C for 3 days)	mg/L	<1.0	IS 3025:Part 44
2.	Calcium(as Ca)	mg/L	124	IS 3025:Part 40
3.	Chemical Oxygen Demand (COD)	mg/L	<1.0	IS 3025:Part 58
4.	Chlorides(as Cl)	mg/L	432	IS 3025:Part 32
5.	Color	Hazen	<1.0	IS 3025:Part 04
6.	Cyanide(as CN)	mg/L	< 0.02	IS 3025 Part 27
7.	Dissolved Oxygen	mg/L	6.3	IS 3025:Part 38
8.	Fluoride (as F)	mg/L	< 0.1	IS 3025:Part 60
9.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53
10.	Magnesium (as Mg)	mg/L	45	IS 3025 Part 46
11.	Nitrite Nitrogen(as NO ₂)	mg/L	BDL (DL = 0.01)	IS 3025:Part 34
12.	pH Value @ 25°C	--	7.2	IS 3025:Part 11
13.	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025:Part 26
14.	Sodium(as Na)	mg/L	98	IS 3025 :Part 45
15.	Sulphates (as SO ₄ ²⁻)	mg/L	205	IS 3025 Part 24

CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

Note : 1. The results relate only to this item tested.

2. Any correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.


4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

Report No : ECI-NN-WA-214/10/2020				
16.	Total Alkalinity (as CaCO ₃)	mg/L	305	IS 3025 Part 23
17.	Total Chromium (as Cr)	mg/L	BDL (DL = 0.01)	IS 3025 Part 52
18.	Total Dissolved Solids(TDS) @ 105°C	mg/L	1214	IS 3025:Part 16
19.	Total Hardness(as CaCO ₃)	mg/L	409	IS 3025 Part 21
20.	Total Suspended Solids(TSS) @ 105°C	mg/L	<1.0	IS 3025 Part 17
21.	Turbidity	NTU	< 0.5	IS 3025:Part 10
<--- End of Report --->				
Verified By : <i>P. M. J.</i>				
Remarks : BDL –Below Detectable Limit, DL – Detectable Limit		For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory		

CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

- Note :**
1. The results relate only to this item tested.
 2. Any correction not attested shall invalidate this report.
 3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
 4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
 5. Total liability of our laboratory is limited to the invoice amount.
 6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



Package-3 Baseline Environmental test Report (Air, Noise and Water test Report)



ISO 9001 : 2008 Certified Company
ISO 14001 : 2004 Certified Company
OHSAS : 18001 : 2007 Certified Company

Accredited by **INABL** (Chemical & Biological)
Recognized by BIS as per IS : 14542 : 2016

TEST REPORT

AMBIENT AIR QUALITY SURVEY

Report No :	ECI-NN-AAQ-130/08/2020	Report Date :	31.08.2020
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai		
Customer Reference :	Kcci/PR/Madurai/Enviro care-114/2020 Dt:27/08/2020	Sample Reference No :	ECI-NN-AAQ-130/08/2020
Sample Drawn By :	ECI	Sample Received On :	26.08.2020
Sample Collected Date :	24.08.2020	Test Commenced On :	26.08.2020
Qty of Sample Received :	Filter Paper & 25ml Solution	Test Completed On :	31.08.2020
Sample Description :	Ambient Air	Sampling Method :	IS 5182 P14
Latitude :	9.9158961	Longitude :	78.078087
Sample Mark:	F - Sambakudi Near Madakulam		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of NAAQs (Industrial, Residential)
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	IS 11255:Part 06	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182:Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182:Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182:Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	ECI-SOP-SAM-08	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182:Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182:Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	18.5	IS 5182:Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182:Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	25.5	EPA 40 CFR Part 50 Appendix L	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	51.8	IS 5182:Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	7.2	IS 5182:Part 02	80

<--- End of Report --->

Verified By : *P. M. J.*

Remarks: In the above mentioned location meets the requirements of NAAQs standards with respect to the parameters tested.

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

[Signature]
Authorized Signatory

CHENNAI Tel : +91 (44) 4246084
Mobile : 9944931111
e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
Mobile : 8220015870
e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
Mobile : 8056766966
e-mail : ecicet@envirocareindia.com

Note : 1. The results relate only to the item tested.

2. Any correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT

 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2018

AMBIENT AIR QUALITY SURVEY

Report No :	ECI-NN-AAQ-131/08/2020	Report Date :	31.08.2020
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai.		
Customer Reference :	Kcol/PR/Madurai/Enviro care-114/2020 Dt:27/08/2020	Sample Reference No :	ECI-NN-AAQ-131/08/2020
Sample Drawn By :	ECI	Sample Received On :	26.08.2020
Sample Collected Date :	24.08.2020	Test Commenced On :	26.08.2020
Qty of Sample Received :	Filter Paper & 25ml Solution	Test Completed On :	31.08.2020
Sample Description :	Ambient Air	Sampling Method :	IS 5182:P14
Latitude :	9.894649	Longitude :	78.0577672
Sample Mark:	G - Vilacheri (Kilakuyilkudi)		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of NAAQs (Industrial, Residential)
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	IS 11255:Part 06	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182:Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182:Part 11	5.0
4	Benzo-a-Pyrine (BaP)	ng/m ³	< 1.0	IS 5182:Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	ECI-SOP-SAM-08	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182:Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182:Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	17.5	IS 5182:Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182:Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	29.3	EPA 40 CFR Part 50 Appendix L	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	58.3	IS 5182:Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	7.0	IS 5182:Part 02	80

<--- End of Report --->

Verified By : *P. M. T.*

Remarks: In the above mentioned location meets the requirements of NAAQs standards with respect to the parameters tested.

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division).
[Signature]
Authorized Signatory


 CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

Note : 1. The results relate only to this item tested.

2. Any correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2015
AMBIENT AIR QUALITY SURVEY

Report No :	ECI-NN-AAQ-132/08/2020	Report Date :	31.08.2020
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai.		
Customer Reference :	Kccl/PR/Madurai/Enviro care-114/2020 Dt.27/08/2020	Sample Reference No :	ECI-NN-AAQ-132/08/2020
Sample Drawn By :	ECI	Sample Received On :	26.08.2020
Sample Collected Date :	24.08.2020	Test Commenced On :	26.08.2020
Qty of Sample Received :	Filter Paper & 25ml Solution	Test Completed On :	31.08.2020
Sample Description :	Ambient Air	Sampling Method :	IS 5182.P14
Latitude :	9.8968742	Longitude :	78.0894489
Sample Mark:	H – TPK Main Road Pykara		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of NAAQs (Industrial, Residential)
1.	Ammonia (as NH ₃)	µg/m ³	< 1.0	IS 11255:Part 06	400
2.	Arsenic (as As)	ng/m ³	< 0.1	IS 5182:Part 22	6.0
3.	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182:Part 11	5.0
4.	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182:Part 12	1.0
5.	Carbon Monoxide (as CO)	mg/m ³	< 1.2	ECI-SOP-SAM-08	2.0
6.	Lead (as Pb)	µg/m ³	< 0.1	IS 5182:Part 22	1.0
7.	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182:Part 22	20
8.	Nitrogen dioxide (as NO ₂)	µg/m ³	25.5	IS 5182:Part 06	80
9.	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182:Part 09	180
10.	Particulate Matter (PM _{2.5})	µg/m ³	29.3	EPA 40 CFR Part 50 Appendix L	60
11.	Respirable Particulate Matter (PM ₁₀)	µg/m ³	59.3	IS 5182:Part 23	100
12.	Sulphur Dioxide (as SO ₂)	µg/m ³	8.1	IS 5182:Part 02	80

<--- End of Report --->

Verified By : *P. M. J.*

Remarks: In the above mentioned location meets the requirements of NAAQs standards with respect to the parameters tested.

 For **ENVIRO CARE INDIA PRIVATE LIMITED**
 (Laboratory Division)

[Signature]
 Authorized Signatory

 CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220915870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056765966
 e-mail : ecicbe@envirocareindia.com
Note : 1. The results relate only to this item tested

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT


 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

AMBIENT AIR QUALITY SURVEY

Report No :	ECI-NN-AAQ-133/08/2020	Report Date :	31.08.2020
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai.		
Customer Reference :	Kcci/PR/Madurai/Enviro care-114/2020 Dt.27/08/2020	Sample Reference No :	ECI-NN-AAQ-133/08/2020
Sample Drawn By :	ECI	Sample Received On :	26.08.2020
Sample Collected Date :	24.08.2020	Test Commenced On :	26.08.2020
Qty of Sample Received :	Filter Paper & 25ml Solution	Test Completed On :	31.08.2020
Sample Description :	Ambient Air	Sampling Method :	IS 5182:P14
Sample Mark:	Sivananapuram (C.Pudur)		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of NAAQs (Industrial, Residential)
1.	Ammonia (as NH ₃)	µg/m ³	< 1.0	IS 11255:Part 06	400
2.	Arsenic (as As)	ng/m ³	< 0.1	IS 5182:Part 22	6.0
3.	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182:Part 11	5.0
4.	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182:Part 12	1.0
5.	Carbon Monoxide (as CO)	mg/m ³	< 1.2	ECI-SOP-SAM-08	2.0
6.	Lead (as Pb)	µg/m ³	< 0.1	IS 5182:Part 22	1.0
7.	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182:Part 22	20
8.	Nitrogen dioxide (as NO ₂)	µg/m ³	26.3	IS 5182:Part 06	80
9.	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182:Part 09	180
10.	Particulate Matter (PM _{2.5})	µg/m ³	28.5	EPA 40 CFR Part 50 Appendix L	60
11.	Respirable Particulate Matter (PM ₁₀)	µg/m ³	54.2	IS 5182:Part 23	100
12.	Sulphur Dioxide (as SO ₂)	µg/m ³	8.2	IS 5182:Part 02	80

< --- End of Report --- >

Verified By : <i>P. M. J.</i> Remarks: In the above mentioned location meets the requirements of NAAQs standards with respect to the parameters tested.	For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory
--	---


 CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com
Note : 1. The results relate only to this item tested

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT

 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016


AMBIENT AIR QUALITY SURVEY

Report No :	ECI-NN-AAQ-134/08/2020	Report Date :	31.08.2020
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai.		
Customer Reference :	Kcci/PR/Madurai/Enviro care-114/2020 Dt:27/08/2020	Sample Reference No :	ECI-NN-AAQ-134/08/2020
Sample Drawn By :	ECI	Sample Received On :	26.08.2020
Sample Collected Date :	24.08.2020	Test Commenced On :	26.08.2020
Qty of Sample Received :	Filter Paper & 25ml Solution	Test Completed On :	31.08.2020
Sample Description :	Ambient Air	Sampling Method :	IS 5182:P14
Sample Mark:	Aanapatti		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHQD	Permissible limits of NAAQs (Industrial, Residential)
1.	Ammonia (as NH ₃)	µg/m ³	< 1.0	IS 11255:Part 06	400
2.	Arsenic (as As)	ng/m ³	< 0.1	IS 5182:Part 22	6.0
3.	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182:Part 11	5.0
4.	Benzo-a-Pyrine (BaP)	ng/m ³	< 1.0	IS 5182:Part 12	1.0
5.	Carbon Monoxide (as CO)	mg/m ³	< 1.2	ECI-SOP-SAM-08	2.0
6.	Lead (as Pb)	µg/m ³	< 0.1	IS 5182:Part 22	1.0
7.	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182:Part 22	20
8.	Nitrogen dioxide (as NO ₂)	µg/m ³	21.2	IS 5182:Part 06	80
9.	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182:Part 09	180
10.	Particulate Matter (PM _{2.5})	µg/m ³	27.7	EPA 40 CFR Part 50 Appendix L	60
11.	Respirable Particulate Matter (PM ₁₀)	µg/m ³	58.3	IS 5182:Part 23	100
12.	Sulphur Dioxide (as SO ₂)	µg/m ³	7.9	IS 5182:Part 02	80

<--- End of Report --->

Verified By : *P. M. J.*

Remarks: In the above mentioned location meets the requirements of NAAQs standards with respect to the parameters tested.	For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory
--	---


 CHENNAI Tel : +91 (44) 4355103
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com
Note : 1. The results relate only to this item tested.

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total Liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORTAccredited by **NABL** (Chemical & Biological)

Recognized by BIS as per IS : 14543 : 2016

NOISE MONITORING

Report No :	ECI-NN-NM-114/08/2020	Report Date :	31.08.2020
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai.		
Customer Reference :	Kccl/PR/Madurai/Enviro care-114/2020 Dt:27/08/2020	Sample Reference No :	ECI-NN-NM-114/08/2020
Sample Description :	Noise	Monitoring Date :	25.08.2020
Monitored By :	ECI	Data Received On :	26.08.2020

S.No	Locations	Latitude	Longitude	Day Time	
				Minimum	Maximum
1.	F - Sambakudi Near Madakulam	9.9158961	78.078087	52.4	53.0
2.	G - Vilacheri (Kilakuyilkudi)	9.894643	78.0577672	51.7	52.3
3.	H - TPK Main Road PYKARA	9.8968742	78.0894489	53.7	54.9
4.	Sivananapuram(C.Pudur)	10.116226	77.977027	52.6	53.9
5.	Aanapatti	10.090815	77.854296	53.1	54.3


Unit	dB (A)
TNPCB Max. Permissible Limit for Day Time (Residential Area)	55
Reference Method	IS 9589

<--- End of Report --->

Verified By : 

Remarks: in the above mentioned locations meets the requirements of TNPCB standards.

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory 



CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com

Note : 1. The results relate only to this item tested.

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016
WATER ANALYSIS

Report No :	ECI-NN-WA-120/08/2020	Report Date :	31.08.2020	
Customer Name & Address	M/s. Koya& Company Construction Limited, Madurai.			
Customer Reference :	Kcc/PR/Madurai/Enviro care-114/2020Dt:27/08/2020	Sample Reference No :	ECI-NN-WA-120/08/2020	
Sample Drawn By :	Customers	Sample Received On :	26.08.2020	
Sample Collected Date :	25.08.2020	Test Commenced On :	26.08.2020	
Qty of Sample Received :	2 L	Test Completed On :	31.08.2020	
Sample Description :	Water	Sampling Method :	IS 3025.Part 01 & IS 1622	
Latitude:	9.9158961	Longitude:	78.0780875	
Sample Mark:	Maadakkulam Surface Water - D			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1	Bio chemical oxygen demand (BOD @ 27°C for 3 days)	mg/L	<1.0	IS 3025.Part 44
2	Calcium(as Ca)	mg/L	43	IS 3025.Part 40
3	Chemical Oxygen Demand (COD)	mg/L	<1.0	IS 3025.Part 58
4	Chlorides(as Cl)	mg/L	49	IS 3025.Part 32
5	Color	Hazen	<1.0	IS 3025.Part 04
6	Cyanide(as CN)	mg/L	< 0.02	IS 3025.Part 27
7	Dissolved Oxygen	mg/L	6.5	IS 3025.Part 38
8	Fluoride (as F)	mg/L	< 0.1	IS 3025.Part 60
9	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025.Part 53
10	Magnesium (as Mg)	mg/L	14	IS 3025.Part 46
11	Nitrite Nitrogen(as NO ₂)	mg/L	BDL (DL = 0.01)	IS 3025.Part 34
12	pH Value @ 25°C	--	8.4	IS 3025.Part 11
13	Phenolic Compound (as C6H5OH)	mg/L	< 0.001	IS 3025.Part 43
14	Potassium (as K)	mg/L	6.0	IS 3025.Part 45
15	Reactive Silica (as SiO ₂)	mg/L	12.6	IS 3025.Part 35
16	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025.Part 26
17	Sodium(as Na)	mg/L	14	IS 3025.Part 45
18	Sulphates (as SO ₄ ²⁻)	mg/L	20	IS 3025.Part 24
19	Total Alkalinity (as CaCO ₃)	mg/L	131	IS 3025.Part 23
20	Total Chromium (as Cr)	mg/L	BDL (DL = 0.01)	IS 3025.Part 52

CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8720015870
 e-mail : fb@envirocareindia.com

COIMBATORE Tel : +91 (422) 4706686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com
Note : 1. The results relate only to this item tested.

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



**TEST REPORT**

Accredited by **INTELS** (Chemical & Biological)
Recognized by **BIS** as per IS : 14543 : 2016

Report No : ECI-NN-WA-120/08/2020				
21	Total Dissolved Solids(TDS) @ 105°C	mg/L	264	IS 3025:Part 16
22	Total Hardness(as CaCO ₃)	mg/L	143	IS 3025 Part 21
23	Total Suspended Solids(TSS) @105°C	mg/L	48	IS 3025 Part 17
24	Turbidity	NTU	< 0.5	IS 3025:Part 10
<--- End of Report --->				
Verified By : <i>P.M.</i>				
Remarks : BDL –Below Detectable Limit, DL – Detectable Limit		For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division) <i>[Signature]</i> Authorized Signatory		



CHENNAI Tel : +91 (44) 42867084
Mobile : 9944938637
e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
Mobile : 9220015870
e-mail : ls@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
Mobile : 8056766966
e-mail : ecicbe@envirocareindia.com

Note : 1. The results relate only to this item tested.

2. Any correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT

 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

WATER ANALYSIS

Report No :	ECI-NN-WA-122/08/2020	Report Date :	31.08.2020	
Customer Name & Address	M/s. Koya& Company Construction Limited, Madurai.			
Customer Reference :	KccI/PR/Madurai/Enviro care-114/2020 Dt:27/08/2020	Sample Reference No :	ECI-NN-WA-122/08/2020	
Sample Drawn By :	Customers	Sample Received On :	26.08.2020	
Sample Collected Date :	25.08.2020	Test Commenced On :	26.08.2020	
Qty of Sample Received :	2.0 Lit	Test Completed On :	31.08.2020	
Sample Description :	Water	Sampling Method :	IS 3025:Part 01 & IS 1622	
Sample Mark:	Sivaganapuram Borewell Water			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1.	Bio chemical oxygen demand (BOD @ 27°C for 3 days)	mg/L	<1.0	IS 3025:Part 44
2.	Calcium(as Ca)	mg/L	132	IS 3025:Part 40
3.	Chemical Oxygen Demand (COD)	mg/L	<1.0	IS 3025:Part 58
4.	Chlorides(as Cl)	mg/L	117	IS 3025:Part 32
5.	Color	Hazen	<1.0	IS 3025:Part 04
6.	Cyanide(as CN)	mg/L	< 0.02	IS 3025 Part 27
7.	Dissolved Oxygen	mg/L	6.7	IS 3025:Part 38
8.	Fluoride (as F)	mg/L	< 0.1	IS 3025:Part 60
9.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53
10.	Magnesium (as Mg)	mg/L	45	IS 3025 Part 46
11.	Nitrite Nitrogen(as NO ₂)	mg/L	BDL (DL = 0.01)	IS 3025:Part 34
12.	pH Value @ 25°C	--	7.6	IS 3025:Part 11
13.	Phenolic Compound (as C ₆ H ₅ OH)	mg/L	< 0.001	IS 3025 Part 43
14.	Potassium (as K)	mg/L	16	IS 3025:Part 45
15.	Reactive Silica (as SiO ₂)	mg/L	16.3	IS 3025:Part 35
16.	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025 Part 26
17.	Sodium(as Na)	mg/L	38	IS 3025 :Part 45
18.	Sulphates (as SO ₄ ²⁻)	mg/L	52	IS 3025 Part 24
19.	Total Alkalinity (as CaCO ₃)	mg/L	328	IS 3025 Part 23
20.	Total Chromium (as Cr)	mg/L	BDL (DL = 0.01)	IS 3025 Part 52

 CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com


 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056764966
 e-mail : ecicbc@envirocareindia.com
Note : 1. The results relate only to this item tested.

- Any correction not attested shall invalidate this report
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

Report No : ECI-NN-WA-122/08/2020				
21.	Total Dissolved Solids(TDS) @ 105°C	mg/L	557	IS 3025:Part 16
22.	Total Hardness(as CaCO ₃)	mg/L	424	IS 3025 Part 21
23.	Total Suspended Solids(TSS) @105°C	mg/L	<1.0	IS 3025 Part 17
24.	Turbidity	NTU	< 0.5	IS 3025:Part 10
<--- End of Report --->				
Verified By : <i>[Signature]</i>				
Remarks : BDL –Below Detectable Limit, DL – Detectable Limit		For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory		


CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com
Note : 1 The results relate only to this item tested.

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT

 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

WATER ANALYSIS

Report No :	ECI-NN-WA-123/08/2020	Report Date :	31.08.2020	
Customer Name & Address	M/s. Koya & Company Construction Limited, Madurai.			
Customer Reference :	Kcci/PR/Madurai/Enviro care-114/2020 Dt:27/08/2020	Sample Reference No :	ECI-NN-WA-123/08/2020	
Sample Drawn By :	Customers	Sample Received On :	26.08.2020	
Sample Collected Date :	25.08.2020	Test Commenced On :	26.08.2020	
Qty of Sample Received :	2.0 Lit	Test Completed On :	31.08.2020	
Sample Description :	Water	Sampling Method :	IS 3025:Part 01 & IS 1622	
Sample Mark:	Anaipatti Borewell Water			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1.	Bio chemical oxygen demand (BOD @ 27°C for 3 days)	mg/L	<1.0	IS 3025:Part 44
2.	Calcium(as Ca)	mg/L	98	IS 3025:Part 40
3.	Chemical Oxygen Demand (COD)	mg/L	<1.0	IS 3025:Part 58
4.	Chlorides(as Cl)	mg/L	235	IS 3025 Part 32
5.	Color	Hazen	<1.0	IS 3025:Part 04
6.	Cyanide(as CN)	mg/L	< 0.02	IS 3025 Part 27
7.	Dissolved Oxygen	mg/L	6.3	IS 3025:Part 38
8.	Fluoride (as F)	mg/L	< 0.1	IS 3025:Part 60
9.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53
10.	Magnesium (as Mg)	mg/L	34	IS 3025 Part 46
11.	Nitrite Nitrogen(as NO ₂)	mg/L	BDL (DL = 0.01)	IS 3025:Part 34
12.	pH Value @ 25°C	--	7.5	IS 3025:Part 11
13.	Phenolic Compound (as C ₆ H ₅ OH)	mg/L	< 0.001	IS 3025 Part 43
14.	Potassium (as K)	mg/L	20	IS 3025:Part 45
15.	Reactive Silica (as SiO ₂)	mg/L	18.5	IS 3025:Part 35
16.	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025 Part 26
17.	Sodium(as Na)	mg/L	45	IS 3025 :Part 45
18.	Sulphates (as SO ₄ ²⁻)	mg/L	104	IS 3025 Part 24
19.	Total Alkalinity (as CaCO ₃)	mg/L	292	IS 3025 Part 23
20.	Total Chromium (as Cr)	mg/L	BDL (DL = 0.01)	IS 3025 Part 52

 CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com


 MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

 COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com
Note : 1. The results relate only to this item tested.

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



TEST REPORT
 Accredited by **NABL** (Chemical & Biological)
 Recognized by BIS as per IS : 14543 : 2016

Report No : ECI-NN-WA-123/08/2020				
21.	Total Dissolved Solids(TDS) @ 105°C	mg/L	670	IS 3025:Part 16
22.	Total Hardness(as CaCO ₃)	mg/L	356	IS 3025 Part 21
23.	Total Suspended Solids(TSS) @105°C	mg/L	<1.0	IS 3025 Part 17
24.	Turbidity	NTU	< 0.5	IS 3025:Part 10
<--- End of Report --->				
Verified By : 				
Remarks : BDL –Below Detectable Limit, DL – Detectable Limit		For ENVIRO CARE INDIA PRIVATE LIMITED (Laboratory Division)  Authorized Signatory		


CHENNAI Tel : +91 (44) 42867084
 Mobile : 9944938637
 e-mail : ecichennai@envirocareindia.com

MADURAI Tel : +91 (452) 4355103
 Mobile : 8220015870
 e-mail : lab@envirocareindia.com

COIMBATORE Tel : +91 (422) 4206686
 Mobile : 8056766966
 e-mail : ecicbe@envirocareindia.com
Note : 1. The results relate only to this item tested.

- Any correction not attested shall invalidate this report.
- Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
- Total liability of our laboratory is limited to the invoice amount.
- Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



Package-4 Baseline Environmental test Report (Air, Noise and Water test Report)


TEST REPORT Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/182	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014		
Customer Reference:	IWC Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/182
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 8 Malligai Nagar – DMA 2		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	24.6	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	32.4	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	62.8	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	12.5	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< - - - End of Report - - - >

Verified By:

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

Note: 1. The results relate only to this item tested.

2. Any Correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



**TEST REPORT**

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/183		Report Date:	24.06.2023	
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014				
Customer Reference:	IWO Date: 20.06.2023		Sample Reference No:	ECI-AAQ-2023/06/183	
Sample Drawn By:	ECI		Sample Received On:	20.06.2023	
Sample Collected Date:	20.06.2023		Test Commenced On:	20.06.2023	
Qty of Sample Received:	Filter Paper & 25ml Solution		Test Completed On:	24.06.2023	
Sample Description:	Ambient Air		Sampling Method:	IS 5182: Part 14	
Sample Mark:	Zone 6 Indra Nagar – DMA 1				
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrine (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	22.1	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	27.5	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	56.5	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	9.8	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





(Certified by ISO 9001:2015 | ISO 14001:2015 | ISO 45001:2018)

TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/184	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai - 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/184
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 6 Indra Nagar - DMA 2		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible Limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrine (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	27.2	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	33.6	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	63.1	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	9.7	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

Note: 1. The results relate only to this item tested.

2. Any Correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





(Certified by ISO 9001:2015 | ISO 14001:2015 | ISO 45001:2018)

TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/185	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai - 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/185
Sample Drawn By:	ECI -	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 4 Railar Nagar		


S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	25.8	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	28.9	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	54.5	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	7.9	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

Verified By: 

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)


Authorized Signatory



#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

Note: 1. The results relate only to this item tested.

2. Any Correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/186	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/186
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 9 Alangulam		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	26.4	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	32.6	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	58.6	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	11.3	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< - - - End of Report - - - >

[Signature]

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

[Signature]
Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- 10: 1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/187	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai - 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/187
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 7 Park Town - DMA 1		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	24.1	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	30.5	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	62.6	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	10.5	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)
R. K. R.
Authorized Signatory

Verified By:



#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

019: 1. The results relate only to this item tested.

2. Any Correction not attested shall invalidate this report.

3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.

4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.

5. Total liability of our laboratory is limited to the invoice amount.

6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



**TEST REPORT**

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/188	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014		
Customer Reference:	IWC Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/188
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 7 Park Town – DMA 2		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	25.2	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	32.2	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	63.4	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	12.8	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- 010: 1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



**TEST REPORT**

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/189	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/189
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 7 Park Town – DMA 3		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible Limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	26.2	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	31.6	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	58.6	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	12.5	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No:	ECI-AAQ-2023/06/190	Report Date:	24.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai - 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-AAQ-2023/06/190
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	Filter Paper & 25ml Solution	Test Completed On:	24.06.2023
Sample Description:	Ambient Air	Sampling Method:	IS 5182: Part 14
Sample Mark:	Zone 23 EB Colony		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD	Permissible limits of CPCB
1	Ammonia (as NH ₃)	µg/m ³	< 1.0	NIOSH Method: 6015	400
2	Arsenic (as As)	ng/m ³	< 0.1	IS 5182: Part 22	6.0
3	Benzene (C ₆ H ₆)	µg/m ³	< 1.0	IS 5182: Part 11	5.0
4	Benzo-a-Pyrene (BaP)	ng/m ³	< 1.0	IS 5182: Part 12	1.0
5	Carbon Monoxide (as CO)	mg/m ³	< 1.2	IS 5182: Part 10	2.0
6	Lead (as Pb)	µg/m ³	< 0.1	IS 5182: Part 22	1.0
7	Nickel (as Ni)	ng/m ³	< 0.1	IS 5182: Part 22	20
8	Nitrogen dioxide (as NO ₂)	µg/m ³	26.2	IS 5182: Part 06	80
9	Ozone (as O ₃)	µg/m ³	< 9.8	IS 5182: Part 09	180
10	Particulate Matter (PM _{2.5})	µg/m ³	27.8	IS 5182: Part 24	60
11	Respirable Particulate Matter (PM ₁₀)	µg/m ³	55.6	IS 5182: Part 23	100
12	Sulphur Dioxide (as SO ₂)	µg/m ³	12.5	IS 5182: Part 02	80

Opinion: In the above mentioned location meets the requirements of CPCB standards with respect to the parameters tested

< --- End of Report --- >

[Signature]

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

[Signature]
Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- Note: 1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No :	ECI-NM-2023/06/183		Report Date :	20.06.2023	
Customer Name & Address :	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5th Street Madurai - 625 014				
Customer Reference :	IWO Dt.: 20.06.2023		Sample Reference No :	ECI-NM-2023/06/183	
Sample Description :	Noise		Monitoring Date:	20.06.2023	
Monitored By:	ECI		Date Received On:	21.06.2023	

S.No	Location	Day Time																	Mean
		6-7 am	7-8 am	8-9 am	9-10 am	11 am	12 am	12-1 am	1-2 am	2-3 am	3-4 am	4-5 am	5-6 am	6-7 am	7-8 am	8-9 am	9-10 am		
1	Zone 8 Malligai Nagar	Min	39.5	40.2	52.8	60.9	74.2	81.4	83.2	78.5	67.2	38.2	65.3	59.3	68.3	59.7	58.3	52.1	61.13
		Max	41.2	45.7	59.3	63.8	78.3	83.5	88.2	82	69.4	74.7	68.2	63.2	71.4	63.7	60.5	54.7	66.61
2	Zone 8 Malligai Nagar	Min	38.3	43.2	58.2	71.2	83.2	77.5	80.2	73.4	67.5	70.3	78.2	78.1	72.2	69.3	67.5	58.2	67.91
		Max	40.9	48.4	60.3	78.3	88.2	79.3	81.5	78.2	71.2	74.4	81.3	81.3	75.3	72.4	71.3	60.3	71.29
3	Zone 6 Indra Nagar	Min	41.4	40.7	52.5	60.4	74	81.1	83.7	78.8	68.2	65.1	68.1	58.7	66.7	62.1	57.8	50.1	62.94
		Max	45.4	45.2	58.4	63.1	77.2	82.8	88.5	81.6	70.5	77.4	69.1	63.4	72.4	67.1	62.1	53	67.19
4	Zone 6 Indra Nagar	Min	41.1	51.3	50.8	56.1	61.6	62.5	67.8	63.4	71.6	68.2	66.1	60.5	62.4	57.6	51.3	52.4	59.03
		Max	46.6	54.3	54.2	58.2	63.8	65.2	69.8	68.1	73.7	74.2	69.7	66.8	68.4	61.5	53.5	55.8	62.58
5	Zone 4 Rattai Nagar	Min	42.3	47.3	49.1	53.3	54.7	59.9	68.4	68.5	67.3	62.4	65.1	68.4	65.3	59.3	59.1	52.1	58.84
		Max	44.3	49.5	50.4	56.8	58.4	62.7	68.7	71.5	70.5	66.1	68.3	69.6	72.4	63.5	64.2	58.5	62.48
6	Zone 9 Alangulam	Min	44.5	47.8	46.8	51.2	53.2	54.5	67.8	65.9	64.8	67.6	70.2	70.7	66.5	66.1	58.4	52.3	59.13
		Max	47.8	51.1	50.4	54.3	57.8	59.5	71.2	69.9	68.4	70.5	77.8	78.5	70.1	71.5	60.2	55.3	63.26
7	Zone 7 Park Town DMA 1	Min	41.5	40.8	52.8	60.5	74.1	81.2	83.8	73.8	67.7	70.5	78.4	78.3	72.4	69.5	67.7	58.4	66.94
		Max	45.6	45.4	58.6	63.3	77.4	82.8	88.7	78.3	71.3	74.5	81.4	81.4	75.4	72.5	71.4	60.4	70.40
8	Zone 7 Park Town DMA 2	Min	40.9	51.1	50.6	55.9	61.4	62.3	67.6	63.2	68.7	68	65.9	60.2	62.2	57.3	51.1	52.2	58.86
		Max	45.1	44.9	58.1	62.8	66.5	67.2	72.5	69.4	70.2	72.2	68.8	63.1	72.1	66.8	61.8	52.7	63.39
9	Zone 7 Park Town DMA 3	Min	43.6	47.8	53.6	57.8	61.5	61.8	66.7	70.5	71.8	72.5	70.6	71.8	68.5	66.4	60.4	54.4	62.48
		Max	47.2	51.8	55.2	59.1	63.6	64.6	68	73.6	77.6	77.6	75.1	77.8	71.5	69.1	63.2	58.1	65.71

Unit	dB (A)
TNPSB Max. Permissible Limit for Day Time (Industrial Area)	75
Reference Method	IS 9389
Opinion : In the above mentioned locations meets the requirements of TNPSB Standards	
← End of Report →	
Verified By:	For Envirocare India Private Limited (Laboratory Division) Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- note:
1. The results relate only to this item tested
 2. Any Correction not attested shall invalidate this report
 3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
 4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
 5. Total liability of our laboratory is limited to the invoice amount.



**TEST REPORT**

Accredited by NABL (Chemical & Biological)

Report No:	ECI-WA-2023/06/212	Report Date:	26.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai - 625 014		
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-WA-2023/06/212
Sample Drawn By:	ECI	Sample Received On:	20.06.2023
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023
Qty of Sample Received:	2L	Test Completed On:	26.06.2023
Sample Description:	Water	Sampling Method:	IS 3025: Part 1
Sample Mark:	Surface Water - Zone 6 Indra Nagar		

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1	Turbidity	NTU	27.1	IS 3025: Part 10
2	Color	Hazen	BDL (DL = 1.0)	IS 3025: Part 04
3	pH Value @ 25°C	--	7.4	IS 3025: Part 11
4	Total Dissolved Solids (TDS) @ 180°C	mg/L	598	IS 3025: Part 16
5	Calcium (as Ca)	mg/L	51	IS 3025: Part 40
6	Chloride (as Cl)	mg/L	210	IS 3025: Part 32
7	Magnesium (as Mg)	mg/L	27	IS 3025: Part 46
8	Sulphates (as SO ₄ ²⁻)	mg/L	115	IS 3025: Part 24
9	Total Alkalinity (as CaCO ₃)	mg/L	203	IS 3025: Part 23
10	Manganese (as Mn)	mg/L	< 0.03	IS 3025: Part 59
11	Copper (as Cu)	mg/L	BDL (DL = 0.1)	IS 3025: Part 42
12	Fluoride (as F)	mg/L	< 0.1	IS 3025: Part 60
13	Barium (as Ba)	mg/L	< 0.5	IS 13428 (Annex F)
14	Boron (As B)	mg/L	< 0.2	IS 3025: Part 57
15	Total Hardness (as CaCO ₃)	mg/L	227	IS 3025: Part 21
16	Iron (as Fe)	mg/L	BDL (DL = 0.01)	IS 3025: Part 53
17	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025: Part 26

Remarks: BDL - Below Detectable Limit, DL - Detectable Limit

< --- End of Report --- >

Verified By:

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- Note: 1 The results relate only to this item tested.
2 Any Correction not attested shall invalidate this report.
3 Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4 Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5 Total liability of our laboratory is limited to the invoice amount.
6 Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.



**TEST REPORT**

Accredited by NABL (Chemical & Biological)

Report No:	ECI-WA-2023/06/213	Report Date:	26.06.2023	
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014			
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-WA-2023/06/213	
Sample Drawn By:	ECI	Sample Received On:	20.06.2023	
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023	
Qty of Sample Received:	2L	Test Completed On:	26.06.2023	
Sample Description:	Water	Sampling Method:	IS 3025: Part 1	
Sample Mark:	Surface Water – Zone 23 EB Colony			
S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1	Turbidity	NTU	28.1	IS 3025: Part 10
2	Color	Hazen	BDL (DL = 1.0)	IS 3025: Part 04
3	pH Value @ 25°C	--	7.6	IS 3025: Part 11
4	Total Dissolved Solids (TDS) @ 180°C	mg/L	630	IS 3025: Part 16
5	Calcium (as Ca)	mg/L	58	IS 3025: Part 40
6	Chloride (as Cl)	mg/L	190	IS 3025: Part 32
7	Magnesium (as Mg)	mg/L	16	IS 3025: Part 46
8	Sulphates (as SO ₄ ²⁻)	mg/L	121	IS 3025: Part 24
9	Total Alkalinity (as CaCO ₃)	mg/L	199	IS 3025: Part 23
10	Manganese (as Mn)	mg/L	< 0.03	IS 3025: Part 59
11	Copper (as Cu)	mg/L	BDL (DL = 0.1)	IS 3025: Part 42
12	Fluoride (as F)	mg/L	< 0.1	IS 3025: Part 60
13	Barium (as Ba)	mg/L	< 0.5	IS 13428 (Annex F)
14	Boron (As B)	mg/L	< 0.2	IS 3025: Part 57
15	Total Hardness (as CaCO ₃)	mg/L	225	IS 3025: Part 21
16	Iron (as Fe)	mg/L	BDL (DL = 0.01)	IS 3025: Part 53
17	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025: Part 26

Remarks: BDL - Below Detectable Limit, DL - Detectable Limit

< --- End of Report --- >

Verified By:

For ENVIRO CARE INDIA PRIVATE LIMITED
(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.





(Certified by ISO 9001:2015 | ISO 14001:2015 | ISO 45001:2018)

TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No:	ECI-WA-2023/06/213		Report Date:	26.06.2023
Customer Name & Address	M/s. The Indian Hume Pipe 8-D/6, Krishnapuram Colony, East Cross 5 th Street Madurai – 625 014			
Customer Reference:	IWO Date: 20.06.2023	Sample Reference No:	ECI-WA-2023/06/213	
Sample Drawn By:	ECI	Sample Received On:	20.06.2023	
Sample Collected Date:	20.06.2023	Test Commenced On:	20.06.2023	
Qty of Sample Received:	2L	Test Completed On:	26.06.2023	
Sample Description:	Water	Sampling Method:	IS 3025: Part 1	
Sample Mark:	Surface Water – Zone 25 Bharath Nagar			

S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
1	Turbidity	NTU	27.4	IS 3025: Part 10
2	Color	Hazen	BDL (DL = 1.0)	IS 3025: Part 04
3	pH Value @ 25°C	--	7.6	IS 3025: Part 11
4	Total Dissolved Solids (TDS) @ 180°C	mg/L	547	IS 3025: Part 16
5	Calcium (as Ca)	mg/L	51	IS 3025: Part 40
6	Chloride (as Cl)	mg/L	210	IS 3025: Part 32
7	Magnesium (as Mg)	mg/L	15	IS 3025: Part 46
8	Sulphates (as SO ₄ ²⁻)	mg/L	98	IS 3025: Part 24
9	Total Alkalinity (as CaCO ₃)	mg/L	217	IS 3025: Part 23
10	Manganese (as Mn)	mg/L	< 0.03	IS 3025: Part 59
11	Copper (as Cu)	mg/L	BDL (DL = 0.1)	IS 3025: Part 42
12	Fluoride (as F)	mg/L	< 0.1	IS 3025: Part 60
13	Barium (as Ba)	mg/L	< 0.5	IS 13428 (Annex F)
14	Boron (As B)	mg/L	< 0.2	IS 3025: Part 57
15	Total Hardness (as CaCO ₃)	mg/L	219	IS 3025: Part 21
16	Iron (as Fe)	mg/L	BDL (DL = 0.01)	IS 3025: Part 53
17	Residual Free Chlorine (RFC)	mg/L	< 0.1	IS 3025: Part 26

Remarks: BDL - Below Detectable Limit, DL - Detectable Limit

< --- End of Report --- >

Verified By:



For ENVIRO CARE INDIA PRIVATE LIMITED

(Laboratory Division)

Authorized Signatory

#43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 016 Tel: 78239 30420
Email: lab@envirocareindia.com | Web: www.envirocareindia.com

- Note: 1. The results relate only to this item tested.
2. Any Correction not attested shall invalidate this report.
3. Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
4. Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
5. Total liability of our laboratory is limited to the invoice amount.
6. Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.

