



Maritime &
Coastguard
Agency

Guidance

Safety Bulletin 33 – Paroc Navis 60 non-compliant structural fire protection

Updated 12 October 2023

Contents

Summary of issue

Actions to take



© Crown copyright 2023

This publication is licensed under the terms of the Open Government Licence v3.0 except where otherwise stated. To view this licence, visit nationalarchives.gov.uk/doc/open-government-licence/version/3 or write to the Information Policy Team, The National Archives, Kew, London TW9 4DU, or email: psi@nationalarchives.gov.uk.

Where we have identified any third party copyright information you will need to obtain permission from the copyright holders concerned.

Summary of issue

Following independent testing it has been found that the PAROC Marine Navis Slab/Mat/Wired 60 product line does not meet the A-60 Test requirements despite the products holding a Type Approval Certificate and having MED approval. While the product does provide some structural fire protection it was found to not restrict the temperature rise for the full 60 minutes required for A-60 approval.

The MCA believes that supply of this product in the UK for use in newbuild ships has been limited but believe it could have been installed by third party suppliers for repair and modification purposes.

Actions to take

If you believe you have non-installed stock of these products, please inform PAROC who will make arrangements for recompense.

PAROC can be contacted by email at

media_relations@paroc.com

If the product is installed on board, the supplier should be contacted and a remedial action plan agreed with your local marine office.

Any queries should be directed to the MCA at

Email: marine.technology@mcga.gov.uk

Tel: +44 (0) 203 8172000

Maritime and Coastguard Agency,
Bay 2/23,
Spring Place,
105 Commercial Road,
Southampton,
SO15 1EG



OGI

All content is available under the [Open Government Licence v3.0](#), except where otherwise stated



© Crown copyright