



# Check List

Order Code:

**TGM-61110**

Software code:

**C398**

Instruction : ทดสอบการทำงานของอินพุต Remote

1. Config							
Function	Input	Botton	Comment	Min	Max	Pass	Fail
SCALE High 1	Remote	SCALE+	แสดงค่า เป็นตัวเลข	> SCALE Low	9999		
SCALE Low 1		SCALE-		-1999	< SCALE High		
ขีดเขย Ch 1		F4		-1999	9999		
Decimal point 1		DP		0	2		
Address		ADD		1	255		
Baus Rate		F1		0	4		
Communication		F2		0	2		

Prepared By	Verified By	Approved By



# Check List

Order Code: **TGM-61110**Software code: **C398**

Instruction : ทดสอบการทำงานของ Input

COUNTER								
Function	Input	IN	Scale High	Scale Low	ค่าชดเชย	Display	Pass	Fail
INPUT	4-20 mA	5 V	10.0000	0.0000	0.0000	5.0000		

Prepared By	Verified By	Approved By



# Check List

Order Code:

**TGM-61110**

Software code:

**C398**

Instruction : ทดสอบการทำงานของ RS485 Modbus RTU Write Function 16 Multi Registers

Modbus RTU								
Function	Channel	Input	Address	Baud Rate	Parity	Output	Pass	Fail
Modbus RTU	PVS	1234	1	9600	b8n1	1234		
	DP							
	PV HIGH							
	PV LOW							

Instruction : ทดสอบการทำงานของ RS485 Modbus RTU read

2. Input								
Function	Input	Address	Baud Rate	Parity	Responses	Error	Pass	Fail
Modbus RTU	RS485 Modbus RTU	1	9600	b8n1	1000	0		

Prepared By	Verified By	Approved By





