

ARCHANGEL CONTRACTORS

MAKE-READY / UNIT PUNCH — SCOPE OF WORK CHECKLIST

Serving Dallas–Fort Worth • Licensed & Insured • Since 2011 • admin@archangelcontractors.com

Property: _____ Unit: _____ Date: _____ Crew: _____

ELECTRICAL

- ☐ Test all fixtures, switches, outlets, and GFCIs
- ☐ Breaker box: all circuits labeled, no open knockouts
- ☐ All detectors mounted securely
- ☐ New batteries in all smoke/CO detectors; test function

ENTRANCE

- ☐ Test doorbell/intercom and peephole
- ☐ Door locks and latches work and are installed correctly
- ☐ Hardware secure, clean, paint-free; resident-added hardware removed
- ☐ Doorstop present — install if missing
- ☐ Door face free of dents, scratches, and scuffs
- ☐ Door opens/closes easily and seals tight when closed
- ☐ Sweep, weather stripping, and threshold in good condition — replace or secure as needed
- ☐ Doorjamb free of cracked/split wood; handrails clean and secure

LIVING ROOM

- ☐ Light fixtures secure and functional
- ☐ Outlets, switches, and covers — no cracks or charring
- ☐ Ceiling fans balanced, clean, and functional
- ☐ Closet door and shelving in good condition
- ☐ Cable, phone, and data connections work
- ☐ Fireplace: damper and screen function properly; hearth and mantle damage-free
- ☐ Log cradle and insert — repaint with high-heat paint if needed; clean all vents

WINDOWS, PATIO DOORS & BLINDS

- ☐ No broken or cracked glass; glazing secure in frame
- ☐ Working locks on all windows and sliders; open and close easily
- ☐ Vertical sliding windows stay open on their own
- ☐ Screens fit properly with no tears
- ☐ Door and window seals good — repair as needed
- ☐ Window sills: check for water intrusion, repair as needed
- ☐ Deck railing brackets, screws, and bolts tight
- ☐ Cord safety: loop cords cut with tassels on each end; cord stops within 1" of head rail; cords tangle-free, never tied; vertical loop chains anchored to wall
- ☐ Blinds open and close smoothly — replace bent, broken, or missing slats

BEDROOMS

- ☐ Light fixtures function properly
- ☐ Outlets, switches, covers — no cracks or charring; “half-hot” outlets work
- ☐ Closet doors: tracks, rollers, and glides operate properly
- ☐ Shelving and clothes rod damage-free
- ☐ Doors latch properly; hinges good; passage knobs on all bedroom doors
- ☐ Cable, phone, and data connections work
- ☐ Window sills damage-free; weather stripping in good condition

LAUNDRY — START OF MAKE-READY

- ☐ Washer: run full cycle; supply lines free of leaks/bulges (replace every 5–7 yrs)
- ☐ Washer drain hose strapped or zip-tied to wall drain
- ☐ Dryer heats properly; knobs in good condition
- ☐ Vent hose: no kinks, secured at both ends, cleaned — excess lint means an exhaust leak
- ☐ Clean lint trap and dryer vent line

— Continued on back: Kitchen, Bathrooms, HVAC & Final Safety —

KITCHEN — CABINETS & COUNTERS

- ☐ Doors and drawers open/close easily; handles, pulls, and hinges secure and adjusted
- ☐ No water damage or staining, including under the sink
- ☐ Cabinet fronts and interiors damage-free; paint cabinet interiors
- ☐ All shelving pins installed
- ☐ Countertop free of wear and burns; recaulk as needed

DISHWASHER

- ☐ Run full cycle at start of turn — no leaks, heat element works, no water left in sump
- ☐ Door opens, closes, and seals; gasket intact and pliable
- ☐ Soap dispenser latches, then opens during cycle
- ☐ Racks slide smoothly; knobs and control panel good
- ☐ Kick plate secure; unit anchored to counter
- ☐ Air gap and return hose inspected and clean

DISPOSAL, SINK & FAUCET

- ☐ Disposal runs freely with no obstructions; no leaks under sink; strainer and stopper present
- ☐ Faucet turns easily, no corrosion or leaks; drains open and free-flowing
- ☐ Hot water within local code limits
- ☐ Aerator clean; sprayer pattern and pressure good
- ☐ Air gaps cleared

RANGE, OVEN, HOOD & MICROWAVE

- ☐ Bake, broiler, and all stovetop elements work
- ☐ Oven door opens, closes, and seals; door seal undamaged
- ☐ Oven and hood lights work; all indicator lights function
- ☐ Oven sits level, no rocking; racks and knobs in good condition
- ☐ Install new drip pans
- ☐ Hood fan operates properly; filter cleaned or replaced
- ☐ Microwave operational — handle, frame, door, bulb, cover, tray

REFRIGERATOR

- ☐ Door seals good; shelves free of rust and discoloration
- ☐ Light works with proper 40W bulb
- ☐ Condensation pan, condenser coils, and fan clean and ventilated
- ☐ Icemaker hose connected — if no icemaker, 2 ice trays in freezer
- ☐ Level with no rocking; handles secure; no leaks
- ☐ Set thermostat to warmest setting

BATH — SINK & VANITY

- ☐ Faucet turns on easily, no corrosion or leaks; drains clear and open
- ☐ Drain lines leak-free; pop-up assemblies and P-trap clean
- ☐ Repair sink chips with porcelain repair kit
- ☐ Replace cracked or discolored vanity-top caulk; no cabinet water damage
- ☐ Aerator clean; air gaps cleared

TOILETS

- ☐ Flush — handle operates freely; fill valve shuts off at correct level
- ☐ Tank bolts leak-free
- ☐ Replace the flapper
- ☐ Recaulk base if needed (front and sides only)
- ☐ Seat tight — replace if broken or discolored; both bolt caps in place

BATHTUBS & SHOWERS

- ☐ Recaulk tub/shower, spout, and escutcheon plates as needed
- ☐ Shower arm and escutcheon rust-free; repair chipped porcelain and cracked grout
- ☐ Install corner guards on tub ledges if needed
- ☐ Tub holds water and drains properly; shoe and stop clean — replace if rusted
- ☐ Enclosure doors and curtain rod secure and smooth
- ☐ Shower valve leak-free; diverter works; hot and cold correct
- ☐ Shower head spray even — clean or install new head if weak

BATH — GENERAL

- ☐ Light fixtures secure; exhaust fan cleaned, cover cleaned, motor lubricated
- ☐ Mirror and medicine cabinet free of cracks and discoloration
- ☐ Towel bars and toilet paper holder secure — replace as needed
- ☐ Door hinges rust-free; drawers smooth; vanity top undamaged
- ☐ Privacy lock installed; door latches smoothly

HVAC & WATER HEATER

- ☐ Replace furnace and A/C filters
- ☐ Test heat and cool modes — vents blow hot/cold as set
- ☐ Gas furnace: steady blue flame; check pilot, thermocouple, burner; inspect heat exchanger and flue; compartment covers tight
- ☐ Clear condensation lines; test overflow switch; add tablet to pan; condenser coils clean
- ☐ Water heater: test T&P relief; valve pipe ends within 6" of floor and plumbed outside per code
- ☐ Tank and pan leak-free; all valves open and close fully
- ☐ Gas heater: tight flue, no backdraft, steady blue flame • Electric: ohm-test elements
- ☐ Set thermostat per Owner: 55° heat / 80° cool

FINAL ITEMS & SAFETY VERIFICATION

- ☐ Paint front door and patio/balcony (paint provided by Owner)
- ☐ Check smart-home devices — front door batteries, leak sensors, smart plug, and hub
- ☐ SAFETY: verify all blind pull cords meet safety requirements
- ☐ SAFETY: smoke/CO detectors tested with new batteries; all windows and exterior doors have working locks

Technician Sign-Off: _____ Supervisor Approval: _____