



Cable Id : Cable

Fiber Id/Number : Fiber 24

Location A : Loc A

Location B : Loc B

Job ID : 12

Technician Id :

SmartOTDR (S/N 92589)

E100AS (S/N 92589)

Calibration Date : 29/09/2025

Date : 26/11/2025 14:45 (UTC+0)

Test Setup								
OTDR	Laser	Pw	Range	Acq Time	IOR	Scatter Coefficient		
EXPERT	1310nm	30ns	5km	10.0s	1.46750(G652 G657)	-79.0 dB		
Alarms								
Thresholds	None							
Summary								
Filename	Laser nm	Link Loss dB	Link ORL dB	Fiber End Km	Direction	Avg Loss dB/Km	Event	Alarms
kusmi gp to olt .sor	1310	0.375	39.79	0.922	Loc A -> Loc B	0.407	2	



1/2

0.671

2/2


0.923 Km

A : 0.000km 0.297 dB

B : 0.659km 0.141 dB

A-B : 0.659km 0.237 dB/Km

0.156 dB



Event	Distance	Loss	Reflect.	Slope	Section	T. Loss
	Km	dB	dB	dB/km	Km	dB
1	0.670	0.129		0.313	0.670	0.210
2	0.922		-35.43		0.252	0.375