## Panel schedule for SMRT.

		2	₽				
* NOT A TO A TO	BASEBOARD HEATER	LIGHTING	BATHROOM RECEPTACLES*	DESCRIPTION	MAI		
	15A	15A	15A	RATING	MAIN BREAKER: 60A	PHASE, WIRE 1 Ø, 2W	PANEL A
	15A	15A	15A	RATING	60A	1 Ø, 2W	A
	RWH PUMP	LIVING SPACE RECEPTACLES	OUTDOOR RECEPTACLES*	DESCRIPTION			
		2	1	CCT			

\*INSTALL GFCI BREAKER