

Verify tie-in flange rating conforms to Class 300 RTJ specification

Remove all Revision B flags and revision clouds throughout this drawing

Provide minimum 150mm pipe support clearance from adjacent cable tray

P&ID tag discrepancy: replace manual valve tag HV-102 with XV-102 per line list

Beam elevation mismatch: confirm top of steel EL +104.500 against structural drawings

PROJECT: UCC INDUSTRIAL EXPANSION
DWG NO: SAMPLE-DWG-PIPING-001
DISCIPLINE: PIPING ENGINEERING
REV: B - ISSUED FOR REVIEW