

GENERAL STRUCTURAL PLAN - LEVEL 2

ALL REBAR ASTM A615 GRADE 60

REVISE BEAM SIZE TO W24X68 AT MOMENT CONNECTION

VERIFY CLEARANCE DIMENSION TO GRIDLINE 4

CHECK AWS A2.4 WELD SYMBOL SPECIFICATION