

WL 4410

M 0.0000 L
-
K 255.87 V
M 0.000 A
-
K 50.03 F
M
-
K

I/O 1

I/O 2

I/O 3

I/O 4

B
CLRP
PRG

E



MULTIFUNCTION METER

VishaLEMS System
IOCL Akola Depot

23:28

48%

No internet connection



192.168.4.1



VishaleMS Live Dashboard

Professional Industrial Energy Monitoring System

Version 5.1

SYSTEM STATUS

Meter	ONLINE
Communication	HEALTHY
Processor	RUNNING
Network	CONNECTED

LIVE ELECTRICAL DATA

Voltage Avg	255.87 V
Voltage R	255.87 V
Voltage Y	0.00 V
Voltage B	0.00 V
Current Total	0.00 A
Current R	0.00 A
Current Y	0.00 A
Current B	0.00 A
Frequency	50.03 Hz
Power Factor	1.00
Active Power	0.000 kW
Peak Demand	0.00 kW
Peak Time	0 sec

ENERGY SUMMARY

Total Energy	0.000 kWh
Interval Energy	0.000 kWh
Peak Demand	0.00 kW
Peak Time	00:00:00
Average Demand	0.00 kW

Developed by VISHAL ENTERPRISES