

Green Valley Geotechnical Soil Report

Prepared by Austin Geotechnical Consultants
Inspection Date: May 2026

Executive Summary

Preliminary investigation indicates the site is suitable for conventional residential construction.

Soil Conditions

Primary Soil: Sandy Clay Loam
Drainage: Good
Bearing Capacity: Moderate to High

Foundation Recommendation

Conventional reinforced concrete slab is recommended. Basement construction requires additional engineering review.

Flood Assessment

Outside FEMA high-risk flood zone. Overall flood risk is low.

Construction Notes

Perform final soil testing before construction and install proper site drainage.